

equal to the cost of providing such service, such cost to be determined by the Superintendent, and upon the receipt of such sum the Corporation will provide such service-pipe.

SIZE OF PIPES.

18. The Corporation shall in every case determine the size of the pipe to be used in supplying any premises, and also the position in the street in which it is to be laid.

19. When any departure from the prescribed rules is permitted in order to accommodate a water-taker, the water-taker shall be charged with the expense of making the change.

20. No work of any kind connected with the water services, either for the laying of new or the repair of old services, shall be permitted to be done upon or under the streets by other than the employees of the Corporation.

21. No work shall be done by the Corporation upon the premises of water-takers, except the placing of meters, but the Corporation may direct all work to be done in connection with water services.

LAYING SERVICE-PIPES.

22. Any direction as to the position in which it may be desired to have the service-pipe laid, when such directions does not interfere with the requirements of the Corporation, must be given in writing at the Water Works Office, and the applicant shall be notified of the time at which the service pipe is to be laid.

23. If any party fail to appear at the time appointed for laying the service-pipe the work may be proceeded with in the ordinary way, and any subsequent alteration shall only be made at the expense of the water-taker.

24. In all cases the water-taker must show that the pipe laid within his premises is laid according to the requirements of the Corporation, and, unless the same is shown to the satisfaction of the inspector or foreman of the Water Works in charge of the work, connection shall not be made with the street pipe.

25. No two premises supplied with water from the Water Works shall be dependent upon one service-pipe beyond the street line, but each separate and distinct tenement or premises shall be supplied through a separate pipe provided with proper stop-cocks, or other means of cutting off the water.

26. All service-pipes upon the premises of water-takers shall be laid at a depth of not less than five feet six inches below the level of the surrounding ground; and where they cross or are near other excavations they must be properly protected against settlement.

27. The material employed in the construction of service-pipes shall correspond in all particulars with that of a similar kind used by the Corporation.

KEY HYDRANTS.

28. Key hydrants for the supply of a number of houses shall not be allowed, except by permission of the Superintendent.