

119083-5 25-11-95

136312

Indian Superintendent N.B.

Wamloops Industrial School, 31st Decem^r

136312

119083-5



Sir,

In compliance with the request contained in your Circularth &^d, dated the 11th inst., regarding provisions made for protection against fire, I have the honor to report as follows:

1. There is a tank, of a capacity of 1800 Gallons, near the laundry; we could not keep it full in the winter, owing to the well, from which the water is supplied, not being large enough, but we have just completed the digging of a well 6x6 ft. x 28 ft. deep, from which we hope to get an abundant supply of water.
2. There is a force pump in the laundry, used to fill up the boiler in the kitchen, but it is not powerful enough to throw up a stream of water, and in case of fire, the water would have to be carried by hand. It would therefore be advisable to get some chemical engines which the pupils could operate.
3. A 50 Gallons barrel is kept full of water in the boys' building, and there are 6 iron buckets always on hand near by.
4. In the laundry, near the tank, two large barrels are kept full of water; one dozen buckets are kept there. The buckets are not kept full of water, for the water would freeze in the winter.
5. One bucket full of water is kept near the stove in the school room.
6. A ladder is permanently attached to black building with another on the roof.
7. No fires are kept going during the night; the stoves are kept lighted by the day.

advised that:-
 1 doz hand grenades
 1/2 doz hand fire extinguishers
 1 extra change for do
 have been ordered for the
 Wamloops Industrial School