

JORDAN PETROLEUM REFINERY CO. LTD.

LABORATORY

Certificate No. : _____
 Date Issued : _____
 Tank No. : _____
 Sampling Date : _____

SPECIFICATION
Gasoil

TESTS	RESULTS	METHODS
Distillation		ASTM D-86
90% recovered at °C	357 Max.	
Density @ 15 °C gm/ml	0.82 - 0.870	ASTM D-1298
Color ASTM	2.4 Max.	ASTM D-1500
Total Sulfur %wt	1.5 Max.	ASTM D-1266
Flash point P.M. °C	55 Min.	ASTM D-93
Viscosity Red wood at 100 °F Sec.	45 Max.	IP - 70
Pour point Summer °C	+5 Max.	ASTM D-97
Pour point Winter °C	-9 Max.	
Corrosion, copper discoloration	NO. 1 Strip	ASTM D-130
Carbon residue on 10% residue, %wt	0.1 Max.	ASTM D-189
Total acid number mg KOH/gr	1.0 Max.	ASTM D-974
Strong acid number mg. KOH/gr	NIL	ASTM D-974
Ash %wt	0.01 Max.	ASTM D-482
Water by distillation %vol	0.05 Max.	ASTM D-95
Sediment by extraction %wt	0.01 Max.	ASTM D-473
Diesel Index	50 Min.	IP - 21
Remarks : _____ _____ _____ _____		

(Lab.) Chief Chemist

mezzal
 21/1/94