

Chapter 3
Danger Alarm

Issued by virtue of Section 39(3)

Article 11. A factory which contains gas that may endanger persons, or has inflammable material and more than 50 workers, or has combustible material and more than 100 workers must provide danger alarm which gives clear and adequate warning to workers in danger area to evacuate immediately and to notify officials concerned to prevent the danger quickly.

Article 12. Must provide danger alarm in at least two-different points which must be in safe area away from the above mentioned danger, and must be in position where a person can easily and quickly activate the danger alarm.

Article 13. The danger alarm under the preceding Article must be of the type which does not require energy from lighting system and is used for machinery.

Chapter 4
Fire-Fighting Equipment and Other Equipment for
Extinguishing Fire and Means of Fire Prevention

Issued by virtue of Section 39(4)

Article 14. Fire operation of a factory may cause fire: Factory buildings or warehouses which are constructed with combustible materials, the storage of combustible materials must be provided with adequate fire-fighting equipment, in proportion to condition, size and nature of the factory, to be located at different points within the compound of factory for accessibility. Provided, there must