

being the possibility of movement occurring quite rapidly under proper conditions, I would advise that the building be vacated and the contents removed at the earliest possible date, as no chances whatever should be taken by the University of having any accident occur.

In the event of a continued settlement of the north east corner where the wall is cut up by the bay window, it will probably be necessary to demolish the building, as this portion of the wall will be in danger of collapsing, and it would not be advisable to go to any expense for repairs which while costly would only be of a temporary nature.

Yours truly,

(signed) WM. D. Lawrence,

Supt. Engineer.