

Required only for Method III

(g) All exposed surfaces and their coatings in accommodation spaces shall be of limited flame-spreading power to the satisfaction of the Administration.

Regulation 41*Cinematograph Apparatus (Methods I, II and III)*

Except where only "non-inflammable" film is used the installation and use of cinematograph apparatus on ships shall be subject to special fire precautions to be prescribed by the Administration. Lockers for the storage of highly inflammable film shall have an outlet to the open air with a total area of 1 square inch for each 5 lbs. (10 square centimetres for each 3.5 kilogrammes) reel of film or equivalent stored therein.

Regulation 42*Automatic Sprinkler and Fire Alarm and Detection Systems (Method II)*

In ships in which method II is adopted, an automatic sprinkler and fire alarm system of a type approved by the Administration and complying with the requirements of Regulation 48 shall be installed and so arranged as to protect all enclosed spaces appropriated to the use or service of passengers or crew, except spaces which afford no substantial fire risk.

Regulation 43*Automatic Fire Alarm and Fire Detection Systems (Method III)*

In ships in which method III is adopted a fire detecting system of a type approved by the Administration shall be installed and so arranged as to detect the presence of fire in all enclosed spaces appropriated to the use or service of passengers or crew (except spaces which afford no substantial fire hazard) and automatically to indicate at one or more points or stations, where it can be most quickly observed by officers and crew, the presence or indication and location of fire.

Regulation 44*Plans (Methods I, II and III)*

There shall be permanently exhibited, for the guidance of the officer in charge of the ship, general arrangement plans showing for each deck the various fire sections enclosed by fire-resisting bulkheads, the sections enclosed by fire-retarding bulkheads (if any), together with particulars of the fire alarms, detecting systems, the sprinkler installation (if any), the fire-extinguishing appliances, means of ingress to and egress from different compartments, decks, &c., and the ventilating system including the positions of dampers and identification numbers of the ventilating fans serving each section.