

2.

first-floor, and as you have placed there a staff dining-room and sitting-room, this arrangement would not permit of an additional bed-room, but, for the purpose of supervision, a folding-bed could be used in the sitting-room if necessary.

The plumbing is also more economical-ly placed, and better protected from cold weather.

With reference to chimneys for kitchen and heating plant, these are shown as 7" x 12" and 12" x 12" flues respectively, which are necessary to give satisfactory service.

There are no class-rooms, recreation-rooms, work-rooms or isolation sick-rooms provided in this building, and as these are necessary for the proper equipment of the school, it is understood that this will be provided for in the existing old building.

As my approval of the plans for boarding school purposes is dependent on the proper construction of the buildings and installation of satisfactory heating, water, plumbing, and lighting systems, I have to

Respectfully

Indian Affairs. Letterbook,
17 May 1918 - 7 June 1918, (R.G. 10, Volume 5719)

Poor
Copy.

PUBLIC ARCHIVES
ARCHIVES PUBLIQUES
CANADA