TABLE 6.28

IBM NO_X Emission Factors

Fuel/Combustor Size	Installed pre-1974	Installed post-1974
Coal		
Over 250 MMBtu/hr Under 250	1.25 to 1.7 0.6 to 0.7	0.7 0.6 to 0.7
Residual Oil		
Over 250 Under 250	0.7 0.4	0.3 0.4
Distillate Oil	•	
Over 250 Under 250	0.7 0.16	0.3 0.16
Natural Gas		
Over 250 Under 250	0.7 0.1	0.2 0.1