

## Chapter 2

Emergency Exits in Factory

Issued by virtue of Section 39 (2)

Article 6. Emergency exit must be of at least 110 centimeters in width, but if the number of people using this exit exceeds 50 persons it must be widened at the ration of at least 2 centimeters per person.

Article 7. Must maintain emergency exit door in condition that it can easily be opened by workers at any time during work.

Article 8. Must maintain adequate lights and must not permit obstruction of exits or emergency stairs or passage which will be used in emergency.

Article 9. Emergency exit of a factory which has more than 50 workers must have substitute lighting system in case the regular lighting system fails; provided, in adequate size and number for emergency exit.

Article 10. Must provide and maintain clear posters or signs for exits or emergency stairs which are not in regular use, so that workers are continuously aware of the emergency exits or stairs.