

out of the water so easily why they are not taken out before letting them into the boiler?

Chairman,—

You simply cannot do it. You can theorize and read about it but you simply cannot do it in actual practice. If you could do this, companies would not be spending hundreds of dollars in repairs and Mr. Taylor would not have a position. My theory is that the people who want to get the scale out of their boilers by compounds will have trouble with their stay-bolts, piston rods and packings. It is really cheaper to regularly wash out and periodically take the tubes out and clean them.

We are going to have a paper for October meeting by Mr. Shales of the Elevator Specialty Co., on the "Care and Maintenance of Elevators." I would like to have as many present at that meeting as possible.

Proposed by Mr. Herriot, seconded by Mr. Logan, that the meeting adjourn. Carried.