

TABLE 6.19

1971 and 1979 NSPS NO_x Standards
(lbs NO_x per 10⁶ Btu's)

	<u>1971 NSPS*</u>	<u>1979 NSPS**</u>
Bituminous Coal	.70	.60
Lignite***	.60	.60
Oil	.30	.30
Gas	.20	.20

* Fossil fuel fired steam generators for which construction was commenced after August 17, 1971.

** Electric utility steam generators for which construction was commenced after September 18, 1978.

*** Cyclone fired units burning lignite and on-line by 1980 were assumed to be limited by the .8 pound standard in 60.44(a)(5).