

## ANNEX 3

## USE OF OTHER FIRE TEST PROCEDURES

Administrations may use test procedures other than those referred to in annex 1 as follows:

- 1 for fire test procedures previously adopted by the Assembly, the expiry dates are given in the table below; and
- 2 for other established test procedures and acceptance criteria applied by an Administration, the test expiry date is 31.12.1998 and the approval expiry date is 31.12.2003.

Products (reference part in annex 1)	Test procedure	Test expiry date	Approval expiry date
Non-combustible materials (part 1)	Resolution A.472(XII)	31.12.1998	31.12.2003
	Resolution A.270(VIII)	1.7.1997	1.7.2002
Materials not generating excessive quantities of smoke nor toxic products (part 2)	-	-	-
A, B and F class divisions (part 3)	Resolution A.517(13)*	31.12.1998	31.12.2003
	Resolution A.163(ES.IV)* as corrected by Resolution A.215(VII)	1.7.1997	1.7.2002
	Resolution A.163(ES.IV)*	1.7.1997	1.7.2002
Fire door control systems (part 4)	-	-	-
Surface materials (part 5)	Resolution A.564(14)	31.12.1998	31.12.2003
	Resolution A.516(13)	31.12.1998	31.12.2003
Primary deck coverings (part 6)	Resolution A.214(VII)	31.12.1998	31.12.2003
Vertically supported textiles (part 7)	Resolution A.471(XII)	31.12.1998	31.12.2003
Upholstered furniture (part 8)	-	-	-
Bedding components (part 9)	-	-	-

\*The maximum average temperature rise of 140°C may be used instead of 139°C in the acceptance criteria in resolutions A.163(ES.IV) and A.517(13).