

vault, drop, or void of any kind, must be encased in a wooden box, or otherwise fully protected from frost.

No surface pipe shall be laid in any trench in which a tile or other drain is being or shall have recently been laid, but it shall be laid in a trench dug to receive the service pipe only, and a distance of at least three feet shall separate the trench in which the service pipe is laid from any trench made for draining or other purposes, unless the Superintendent permits, in writing, the same to be otherwise laid.

Curb boxes and stop cocks shall be located where required by the Superintendent, and must not be set in any exposed place where there is any ordinary liability of their being broken, and in no case shall they be placed in wagon track or driveway leading into any lot or premises.

4.—All work performed and all material and fixtures furnished shall be subject to the approval of the Commissioners, or their Superintendent, and any work, material, fixtures upon or connections with the water works that shall be disapproved by them, shall be removed at the expense of the owner and made to conform to the requirements of the Commissioners.

5.—No plumber, or employee of the Commissioners, shall be allowed to make any attachment to, or alteration in any pipe by which water is supplied to consumers, or to open the street for the introduction of service pipe, without a written permit is issued by the Commissioners.

Whenever any street or public ground shall be opened for the purpose of making a connection or for laying any water pipe or fixtures, it shall be restored to its original condition as soon as possible; also, whenever a trench is opened, bridges for the