

By Mr. Chevrier:

Q. When did you figure this out? When was this calculation made?—A. This was obtained from Mr. Sterling of the electrical section.

Q. Is he an officer of the Department of Public Work?—A. Yes.

Q. Now, may I come to the question of air-conditioning?—A. I think I might add here that it is very difficult to determine what the cost will be over there if an additional motor of this size were installed, because we are at the demand peak right now. We would have to re-negotiate another contract with Gatineau Power. At the present time the rates are: the service charge is 50 cents per kilowatt hour for demand, and then for the first 24,000 kilowatts hours a month there is no charge; for the next 216,000 kilowatts we pay 2.1 cents per kilowatt hour; for the next 240,000 we pay .5 and the balance at .4, so the actual charge that we may have to pay may be considerably less than what I have here, which is \$73.

Q. Well, can we—time is moving fast—can we discuss for a moment, air-conditioning?

Some hon. MEMBERS: Hear, hear.

Mr. CHEVRIER: I am enjoying this as much as your are.

An hon. MEMBER: You are not smiling.

By Mr. Chevrier:

Q. Mr. Kennedy, may I ask you what your experience in the field of air-conditioning?

Mr. WINCH: Mr. Chairman, just before we get off the steam, I would like to ask Mr. Chevrier—

Mr. WALKER: We have been on that for five weeks.

Mr. WINCH: I would like to ask Mr. Chevrier if he would ask a question in regard to something that has been puzzling me? I want to know how that steam got into the toilet system. Could we have some information as to how it got in?

Mr. CAMPBELL (*Stormont*): Mr. Cormier should be asked that question.

Mr. CORMIER: I can answer right away, if you wish me to.

Mr. CHEVRIER: Go ahead.

Mr. CORMIER: Do you not know that the blow-down tanks are made purposely to avoid steam being evacuated in the soil or sewer pipes? That is the purpose of the blow-down tanks.

The WITNESS: Yes.

Mr. CORMIER: That is the purpose, and if properly operated there would be no steam in the soil pipe.

Mr. WALKER: Just a minute; you gave evidence for ten days here.

Mr. CORMIER: I am answering Mr. Chevrier.

Mr. CRESTOHL: He was asked.

Mr. CORMIER: I was asked to do it.

Mr. MURPHY: He asked the witness the question.

Mr. WALKER: He is asking the witness a question.

Mr. CHEVRIER: Mr. Chairman, it has been drawn to my attention that I have not put in evidence what I had intended, and that is a report of November 18, 1955 with marginal notes. I would like to do it now.

The CHAIRMAN: That is Exhibit P-32.

Mr. STEWART: Is it not P-33?

The CHAIRMAN: It is Exhibit P-32.