


## EXTENSION VALVE BOXES

These boxes are for use with our Valves underground, in order that they may be operated from the surface by means of a wrench. They are made adjustable to conform to depth Valve may be placed, so that the top will be exactly flush with the surface.

The cover fits snugly, and is not liable to be dislodged by anything passing over it; at the same time is free enough to admit of being readily removed by a pick or other similar tool. The words "Water" or "Gas" will be cast on top, as specified. In the absence, however, of any definite instructions on this point, we always furnish covers with the word "Water."

Inquiries on Boxes should state number required, size of Valve and depth of trench, and orders should state, in addition, whether covers are wanted marked "Water," "Gas," or some initial letter.



## INDICATOR VALVE POSTS

### For Fire Protection Valves

This post shows plainly whether the Valve is Open or Closed, and is intended to be used with fire protection valves in street mains, factory and mill yards, grounds of public buildings, etc. It is specified by the Fire Underwriters for this purpose, and prevents all delay and mistakes in finding and operating the valve.

The size and shape of the operating nut will be made to conform to the standard of the system in which the valves are to be used. Our standard for operating nut is  $1\frac{1}{4}$  inches square.

In ordering state whether valves turn to right or to left; distance from surface of ground to bottom of pipe; number of turns required to open valve; size and shape of operating nut.

