

Hydraulic Tables, Applicable for Water Pipes and Sewers; by E. H. Keating.

SLIP

To be inserted between pages 80 and 81 in the "Report of Proceedings of the Fourth Annual Meeting of the American Water Works Association." 1884.

ERRATA.

In the heading to the 3rd column, throughout Table 1.—For "*one inch*" read *one in.*

On page 85, 2nd column.—For "51.784" read 51.744.

On page 87, 2nd column.—For "96.625" read 96.624.

On page 92, 3rd column of Table 2.—For "1.090" read 1.000.

		One Inch.		
.0001	0.528	10,000.00	100.00	4.76
.0002	1.056	5,000.00	70.71	7.04
.0003	1.584	3,333.33	57.73	8.83
.0004	2.112	2,500.00	50.00	10.86
.0005	2.640	2,000.00	44.72	11.73
.0006	3.168	1,666.67	40.83	12.98
.0007	3.696	1,428.57	37.80	14.15
.0008	4.224	1,250.00	35.36	15.23
.0009	4.752	1,111.11	33.33	16.27
.0010	5.280	1,000.00	31.62	17.26
.0011	5.808	909.09	30.15	18.20
.0012	6.336	833.33	28.87	19.10
.0013	6.864	769.23	27.74	19.98
.0014	7.392	714.29	26.73	20.83
.0015	7.920	666.67	25.82	21.64
.0016	8.448	625.00	25.00	22.45
.0017	8.976	588.24	24.26	23.23
.0018	9.504	555.56	23.57	24.00
.0019	10.032	526.32	22.94	24.74
.0020	10.560	500.00	22.36	25.46
.0021	11.088	476.19	21.82	26.17
.0022	11.616	454.55	21.32	26.86
.0023	12.144	434.78	20.85	27.55
.0024	12.672	416.67	20.41	28.23
.0025	13.200	400.00	20.00	28.89
.0026	13.728	384.62	19.61	29.54
.0027	14.256	370.37	19.25	30.18
.0028	14.784	357.14	18.90	30.82
.0029	15.312	344.83	18.57	31.44
.0030	15.840	333.33	18.26	32.04
.0031	16.368	322.58	17.96	32.64
.0032	16.896	312.50	17.68	33.24
.0033	17.424	303.03	17.41	33.83
.0034	17.952	294.12	17.15	34.43
.0035	18.480	285.71	16.90	35.00
.0036	19.008	277.78	16.67	35.56
.0037	19.536	270.27	16.44	36.14
.0038	20.064	263.16	16.22	36.69
.0039	20.592	256.41	16.02	37.22
.0040	21.120	250.00	15.81	37.79
.0041	21.648	243.90	15.62	38.30
.0042	22.176	238.10	15.43	38.85
.0043	22.704	232.56	15.25	39.88