

3.4 Insulation materials for cold service systems

Where the exposed surfaces of vapour barriers and adhesives used in conjunction with insulation, as well as insulation of pipe fittings, for cold service systems are required to have low flame-spread characteristics, the surface flammability test procedure and criteria for linings and ceilings according to resolution A.653(16) shall be applied for such exposed surfaces.

3.5 Other references

Part 2 of this annex is also applicable to surface materials.