

December, 1983

Governor Ames Mansion

ELECTRICAL SAFETY AND CODE CONSIDERATIONS

1.	Upgrade and increase existing electric service size, main distribution equipment, etc.	\$ 8,000
2.	Install new diesel generator, transfer switch, fuel storage tank, piping, etc.	12,000
3.	Disconnect and remove existing DC electric service to elevator equipment, etc.	3,500
4.	Power distribution feeder and branch circuit survey.	5,000
5.	New emergency lighting and exit signs for new stairwell, egress paths, etc.	6,400
6.	New automatic fire alarm system.	15,000
7.	New stairwell lighting.	2,000
8.	Disconnection, removal and/or relocation of various existing electrical systems wiring and equipment due to architectural and mechanical renovations	4,000
9.	Original items.	<u>14,800</u>
TOTAL COST FOR ELECTRICAL CONSIDERATIONS		\$70,700