

Class A-0 deck

A steel deck with dimensions not less than the minimum dimensions given below:

- thickness of plating: 4 mm
- stiffeners 95 x 65 x 7 mm spaced at 600 mm or structural equivalent.

3.2 Notwithstanding the provisions in 3.1 above, the materials which are used in "A", "B" and "F" class divisions and which are required to have certain other specified characteristics (e.g. non-combustibility, low flame-spread characteristics, etc.) shall comply with the appropriate parts of annex 1 or section 8 and annex 3, of this Code.

4 Fire door control systems
(no entries)

5 Low flame-spread surfaces

5.1 Non-combustible materials are considered to comply with the requirements of part 5 of annex 1. However, due consideration shall be given to the method of application and fixing (e.g. glue).

5.2 Primary deck coverings classified as not readily ignitable in accordance with part 6 of annex 1 are considered to comply with the requirements of part 5 of annex 1 for floor coverings.

6 Primary deck coverings

Non-combustible materials are considered to comply with the requirements of part 6 of annex 1. However, due consideration shall be given to the method of application and fixing.

7 Vertically supported textiles and films
(no entries)

8 Upholstered furniture
(no entries)

9 Bedding components
(no entries)