

TABLE 6.15
Design Capacity Factors Used in the Analysis

	<u>Existing Plants</u>				<u>New Plants</u>
	<u>1985</u>	<u>1990</u>	<u>1995</u>	<u>2000</u>	
Coal Steam	-	-	-	-	.65
Oil Steam	.4	.3	.3	.25	.65
Gas Steam	.4	.3	.3	.25	.65
Oil Nonstream	-	-	-	-	.10
Gas Nonstream	-	-	-	-	.10
Hydroelectric, Other	-	-	-	-	.60
Nuclear Steam	-	-	-	-	.65

* unchanged from base year, varies by unit.