

129992-5

Ottawa, July 17, 1908.

Rev. Sir :-

I beg to acknowledge the receipt of your letter dated June 30, last, enclosing tender from the Standard Plumbing Company of Winnipeg, for the proposed installation of a water supply and drainage system for the Kenora Boarding School, and to say in reply that it will be necessary for you to send to this Department at as early a date as possible, full information in connection with the Pneumatic water supply system, which is covered by tender.

State the weight and thickness of plates in tank (ends and body), test pressure, guaranteed working pressure etc. Type of Gasoline engine, horse power, name of manufacturer, and guarantee. Make and type of pump (if air and water combined or water only), capacity and guarantee.

A full description and specification of each machine is required and catalogue with illustrations of each is preferred if convenient.

A plan of the building is required showing the kitchen and foundation, also elevations for reference in the Department.

In the profile plan sent the high water mark only is given. This shows water of sufficient depth to protect the pipes from frost except at a point near the river channel where the pipe rises about two feet below high water mark.

Dept. of Indian & Northern Affairs, Letterbook,  
13 July 1908 - 31 July 1908, (R.G. 10, Volume 5208)

**PUBLIC ARCHIVES**  
**ARCHIVES PUBLIQUES**  
**CANADA**