

XLVIII.

If the party fail to appear at the time appointed for laying the service pipe the work will be proceeded with in the ordinary way, and any subsequent alterations will only be made at the expense of the water-taker.

XLIX.

The onus shall lie upon the water-taker to show that the pipe laid within his premises is in accordance with the requirements of the Corporation, and unless such be shown to the satisfaction of the inspector or foreman in charge of the work, connection shall not be made with the street pipe.

L.

No two premises supplied with water from the Water Works shall be dependent upon one service pipe beyond the street line, but each separate and distinct tenement or premises shall be supplied, through a separate pipe provided with the proper stop cocks, or other means of cutting off the water

LI.

All service pipes upon the premises of water-takers shall be laid to a depth of not less than five feet six inches below the level of the surrounding ground; and where they cross or are near other excavations they shall be properly protected against settlement.

LII.

The material employed in the construction of these service pipes shall correspond in all particulars with that of a similar kind used by the Corporation.