

- (4) Dry chemical type for extinguishing all kind of fire.

Article 17. Fire extinguisher must be in usable condition and must have record of installation, refill or change of chemical as well as necessary inspection and the recommendation of manufacturer. Inspection must be carried out not less than once every six months.

Article 18. Must provide training session for workers on the use of fire-extinguisher and practical knowledge in case of fire.

## Chapter 5

### Refuse Disposal, Drainage and Ventilation

Issued by virtue of Section 39 (6)

Article 19. Must always keep the factory clean and clear of refuse and must provide refuse receptacle or disposal according to the necessity and suitability.

Article 20. Must separate refuse or unusable material which contains mixture of poison, or cotton wool, cloth or piece of cotton stained with flammable material, in different receptacle with proper lid, and must provide special disposal of the above-mentioned by following safety procedure and without causing annoyance.

Article 21. Must maintain drainage system in good condition and efficiency.

Article 22. Waste water must not be drained from factory except after one or more treatments have been applied and the waste water becomes as follows: