

ANNEX 2

**PRODUCTS WHICH MAY BE INSTALLED WITHOUT TESTING
AND/OR APPROVAL**

General

In general, the products and product groups listed in this annex are considered to have the fire safety characteristics specified below and they may be installed without testing according to and without approval on basis of the specific fire test procedures in this Code for the specific safety characteristics of the product.

The paragraphs below are numbered with the same part number in which the corresponding testing requirements are specified in annex 1.

1 Non-combustible materials

In general, products made only of glass, concrete, ceramic products, natural stone, masonry units, common metals and metal alloys are considered being non-combustible and they may be installed without testing and approval.

2 Materials not generating excessive quantities of smoke nor toxic products in fire

2.1 In general, non-combustible materials are considered to comply with the requirements of part 2 of annex 1 without further testing.

2.2 In general, surface materials and primary deck coverings with both the total heat release (Q_t) of not more than 0.2 MJ and the peak heat release rate (q_p) of not more than 1.0 kW (both values determined in accordance with part 5 of annex 1 or in accordance with resolution A.653(16)) are considered to comply with the requirements of part 2 of annex 1 without further testing.

3 "A", "B" and "F" class divisions

3.1 The following products may be installed without testing or approval:

Classification**Product description**

Class A-0 bulkhead

A steel bulkhead with dimensions not less than the minimum dimensions given below:

- thickness of plating: 4 mm
- stiffeners 60 x 60 x 5 mm spaced at 600 mm or structural equivalent