

**Regulation 30 - Openings in "A" class divisions**

36 Existing paragraph 4 is replaced by the following:

"4 Fire doors in main vertical zone bulkheads, galley boundaries and stairway enclosures other than power-operated watertight doors and those which are normally locked, shall satisfy the following requirements:

- .1 the doors shall be self-closing and be capable of closing against an angle of inclination of up to 3.5° opposing closure;
- .2 the approximate time of closure for hinged fire doors shall be no more than 40 s and no less than 10 s from the beginning of their movement with the ship in upright position. The approximate uniform rate of closure for sliding fire doors shall be of no more than 0.2 m/s and no less than 0.1 m/s with the ship in the upright position;
- .3 the doors shall be capable of remote release from the continuously manned central control station, either simultaneously or in groups and shall be capable of release also individually from a position at both sides of the door. Release switches shall have an on-off function to prevent automatic resetting of the system;
- .4 hold-back hooks not subject to central control station release are prohibited;
- .5 a door closed remotely from the central control station shall be capable of being re-opened at both sides of the door by local control. After such local opening, the door shall automatically close again;
- .6 indication shall be provided at the fire door indicator panel in the continuously manned central control station whether each of the remote-released doors are closed;
- .7 the release mechanism shall be so designed that the door will automatically close in the event of disruption of the control system or main source of electric power;
- .8 local power accumulators for power-operated doors shall be provided in the immediate vicinity of the doors to enable the doors to be operated after disruption of the control system or main source of electric power at least ten times (fully opened and closed) using the local controls;
- .9 disruption of the control system or main source of electric power at one door shall not impair the safe functioning of the other doors;
- .10 remote-released sliding or power-operated doors shall be equipped with an alarm that sounds for at least 5 s but no more than 10 s after the door is released from the central control station and before the door begins to move and continue sounding until the door is completely closed;