

not be less than one fire extinguisher per area of 100 square meters, fraction of 100 square meters is to be counted as 100 square meters.

Article 15. One fire extinguisher means the following fire extinguisher or other equipment for extinguishing fire:

- (1) acid-soda type or water sprayed by gas type of extinguisher, with capacity of not less than 10 litres;
- (2) foam gas type of extinguisher, with capacity of not less than 10 litres;
- (3) carbon dioxide type of extinguisher, with capacity of not less than 5 kilograms;
- (4) dried chemical type of extinguisher, with capacity of not less than 5 kilograms.

Article 16. Chemical fire extinguisher must be of suitable type for the kind of fire which may be caused as follows:

- (1) acid-soda type or water sprayed with gas type for extinguishing ordinary fire i.e. fire caused by wood, paper, cloth. Do not use for extinguishing fire caused by electrical equipment, various type of oil, alcohol, acetone or calcium carbide;
- (2) foam gas type for extinguishing ordinary fire or fire caused by various types of oil, alcohol, or acetone. Do not use for extinguishing fire caused by electrical equipment or calcium carbide;
- (3) Carbon dioxide type for extinguishing all kind of fire but not in a windy or an open area;