

- 15 Existing paragraph 3.5 is replaced by the following:
- ".5 the Administration shall require a test of a prototype bulkhead or deck in accordance with the Fire Test Procedures Code to ensure that it meets the above requirements for integrity and temperature rise."
- 16 In paragraph 4.2, "139°C" is replaced by "140°C".
- 17 Existing paragraph 4.4 is replaced by the following:
- ".4 the Administration shall require a test of a prototype division, in accordance with the Fire Test Procedures Code, to ensure that it meets the above requirements for integrity and temperature rise."
- 18 Existing paragraph 8 is replaced by the following:
- "8 *Low flame spread* means that the surface thus described will adequately restrict the spread of flame, this being determined in accordance with the Fire Test Procedures Code."
- 19 Existing paragraph 22-1 is replaced by the following:
- "22-1 *Central control station* is a control station in which the following control and indicator functions are centralized:
- .1 fixed fire detection and alarm systems;
  - .2 automatic sprinklers, fire detection and alarm systems;
  - .3 fire door indicator panels;
  - .4 fire door closures;
  - .5 watertight door indicator panels;
  - .6 watertight door closures;
  - .7 ventilation fans;
  - .8 general/fire alarms;
  - .9 communication systems including telephones; and
  - .10 microphones to public address systems."
- 20 Existing paragraph 23.3 is replaced by the following:
- ".3 all draperies, curtains and other suspended textile materials have qualities of resistance to the propagation of flame not inferior to those of wool of mass 0.8 kg/m<sup>2</sup>, this being determined in accordance with the Fire Test Procedures Code."
- 21 Existing paragraph 23.4 is replaced by the following:
- ".4 all floor coverings have low flame spread characteristics."
- 22 Existing paragraph 23.6 is replaced by the following:
- ".6 all upholstered furniture has qualities of resistance to the ignition and propagation of flame, this being determined in accordance with the Fire Test Procedures Code."