

**CIHM  
Microfiche  
Series  
(Monographs)**

**ICMH  
Collection de  
microfiches  
(monographies)**



**Canadian Institute for Historical Microreproductions / Institut canadien de microreproductions historiques**

**© 1997**

## Technical and Bibliographic Notes / Notes techniques et bibliographiques

The Institute has attempted to obtain the best original copy available for filming. Features of this copy which may be bibliographically unique, which may alter any of the images in the reproduction, or which may significantly change the usual method of filming are checked below.

- Coloured covers / Couverture de couleur
- Covers damaged / Couverture endommagée
- Covers restored and/or laminated / Couverture restaurée et/ou pelliculée
- Cover title missing / Le titre de couverture manque
- Coloured maps / Cartes géographiques en couleur
- Coloured ink (i.e. other than blue or black) / Encre de couleur (i.e. autre que bleue ou noire)
- Coloured plates and/or illustrations / Planches et/ou illustrations en couleur
- Bound with other material / Relié avec d'autres documents
- Only edition available / Seule édition disponible
- Tight binding may cause shadows or distortion along interior margin / La reliure serrée peut causer de l'ombre ou de la distorsion le long de la marge intérieure.
- Blank leaves added during restorations may appear within the text. Whenever possible, these have been omitted from filming / Il se peut que certaines pages blanches ajoutées lors d'une restauration apparaissent dans le texte, mais, lorsque cela était possible, ces pages n'ont pas été filmées.
- Additional comments / Commentaires supplémentaires: Various pagings.

L'Institut a microfilmé le meilleur exemplaire qu'il lui a été possible de se procurer. Les détails de cet exemplaire qui sont peut-être uniques du point de vue bibliographique, qui peuvent modifier une image reproduite, ou qui peuvent exiger une modification dans la méthode normale de filmage sont indiqués ci-dessous.

- Coloured pages / Pages de couleur
- Pages damaged / Pages endommagées
- Pages restored and/or laminated / Pages restaurées et/ou pelliculées
- Pages discoloured, stained or foxed / Pages décolorées, tachetées ou piquées
- Pages detached / Pages détachées
- Showthrough / Transparence
- Quality of print varies / Qualité inégale de l'impression
- Includes supplementary material / Comprend du matériel supplémentaire
- Pages wholly or partially obscured by errata slips, tissues, etc., have been refilmed to ensure the best possible image / Les pages totalement ou partiellement obscurcies par un feuillet d'errata, une pelure, etc., ont été filmées à nouveau de façon à obtenir la meilleure image possible.
- Opposing pages with varying colouration or discolourations are filmed twice to ensure the best possible image / Les pages s'opposant ayant des colorations variables ou des décolorations sont filmées deux fois afin d'obtenir la meilleure image possible.

This item is filmed at the reduction ratio checked below /  
Ce document est filmé au taux de réduction indiqué ci-dessous.

	10x		14x		18x		22x		26x		30x	
	12x		16x		20x		24x		28x		32x	
									✓			

The copy filmed here has been reproduced thanks to the generosity of:



National Library of Canada

The images appearing here are the best quality possible considering the condition and legibility of the original copy and in keeping with the filming contract specifications.

Original copies in printed paper covers are filmed beginning with the front cover and ending on the last page with a printed or illustrated impression, or the back cover when appropriate. All other original copies are filmed beginning on the first page with a printed or illustrated impression, and ending on the last page with a printed or illustrated impression.

The last recorded frame on each microfiche sheet will contain the symbol  $\rightarrow$  (meaning "CONTINUED"), or the symbol  $\nabla$  (meaning "END"), whichever applies.

Maps, plates, charts, etc., may be filmed at different reduction ratios. Those too large to be entirely included in one exposure are filmed beginning in the upper left hand corner, left to right and top to bottom, as many frames as required. The following diagrams illustrate the method:



L'exemplaire filmé fut reproduit grâce à la générosité de:


Bibliothèque nationale du Canada

Les images suivantes ont été reproduites avec le plus grand soin, compte tenu de la condition et de la netteté de l'exemplaire filmé, et en conformité avec les conditions du contrat de filmage.

Les exemplaires originaux dont la couverture en papier est imprimée sont filmés en commençant par le premier plat et en terminant soit par la dernière page qui comporte une empreinte d'impression ou d'illustration, soit par le second plat, selon le cas. Tous les autres exemplaires originaux sont filmés en commençant par la première page qui comporte une empreinte d'impression ou d'illustration et en terminant par la dernière page qui comporte une telle empreinte.


Un des symboles suivants apparaîtra sur la dernière image de chaque microfiche, selon le cas: le symbole  $\rightarrow$  signifie "A SUIVRE", le symbole  $\nabla$  signifie "FIN".

Les cartes, planches, tableaux, etc., peuvent être filmés à des taux de réduction différents. Lorsque le document est trop grand pour être reproduit en un seul cliché, il est filmé à partir de l'angle supérieur gauche, de gauche à droite, et de haut en bas, en prenant le nombre d'images nécessaire. Les diagrammes suivants illustrent la méthode.



# MICROCOPY RESOLUTION TEST CHART

(ANSI and ISO TEST CHART No. 2)



**APPLIED IMAGE Inc**

1653 East Main Street  
Rochester, New York 14609 USA  
(716) 482-0300 - Phone  
(716) 288-5989 - Fax

R-33-7  
200

DEPARTMENT OF THE INTERIOR  
DOMINION WATER POWER BRANCH  
OTTAWA, CANADA


WATER RESOURCES PAPER No. 3  
VOLUME I


WINNIPEG RIVER POWER  
AND  
STORAGE INVESTIGATIONS

BY  
J. T. JOHNSTON, B.A. Sc.  
Chief Hydraulic Engineer.

Prepared under the direction of the Superintendent of Water Power.

OTTAWA  
GOVERNMENT PRINTING BUREAU  
1915.











AEROPLANE VIEW OF SOUTHEASTERN MANITOBA



SOUTH-EASTERN MANITOBA





**DEPARTMENT OF THE INTERIOR—CANADA**  
Hon. W. J. ROCHE, Minister, W. W. GORY, C.M.G., Deputy Minister.  
**DOMINION WATER POWER BRANCH,**  
J. B. CHALLIES, C.E., Superintendent.

---

---

**WATER RESOURCES PAPER No. 3**  
**VOLUME I**

---

**REPORT**  
ON THE  
**WINNIPEG RIVER POWER**  
AND  
**STORAGE INVESTIGATIONS**

BY  
**J. T. JOHNSTON, B.A. Sc.**  
Chief Hydraulic Engineer.

---

Prepared under the direction of the Superintendent of Water Power.

---

OTTAWA  
GOVERNMENT PRINTING BUREAU  
1915.

86376—A

00938221

*To Field Marshal, His Royal Highness Prince Arthur William Patrick Albert,  
Duke of Connaught and of Strathearn, K.G., K.T., K.P., etc., etc., etc.,  
Governor General and Commander in Chief of the Dominion of Canada.*

MAY IT PLEASE YOUR ROYAL HIGHNESS:

The undersigned has the honour to lay before Your Royal Highness a report on the Winnipeg River Power and Storage Investigations.

Respectfully submitted,

W. J. ROCHE,

*Minister of the Interior.*

OTTAWA, July 20, 1915.



DEPARTMENT OF THE INTERIOR,

OTTAWA, July 20, 1915.

The Honourable W. J. ROCHE,  
Minister of the Interior.

SIR,—I have the honour to submit a report on the Winnipeg River Power and Storage Investigations, and to recommend that it be published as Water Resources Paper No. 3 of the Dominion Water Power Branch.

I have the honour to be, sir,

Your obedient servant,

W. W. CORY,

*Deputy Minister of the Interior.*



OTTAWA, July 17, 1915.

W. W. CORY, Esq., C.M.G.,  
Deputy Minister of the Interior,  
Ottawa, Canada.

SIR,—The people of the province of Manitoba have a keen interest in the important economic problems now brought so forcibly to the attention of the Canadian people as a result of "the conservation movement." That interest is particularly manifested at this time because probably no province in the Dominion is endowed with conditions so favourable and opportunities so promising for the early accomplishment of material progress from practical and sane conservation of one of its most valuable natural resources.

Water is practically the only natural resource within the province for the development of power, that great and fundamental requisite for the prosperity and comfort of a civilized community. This condition is compensated for by the fact that in addition to the existence of an abundance of water, the general topography and the forest cover of a large portion of the province is naturally favourable for the establishment of hydraulic power developments, and also for the construction of storage reservoirs for flow regulation.

Historically considered, the utilization of our power resources has passed through three distinct phases. The first pertained to the production of power directly and from natural sources as water and wind, and its use was necessarily limited to their location. Early manufacturing communities were consequently grouped about easily available water power sites. This phase might be called the water power period in manufacturing industries.

The second phase was characterized by the gradual development of the steam engine which rendered possible the utilization of fuel as a source of power, and at locations where it was required. During this period the development of coal mines and the rapid extension of railway systems imparted a tremendous stimulus to commercial and industrial enterprise. Proximity of water powers was no longer the controlling factor, and industrial communities were established wherever availability of raw material, labour, transportation facilities, markets and fuel power would allow.

The third phase of power development in this country synchronizes with the advancement of the art of high voltage transmission which permits the development of power generated by water or by steam at the most convenient and economical points, and its transmission many miles away to the desired location of use, in a form adapted to a great variety and convenience of use.

This later phase of development and use of power has called for a re-appraisal of all sources from which power is derived. The size of the power plant is no longer limited to requirements of any particular purpose or use, but the power for entire communities, and for an infinite variety of use, civil and commercial, can be supplied from a single station or power site many miles distant.

Extension of the field of use opened by the perfection of the art of electric transmission of power from great distances, has been marvellous. As a result, rapid and revolutionary changes are constantly taking place in the use of power. As the circle of electrical application circumscribes new fields, the opportunities for power development grow proportionately. The tremendous advance to date in the practicable application of the use of electric power in industry and the further accomplishments that are assured, have rendered the conservation and utilization of our power resources, (more especially our water powers), one of the most important problems in Canadian political economy.

The solution of this problem involves complex questions of law and regulation relating to various uses of water for domestic supply, irrigation, power, logging and navigation; of adequate administration under such legislation; of essential engineering and economic investigation of water resources to meet the necessities of administration, and to determine the most efficient and effective method of power development, so that the permanent public interest will be best served; and probably most difficult of all, determinations of economic questions relating to adequate rentals, and reasonable rates.

Canadian water power laws are in the main quite adequate, encouraging to development, with due regard to the public interest, present and future. While in some parts of the Dominion former conditions have been outgrown, and in such parts the evolution of governmental machinery and laws with respect to water powers has not advanced as fast as might be desired, it must be remembered that there is but a short distance in time from the 50 h.p. overshot mill wheel of small efficiency, crude apparatus, local use and of little general importance to the community at large, to the 20,000 h.p. turbine of over 90% efficiency and 200 mile transmission radius of to-day, of such widespread importance owing to the present universality of the electrical industry and the consequent infinite ramifications of power use in respect of the body politic.

So far as the prairie provinces of Manitoba, Saskatchewan and Alberta are concerned, the problems above referred to have been given fairly adequate consideration and the regulations, administration and investigations which have been evolved by the Department of the Interior in the short space of seven or eight years, have marked a creditable achievement. The existing water power regulations (see appendix IV) are admittedly, in some respects, imperfect. At the same time the imperfections and undesirable features are thoroughly well realized, and it is only a matter of time and opportunity when they will be corrected. The regulations now in force afford every reasonable protection to the public in the way of limited grants, rentals and control of rates, both subject to periodic revision, continuous and beneficial use of the power privileges, and at the same time provide sufficiently attractive opportunities for investment to actively interest the capitalist. The departmental administration, is as progressive as the regulations and the Parliamentary appropriations will permit.

The two most important water power situations within the three prairie provinces, that on the Winnipeg river in Manitoba, and that on the Bow river in Alberta, important on account of their strategic location close to important

existing commercial centres, and on account of the great and urgent demand for power within these centres, and also important on account of the complicated problems involved in realizing the best use of the potential power possibilities in a manner consistent with the interests of irrigation, navigation and water supply; have been exhaustively covered by extensive engineering and economic investigations in the field, and by thorough study in the office.

The power and storage investigations of the Bow river were completed over a year ago and published in the form of a report as Water Resources Paper No. 2.

The Winnipeg river power situation in the province of Manitoba within easy transmission radius (about seventy-five miles) of the city of Winnipeg, a city on the eastern threshold of the great prairie country, which competent experts claim will have a future in population, banking, commercial and industrial importance equal to that of Chicago, has also been thoroughly investigated.

These investigations were commenced in 1911 following a report from the undersigned, then Hydraulic Engineer of the Department, to the late Robert Evans Young, D.L.S., then Chief Geographer, and in responsible administrative charge of water power matters in the western provinces. No one in the Canadian service had a deeper appreciation for the importance of the undeveloped natural resources of the west, or a more thorough realization of their tremendous import to the future progress of the prairie provinces. With his boundless enthusiasm for all matters relating to western Canada he determined that this department should, with respect to water powers, have not only an efficient and effective administration, but should obtain by every reasonable means, a thorough knowledge of their nature, extent and value, especially those powers within zones of "reasonable commercial availability." In order that the Winnipeg river water power investigations might be commenced under proper auspices and on a thoroughly satisfactory basis, Mr. Young, early in 1911, conferred with two prominent consulting engineers, eminent in hydro-electric practice, Mr. John R. Freeman of Providence and New York, and Mr. J. B. McRae of Ottawa. Accompanied by Mr. J. T. Johnston, then Assistant Hydraulic Engineer of the department, and Mr. D. L. McLean, these engineers, in the month of September of the same year, made a reconnaissance trip down the Winnipeg river from Kenora at the outlet of the lake of the Woods to lake Winnipeg. After the completion of this investigation, these engineers submitted reports which were so emphatic as to the potential power possibilities of the river, and so strongly recommended that a complete power survey be commenced at once, that arrangements were immediately perfected for the work to be commenced under the immediate direction of Mr. J. T. Johnston.

Up to the time of his resignation in September, 1913, Mr. McLean ably acted as chief engineer of the field operations. Between September 1913 and June 1914 Mr. S. S. Scovill assumed complete charge of the field work to the entire satisfaction of the Department. Since June 1914 Mr. M. C. Hendry has been responsible for the continuation of the field studies. To these three engineers in conjunction with Mr. Johnston, under whose direction from Ottawa the work was carried on, great credit is due for their efficient and satisfactory

completion. Mr. Johnston is wholly responsible for the comprehensive power scheme developed in the report attached hereto, and for the unusually satisfactory presentation of the results of the investigations.

These investigations show that at nine distinct power sites, by means of storage easily and cheaply accomplished at the Lake of the Woods, at Lac Seul and other lakes in the province of Ontario, it is possible and economically feasible to develop over 418,000 continuous 24-hour horse-power, all within seventy-five miles of the city of Winnipeg and within feasible transmission distance of all commercial centres of the present settled portions of the province.

Of the nine possible power sites on the Winnipeg river, there are three now under development, representing a total power capacity of 200,000 24-hour horse-power. One site is completely developed by the Winnipeg Electric Railway Company on the Pinawa channel, and produces about 28,000 horse-power. Another site at Point du Bois falls, developed by the city of Winnipeg produces at the present time about 25,000 continuous horse-power, but is capable of extensions to a maximum of 77,000 24-hour horse-power. Development of the third power site at Great or du Bonnet falls, having a maximum possible development of 95,000 24-hour horse-power, is about to be commenced by the Winnipeg River Power Company.

There is, therefore, at the present time about 53,000 continuous horse power produced, and transmitted for use in and around the city of Winnipeg, which can, with the two present plants, be increased to 200,000 24-hour horse-power.

The six remaining power sites are under the control of the Dominion Government, and can furnish a further amount of 24-hour power to a maximum extent of 218,000 horse-power.

In addition, there are several important power sites on the Winnipeg and English rivers within the province of Ontario, which are within easy transmission distance of Winnipeg.

Experience has abundantly proved the advisability of such investigations as a necessary preliminary to the authorization of all important power or storage projects, and furthermore, that proper government supervision and control of the construction and maintenance of all developments, is the only safe method of intelligently initiating construction and maintaining an adequate system of river improvement for power purposes that will allow of the most advantageous use of the resources of a river from both an engineering and an economic standpoint. Such investigation, supervision and control by government engineers of recognized competence and character, not only secures the scientific treatment of power rivers as a whole, but the safe and economic execution of the various component parts of a comprehensive system of improvement.

Development under the immediate direction of the Government makes certain the fullest possible utilization of the power possibilities of each stream whereas development by private enterprise almost invariably involves waste of natural resources. Private capital is seeking the greatest possible immediate return on investment and naturally concentrates its attention to the most concentrated and easily developed portion of a stretch of a river. The least precipi-

tous portions of the river above and below a concentrated stretch involving a large unit outlay in development, are consequently apt to be neglected and permanently wasted because no other enterprise is likely or able to undertake the subsequent development. On the other hand the Government with its greater power and scope can compel the construction of the more extensive works necessary to develop to the fullest feasible extent so that every foot-pound of energy represented by the falling waters of the province may be given up when necessary to the service of man.

"The prime reason for the exercise of government authority over the control of stream flow for power development, is that under modern social and economic conditions, this step is necessary to insure the equal participation of all citizens in this form of natural wealth which is peculiarly the heritage of the whole people.

In the case of the Winnipeg river the anticipated advantages of such investigations as described herein have been realized to the full. Not only is the Government now in a position to direct developments in connection with storage and power which will strictly conform to the comprehensive scheme worked out, but it is also possible to compel a course of development which will conform with the strictest economic considerations, not only in connection with engineering problems directly involved, but problems indirectly allied and relating to the present and anticipated necessities of the market to be served.

As a direct result of these investigations the Department of the Interior has been able to authorize and start a new power project at Great falls, and at the same time to have the existing developments of the city of Winnipeg and the Winnipeg Electric Railway Company, conform to and be consistent with the comprehensive control scheme worked out as described in detail in this report. The right granted for these three projects are wholly consistent with the ultimate realization of the comprehensive scheme and conform strictly to the policy of water power administration under the Water Power Regulations. Constructive conservation has been realized with the best permanent public interest has been realized to a degree unequalled, and not surpassed in present day water power administration. The department now has at hand all essential data respecting the water power situation on the Winnipeg river to enable it to work out a comprehensive scheme of development realizing the most advantageous use of the whole river for power and other purposes; to enable all new developments to be commenced with a minimum of physical investigation and therefore of delay; to insure that all developments will fit in and be component parts of the whole project. Not only has future administration been simplified and power development to keep pace with all demands been made certain, but present and future developments have been properly co-related as parts of a comprehensive scheme to realize the best possible use of the river for power.

As these investigations conclusively show, there is no more fortunate power situation on the continent than that on the Winnipeg river. Situated as it is within a few miles of the present city of Winnipeg and at the threshold of the western prairie provinces, there can be no doubt about the gradual development

of these various water powers to their maximum possible capacity. The industrial and commercial future of the city of Winnipeg and indeed the province of Manitoba, is assured beyond peradventure and quite independent of outside sources of power-producing agencies.

In view of the great importance of the Winnipeg river power situation to the future development of the city of Winnipeg, the province of Manitoba, and of western Canada, I would recommend that Mr. Johnston's report be sent to the King's Printer for publication as No. 3 of the series of Water Resources Papers of the Dominion Water Power Branch.

Respectfully submitted,

J. B. CHALLIES,  
*Superintendent,*  
*Dominion Water Power Branch.*

July 16, 1915.

J. B. CHALLIES, Esq., C.E.,  
Superintendent,  
Dominion Water Power Branch,  
Department of the Interior,  
Ottawa.

SIR,—I have the honour to submit a report on the Winnipeg River Power and Storage Investigations covering the Field and Office Studies carried on by the Dominion Water Power Branch, with a view to ensuring a full measure of conservation of the power resources of the river, and to providing a definite and permanent basis for the proper administration of these resources.

In submitting this report I wish to make due acknowledgment of the efficient and hearty co-operation of the staff of the Manitoba Hydrographic Survey under the direction of Mr. D. L. McLean as Chief Engineer during the early stages of the work, of Mr. S. S. Scovil as Assistant Chief Engineer since August, 1912, and as acting chief from October, 1913, to June, 1914, and of Mr. M. C. Hendry as Chief Engineer since July, 1914.

I have the honour to be, sir,

Your obedient servant,

J. T. JOHNSTON,

*Chief Hydraulic Engineer.*



TABLE OF CONTENTS.

VOLUME I.

CHAPTER I.

SUMMARY OF INVESTIGATIONS.

	PAGE.
Introductory—Summary of Power and Storage Studies—Conclusions from Investigations—Recommendations—Policy of the Department—Necessity for Crown Control—Situation leading to Commencement of Survey—Scope of the Investigation—Acknowledgments.....	3

CHAPTER II.

WINNIPEG WATERSHED AND FIELD INVESTIGATIONS.

Historical—General description of Basin and River—Preliminary reconnaissance—Field Survey.....	23
--	----

CHAPTER III.

METEOROLOGICAL PHENOMENA AND RUN-OFF.

Temperature—Influence on Run-off—Ice conditions on the Winnipeg river—Sheet Ice—Frazil Ice—Anchor Ice—Effects of Ice on Power Plant Operation.....	45
Precipitation—Records available.....	55
Evaporation—Evaporation Station—Records available.....	57
Run-off—Available records in Basin—Slave falls Metering Station—Discharge Records—Lake of the Woods Outlets—Meterings—Discharge Records—Fort Frances Metering Station—Discharge Records—Chaudière Falls Metering Station—Miscellaneous Stations and Records—Whitemouth river—Ontario Hydro-electric Power Commission Discharge Records—United States Geological Survey Discharge Records—Big Fork river—Little Fork river—Vernilion river—Kawishiwi river—General Run-off.....	60

CHAPTER IV.

STORAGE.

Introductory—Lake and Drainage areas of the Winnipeg Watershed—Ontario Hydro-Electric Power Commission Report, 1913—Manitou lakes—Otukamanawan lake—Lac des Milles Lacs—White Otter lake.....	83
Otter-Slave falls Discharge Records—Maintenance of the seven-year mean flow—Maintenance of a 20,000 second-foot flow.....	93
The Lake of the Woods—General relation of the Lake to the Basin—Outlets from the Lake of the Woods—Surface levels of the Lake of the Woods—Theoretical inflow available at Outlet for Power and storage—Storage possibilities of the Lake—Yearly regulation, 1907-1913—Regulation over the seven-year cycle—Five-foot storage on the Lake of the Woods—Regulation on the Lake in the interests of the Manitoba Power Reach.....	97
Rainy Lake Watershed—Rainy lake—Namakan lake—Regulation of the Rainy lake basin run-off—Surface levels of Rainy lake—Theoretical inflow available at outlet for power and storage—Regulation over the Seven-year cycle.....	111
English river watershed—Run-off conditions—Regulation over the seven-year cycle—Regulation of the watershed above Lac Seul—Run-off conditions—Regulation over the seven year cycle—Effect of regulation of the Lac Seul watershed on the powers of the English river.....	120
Summary of the results to be obtained from storage—Lake of the Woods and tributary drainage—English river and tributary drainage—Power reach in Manitoba—General principles of regulation—Control of regulation—Government construction of reservoirs—Regulating authority—Method of control.....	130

## CHAPTER V.

## EXISTING POWER AND INDUSTRIAL PLANTS.

	PAGE.
Introductory.....	137
First development on the Winnipeg river in Manitoba.....	137
Winnipeg Electric Railway Company's plant—Historical—Construction—Diversion weirs and control dam—Head-race—Power station—Installation—Power dam— Head available—Transmission—Operation—Flow required.....	138
City of Winnipeg Municipal Plant—Historical—Scheme of development—Forebay— Power station—Installation—Head available—Transmission and distribution— Operation—Flow required—Power—Beneficial effect of regulation.....	148
Other developments in the basin—Municipal power plant of Kenora—Lake of the Woods Milling Company's Mills at Keewatin—The Norman dam—Fort Frances dam and power plants—Chaudière falls dam.....	163

## CHAPTER VI.

## POSSIBLE POWER CONCENTRATIONS.

Reach of the river developed—Discharge of the river—Flooding and pondage—Ice con- ditions—Foundation conditions—General basis of design and layout—Head- and tail water elevations—Estimates of cost.....	179
Pine falls site—Special considerations at Pine falls—Reach of river developed—Head- and tailwater elevations—Flooding—Pondage—Ice conditions—Foundation conditions— Layout—Spillway—Fish ladder—Log slide—Sluice-way—Power station—Ice sluices—Embankment—Discharge capacity—Unwatering—Navigation—Estimates of cost—Initial development—Final development.....	186
Du Bonnet site—Special considerations at Du Bonnet falls—Reach of the river developed— Disposal of Whitemud falls—Head- and tailwater elevations—Flooding—Pondage— Ice conditions—Foundation conditions—Layout—Embankment—Ice sluices—Power station—Sluiceways—Spillway—Fish ladder—Log slide—West embankment—Dis- charge capacity—Unwatering—Navigation—Estimates of cost—Initial development —Intermediate development—Final development.....	199
McArthur falls site—Special considerations at McArthur falls—Reach of river developed— Head- and tailwater elevations—Flooding—Pondage—Ice conditions—Foundation conditions—Layout—Spillway—Embankment—Sluiceways—Ice sluices—Power sta- tion—Discharge capacity—Unwatering—Navigation—Estimates of cost—Initial development—Final development.....	211
Seven Sisters reach.....	222
Lower Seven Sisters site—Special considerations at the Lower Seven Sisters site—Reach of the river developed—Head- and tailwater elevations—Flooding—Pondage—Ice conditions—Foundation conditions—Layout—Ice sluices—Power station—Sluice- ways—Spillway—Discharge capacity—Unwatering—Navigation—Estimates of cost —Complete development.....	222
Upper Seven Sisters site—Special considerations at Upper Seven Sisters site—Reach of the river developed—Head- and tailwater elevations—Flooding—Pondage—Removal of weirs—Ice conditions—Foundation conditions—Layout—Spillway—Sluice-ways— Power station—Ice sluices—Embankments—Discharge capacity—Unwatering— Navigation—Estimates of cost—Complete development.....	233
Upper Pinawa site—Special considerations at Upper Pinawa site—Reach of river devel- oped—Head- and tailwater elevations—Flooding—Pondage—Ice conditions—Founda- tion conditions—Layout—Power station—Dam—Embankments—Discharge capa- city—Unwatering—Navigation—Estimates of cost—Complete development.....	243
Slave falls site—Special considerations at Slave falls site—Reach of river developed— Head- and tailwater elevations—Flooding—Pondage—Ice conditions—Foundation conditions—Layout—Fish ladder—Log slide—Sluiceways—Spillway—Ice sluices— Power station—Head-race—Discharge capacity—Unwatering—Navigation—Esti- mates of cost—Initial development—Final development.....	249
Summary of dependable power—Summary of capital and operating costs—Cost of delivery of power to Winnipeg—Initial development—Final development.....	258

## CHAPTER VII.

## POWER FROM COAL, GAS AND OIL.

Introductory—Auxiliary or reserve fuel plant—Estimates of cost of reserve plant—Cost of fuel power in Winnipeg compared with hydro-electric power from Pine falls— Estimates of cost of steam, oil and producer gas power in Winnipeg—Cost of hydro- electric power.....	269
---	-----

*Winnipeg River Power and Storage Investigations.*

xvii

CHAPTER VIII.

MARKET FOR POWER.

PAGE.		PAGE.
137	Introductory—Ratio of horse-power installed to population—Canada as compared with other countries—Hydro-electric development in the United States—Hydro-electric development in Canada—The Winnipeg market—History and growth of the City—Industrial development—The general Manitoba market—General hydro electric distribution in Manitoba—Estimates—Other use for Winnipeg river power—Pulp and paper manufacture—Electro-chemical, etc., industries.	281

CHAPTER IX.

INTERNATIONAL WATERWAYS REFERENCE.

	Introductory	305
	Birch lake diversion	305
	Water supply for Greater Winnipeg Water District	308
179	Level of the Lake of the Woods—Lake levels—Run-off—Conditions resulting from present system of regulation—Conditions resulting from no regulation on the Lake—Conditions resulting from comprehensive and systematically controlled regulation on the lake—Summary of the influence of the Lake of the Woods on the run-off—Influence of the Lake of the Woods on the power available in the Winnipeg river—Outlets of the Lake of the Woods—White Dog falls—City of Winnipeg municipal plant at Point du Bois—Slave falls site—Upper Seven Sisters site—Lower Seven Sisters site—Winnipeg Electric Railway Company's plant—Upper Pinawa site—McArthur site—Du Bonnet site—Pine falls site—Summary of the influence of the Lake of the Woods on the power available in the Winnipeg river—Summary of the relation of the Lake of the Woods to the power resources of the Winnipeg river—Relation of the Lake of the Woods to the watershed—Effect of non-storage regulation on the Lake of the Woods—Effect of systematic regulation on the Lake of the Woods—Additional outstanding features relative to regulation on the Lake of the Woods.	311

APPENDICES.

211	Appendix I	Report of J. B. McRae, C.E., Consulting Engineer	329
222	“ II	Proposed development of the Winnipeg River Power Company	333
	“ III	Report on Geology of Winnipeg River Watershed by Charles Camsell, B.Sc., Ph.D.	341
	“ IV	Water Power Regulations	349
	“ V	List of Bench-marks	359
22	“ VI	Temperature, Precipitation and Evaporation tables	369
	“ VII	Run-off Tables	

INDEX.

VOLUME II.

Topographic Field Plans Nos. 1 to 55.

## LIST OF ILLUSTRATIONS.

	PAGE.
	Frontispiece
Aeroplane View of South Eastern Manitoba.....	24
Route of Red River Expedition.....	29
Pine Falls, Main Drop.....	30
Silver Falls.....	32
Typical Survey Bench Mark.....	33
White Dog Rapids, Third Pitch.....	34
White Dog Rapids, Fourth Pitch.....	35
Pinawa Channel, Rock Cut.....	53
Ice Conditions on Pinawa Channel.....	54
Ice Conditions below Du Bonnet Falls.....	57
Evaporation Station on the Lake of the Woods.....	63
Cable Station at Slave Falls.....	65
Metering Station on Pinawa Channel.....	70
Old Keewatin Lumber Co. Outlet from the Lake of the Woods.....	137
Pine Falls, Old Headrace.....	139
Winnipeg Electric Railway Company, Main Weir.....	139
Fishway and Log Slide at Main Weir.....	140
Winnipeg Electric Railway Company, Secondary Weir.....	140
Winnipeg Electric Railway Company, Spillway on Leon River.....	141
Winnipeg Electric Railway Company, Construction of Control Dam.....	141
Winnipeg Electric Railway Company, Control Dam.....	143
Winnipeg Electric Railway Company, Power Station.....	145
Winnipeg Electric Railway Company, Model of Plant.....	145
Winnipeg Electric Railway Company, Interior of Power Station.....	145
Winnipeg Electric Railway Company, Power Dam.....	146
Winter Conditions at Power Dam.....	147
City of Winnipeg Municipal Plant, Power Station under Construction.....	149
City of Winnipeg Municipal Plant, Power Station under Construction.....	151
Point du Bois Falls.....	151
City of Winnipeg Municipal Plant, Model of Plant.....	153
City of Winnipeg Municipal Plant, Power Station.....	154
City of Winnipeg Municipal Plant, Headgate Room.....	158
City of Winnipeg Municipal Plant, Interior Power Station.....	160
Winnipeg River. Panoramic View City of Winnipeg. Development at Point du Bois Falls.....	164
Kenora Power Station.....	164
Kenora Power Station, Interior.....	167
Lake of the Woods Milling Company's Mills.....	169
Norman Dam, under Construction.....	170
Norman Dam.....	171
Ontario and Minnesota Pulp, Paper and Power Plants at Fort Frances.....	171
Ontario and Minnesota Pulp, Paper and Power Plants at Fort Frances.....	173
Chaudière (Kettle) Falls, Canadian Channel.....	174
Chaudière (Kettle) Falls, International Channel.....	187
Competitive Power Station Designs.....	188
Winnipeg River below Masqua Rapids.....	189
Silver Falls.....	190
Pine Falls, Site of Proposed Power Station.....	192
Model of Proposed Pine Falls Layout.....	193
Pine Falls, Main Drop.....	195
Pine Falls, Main Drop.....	195
Pine Falls, Main Drop.....	200
Little du Bonnet Falls.....	204
Grand du Bonnet Falls, Ice Conditions.....	204
Little du Bonnet Falls, Site of Proposed Power Station.....	205
Model of Proposed Du Bonnet Layout.....	212
Second McArthur Falls, Main Pitch.....	213
First McArthur Falls, Left Channel.....	216
Second McArthur Falls, Site of Proposed Power Station.....	216
Model of Proposed McArthur Layout.....	223
River Bank above Lac du Bonnet.....	223
First Rapids above Lac du Bonnet.....	225
Whitemouth Falls.....	225
Whitemouth Falls.....	225

	PAGE.
Seven Sisters Falls, Fourth Fall.....	226
Seven Sisters Falls, Fourth Fall.....	226
Seven Sisters Falls, Third Fall.....	227
Model of Proposed Lower Seven Sisters Layout.....	229
Seven Sisters Falls, Second Fall.....	235
Seven Sisters Falls, Second Fall.....	235
Seven Sisters Falls, First Fall.....	236
Seven Sisters Falls, First Fall.....	236
Model of Proposed Upper Seven Sisters Plant.....	239
First Rock Cut on Pinawa Channel, site of proposed plant.....	244
Pinawa Channel, First Rock Cut.....	245
Upper Pinawa Power Site—Line of Proposed Dam.....	247
Water Marks on rock below Eight Foot Fall.....	249
Model of Proposed Slave Falls Plant.....	252
Winnipeg River Power Company, Proposed Great Falls Development.....	334

PLATES.

PLATE 1—General plan showing existing plants and possible sites..... To face page.....	4
PLATE 2—General profile showing existing plants and possible sites..... Page.....	6
PLATE 3—General plan of Winnipeg river basin..... To face page.....	26
PLATE 3A—Plan showing approximate character of soil of the Lake of the Woods Watershed..... To face page.....	26
PLATE 3B—Plan showing forest cover of the Lake of the Woods Watershed..... To face page.....	26
PLATE 4—Key plan of topographic survey sheets..... Page.....	39
PLATE 5—Profile of Winnipeg river—Fort Alexander to Lac du Bonnet..... To face page.....	40
PLATE 6—Profile of Winnipeg river—Lac du Bonnet to Point du Bois..... ".....	40
PLATE 7—Profile of Winnipeg river—Pinawa channel..... ".....	40
PLATE 8—Comparative temperature records in typical cities in Canada..... Page.....	46
PLATE 9—Runoff and temperature curve at Kettle falls (Charliere falls).....	47
PLATE 10—Diagram of precipitation in Winnipeg river basin and vicinity..... ".....	56
PLATE 11—Plan of evaporation tank and float..... ".....	59
PLATE 12—Mass curve of mean monthly discharge and volume of runoff at Slave falls..... To face page.....	64
PLATE 13—Plan of outlets of Lake of the Woods..... To face page.....	76
PLATE 14—Mass curves of mean monthly discharge and volume of runoff at Kenora..... To face page.....	76
PLATE 15—Mass curves of mean monthly discharge and volume of runoff at Fort Frances..... To face page.....	76
PLATE 16—Curves of seven year mean monthly discharge at Slave falls, Kenora, Fort Frances, mouth of English river and outlet of Lac Seul..... To face page.....	76
PLATE 17—Duration curves of discharge at Slave falls, Kenora, Fort Frances, mouth of English river and outlet of Lac Seul..... To face page.....	76
PLATE 18—Mass curves of volume of runoff at Slave falls, Kenora, Fort Frances, mouth of English river and outlet of Lac Seul..... To face page.....	76
PLATE 19—Diagrammatic plan of Winnipeg river basin..... To face page.....	84
PLATE 20—Mass curve of discharge of Winnipeg river above and below mean at Slave falls..... To face page.....	94
PLATE 21—Mass curve of runoff above 20,000 second feet at Slave falls..... Page.....	96
PLATE 22—Mass curve of runoff of Winnipeg river above and below mean at Kenora..... To face page.....	100
PLATE 23—Mass curve of runoff of Winnipeg river at Kenora..... Page.....	108
PLATE 24—Mass curve of the use of the Lake of the Woods as a regulating reservoir to maintain 20,000 second feet flow in Manitoba..... To face page.....	112
PLATE 25—Mass curve of the use of the Lake of the Woods as a regulating reservoir to maintain 22,000 second feet flow in Manitoba..... To face page.....	112
PLATE 26—Mass curve of runoff of the Rainy river at Fort Frances..... Page.....	117
PLATE 27—Mass curve of runoff of the English river at point of junction with the Winnipeg..... Page.....	123
PLATE 28—Mass curve of runoff of the English river at the outlet of Lac Seul..... Page.....	126
PLATE 29—Hydrograph showing Winnipeg river flow regulated to a 20,000 second feet minimum..... To face page.....	132
PLATE 30—Plan and typical sections of Winnipeg Street Railway Company's diversion weirs..... To face page.....	144
PLATE 31—Plan of Winnipeg Electric Railway Company's plant on Pinawa channel..... To face page.....	144
PLATE 32—Plan of layout of City of Winnipeg plant at Point du Bois..... Page.....	152
PLATE 33—Section of retaining dam at Point du Bois plant..... ".....	155

## PLATES—Continued.

	Page.....	156
PLATE 34—Plan of power station at Point du Bois plant.	157	157
PLATE 35—Section of power station at Point du Bois plant.	162	162
PLATE 36—Power percentage of time diagram for Point du Bois plant.	176	176
PLATE 37—Plan of Kenora power station, eastern outlet of the Lake of the Woods. To face page.....	176	176
PLATE 38—Plan of Norman dam, western outlet of the Lake of the Woods. To face page.....	176	176
PLATE 39—Plan of Fort Frances dam, outlet of Rainy lake. To face page.....	176	176
PLATE 40—Plan of Kettle falls dam, outlet of Namakan lake.	180	180
PLATE 41—Group diagram of power stations on Winnipeg river.	196	196
PLATE 42—Power percentage of time diagram for Pine falls site. Page.....	196	196
PLATE 43—Plan of proposed layout, Pine falls site. To face page.....	196	196
PLATE 44—Plan and section of proposed power station, Pine falls site. To face page.....	196	196
PLATE 45—Sections and elevations of proposed dam, Pine falls site.	202	202
PLATE 46—Plan of channel excavation at Whitemud falls.	208	208
PLATE 47—Power percentage of time diagram for Du Bonnet site. Page.....	208	208
PLATE 48—Plan of proposed layout at Du Bonnet site. To face page.....	208	208
PLATE 49—Plan and elevation of proposed power station, Du Bonnet site. To face page.....	208	208
PLATE 50—Sections and elevations of proposed dam, Du Bonnet site.	212	212
PLATE 51—Plan of Lac du Bonnet.	218	218
PLATE 52—Power percentage of time diagram for McArthur site. Page.....	218	218
PLATE 53—Plan of proposed layout at McArthur site. To face page.....	218	218
PLATE 54—Plan and section of proposed power station, McArthur site. To face page.....	218	218
PLATE 55—Sections and elevation of proposed dam at McArthur site. Page.....	230	230
PLATE 56—Power percentage of time diagram for Lower Seven Sisters site. To face page.....	230	230
PLATE 57—Plan of proposed layout at Lower Seven Sisters site. To face page.....	230	230
PLATE 58—Plan and section of proposed power station at Lower Seven Sisters site. To face page.....	230	230
PLATE 59—Sections and elevation of proposed dam at Lower Seven Sisters site. To face page.....	240	240
PLATE 60—Power percentage of time diagram for Upper Seven Sisters site. Page.....	240	240
PLATE 61—Plan of proposed layout at Upper Seven Sisters site. To face page.....	240	240
PLATE 62—Plan and section of proposed power station, Upper Seven Sisters site. To face page.....	240	240
PLATE 63—Sections and elevation of proposed dam, Upper Seven Sisters site. To face page.....	248	248
PLATE 64—General layout plan of upper portion of Pinawa channel. To face page.....	248	248
PLATE 65—Plan of proposed layout at Upper Pinawa site.	248	248
PLATE 66—Plan and section of proposed power station, Upper Pinawa site. " ".....	254	254
PLATE 67—Power percentage of time diagram for Slave falls site. Page.....	254	254
PLATE 68—Plan of proposed layout at Slave falls site. To face page.....	254	254
PLATE 69—Plan and section of proposed power station, Slave falls site. To face page.....	254	254
PLATE 70—Sections and elevation of proposed dam, Slave falls site	254	254
PLATE 71—Circular diagram of developed and undeveloped power on Winnipeg river under present minimum flow conditions. Page.....	260	260
PLATE 72—Circular diagram of developed and undeveloped power on Winnipeg river under 20,000 second feet mean flow. Page.....	261	261
PLATE 73—Power percentage of time diagram for Winnipeg river in Manitoba. Page.....	262	262
PLATE 74—Plan showing domestic coal consumption in Western Canada. To face page.....	272	272
PLATE 75—Graphical comparison of area, population and available and developed water-power in Canada, United States and certain European countries. To face page.....	282	282
PLATE 76—Curve of growth and population in Winnipeg. Page.....	289	289
PLATE 77—Curve of growth of power consumption in Winnipeg. To face page.....	290	290
PLATE 78—Curve of proportionate growth of power consumption in Winnipeg. To face page.....	290	290
PLATE 79—Typical daily power load in City of Winnipeg, August, 1914. Page.....	292	292
PLATE 80—Typical daily power load in City of Winnipeg, November, 1914. Page.....	293	293
PLATE 81—Plan of district tributary to Winnipeg river power. To face page.....	298	298
PLATE 82—Circular diagram showing the influence of the Lake of the Woods on the power situation at the lake outlets. To face page.....	320	320
PLATE 83—Circular diagram showing the influence of the Lake of the Woods on the City of Winnipeg plant, Point du Bois. To face page.....	320	320
PLATE 84—Circular diagram showing the influence of the Lake of the Woods on the Winnipeg Electric Railway Company's plant on the Pinawa channel. To face page.....	320	320
PLATE 85—Circular diagram showing the influence of Lake of the Woods on the Du Bonnet falls power site. To face page.....	326	326
PLATE 86—Diagram showing the influence of the Lake of the Woods on each of the available power sites on the Winnipeg river below the lake. To face page.....	326	326



## TABLES—Continued.

	PAGE
TABLE 32—Machine installation of Winnipeg Electric Railway Company in plant on Pinawa channel.....	144
TABLE 33—Profile of the Winnipeg river under natural conditions, and under proposed system of hydro-electric development.....	179
TABLE 34—Pondage and flooded area of the proposed power concentrations.....	181
TABLE 35—Undeveloped power sites on the Winnipeg river in Manitoba.....	258
TABLE 36—Total power developed and undeveloped on the Winnipeg river in Manitoba.....	258
TABLE 37—Dependable power on Winnipeg river in Manitoba.....	259
TABLE 38—Estimated capital cost of developing the proposed power sites on the Winnipeg river in Manitoba. Power placed on the low tension switchboard in the power stations.....	259
TABLE 39—Estimated annual cost of operation of the proposed power developments on the Winnipeg river in Manitoba. Power placed on the low tension switchboard in the power stations.....	264
TABLE 40—Approximate cost of steam turbine plant, complete with steel and concrete buildings and electrical equipment.....	271
TABLE 41—Pine falls power site on Winnipeg river.....	273
TABLE 42—Comparison of the cost of fuel power in Winnipeg with power from Pine falls.....	274
TABLE 43—Comparative status of available water power and of developed water power in Canada and other countries.....	283
TABLE 44—Ratio of developed power to population in Canada.....	285
TABLE 45—Increase in population, realty values, building permits and factory output of the City of Winnipeg.....	288
TABLE 46—Ratio of the growth of the total electrical energy used in Winnipeg to the growth in population. Power supplied by the Winnipeg Electric Railway Company's steam and hydro-electrical plants and by the City Municipal hydro-electric plant.....	291
TABLE 47—Effect of no regulation and systematic regulation on the Lake of the Woods, on the power possibilities and hydro-electric plants from the Lake of the Woods to lake Winnipeg.....	322
TABLE 48—Records of daily temperature at Winnipeg.....	369
TABLE 49—Records of monthly temperature at Winnipeg and Kenora.....	375
TABLE 50—Records of monthly precipitation in the vicinity of the Winnipeg river and basin.....	378
TABLE 51—Meteorological and evaporation records secured on the Lake of the Woods.....	388
TABLE 52—Discharge measurements of Winnipeg river at Otter and Slave falls, Manitoba.....	412
TABLE 53—Daily discharge in second feet, of Winnipeg river at Otter and Slave falls, Manitoba.....	415
TABLE 54—Monthly discharge of Winnipeg river at Otter and Slave falls, Manitoba.....	423
TABLE 55—Discharge measurements of the Pinawa channel of the Winnipeg river at control dam.....	425
TABLE 56—Daily discharge in second feet of the Pinawa channel of the Winnipeg river at control dam.....	426
TABLE 57—Monthly discharge of the Pinawa channel of the Winnipeg river at control dam.....	430
TABLE 58—Total daily discharge in second feet of the Winnipeg river at outlets of Lake of the Woods, Ontario.....	432
TABLE 59—Total monthly discharge of the Winnipeg river at outlets of Lake of the Woods, Ontario.....	440
TABLE 60—Discharge measurements in headrace of Kenora power station.....	442
TABLE 61—Daily discharge of Rainy river at Fort Frances, Ontario.....	444
TABLE 62—Monthly discharge of Rainy river at Fort Frances, Ontario.....	449
TABLE 63—Discharge measurements at Chaudière falls (Kettle falls), Rainy river.....	451
TABLE 64—Daily discharge at Chaudière falls (Kettle falls), Rainy river.....	452
TABLE 65—Monthly discharge at Chaudière falls (Kettle falls), Rainy river.....	453
TABLE 66—Discharge measurements of Whitemouth river at Whitemouth, Manitoba.....	453
TABLE 67—Daily discharge records of Whitemouth river at Whitemouth, Manitoba.....	454
TABLE 68—Monthly discharge of Whitemouth river at Whitemouth, Manitoba.....	457
TABLE 69—Miscellaneous discharge measurements in Winnipeg river watershed.....	457
TABLE 70—Discharge measurements at Skunk rapids, Seine river, Ontario.....	458
TABLE 71—Daily discharge at Skunk rapids, Seine river, Ontario.....	459
TABLE 72—Monthly discharge at Skunk rapids, Seine river, Ontario.....	459
TABLE 73—Discharge measurements of Turtle river at Mountain rapids, Ontario.....	460
TABLE 74—Discharge measurements of Manitou river, Devil's Cascades, Ontario.....	461
TABLE 75—Daily discharge of Manitou river, Devil's Cascades, Ontario.....	462
TABLE 76—Monthly discharge of Manitou river, Devil's Cascades, Ontario.....	462
TABLE 77—Discharge measurements of Footprint river at Rainy lake falls, Ontario.....	463
TABLE 78—Daily discharge records of Footprint river at Rainy lake falls, Ontario.....	464
TABLE 79—Monthly discharge of Footprint river at Rainy lake falls, Ontario.....	464

TABLES - Continued.

	PAGE.
TABLE 80—Discharge measurements of Wabigoon river, at Wabigoon falls, Ontario, 1914	465
TABLE 80A—Discharge measurements of Wabigoon river, near Quibell, Ontario	466
TABLE 81—Daily discharge records of Wabigoon river, near Quibell, Ontario	466
TABLE 82—Monthly discharge of Wabigoon river, near Quibell, Ontario	467
TABLE 83—Discharge measurements of Eagle river at Eagle river, Ontario	468
TABLE 84—Daily discharge records of Eagle river at Eagle river, Ontario	468
TABLE 85—Monthly discharge of Eagle river at Eagle river, Ontario	468
TABLE 86—Discharge measurements of English river at Ear falls, Ontario	470
TABLE 87—Discharge measurements of English river at Manitowish falls, Ontario	471
TABLE 88—Discharge measurements of English river at Oak lake falls, Ontario	471
TABLE 89—Discharge measurements of English river at Sturgeon falls, Ontario	472
TABLE 90—Discharge measurements of English river at Caribon falls, Ontario	473
TABLE 91—Miscellaneous discharge measurements by the Hydro-Electric Power Commission of the Province of Ontario in Winnipeg river watershed in Ontario	473
TABLE 92—Discharge measurements of Big Fork river at Big falls, Minnesota	475
TABLE 93—Daily discharge records of Big Fork river at Big falls, Minnesota	476
TABLE 94—Monthly discharge of Big Fork river at Big falls, Minnesota	478
TABLE 95—Discharge measurements of Little Fork river at Little Fork, Minnesota	479
TABLE 96—Daily discharge records of Little Fork river at Little Fork, Minnesota	480
TABLE 97—Monthly discharge of Little Fork river at Little Fork, Minnesota	480
TABLE 98—Discharge measurements of Vermillion river below Lake Vermillion, near Tower, Minnesota	487
TABLE 99—Daily discharge records of Vermillion river below Lake Vermillion, near Tower, Minnesota	488
TABLE 100—Monthly discharge of Vermillion river below Lake Vermillion near Tower, Minnesota	489
TABLE 100A—Discharge measurements of Kawishiwi river near Winton, Minnesota	493
TABLE 101—Daily discharge records in second feet of Kawishiwi river near Winton, Minnesota	494
TABLE 102—Monthly discharge of Kawishiwi river near Winton, Minnesota	495
	501



REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

CHAPTER I.  
SUMMARY OF INVESTIGATIONS



## CHAPTER I.

### SUMMARY OF INVESTIGATIONS.

In the province of Manitoba, richly endowed as it is with natural wealth, no one resource offers to the community such assured prospects of present prosperity and of future commercial and industrial progress as does the enormous reserve of dependable and economically developable water-power, lying ready for use, awaiting a market. Vast plains of unexcelled agricultural lands, lying in the immediate vicinity or within easy transmission distance, of almost unlimited resources of water-power, present a combination rarely found, and one which is conducive to exceptional opportunities for industrial development.

Lake Winnipeg, the great central reservoir of the province, receives from the west the entire drainage of the prairies, collected and conveyed by the Saskatchewan river from the far-distant Rocky mountains; from the south comes the run-off from the Red river carrying the surplus waters of southern Manitoba and northern Dakota; while from the east flows the Winnipeg river, draining the western section of the province of Ontario. The enormous run-off from this basin, varying vastly in volume in different seasons and at different times, is collected and conserved in the great natural balancing reservoir of lake Winnipeg; the outflow therefrom, largely modified by naturally regulated, discharges down the 700-foot drop of the Nelson river in a series of magnificent falls, cataracts, and rapids, finally entering into Hudson Bay.

Before the era of the railroad, this great system of waterways formed the natural route of trade and commerce throughout the basin. The Nelson, Winnipeg, Red, and Saskatchewan rivers were the main arteries of traffic, and the boats and canoes of fur trader and pioneer found their way to the most distant parts of the basin. Even to-day these waterways have not entirely lost their former high repute as avenues of transport, while prospective navigation improvements may renew to a large extent their old pre-eminence.

In the province of Manitoba, and following the construction of the main line of the Canadian Pacific railway, the city of Winnipeg grew with unexampled rapidity in population, wealth, and industry; and engineers, ever in search of possibilities of using the forces of nature to supply the needs of man, soon began to explore the province for sources of power to supply the urgent municipal and industrial requirements of the growing community. The Winnipeg river, owing to its general familiarity to a large section of the population and to the many and obvious advantages it offered in respect to power development, received early consideration. Hydro-electric practice no longer confined the use of power generated from water to the actual power sites. Long-distance transmission made the energy of the many waterfalls of the Winnipeg river easily available in the city of Winnipeg, many miles away.

For exceptional natural power and storage advantages the Winnipeg river is probably unequalled in Canada and possibly on this continent. It drains an almost circular area of 53,500 square miles, dotted in all directions with innum-

able lakes. The balance of the basin is fairly well forested, the precipitation is regular and well distributed, and the run-off is, in consequence, remarkably uniform from season to season, the maximum high water in a normal year seldom exceeding four times the minimum flow. Owing to its strategic location close to the city of Winnipeg, on the threshold of the western prairies, it soon became the Mecca of hydraulic and civil engineers seeking out suitable power sites for development in the interests of the various municipal and commercial centres. In 1895 Mr. James C. Kennedy, Consulting Hydraulic Engineer of Montreal, made the first comprehensive reconnaissance survey of this river for power. The results of this survey are unique and interesting as they, even at that time, brought out the promising and unequalled power possibilities of this river. In the year 1907, Mr. W. Thibaudeau, C.E., made, on behalf of the department, a reconnaissance investigation of the Winnipeg River powers, and submitted an interesting and valuable report on the river's resources. Many other investigations were made by various hydraulic and civil engineers in connection with special or particular power sites. Following these investigations, two developments on the Winnipeg river were undertaken, the first being that of the Winnipeg Electric Railway Company on the Pinawa channel, the pioneer power project of the west. This company has, since 1906, furnished the power necessary for the operation of the street car system and many other industries in the city of Winnipeg. In the year 1911, the city of Winnipeg authorities, largely on the initiative of Controller J. W. Cockburn, of the City Council, who has ever since been one of the pioneer movers in the power situation in Winnipeg, completed the initial installation of an ultimate 76,000-horsepower municipal power station.

Following the successful development of these two plants, and in view of the rapidly increasing demand for further power which students of the power situation at Winnipeg at once realized could not be met by the two existing plants, even when extended to their maximum capacity, many capitalists interested in the power and industrial situation in Winnipeg became actively interested in the question of power development on this river, and many separate and conflicting power schemes were submitted to the Dominion Government for authorization.

These schemes were frequently supported by fairly complete plans and specifications from eminent and experienced hydro-electric engineers, and the conflict of interests involved in the various projects soon emphasized the necessity of an independent investigation, by the Dominion Government, of the whole river. Such an investigation was the only means of ensuring the conservation of the river's power resources in the interests of the investor, the consumer, and the general public. It was considered by the engineers of the Dominion Water Power Branch that private, municipal, and provincial enterprise in hydro-electric development on the Winnipeg river could best be ensured and safeguarded by furnishing the prospective power user with thoroughly reliable data upon which the economic and engineering features of the prospective sites could be properly and accurately judged and compared. That such definite and dependable information should be secured, and made available in reliable form, is considered essential for attracting and securing the confidence of capital.


Department of the Interior, Canada  
HON. J. A. McNICOLL, Minister  
A. W. JONES, M. G. DEBAY, M. G. S. P.  
Water Power Branch  
Geological Survey of Canada

# WINNIPEG RIVER POWER SURVEYS PLAN SHEWING EXISTING PLANTS AND POSSIBLE SITES

Prepared by J. T. Johnston, B.A.Sc.  
Hydro. Eng. W. I. Dr.  
Sep. 1914

Scale of Miles

LEGEND  
1. Top of Dam  
2. In the Site  
3. In the Site





The conservation of natural resources is one of the most important public problems which has in recent years confronted the people of Canada. The widespread publicity given to this question in the press and on the platform during recent years has met with an enthusiastic response from the public, and has resulted in an active interest being taken in all forms of governmental activity respecting water-power.

Of the many phases of conservation proposed and practised, that having to do with the conservation of water for power is probably the most productive of direct and immediately favourable results. The situation in the Winnipeg River watershed offered exceptional opportunities for the practical realization of the best principles of conservation as applied to the preservation and utilization of water-power resources.

Among the power investigations of the Dominion Water Power Branch extending over the provinces of Manitoba, Saskatchewan, and Alberta, and the Railway Belt of British Columbia, none have been so comprehensive, complete, and consequential as those of the power and storage possibilities of this river, commencing in the year 1911 and now completed in so far as data pertinent to this report are concerned, but to be continued so far as basic hydraulic data are required for the absolutely final and complete investigation of the power and storage resources of the whole watershed.

The principal objective kept in view in the investigations was the institution of a system of power installation which would utilize without waste the entire available and unutilized power resources of the river in Manitoba. In order to render this study complete and comprehensive, it was necessary that it should be supplemented by a thorough investigation into the storage possibilities of the watershed. Systematic discharge measurements and the collation and analysis of all existing run-off data and gauge records, formed a necessary complement to the information to be gathered.

#### SUMMARY OF POWER AND STORAGE STUDIES.

The principal result of the power and storage investigations can be briefly summarized by stating that it has been determined that a minimum flow of 20,000 cubic feet per second is feasible at all seasons, with an efficient and systematic control of the river run-off, and that it is possible to concentrate practically the entire unused river fall in Manitoba into seven economic power concentrations with a minimum output of 175,000 continuous 24-hour power under present conditions of flow, and of 313,000 horse-power with the river regulated to a 20,000 second-foot minimum. These power concentrations, together with the existing plants, will conserve to the utmost the power resources of the river in Manitoba, and will supply a total ultimate output of over 420,000 continuous horse-power. (Plates 1 and 2.)

The main features of the investigations are summarized below:—

- (1) A complete contour survey has been made of the Winnipeg river in Manitoba from the mouth of the river to the headwaters of the city of Winnipeg municipal plant at Point du Bois. This survey has been supplemented by detail cross-sections and soundings at all falls and rapids



where power concentration is in prospect. All existing dams, weirs, bridges, and permanent works have been tied in to the basic field survey lines.

(2) A permanent system of bench-marks, located on the bedrock and tied in to sea-level datum, has been established throughout the entire power reach.

(3) The complete survey notes have been plotted on standard topographic sheets, and are appended to this report.

(4) Seven points of concentration have been selected as the prospective sites of future power development. These sites will develop practically the entire remaining drop of the Winnipeg river in Manitoba, unutilized by the present existing power plants on the river.

(5) At each of these seven sites, detail layouts and designs covering a feasible method of development have been prepared, and the estimated cost of development, maintenance, and operation has been deduced, for the double purpose of comparing their individual engineering features and their commercial possibilities. The plans upon which the estimates were based are appended.

(6) The seven proposed power concentrations, with estimated capital and operating costs, are listed in table I.

(7) The total dependable power on the river in Manitoba, based on a regulated minimum flow of 20,000 cubic feet per second, including that available at the two power stations already in operation, is 418,000 horsepower in terms of 24-hour continuous power.

(8) Permanent metering stations have been established at Slave falls on the power reach in Manitoba; at the head of the Pinawa channel; at the outlets of the Lake of the Woods; and on the Whitemouth river. Miscellaneous measurements have been secured throughout the basin. All early run-off records, and all records secured by other organizations, such as the Dominion Department of Public Works, the Ontario Hydro-electric Commission, and the United States Geological Survey, have been collated and are appended.

(9) The power station of the Winnipeg Electric Railway Company, and the Kenora municipal power station have been rated.

(10) Existing records of lake levels, of head and tailwater elevations, of power loads, and of precipitation and temperature have been collated and studied.

(11) A fully equipped evaporation station has been established on the Lake of the Woods.

(12) The storage necessities and possibilities of the watershed have been exhaustively analysed, and the steps necessary to ensure an adequate minimum flow at the various vital points on the river determined.

(13) A study has been made of existing water rights throughout the basin and of international questions which have arisen in connection with the boundary waters.

Table 1.—Summary of the Power Sites available for development on the Winnipeg River in Manitoba.

Site.	Distance from Winnipeg.	Head.	24-HOUR POWER AVAILABLE AT 75% EFFICIENCY.		CAPITAL COST.		ANNUAL OPERATIVE COST.				Remarks.	
			H. P.	H. P.	Total.	Per H.P. on basis of 24-hour power.	Per H.P. on basis of 24-hour power.	Per H.P. on basis of 100% load factor.	Cents.	Cents.		
												12,000 c.f.s.
Pine Falls.....	Miles 64	Feet 37	37,000	63,100	\$ 3,057,000	\$ 80.66	\$ 69.84	\$ 8.00	\$ 7.08	0.172	0.108	Entire river flow available.
Dit Becnet Falls.....	64	56	57,500	95,500	4,624,000	80.70	68.60	7.56	6.65	0.116	0.102	"
McArthur Falls.....	62	18	18,400	30,700	2,031,000	110.38	89.25	10.82	8.89	0.166	0.136	"
Lower Seven Sisters.....	52	37	12,600	37,000	3,409,000	270.00	224.00	182.00	158.00	0.216	0.182	"
Upper Seven Sisters.....	55	29	9,000	26,600	1,724,000	192.67	154.00	172.00	140.00	0.188	0.158	"
Upper Pinawa.....	58	18	12,300	12,300	1,430,000	116.26	104.07	104.07	104.07	0.189	0.159	"
Slave Falls.....	74	26	26,600	44,400	2,427,000	91.24	77.39	8.58	7.62	0.131	0.117	" (On Pinawa Channel. Entire river flow available.)

Note.—12,000 cubic feet per second is available under present conditions of regulation on the Winnipeg River, and 20,000 cubic feet per second is feasible under a properly controlled system of regulation.

(14) The possibilities of future navigation have been given full consideration. The limiting head and tailwater elevations proposed will permit of the ready canalization of the river, while provision has been made for the inclusion of lockage facilities in the provisional layouts, should the future canalization of the river ever become desirable.

(15) Existing power plants and all other vested interests along the river have been carefully studied.

(16) Present and future market conditions and possibilities for the utilization of the Winnipeg River power have been investigated.

(17) A consecutive policy looking to the full realization of the power resources of the river basin, according to the best principles of conservation, has been determined for the future guidance of hydro-electric development.

#### CONCLUSIONS FROM INVESTIGATIONS.

The detail study which has been given to the power and storage questions involved in the proper utilization of the resources of the Winnipeg River watershed has of necessity been extended to cover the ways and means by which the vast power resources, now lying dormant, can be made fully available for the public good. The conclusions evolving from these studies are discussed in detail throughout this report, in connection with the various subjects to which they are pertinent. The more important may here be summarized.

Full realization of the power resources of the Winnipeg river in Manitoba is only attainable by a power system in which each developed site forms a component link in a comprehensive scheme looking to the development of the entire river reach. Such a power scheme is outlined and discussed herein, and furnishes the basic principles for the guidance of future hydro-electric development.<sup>(2)</sup> Due to the interdependence of a series of hydro-electric plants such as is proposed, and to the conflict of head- and tailwater elevations, satisfactory operation can only be realized through an independent supervising control over local pond regulation.

Full realization of the power resources of the Winnipeg river in Manitoba is possible only through an exhaustive measure of run-off control, and feasible only through the establishment of storage reservoirs in the upper watershed. Due to the conflicting requirements of the lumbering, fishing, navigation, and power interests represented in the watershed, a proper run-off control, satisfactory to all, can best be insured by some central governmental authority possessing the full confidence of all interests affected, and having entire authority over all questions affecting lake, reservoir, and pond levels, and over all questions of river flow and of discharge requirements. This authority can only be properly exercised through government owned or operated storage reservoirs.

As a result of the exhaustive nature of the data gathered in the power and storage studies, the Dominion Water Power Branch is now in a position to

<sup>1</sup> In this connection it might be pointed out that the Department of Public Works has already approved the power layouts on the Winnipeg river as submitted in this report in so far as the navigation interests are concerned.

<sup>2</sup> Since the completion of the power studies along the river reach below Lac du Bonnet, the Winnipeg River Power Company has commenced operations on the Great falls development corresponding to the du Bonnet site in this report, and has adopted the limiting head- and tailwater elevations in keeping with the comprehensive river development scheme outlined herein. For full discussion of this development see Appendix II.

intelligently supervise a comprehensive power system such as is proposed for the development of the river in Manitoba, and to ensure the maximum utilization and preservation of its power resources.

The full conservation of the power resources of the watershed, requires also the institution throughout the watershed of a systematic policy looking to a proper preservation of the forest cover, which now so effectively assists in natural regulation of the river flow. Consistent steps have already been taken to this end by the Dominion Water Power Branch.

To realize the maximum power output of the Winnipeg river will require the most thorough and scientific control of the forest and water resources of the entire watershed, by an authority with sufficient power and breadth of view to ensure that all affected interests receive their just due.

#### RECOMMENDATIONS.

As a result of the power and storage studies now successfully completed in so far as is necessary to outline a comprehensive scheme of power development and to enunciate a policy suitable to the proper operation of such a system as is proposed, the following recommendations are appended:—

(1) All future hydro-electric, milling, or industrial undertakings acquiring power privileges on the power reach of the Winnipeg river in Manitoba, should be authorized only in accordance with the general scheme of power development outlined herein, or in accordance with such modifications of the same as may be considered advisable as a result of the further information and data being secured by the continuance of the present studies.

(2) Authority for all such undertakings should fully protect the head- and tailwater levels, not only of all existing interests on the river, but also of all sites of future power concentration.

(3) Authority for all such undertakings should retain to the Government a measure of supervising local pond control for the protection of other plants on the river.

(4) Authority for all such undertakings should call for the bearing by the lessee of the cost of reservoir construction and of storage control operation and maintenance in the upper watershed, in proportion to the benefits accruing to the lessee therefrom.

(5) The establishment of new regulating reservoirs should be undertaken by the Crown, and the cost of constructing the necessary dams and regulating works, as well as of maintaining and operating the same, should be apportioned among the various power undertakings benefiting therefrom, in proportion to the benefits accruing.

(6) An appraisal of the value of existing storage works throughout the watershed should be undertaken by the Government, with a view to their ultimate purchase or expropriation, the cost of such purchase or expropriation to be apportioned among the power users benefiting from the use of the storage, in proportion to the benefits accruing.

(7) All matters pertaining to the regulation of the lake and reservoir levels, and to questions of run-off and discharge requirements, should be under the joint control of the Dominion Water Power Branch, and the Hydro-electric Power Commission of the Province of Ontario, or, failing this, of a governmental board or commission. The controlling body must have the full confidence of all interests affected by questions of run-off and lake levels, and must possess entire authority and exercise its control actively and directly.

(8) Some definite measures of forest preservation should be instituted in the immediate future, and be continuously maintained. These measures should include scientific timber cutting and lumbering, systematic reforestation and effective protection from fire ravages,

(9) All lands which will be necessary for or affected by the future construction of power undertakings or of storage works, should be reserved to the Crown.

(10) The present studies should be aggressively continued, more particularly with respect to the storage requirements and possibilities of the basin. Among the various phases of activity which are essential to the proper future control of the water resources of the river basin are: continuous stream measurement records at all vital points; continuous surface level records of all prospective and existing reservoirs; continuous evaporation records in various parts of the watershed; the establishment of numerous precipitation stations; the prosecution of reconnaissance surveys for the investigation of storage possibilities; the rating of all power stations, mills, dams, and weirs in the watershed; a study of the relation between the various existing reservoirs and storage prospects, and the existing plants and possible power sites; continuous surface level records under all stages of flow at all vital points on the power reach of the river in Manitoba; and the maintenance of an efficient policy of forest preservation and protection.

#### POLICY OF THE DEPARTMENT.

The policy of the Dominion Water Power Branch is, in brief: to encourage desirable development of water-power resources; to discourage and prevent the initiation and development of uneconomic and wasteful projects; to ensure that each site developed shall utilize or provide for the future utilization of the maximum available power; to ensure that river systems are developed along comprehensive lines wherein each unit is a component link in a system; to ensure adequate storage measures in the interests of all powers affected; to prevent unnecessary and costly duplication of expenditures on the part of competing plants; to protect the public from inadvisable power schemes and ill-designed plants and dams; to safeguard the public from monopolistic control, by regulation and periodical revision of rates; to see to the early carrying into effect of agreements issued by the Department for the development of power; to compel the development of existing plants to their limit when the market demands; and to promote in every way the fullest conservation of the power resources of the West.

<sup>1</sup>For fuller recommendations re storage control see chapter IV, page 133.

The regulations governing the granting of water-power rights in Manitoba, Saskatchewan, Alberta, and the Northwest Territories are attached to this report in full in Appendix IV. A careful study of the various clauses of the regulations, and of the conditions which are imposed upon, and the privileges conveyed to the applicant, will serve to make clear the measures which are deemed essential to the proper administration of the water-powers under control of the Department of the Interior, in the interests of both the investor and the consumer.

The initial steps taken by the department in dealing with an application for water-power privileges are largely dependent upon the character of the site applied for, and upon the detailed data submitted by the applicant. General information covering the project is required along the lines set out in section II of the regulations. Upon the character of the information supplied, further action is based. A consideration of the data submitted, in conjunction with whatever existing information may be on file in the department, determines whether further information is required and whether an inspection by one of the field engineers is necessary. This inspection is always required should the site applied for be one which has not been previously covered by the field investigations of the Dominion Water Power Branch. Based upon the field officer's report, or upon head office studies, the applicant may be advised that his project is unsound upon either engineering or economic grounds, or, should the scheme be feasible, he may be called upon for further details under section IV of the regulations.

When the department is convinced, after independent investigation, that the engineering features of the project are sound, and that it offers reasonable prospects of financial success, and has approved the scheme, an agreement is issued authorizing the construction of the plant. At no stage does the priority of application convey any rights to development. This is a necessary provision in order to forestall blanket applications made with a view to holding power sites for speculative purposes.

The principal clauses of the agreement are framed to protect the public from exploitation at the hands of interests which may have in view the sale of rights only, and not actual development. The more important features included are: a definite time within which the proposed works shall be begun; a stated minimum amount of expenditure to be made annually on actual construction of the works; a stated amount of water-power to be developed from the water applied for within a fixed period not exceeding five years; summary cancellation of the agreement by the minister if any of the above conditions have not been complied with; and provision for the issuing of a lease and a license to the applicant upon the fulfilment of the conditions of the agreement. The license covers the use for water-power purposes of a stated amount of water. The lease covers the use of the necessary land. Other clauses are included looking to the full protection of the public interests involved, and varying with the particular necessities of each project.

Before actual construction work is commenced on the ground, the general layout plans and the actual construction plans covering the plant must be submitted to the department for approval.

During the period of construction, the department maintains an inspecting engineer on the works whose duty is to see that all the terms of the agreement are observed and that the works are constructed according to plans which have been approved or revised by the department. Prompt weekly progress reports are forwarded direct to the department at Ottawa, and the head office is at all times directly in touch with all the construction being carried on under its jurisdiction. Pressing matters are dealt with by the inspecting engineer on the ground. Matters of vital importance or involving questions of policy are referred to head office, and are dealt with by correspondence or by wire as the case demands. Serious differences of opinion as to engineering questions are referred to the departmental Board of Consulting Engineers. In all phases of the construction the department endeavours to exercise the functions of an impartial authority mediating between the respective interests of the owner, the investor, and the public.

Upon the completion of the undertaking in accordance with the conditions of the agreement, a license for the use of the water is issued, incorporating the following principal clauses: terms of license, twenty-one years renewable for three further consecutive 21-year terms; schedule of rates and prices to be charged to the public for use of the power, to be submitted to the Board of Railway Commissioners of Canada for adjustment and approval, the same to be revised every seven years.

The procedure as outlined above is slightly altered in dealing with projects along a river whose resources have been thoroughly investigated by the field engineers of the Dominion Water Power Branch. Immediately such investigation is completed, and the conclusions determined, the department is in a position to dictate a scheme of development for the entire river, so that each individual project will form a component part of the whole. This policy is followed, and all hydro-electric undertakings on such rivers are carried out along these lines. The outstanding feature resulting from such administration is the greatly increased maximum output secured, over that obtainable from unguided and unrestrained private initiative.

This administrative policy can now be adopted along the Winnipeg river, and in fact has already been put into force in dealing with the power project which the Winnipeg River Power Company has at present under construction at the Bonnet falls, and which is discussed at length in Appendix II.

Water-power is readily subject to monopolistic control. This is largely due to the heavy capital expenditure necessary in the development of large hydro-electric undertakings and in the transmission of power to the consumer. Again, power obtained from river discharge is perpetual and at the same time limited. If, therefore, it is to be kept always available to the public at reasonable rates, its disposal must be carefully safeguarded and controlled.

The power situation on the Winnipeg river has an equalizing factor in the municipal plant of the city of Winnipeg at Point du Bois. This large and successful municipal undertaking, with its modern and extensive installation and with its great reserve of power, feeding into the city of Winnipeg over its own transmission system, will always serve to moderate and to regulate the rates chargeable for power in this territory. The department is also, as a result of

the surveys just completed, in command of complete and detailed data as to the sources and extent of the power available, the larger portion of which is still vested in the Crown. Under these conditions, and with the control of rates provided by the regulations which govern the granting of water-power rights, there is no prospect of the southern portion of the province of Manitoba coming under a monopolistic power regime.

While the danger of single and unlimited private control must be guarded against, the question of unnecessary duplication of transmission systems must also be considered. Competition which involves carrying heavy overhead charges due to unnecessary duplication of transmission and distribution systems is unprofitable both to the investor and to the consumer; this phase of power development requires and receives careful consideration in the granting of water-power privileges. Crown supervision and control of rates allowing for reasonable financial returns on investment while guarding against extortion and overcharging, would appear to be the most satisfactory arrangement for all parties interested. Such a policy must recognize both the need for the utilization of the power and the dangers of monopolistic control, and must take effective action for the proper guidance and control of each.

#### NECESSITY FOR CROWN CONTROL OVER HYDRO-ELECTRIC INVESTIGATION AND DEVELOPMENT.

An impartial governmental supervision of water-power development, from the initial stages to the final distribution and sale of the power, is to the mutual advantage of the investor, the general public, and the direct consumer. The truth of this is particularly evident in planning the proper and comprehensive utilization of the power resources of a river such as the Winnipeg, where but few vested interests interfere with hydro-electric development along lines of maximum beneficial use. The various phases which render a greater or less degree of Crown control essential to the true conservation both of the public interests and of capital can be summarized as follows:

(1) The selection of a hydro-electric site by private interests usually results in the utilization of the greatest drop which can be economically concentrated, without, as a rule, considering the requirements and the possibilities of the river as a whole. This has been particularly noticeable on the Winnipeg river.

(2) The Government is best able to thoroughly study a complete river system, since it alone is in a position to impartially analyse the conflicting interests which are affected.

(3) The relative importance and merits of various power possibilities and storage projects can best be determined by an impartial authority, based upon independent and thoroughly tested information, rather than by interested individuals, companies, or municipalities.

(4) The Crown, from first-hand information, is in a position to ensure that each individual power site is developed to its maximum efficiency and, by the supervision it maintains over the plans and designs

of the plant and power dam and over the actual construction operations, to ensure that thoroughly stable structures are built.

(5) The Winnipeg river is classed as a navigable waterway, and, as such, consideration must be given to its possible future canalization. Private enterprise in hydro-electric undertakings is naturally concerned with this phase, and whatever provision is made for future water transportation by unguided private initiative is at best makeshift. On the other hand, a complete power system, pre-determined and supervised throughout by the Crown, can fully consider the possibilities, as in the case of the Winnipeg river, the pool levels, and the need, for the future inclusion of locks in the power layouts, should the necessity for constructing the same ever arise.

(6) A pre-determined hydro-electric power scheme covering the entire river, and deciding the points of concentration, and also the head- and tailwater elevations throughout the whole system, enables the State to fix the location and elevations of railroad and traffic bridges, of railways and roads, and to guide the development of municipalities so as not to interfere with the future utilization of the undeveloped portions of the river.

(7) The present and future diversion of water supplies for domestic, irrigation, and other purposes, can be properly protected and arranged for, only through and by governmental supervision.

(8) Provision for the drainage and protection of those lands along the river which will be affected by raising the water level, can, in the public interests, be best arranged for by an authority giving full and impartial consideration of all issues involved.

(9) In patenting Dominion lands adjoining the river banks, the Crown is enabled to reserve for water-power purposes such sections as may be subsequently required, thus keeping down the future cost of actual development. For some time past the department has been following this course with all homestead entries along the Winnipeg river.

(10) The numerous, and at times conflicting, interests affected by storage in such natural reservoirs as the Lake of the Woods, Rainy lake, and other lakes in the upper Winnipeg basin, compel the intervention of some impartial authority, so that some equitable storage arrangement may be evolved satisfactory to all parties and interests concerned. Private investigation or control by any single interested party seldom secures a satisfactory settlement of questions of this nature.

(11) Since the tailwaters of each plant as designed herein, are dependent on, and controlled by, the headwater elevation of the plant below, and since certain sites along the river can be so developed and so operated as to entirely cut off the flow from plants lower down the river, a centralized control for the whole river in the interests of all the powers and parties concerned must form an essential feature of the completed scheme. As a result of the extensive studies just completed, such a system of control can now be readily instituted.

(12) Water-power is perpetual inasmuch as river discharge is continuous, and in this respect differs from power derived from coal and other sources. It is essential, therefore, that its utilization should be conserved to the utmost by efficient and complete development, in order that future as well as present power requirements of the public may be served to the maximum capacity of the river.

(13) Water-power is, from its nature, peculiarly susceptible to monopolistic control. The Winnipeg river forms the natural source of power for the city of Winnipeg and for southern Manitoba. Investigation by the Dominion Water Power Branch shows that water-power from other sources in this section is limited. With the supply thus limited, it becomes the duty of the Crown to see that the perpetual cheap power which nature has provided is kept available for the public use, at rates not dictated by "what the traffic will bear," but determined upon a reasonable competitive basis.

(14) Full conservation in all its phases, both of power and of capital, can only be secured through Crown control, dictated from the most reliable and independent data obtainable.

#### SITUATION LEADING TO COMMENCEMENT OF SURVEY.

At the time when the power and storage investigations along the Winnipeg river were begun by the Dominion Water Power Branch, the hydro-electric plant of the Winnipeg Electric Railway Company was in operation on the river, and the initial installation of the municipal plant of the City of Winnipeg was rapidly approaching completion.

The Winnipeg Electric Railway Company's plant is located on the Pinawa channel of the Winnipeg river, about 58 miles from Winnipeg. The construction of this plant was commenced in 1902, and was completed in 1906, with a total turbine capacity of 34,000 h.-p. A 22,000-horsepower steam turbine plant in the city, supplements the Pinawa plant.

In order to meet a growing market demand, construction operations on a municipally owned power plant were commenced by the city of Winnipeg in 1908, and the first installation of five 5,200-horsepower turbines was being placed in position when the departmental field studies were commenced. The power output of both the company's and the city's undertakings is transmitted to Winnipeg for traction, lighting, industrial, and domestic use.

With the power from these two sites either developed or in course of development, the department was in receipt of numerous applications covering other sites along the river. The majority of these were in the nature of blanket applications for particular falls, and were accompanied by no engineering data or plans of proposed development. Others were supported by exhaustive reports and estimates based on extensive field work from reliable engineering firms.

It was realized that further hydro-electric development on the river was a matter of the immediate future, and that if a comprehensive policy was to be mapped out into which new developments could be incorporated as component

units, no delay should be permitted in commencing the departmental power investigations. Independent schemes before the department were based on the individual viewpoint, and contemplated development of certain sites without considering the effect of such concentrations on the power possibilities of the balance of the river.

Early in 1911 aggressive steps were taken to organize a field party for the thorough study of the Winnipeg river in Manitoba.

#### SCOPE OF THE INVESTIGATION.

The departmental purpose of guiding the development of the river along a definite system, complete in all details, necessitated securing full and reliable data covering all features of hydro-electric studies.

The plan of campaign laid down involved:—

- (1) A preliminary reconnaissance of the power reach of the river, by engineers of recognized standing, with a view to mapping out a systematic method of attack by the field parties.
- (2) A continuous profile of the power reach of the river, on which could be based all the detail surveys.
- (3) Detailed contour surveys with soundings of all falls or rapids at which power concentration was possible.
- (4) Contour survey of the river banks throughout the entire power reach of the river.
- (5) Determination of the locations at which the drop of the river could best be centralized and developed.
- (6) Design of layouts for such locations, in sufficient detail to permit fairly accurate estimating.
- (7) Estimates of the capital cost of constructing the various plants proposed, in order to compare the economic feasibility of the different sites.
- (8) Estimates of the annual cost of operation of the various plants proposed.
- (9) Estimates of the cost of transmission from a typical site to Winnipeg.
- (10) Establishment of metering stations for the purpose of obtaining accurate records of the river flow, and the thorough study of the same together with all pre-existing records.
- (11) Establishment of evaporation stations.
- (12) Study of existing rainfall and temperature records, with effect of same on run-off.
- (13) Close investigation into the question of storage in the upper waters of the basin in all its aspects.
- (14) Investigation into and study of prior water rights, and the relative value and effect of the same.
- (15) Comprehensive provision for future navigation should the necessity for it ever arise.

(16) Close study of existing power plants, and of all existing interests on the river.

(17) Study of present and future power market conditions and prospects.

(18) Recommendations for the carrying out of an aggressive policy of hydro-electric and power development, and of ensuring government supervision over regulation, both in connection with individual power plants, and of the storage conditions as a whole.

In instituting an investigation with such far-reaching ends in view, it was essential that the department should be guided by expert engineering advice and opinion. This was particularly the case in consideration of the fact that the powers of the Winnipeg were of such magnitude as to require the services of engineers and engineering firms of outstanding reputation, in the actual design and layout of the various independent plants. If the conclusions of the department were to be made the basis of the development of the river, it was therefore necessary that such conclusions should be backed by recognized and reliable engineering authorities. To this end the services of Mr. J. R. Freeman, C.E., of Providence, Rhode Island, were secured in a consulting capacity, to assist in the commencement and organization of the field investigations. The services of Mr. J. B. McRae, C.E., of Ottawa, were likewise secured in this connection, and he was further retained to act as consulting engineer throughout the full period of field and office investigations.

The suggestions and advice of these engineers were acted upon in full, and the results of the investigations as submitted in this report are considered as forming a reliable basis on which to administer the water powers of the Winnipeg river. The direct connection of Mr. Freeman and Mr. McRae with the work is referred to in more detail throughout the report.

It must be kept in view that the layouts designed herein are mainly for the purpose of securing a fair estimate of the cost of developing the various sites in order to demonstrate their economic feasibility. It is not intended that the designs will be followed without alteration by the parties doing the actual development work. It is intended, however, that the general head- and tail-water elevations shall be observed as now submitted, with such modifications as may be considered advisable from the further detailed investigations and the more complete run-off and surface level records now being secured.

#### ACKNOWLEDGMENTS.

It is desired to acknowledge here the hearty co-operation which the various interests affected by and interested in the general situation, have evinced in making available data pertinent to the question at issue. Particular mention in this connection is due to:—

- The civic officials of the city of Winnipeg.
- The civic officials of the town of Kenora.
- The Winnipeg Electric Railway Company.
- The Winnipeg River Power Company.
- The Lake of the Woods Milling Company.

- The Ontario and Minnesota Power Company.
- The Keewatin Power Company.
- The Director of the United States Geological Survey.
- The Department of Public Works of the province of Ontario.
- The Meteorological Service of Canada.
- The Lake of the Woods Technical Board.
- W. J. Stewart, Chief Hydrographer of the Naval Service Department.
- H. G. Acres, Hydraulic Engineer of the Hydro-electric Power Commission of Ontario.
- S. J. Chapleau, of the Dominion Department of Public Works.
- Hon. H. A. Robson, Public Utilities Commissioner of Manitoba.
- C. F. Roland, Industrial Commissioner of the city of Winnipeg.



REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

---

CHAPTER II.  
WINNIPEG WATERSHED AND FIELD  
INVESTIGATIONS



## CHAPTER II.

### WINNIPEG WATERSHED AND FIELD INVESTIGATIONS.

#### HISTORICAL.<sup>1</sup>

In this highly utilitarian age very little thought is given to romance, and the appropriation of any natural resource for the use of commerce is usually a matter of dollars and cents, interest charges and depreciation. The financier in his office studies the reports and plans of his engineers with no thought of the long process of development that brought this or that scheme within the realms of profitable investment.

The Winnipeg river formed the last link in the chain of waterways connecting the vast basin and tributaries of the Great Lakes with lake Winnipeg, in which was centralized a second great system of canoe routes. In early and pioneering days this gave to the Winnipeg river an exceptional importance as an avenue of travel, trade and commerce.

Without expending much time on this aspect of lake Winnipeg, it is interesting to note that by the Red and Mississippi rivers there was a way to the gulf of Mexico; by the Nelson to Hudson bay; by the Saskatchewan to the Rockies, and thence by the Columbia river to the Pacific; by way of Cumberland House and up the Churchill river to the Clearwater and Athabaska waterways, giving access on one hand to the Arctic ocean by way of the MacKenzie, and on the other, to the Fraser by way of the Peace and Parsnip rivers.


In the early days, the Hudson's Bay Company operated from Hudson bay; many of the routes in the Northwest were known to them, and their traders and trappers soon reached lake Winnipeg by way of the Nelson.

The Winnipeg river, on the other hand, was first discovered by the French penetrating from Montreal. We see Le Caron and Champlain in 1615, Etienne Brulé in 1622, Nicolet in 1634, and Joques in 1641 pushing westward from Montreal to lake Huron. Gradually the traders of New France (the French Company) and their legitimate successors, the Northwest Company, pushed around the north shore of lake Superior, Menard and Radisson in 1651, Allouez in 1665, and Du Lhut in 1678. Jacques de Noyon reached Rainy lake in 1688, and in 1689 descended to the Lake of the Woods and here heard fabulous stories from the Indians concerning a great sea, probably referring to lake Winnipeg.

There seems to have been a lull here, and we have no record of progress, until 1731, when the Sieur de la Verendrye was stationed at Kaminitikwia and began his long series of western exploration, apparently rediscovering Rainy lake and the Lake of the Woods. He also led the way into lake Winnipeg by the river of the same name, which river became and remained the highway for the fur trade for upwards of 100 years.

<sup>1</sup> Lawrence J. Burpee's "The Search for the Western Sea" contains much interesting information concerning the routes of early explorers. Mr. Burpee has also contributed papers published in the Proceedings of the Royal Society of Canada, which contain interesting notes on early travel in the West.

Now and again we turn up old books of travel and read of some well-known explorer who journeyed by this route. Sir John Franklin, in May and June, 1825, passed down the Winnipeg river *en route* for the Arctic, his second over-land journey; returning safely he passed up the river in July, 1827. Earlier than this, in Sir Alexander MacKenzie's account of his voyages in the years 1789 and 1793, we read a detailed description of the river.



Route of Red River Expedition.

Probably the most interesting historical incident in connection with the Winnipeg river was the passage in 1870 of "The Red River Expedition" under the late Lord Wolseley *en route* to the suppression of the ill-fated Riel rebellion. The problems connected with the transport of a completely equipped military expedition by canoe and boat over some five hundred miles of river and lake, with innumerable portages, can only be faintly realized even by those who have been fortunate enough to travel the same route under more advantageous conditions. The force under Colonel Wolseley, as he was then, consisted of detachments of the Royal Artillery, Royal Engineers, Army Service Corps, and Army Hospital Corps, together with 26 officers and 351 non-commissioned officers and men of the 60th Rifles, all of the British Regular Army. There were also 28 officers and 350 men each of the 1st or Ontario Battalion and 2nd or Quebec Battalion of the Canadian Militia, a total of 1,213 men of all ranks.

The force assembled for the boat journey at Prince Arthur Landing, in Thunder bay, lake Superior, where one company of the Quebec Battalion remained to protect the depot from possible Fenian attack. The remainder of the force, with 150 boats, 32 feet in length and 6-foot beam, a light gig and three large bark canoes pushed forward towards Fort Frances. Each boat carried about 3,300 pounds of stores, besides nine or ten soldiers and three Iroquois and voyageurs, with their camp equipment.

From Fort Frances a start was made on or about the 8th August, 1870, this part of the expeditionary force consisting of all the regulars, with fifty

boats. The passage down the Rainy river, across the Lake of the Woods and down the Winnipeg was successfully made and with remarkable speed, the force arriving at Fort Alexander on August 20, and proceeding across lake Winnipeg on the 21st.

Riel having fled, the regulars started back by the same route on August 29, with the exception of one company of the 60th Rifles, which went across country to the Northwest Angle of the Lake of the Woods.

Lieutenant Riddell, of the 60th Rifles, and Captain Huyshe, of Wolseley's staff, have left interesting accounts of the campaign, referring at some length to the beauties, excitement, and dangers of the trip down the Winnipeg river, enabling one to picture to some extent the difficulties successfully overcome.

Since the advent of the railroad, the Winnipeg river has fallen from its former greatness as a route of travel, though pleasure boats from Kenora ply regularly during the summer past Minaki on the National Transcontinental railway to the head of White Dog falls. The river still forms the local medium of travel for the hunter and the fisherman, and for the Indian and the settler, while the hydro-electric activity which has developed in recent years has made it a highway for field parties and engineers. The old Indian legends are still told to the traveller—how Slave falls is named after the slave who, unable to further submit to the cruelty of her master, stepped into a canoe and floated gently over the cataract, and how in the days of Indian tribal warfare, the islands were by mutual agreement made sanctuaries where the squaws and non-combatants might remain unmolested.

#### GENERAL DESCRIPTION OF BASIN AND RIVER.

The basin of the Winnipeg river (Plate 3) forms a portion of the great Nelson River drainage system. The Winnipeg river from the east, the Red river from the south, and the Saskatchewan river from the west, unite their waters in a great central reservoir, lake Winnipeg, which in turn discharges the combined run-off into the Nelson river, and thence into Hudson Bay. The Winnipeg River basin, itself 53,500 square miles in area, lies largely in the westerly portion of New Ontario, while what is referred to in this report as the power reach of the river, i.e., the reach below the junction of the English river, lies almost entirely within the province of Manitoba. The basin is international as well as interprovincial; 11,000 square miles lying in the state of Minnesota; 4,600 square miles in Manitoba; and 37,900 square miles in Ontario. The upper waters are almost equally divided between two drainage systems, which together make up practically the entire basin outside of the province of Manitoba. The southern portion of the run-off is collected by the Rainy river, which in reality is the continuation of the Winnipeg above the Lake of the Woods, while the northern portion is carried by the English river. The two branches unite at a point about 4 miles east of the Manitoba-Ontario boundary.

The entire watershed is very sparsely populated, and a large proportion offers little opportunity for agricultural settlement. Those portions best adapted for such use are the sections lying in southern Manitoba, in Minnesota, and extending inland on the Canadian side from the Rainy river. The balance

of the basin consists for the most part of a forest-covered Laurentian formation, with much granite outcropping, and is interspersed with lakes and muskegs and occasional stretches of agricultural land. The forest cover is composed largely of spruce, poplar, jack pine, and oak, a considerable portion of which is too small to possess any great timber value. In the sheltered valleys and gullies the timber is better developed and is of great commercial value. The smaller timber makes excellent pulpwood material.

The great extent of the forest cover exercises a most beneficial influence on the run-off from the basin. It is to the interests of the conservation not only of the timber resources, but also of the power resources as dependent on the regularity of the run-off, that efficient measures be taken towards the preservation of the forest cover from wanton and wasteful timber cutting, and towards the reforestation of denuded areas. Large sections of the basin are suited only to forest growth, and a consistent policy of reforestation will not only directly repay many times over the organization and administrative charges, but will also prove an invaluable and direct aid to the preservation of the water-power resources of the basin. It is to the best interests of the entire district that the watershed area should be created a forest reserve, and so administered.

Throughout the entire central, northern, and western portion of the basin the granite formation is almost continuously in evidence in the form of ridges, mounds, cliffs, and gullies, showing in all directions, traces of glacial striation.<sup>1</sup> As is characteristic of this formation, the entire region is scamed and dotted with lakes of every size, from mere ponds to the expansive spread of the Lake of the Woods. The lakes are likewise dotted with outcropping granite islands and islets, the Lake of the Woods being sometimes, for this reason, referred to as the Lake of Ten Thousand Islands, in contra-distinction to the Lake of a Thousand Islands on the St. Lawrence.

Joining the lakes are innumerable streams and rivers, of size depending on their respective catchment basins, and for the most part made up of deep ponds and lake-like expanses interspersed with rapids and falls tumbling over the natural granite. It is to these conditions both of lake and forest that the Winnipeg river owes its almost unequalled natural regulation, its normal yearly flood seldom exceeding three or four times its minimum.


In the more level sections along the Rainy river, and in Manitoba, and to the south and west of the Lake of the Woods, the existing alluvial conditions are not favourable to lake formation, and the innumerable reservoirs, so much in evidence elsewhere, are almost non-existent. The country is therefore more adapted for settlement.

The basin is now traversed by the three transcontinental lines of railway, the Canadian Pacific, the National Transcontinental, and the Canadian Northern. These routes, running through the heart of the region, are rapidly making its resources available, and are promoting its settlement wherever conditions are favourable. Among the more important towns are Kenora and Fort Frances, in Canada, and International Falls and Warroad in the United States.

The more important natural reservoirs in the southern portion of the basin are lakes Rainy and Namakan, of 330 and 100 square miles area, respec-

<sup>1</sup> For a detailed description of the geological characteristics of the basin, see Appendix III by Mr. Charles Camsell, B.Sc., Ph.D., of the Geological Survey of Canada.





**WINNIPEG RIVER POWER SURVEY**

PLAN 10

**WINNIPEG RIVER BASIN**

RELATION OF THE OBSERVATIONS TO THE POWER BASIN OF THE WATERSHED

1. THE WATERSHED OF THE WATERSHED

2. THE WATERSHED OF THE WATERSHED

3. THE WATERSHED OF THE WATERSHED

4. THE WATERSHED OF THE WATERSHED

5. THE WATERSHED OF THE WATERSHED

Drawn in the Office of the Chief Draftsman, Dominion Water Power Branch



of the l  
with m  
and occ  
largely  
is too :  
gullies  
smaller

Th  
on the  
only of  
the reg  
vation  
the ref  
to fore  
repay  
also pr  
resourc  
waters

Th  
the gra  
mound  
As is c  
with la  
of the  
and is  
to as †  
Thous

Je  
their r  
and la  
natur  
peg riv  
seldom


It  
the so  
are no  
in evi  
adapt

T  
the Ca  
These  
resour  
favou  
in Car

T  
basin


<sup>1</sup> Fo  
B.Sc., Pt





Department of the Interior, Canada.  
 HON. W. J. ROCHE, MINISTER  
 W. W. CORY, C. M. G., DEPUTY MINISTER  
 Dominion Water Power Branch.  
 J. B. CHALLIER, SUPERINTENDENT

**WATERSHED of the LAKE OF THE WOODS**  
 SHOWING APPROXIMATE  
**CHARACTER OF SOIL**



This based on plan published in a report made in 1915 to the International Joint Commission on Lake of the Woods by Arthur V. White and Arthur F. Meyer Consulting Engineers.

December 1917

Drawn in the Office of the Chief Draftsman, Dominion Water Power Branch.



**NOTE**

The data upon which this map is based were obtained, mainly from the State Geologist of Minnesota and the Geological Survey of Canada. An effort has been made to represent the principal soil types rather than to accurately delineate all areas of the various surface horizons occurring on the watershed. The character of large portions of the area in Canada has not been ascertained. For purposes of hydrographic construction, however, the classifications here indicated may be regarded as substantially correct.

**LEGEND**

- Blank outcrops with little soil covering and suitable mainly for forestry and mining.
- Loessly, clayey siltstone covered with sandstone, shale, or limestone. Most of this area is well forested, when cleared of timber for use as range of all agricultural crops suitable to the great lakeside. Partly cleared and partly pasture.
- Loessly, sandy loam, reasonably fit for agriculture, although subject to droughts, ranging to almost pure sandstone.
- Clay with boulders, ranging from land suitable for agriculture to land which may occasionally be used for agriculture by the removal of the boulders.

50 00

49 30

49 00

48 30

48 00

87 30

91 00

90 30

90 00

92 30'

92 00'

91 30'

93 00

92 00

Rapids

Chute

Cedar L.

Sandy L.

Wabigoon

Stormy

Manitou

Lawrence

Larson

Falls

Pelican

Serrano

White Otter

Beaverhouse

Northern Light

Sturgeon

DOC L.

BOTSFOSS L.

ROCK

VERMILION

GULL

SANDY L.

RASKET

DINDORWIC L.

MARKHILLS L.

RAVENSHEGAMUF

STORMY

MANITOU

LAWRENCE

LARSON

FALLS

PELICAN

SERRANO

WHITE OTTER

BEAVERHOUSE

NORTHERN LIGHT

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

DOC L.

BOTSFOSS L.

ROCK

VERMILION

GULL

SANDY L.

RASKET

DINDORWIC L.

MARKHILLS L.

RAVENSHEGAMUF

STORMY

MANITOU

LAWRENCE

LARSON

FALLS

PELICAN

SERRANO

WHITE OTTER

BEAVERHOUSE

NORTHERN LIGHT

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

DOC L.

BOTSFOSS L.

ROCK

VERMILION

GULL

SANDY L.

RASKET

DINDORWIC L.

MARKHILLS L.

RAVENSHEGAMUF

STORMY

MANITOU

LAWRENCE

LARSON

FALLS

PELICAN

SERRANO

WHITE OTTER

BEAVERHOUSE

NORTHERN LIGHT

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

DOC L.

BOTSFOSS L.

ROCK

VERMILION

GULL

SANDY L.

RASKET

DINDORWIC L.

MARKHILLS L.

RAVENSHEGAMUF

STORMY

MANITOU

LAWRENCE

LARSON

FALLS

PELICAN

SERRANO

WHITE OTTER

BEAVERHOUSE

NORTHERN LIGHT

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

DOC L.

BOTSFOSS L.

ROCK

VERMILION

GULL

SANDY L.

RASKET

DINDORWIC L.

MARKHILLS L.

RAVENSHEGAMUF

STORMY

MANITOU

LAWRENCE

LARSON

FALLS

PELICAN

SERRANO

WHITE OTTER

BEAVERHOUSE

NORTHERN LIGHT

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

DOC L.

BOTSFOSS L.

ROCK

VERMILION

GULL

SANDY L.

RASKET

DINDORWIC L.

MARKHILLS L.

RAVENSHEGAMUF

STORMY

MANITOU

LAWRENCE

LARSON

FALLS

PELICAN

SERRANO

WHITE OTTER

BEAVERHOUSE

NORTHERN LIGHT

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

DOC L.

BOTSFOSS L.

ROCK

VERMILION

GULL

SANDY L.

RASKET

DINDORWIC L.

MARKHILLS L.

RAVENSHEGAMUF

STORMY

MANITOU

LAWRENCE

LARSON

FALLS

PELICAN

SERRANO

WHITE OTTER

BEAVERHOUSE

NORTHERN LIGHT

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

STURGEON

of the l  
with n  
and oo  
largely  
is too  
gullies  
smaller

TI  
on the  
only of  
the reg  
vation  
the ref  
to fore  
repay  
also pr  
resourc  
waters

TI  
the gra  
mound  
As is c  
with la  
of the  
and isl  
to as t  
Thous


Jo  
their n  
and la  
natura  
peg riv  
seldom


In  
the son  
are no  
in evid  
adapte

TI  
the Ca  
These  
resourc  
favour  
in Can

TI  
basin a

<sup>1</sup> For  
B.Sc., Ph.








**NOTE**  
 The forest cover shown for the United States is based on data furnished by the State Forester of Minnesota. The forest cover shown for the Canadian portion of the watershed is based mainly on data furnished by the Department of Lands, Forests and Mines, Ontario. Information regarding the character of the forest cover in Canada has not been ascertained.  
 An effort has been made to represent correctly the general character of forest cover with out reference to minor variations, and from the very nature of hydrographic observations no attempt has been made to delineate the individual local watershed, or only a relatively small portion of the watershed along the stream, lake and reservoir, or at present water collection.

**LEGEND**

- Heavy stand of mixed deciduous and coniferous trees
- Mixed coniferous and deciduous trees
- Spruce, cedar and firwood
- Mainly white and grassy pine



tively. These lakes together collect the run-off from 14,400 square miles of drainage basin.

Passing from the western end of the Rainy lake into the Rainy river, the discharge takes place over what were formerly the Koochiching falls, but which are now utilized in operating the hydro-electric and pulp-mill installations of the Ontario and Minnesota Power Company at the towns of Fort Frances and International Falls. A normal head of some 33 feet is developed here. The Rainy river flows in a westerly and slightly northerly direction to the Lake of the Woods, the largest body of water in the Winnipeg watershed. The river below Fort Frances is navigable, 6-foot draught being maintained. Plans have been developed by the Dominion Department of Public Works, for the installation of a lock with an 11-foot lift at Long Sault rapids to improve navigation, but no construction steps have as yet been taken.

The Lake of the Woods receives the discharge of numerous streams, other than the Rainy river, none of which are of outstanding importance. Its surface, as stated above, is dotted with innumerable islands, which form ideal sites for summer houses, a fact which is being fully recognized by the people of Winnipeg and the surrounding cities and towns. The lake discharges through two branches, the eastern and the western, the entrances to which lie within the limits of the town of Kenora. Here the Winnipeg river proper begins. The basin above Kenora is 26,400 square miles in extent, and the Lake of the Woods is 1,500 square miles in surface area, forming a unique combination in the interests of storage, more especially in view of the 347-foot drop between the lake level and lake Winnipeg 160 miles below.

The eastern outlet is closed by the Kenora municipal power station, developing a normal head of 20 feet. The western outlet is closed by the Norman dam, a rock-fill, stoplog controlled structure. Farther to the west, at the town of Keewatin, are two additional outlets which have been blasted for power purposes through the rock ridge separating the lake from the river below. The situation at the outlets of the lake is treated fully in chapter III.

Leaving the Lake of the Woods, the Winnipeg river flows first in a northerly direction, expanding into deep lake-like expanses with little or no current, and again narrowing into congested channels and forming rapids and falls of greater or less turbulence. This characteristic formation continues throughout the entire reach of the river to lake Winnipeg. The ponds are usually very deep, having, in fact, originally been the deeper gullies and valleys lying between the rocky ridges and hummocks covering the surface of the region, through which the drainage of the basin above found exit towards lake Winnipeg. As a rule, discharge from these basins takes place over granite ridges at points where the elevation drops below the general level, thus forming the falls and rapids which obtain throughout the length of the river. Evidence as to the existence of these submerged ridges can be readily noted, and is definitely shown at all rapids and falls where detailed soundings have been secured. Granite outcrop is invariably in evidence on both river banks at all such points and is, as a rule, indicated also in the intervening river-bed, by outcropping islands and ridges. In all cases, the rock is of the most massive character, showing small signs of wear or dis-

integration even where exposed to the most turbulent current or to the most severe ice action.

These submerged ridges at the critical points along the river, combined with the deep ponds which are already in existence immediately above, which ponds are deepened and bettered by the construction of power dams, supply unequalled sites for the development of power.

About 11 miles below Kenora the river enters a somewhat narrow channel of rather rapid current, known as the Dalles. Leaving this, open expanses with little or no current are the rule until the crossing of the National Transcontinental railway at Minaki is reached. From Kenora to this point the river is navigable by steamer. Minaki has become recognized as a summer resort by the people of Winnipeg, as it is the centre of a beautiful lake and island region, and has good rail connection with the city.

Fifteen miles below this, the river discharges through the White Dog rapids. In these rapids there is a total drop of 45 feet, occurring in several abrupt pitches, with quieter water intervening. These form an excellent power prospect but, as they lie within the province of Ontario, do not come within the jurisdiction of the Dominion Water Power Branch, and hence are not treated in the power studies covered in this report.

The English river joins the Winnipeg at a point 50 miles below Kenora. It is a river very similar to the Winnipeg at this point, draining 21,600 square miles of basin as against 27,500 square miles by the Winnipeg. The principal reservoir in the upper reaches of the English river is Lac Seul, 340 square miles in area. There are, however, innumerable other lakes of sizes up to 94 square miles, scattered over the region in all directions. The waters of these two great branches combine within 4 miles of the boundary between Ontario and Manitoba. Before reaching the interprovincial boundary, what is known as the First fall is passed. The drop here is 4 feet.

From the eastern boundary of Manitoba, the Winnipeg river flows in a generally northwesterly direction towards lake Winnipeg. Its general characteristics continue as already described, and since the individual falls and rapids are treated at length in connection with the power concentrations, it is unnecessary to do more than refer to them here. Only a few of the main features will be dealt with.

After crossing the interprovincial boundary there is but one distinct drop before the municipal plant of the city of Winnipeg is reached. This slight pitch of about one and a half feet is all that is left of Lamprey falls, the former 16-foot natural drop which has been flooded out by the construction of the city plant. This development incorporates Lamprey falls, together with the Point du Bois falls, making in all a 45-foot normal working head.

Below the city plant come the Eight Foot and Slave falls, of 7 and 19-foot drop respectively. At the latter of these,  $4\frac{1}{2}$  miles below Point du Bois, the first power concentration of 26-foot head is proposed.

Sixteen miles below Slave falls the river is broken into two channels, the left carrying the main flow through what is known as the Seven Sisters reach, and on which two of the proposed power sites are located; and the right or

Pinawa channel, carrying a sufficient flow to properly operate the hydro-electric plant of the Winnipeg Electric Railway Company. The latter channel, 21 miles in length, was formerly a high water by-pass of the main river. It has been very considerably straightened and deepened in the upper reaches, while diversion weirs have been placed across the main and secondary channels, with the result that a flow of from 7,000 to 12,000 second-feet is diverted for the operation of the power station. A power concentration is proposed on this channel above the present power station.

The main and Pinawa channels unite in Lac du Bonnet, a body of water 32 square miles in area. From Lac du Bonnet, the river discharges over the First McArthur falls, followed a short distance below by the second drop of the same name. At the latter point is placed the fifth concentration, with a proposed head of 18 feet, partially secured by raising the level of Lac du Bonnet. Below the McArthur falls the river's flow is quiet, with a just appreciable current in places, until the Grand du Bonnet falls are reached. Here a total drop of 35 feet takes place in four distinct pitches, and is followed a short distance below by the Little du Bonnet drop of 8 feet. At this point has been placed the sixth concentration, with an ultimate proposed head of 56 feet, to be partly secured by blasting away the ridge forming the Whitemud falls.



Pine Falls, Main Drop.

After leaving the Du Bonnet falls, the river resumes its characteristic course, abrupt drops taking place at Whitemud and Silver falls. The latter are the most spectacular falls on the Winnipeg river, owing to the comparative concentration of the 21-foot drop. Below the Silver falls the river flows without disturbance to the Masqua rapids, where there is a total drop of 5 feet. Passing the Masqua rapids, quiet water prevails until the Pine falls, forming the last pitch before reaching Lake Winnipeg level, are reached. At Pine falls the seventh



Silver Falls.

concentration is proposed with a head of 37 feet. Below Pine falls the river gradually broadens out and enters Traverse bay, an eastern arm of lake Winnipeg.

With the exception of that section of the river below Silver falls, settlement along the river banks is not as yet far advanced. Below Silver falls, the river banks have been cleared and cultivated. This comparative freedom from settlement is an outstanding advantage in mapping out a general scheme of hydro-electric development.

#### PRELIMINARY RECONNAISSANCE.

In June of 1911, initial steps were taken looking to the commencement of active field investigations. As already stated, the services of Mr. J. B. McRae, C.E., of Ottawa, were secured in the capacity of consulting engineer, to act throughout the investigation, while the services of Mr. J. R. Freeman, C.E., of Providence, R.I., were engaged to advise, in company with Mr. McRae, on the organization and scope of the survey. Mr. D. L. McLean, B.Sc., of Ottawa, was engaged as chief engineer in charge of the field investigations, and a preliminary field staff was organized.

The main survey work was preceded by a reconnaissance trip made by the consulting and departmental engineers down the Winnipeg river from Kenora to lake Winnipeg, with a view to securing a comprehensive grasp of the entire power reach, and of laying out the general plan of attack. In the meantime, Mr. McLean proceeded to the ground and placed a levelling party in the field for the purpose of establishing the essential base profile to which the further survey work could be tied in. The levelling party, under Mr. A. M. Beale, commenced operations on June 21, 1911, starting from a Canadian Pacific Railway bench-mark near the Winnipeg City bridge at Lac du Bonnet. This datum, based on mean sea-level, was used throughout.<sup>1</sup>

Leaving Lac du Bonnet, the levelling party carried the profile down to Fort Alexander at the mouth of the river, reaching the settlement on July 18. High-water marks, which are most distinctly preserved on the rock formation, were tied in at frequent intervals. The party returned to Lac du Bonnet on the 22nd, and continued the profile up the river by way of the Seven Sisters reach arriving at Kenora on September 20, after an uninterrupted trip. Here the levels were tied in to the Canadian Pacific Railway bench-marks, and a most satisfactory check obtained.

In running the line up the river, a diversion was made at the head of the Pinawa channel, and the levels were carried down the same to the Winnipeg Electric Railway Plant. From this point, a pre-existing line of levels was utilized to the exit of the channel into Lac du Bonnet, and by water transfer carried across the lake to the head of the First McArthur falls, a check on the closed circuit of 0.15 feet being obtained.

Due to the prevalence of exposed granite along the entire river, it was possible to establish bench-marks of the most permanent description. Standard bench-marks were located on suitably exposed granite knolls, these being as a

<sup>1</sup> 0.0 Water Power Survey Datum is equal to 1.31 mean sea tide at New York, i.e. the United States Coast and Geodetic Survey Datum.

rule in evidence at all vital points. The bench-marks were given succession numbers, which, together with the elevations, were painted on the rock surface. A complete list of the principal bench-marks established along the power reach, together with their location, is attached in Appendix V.



Typical Survey Bench Mark.

Towards the end of August, when the levelling party were in the midst of their operations, arrangements were completed for the desired power reconnaissance of the river. The reconnaissance party, consisting of Mr. Freeman, Mr. McRae, Mr. McLean, and the writer, assembled at Winnipeg on the morning of August 26, and immediately proceeded to Kenora, from whence the start was to be made. During the afternoon a detailed inspection was made of the various outlets of the Lake of the Woods, together with their control structures in the way of dams, power stations, and mills.

The following morning the party boarded the *Kathleen*, a small steamer making regular trips from Kenora to Minaki at the crossing of the National

Transcontinental railway, 19 miles down the river. From this point, the trip was continued by canoe and portage to the mouth of the river.

At each fall or rapid, a stop was made to permit of a thorough inspection of the site and surroundings, and the securing of such notes, sketches, and photographs as were desirable. Throughout the reaches between the falls, careful note was made of the banks, mainly from the canoe. Each site was studied from the viewpoint of concentrating thereat the greatest feasible head. It was impossible to do more than form general conclusions at this stage, and it was recognized that such temporary findings were merely useful as forming a preliminary guide on which to base the field work, and were to be revised in the



White Dog Rapids, Third Pitch.

light of the actual results secured by the field parties. With such information as could be obtained by observation on the ground, conferences were held at the various falls, in which the scope of the necessary surveys was discussed, and the best prospect of development at each site tentatively outlined. It might be said here, that while the conditions exposed by actual survey work called for several radical departures from these first outlined suggestions, and required different treatment from that tentatively discussed, the basic principles laid down served as a continuous and sufficient guide throughout the entire work.

While the scope of the actual power investigations was not to extend beyond the province of Manitoba, the reach of river between Kenora and the boundary was included in the reconnaissance examination. The White Dog rapids was passed on the morning of the 28th. There is here a total drop of 45 feet, with the apparent opportunity of developing the entire head, and of flooding back to the tailwater of the Kenora plants. Such a development would undoubtedly

prove commercially attractive. Extensive detail contour surveys of the river banks above are necessary to determine the flooding which would be involved. A back channel, with upper entrance above the first drop, also requires investigation in connection with any development here.

The First falls, reached during the same day, are located about 16 miles below the White Dog rapids, and 1 mile below the junction with the English river. There is here a natural drop of 4 feet, and the fall forms an excellent power prospect, the full capacity of which can only be ascertained by a contour survey of the river banks above.



White Dog Rapids Fourth Pitch.

On the morning of August 29, the party left First falls, and about noon encountered the levelling party working up stream, a short distance above Lamprey falls. These falls have a drop of about  $1\frac{1}{2}$  feet only, all that is now left of the original 16-foot pitch, which has been flooded out by the construction of the city of Winnipeg municipal plant.

The city plant was reached at 4 p.m., and a thorough inspection made. At this time, the initial installation was being rushed to completion. Leaving the city plant and passing the Eight Foot falls, Slave falls was reached the same evening.

On the morning of the 30th, the Slave site was inspected. This appeared to be the obvious point of concentration for the Slave and Eight Foot falls. Subsequent survey has confirmed this conclusion, as is covered in chapter VI. Immediately above Slave falls there occurs a fairly narrow river section, which appeared to offer better opportunities for the establishment of a metering station than were elsewhere obtainable along the river. This was confirmed

in the subsequent detailed examination of the river, and a cable station was established here in October of the same year.

The diversion weirs of the Winnipeg Electric Railway plant were reached shortly after noon, and were briefly inspected. The canoes were then turned down the Pinawa channel. Time did not permit of a reconnaissance of the main or Seven Sisters channel, and as the problems to be investigated thereon were not of as pressing importance as were those on the Pinawa, the latter channel was selected for immediate attention. The principal features of the Pinawa channel are referred to in another section of this report, and need not be repeated here. The street railway plant was reached at 4 p.m. Leaving the power station, the party reached Lac du Bonnet about nightfall. Good progress was made throughout the Pinawa, due to the rapid current which prevails for a considerable portion of its length.



Pinawa Channel, Rock Cut.

On the morning of the 31st, the two McArthur falls were examined, followed by the Grand and Little du Bonnet falls. The outstanding advantages of combining the entire drop of this group of falls at the last named was recognized, and was made the basis of the subsequent field investigations. These, however, showed that the scheme was not practicable in its entirety, owing to the low-lying lands to the east, and it has been found necessary to break this section into two developments, as is discussed in chapter VI.

The Whitmud, Silver, and Pine falls were passed during the afternoon, and the general scope of the field investigations covering the same decided upon.

At 7 p.m. the party boarded the launch which was waiting at the foot of Pine falls, and proceeded across lake Winnipeg to Gimli, and thence by train the following morning to Winnipeg. The entire trip from Kenora to Pine falls

occupied five full days, which, considering the time spent on the examination of the falls, rapids, and plants, en route, was considered exceptionally good travelling, and was only attained as a result of continuous effort and hard paddling by every member of the party.

Mr Freeman and Mr. McRae submitted to the department comprehensive reports covering the trip, the investigations, the field work recommended, and the general conclusions as to the scope of the work to be undertaken. The following final summing of Mr. Freeman's report is quoted:—

“In brief, I recommend that you have surveys made in sufficient detail at each site so that the best plan for conserving all the power can be worked out, and that plans be prepared in outline, and the cost of each project carefully estimated, and the whole then published very fully, so as to attract attention and at the same time give opportunity for easily verifying the principal statements and estimates, and that this be prefaced by a statement of the generous policy of the Government regarding the granting of water-power rights.”

This summary was supplemented by recommendations to thoroughly study the river discharge, and to establish the records of the same on a reliable basis, to collate all existing rainfall records and establish new stations where necessary, to establish a fully equipped evaporation station on the lake of the Woods, and to look into the storage prospects on Lake of the Woods, Rainy lake, Lac Seul, and other lakes of the watershed. All these questions had been the subject of conference and discussion throughout the reconnaissance, and the various aspects and details in connection with the same, had been thoroughly considered.

#### FIELD SURVEY.

In view of the pressing and conflicting character of the applications which were before the department covering the development of the Du Bonnet falls, the reach of the river below Lac du Bonnet called for first consideration in the field, and it was at the Du Bonnet falls that the actual detail survey work was commenced. In spite of the extreme temperature conditions which prevail in this latitude, it was determined that the field work should be prosecuted continuously throughout the winter season. The disadvantages and hardships incident to work during this season were largely counterbalanced by the added speed which could be attained in cross-section work, due to the bareness of the trees and shrubbery. The necessary soundings could also be obtained much more readily from the ice surface, than under open-water conditions.

Upon the completion of the profile work in the latter part of September, the levelling party was enlarged and transferred to the Du Bonnet falls, and there installed in a roomy log shanty which had formed the headquarters of previous power survey parties conducted by private enterprise. In the meantime, a cable metering station was established at Slave falls, and gauges were placed at all points where records of the water level would prove of value, and where gauge readers could be secured.

The survey work in the vicinity of the Du Bonnet falls was more extensive in scope than was necessary at other possible concentrations along the river.

This was due to the conflicting nature of the schemes of development proposed by private interests, and to the necessity of ascertaining, beyond doubt, the feasibility or otherwise of carrying the Lac du Bonnet level to the Du Bonnet falls for incorporation with the existing drop. This involved very extensive cross-section work back from the direct river bank, in a search for the highest land. Also, before any final decision could be reached as to the head- and tailwater elevations permissible at the Du Bonnet site, full detail data were necessary covering the entire reach of the river down to Pine falls, and up to and including the shores of Lac du Bonnet.

In addition to the extensive work which was required in the vicinity of the Du Bonnet falls, the balance of the field data secured along this reach consisted principally of a contour survey of the river banks between the various falls, and of detail cross-sectioning and sounding at the falls and wherever there was prospect of future construction. This detail included the two McArthur falls, the Du Bonnet group, the Whitemud, the Slave, and the Pine falls. During this season also, a reconnaissance survey was made along the shores of Lac du Bonnet. Some realization of the conditions under which this work was carried on is conveyed by the statement that during January and February there were thirty-four days during which the temperature never rose above zero, and eighteen days during which the temperature never rose above  $10^{\circ}$  below zero. Extreme temperatures of  $20^{\circ}$ ,  $25^{\circ}$  and  $30^{\circ}$  below were common. The remainder of the winter was of similar severity, but, notwithstanding, there were no days in which outside work was not carried on.

As fast as the field work was completed, it was plotted in the camp, and traced on standard-sized sheets 30 by 37 inches, reproductions of which accompany this report. This immediate plotting on the ground was greatly aided by the loose-leaf system of field notes adopted throughout the work. Standard-size leather covers, with 5-inch by 8-inch fillers, suitably printed and ruled for transit, stadia, and level work, were provided. The great flexibility of the loose-leaf system proved of outstanding advantage to the rapid and efficient carrying on of the work, more especially as the results were being plotted into final shape as rapidly as the notes were available. The loose leaves also lent themselves most readily to a simple filing system, in which the records of the survey could be properly grouped, and be at all times available for instant reference.

The field work for this lower section of the river was practically completed by the middle of April, 1912, and the party was moved to the Point du Bois power plant, in order to commence the detailed work required from that point down the river. Pressing questions arising in the department in connection with this reach called for first-hand information, and made it the next section of the river requiring urgent attention. The survey work was similar to that on the lower reach, contours of the banks being secured, with detail work at the Eight Foot and the Slave falls. The work was at this stage continued down the river to Sturgeon falls, which point was reached early in July. The party worked from a movable tent camp headquarters, transport being secured by means of canoes.

Towards the end of July it became necessary, in the interests of departmental work, to transport the Winnipeg River party and outfit to the Grand

Rapids on the Saskatchewan river, for the purpose of there carrying out similar power investigations. This work was not completed until about the middle of October, and it was the 23rd of this month before the Winnipeg River survey was recommenced.


The Winnipeg field work was restarted from the McArthur falls, and continued up the western shore of Lac du Bonnet to the Winnipeg City bridge, after which it was continued from the falls around the shores of the lake and up the Pinawa channel. At all points, the bank contours were secured, and the low-lying sections and muskegs traced. Along the western shore of the lake, this involved rather extensive exploration work as the land is low-lying and adjoins an extensive muskeg, of which limits have never been definitely ascertained. Its mean elevation in the vicinity of the lake is 829. This forms a limiting feature in the power investigations, which is fully discussed herein in the section dealing with the McArthur power site.

Further detail work along the Pinawa channel was stopped for the time being at the city bridge, which point was reached on February 3, 1913, work having been proceeded with throughout the winter season as in the previous year. From this point, a traverse line was run along the city tramway and tied in to the detail work on the main channel, completing the closure.

The field work was then continued up past the town of Lac du Bonnet, and along the Seven Sisters reach. The usual bank contours were secured, and detail soundings obtained at the falls and rapids. At the head of the reach, the three diversion weirs and the control dam of the Winnipeg Electric Railway Company were tied in. The numerous islands and structures in this vicinity necessitated a considerable amount of traverse work, and occupied the party until the middle of July.

From the head of the Pinawa channel, the survey was carried down to the street railway company's plant, and united to the work which had been carried up to this point in February. All the company's plant and buildings were carefully tied in to the power survey lines. This work was finished by the end of August and, for the time, completed the regular survey of the river.

At this stage, the entire river banks from Pine falls to the city of Winnipeg plant at Point du Bois, with the exception of one small gap, had been completely contoured, and the sites detailed. The unclosed gap consisted of about 6 miles of river extending from a short distance above the diversion weirs to the Sturgeon falls. The information along this reach was not immediately necessary, and was left to a more convenient season, the power party being more profitably used in securing additional sections and soundings, etc., at points where the office studies had shown the same to be necessary. The gap was closed the following year, in order to complete the series of topographic sheets, and at the same time further and more accurate data were secured respecting the higher contours along the Pinawa channel. The complete series of topographic sheets, Nos. 1 to 50 accompany this report, and depict the field data secured. Plate 4 is a key plan of these topographic sheets, and illustrates the reach of river covered. Sheets 51, and 55 were plotted in Ottawa, and are based on land survey field notes. They depict the flooding caused by the construction of the municipal power plant of the city of Winnipeg at Point du Bois.



The completion of the survey work to the electric railway company's plant finished that portion which was essential to the preliminary power studies. The field work, as it was completed, was compiled and plotted as rapidly as possible, those portions which were most urgently required being given first consideration. This plotting was carried on under Mr. McLean's direction in the Winnipeg office after the removal of the headquarters to that city in April of 1912, at the time of the organization of the Manitoba Hydrographic Survey. The finished tracings, on standard sheets, were forwarded to Ottawa as completed, where immediate study was given to a scheme of comprehensive power development.

In this study, the writer collaborated constantly with Mr. J. B. McRae, and the results are incorporated in the plans and text following.

Preliminary studies for the determination of the points of power concentration indicated that these would be placed at the Second McArthur, the Little du Bonnet, and the Pine falls, while the natural drop below the Point du Bois plant could be concentrated at the Slave falls. Tentative layouts were designed for these sites, and general conclusions were drawn as to the feasibility and efficiency of the same.


Before final designs or estimates were proceeded with, the writer made a further inspection trip along the river, in order to examine the actual selected sites, and to determine whether the detail of the ground was wholly suited to the layouts proposed.

This inspection trip was made in September, 1913, and the Pine, Du Bonnet, and McArthur sites were visited, together with such other points on the reach as the office study of the field plans had indicated as requiring inspection. The information secured served to confirm the preliminary conclusions which had been reached. Further detail work was outlined on the ground to ensure additional accuracy in the estimates and to the location of the shoreline and rock outcrop in the immediate vicinity of the proposed plants.

This reconnaissance also included the Seven Sisters reach, in which two concentrations were necessary. The general location of these two sites was tentatively pre-determined from a study of the uncompleted field plans, and it was possible to study the ground forearmed with a fair idea of the final scheme of development, and of the particular features and localities which required close investigation in connection with the same.

The receipt of the further detailed data, secured as a result of this inspection of the proposed sites, permitted immediate and aggressive work on the final designs and layouts, the results of which are submitted herein. The points of power concentration are shown in profile on plates 5, 6, and 7.

While the power survey was being prosecuted, steps were taken towards securing and collating the further data pertinent to the investigation. Continuous meterings were secured at the cable station at Slave falls, and the results obtained were combined with prior records secured by the engineers of the city and of the electric railway company. A careful rating was made of the Pinawa channel, and a continuous record of its discharge secured. The importance of the Lake of the Woods to a storage system for the river was recognized from the commencement of the investigations, and particular care has been exercised to secure a reliable record of the run-off. Metering stations were



Department of the Interior, Canada  
 Geological Survey of Canada  
 Water Power Branch  
 Ottawa, Ontario



# WINNIPEG RIVER POWER SURVEY

## PROFILE OF WINNIPEG RIVER

FORT ALEXANDER TO LAC DU BONNET  
 SHOWING PROPOSED POWER CONCENTRATIONS

Note: Water levels were taken between the 27<sup>th</sup> and the 31<sup>st</sup> of May 1914, during which period the discharge at Silver Falls rose from 17,000 to 4,800 C.F.P. per Sec.  
 Distances in feet are measured from the original profiled plane of the Winnipeg River, zero being at B.M. 1917.  
 Elevations are referred to Mean Sea Level datum obtained from the C.P.R. at Lac du Bonnet.

*J. J. ...*  
*...*








# MICROCOPY RESOLUTION TEST CHART

(ANSI and ISO TEST CHART No. 2)



APPLIED IMAGE Inc

1653 East Main Street  
Rochester, New York 14609 USA  
(716) 482-0300 - Phone  
(716) 288-5989 - Fax

Th  
 finished  
 field wo  
 those pr  
 This pl  
 office af  
 time of  
 tracings  
 immedi

In  
 and the

Pre  
 tion ind  
 du Bonr  
 plant co  
 for the  
 efficiency

Beft  
 further i  
 sites, an  
 the layo

This  
 and Mc/  
 as the of  
 informat  
 been rea  
 tional ac  
 outcrop i

This  
 concentra  
 tentative  
 was possi  
 of develo  
 close inve

The r  
 of the pr  
 designs a  
 of power

While  
 securing a  
 tinuous n  
 results of  
 the city ar  
 Pinawa ch  
 ance of th  
 from the  
 exercised :

[

Department of the Interior, Canada  
 MINISTÈRE DES TERRES ET DES FORÊTS  
 Water Power Branch  
 Ottawa, Ontario

## WINNIPEG RIVER POWER SURVEY


### PROFILE OF WINNIPEG RIVER


LAC DU BONNET TO POINT DU BOIS  
 SHOWING PROPOSED POWER CONCENTRATIONS

PROPOSED POWER CONCENTRATIONS  
 SHOWING PROPOSED POWER CONCENTRATIONS


Notes: Water levels were taken between the 1<sup>st</sup> and the 13<sup>th</sup> of May, 1914 during which period the discharge at Seven Falls varied from 17,000 to 12,000 cu ft per sec.  
 Distances in feet are measured from the original plotted plans of the Winnipeg River, zero being at S.M. 407.  
 Elevations are referred to Mean Sea Level Datum obtained from the CPR at Lac du Bonnet.


Legend: Continuous Profile Water Surface  
 Maximum High Water  
 High Bank Contours  
 Proposed Spillway Level  
 Rock Bottom





IN FEET





Department of the Interior, Canada

PROJETS DE LA RIVER AND STORAGE INVESTIGATIONS  
 Water Power Branch  
 W. J. JOHNSON, S.A.S.

# WINNIPEG RIVER POWER SURVEY


## PROFILE OF PINAWA CHANNEL

TO ACCOMPANY REPORT ON POWER AND STORAGE INVESTIGATIONS  
 BY W. J. JOHNSON, S.A.S.

*W. J. Johnson*  
 S.A.S.  
 Water Power Branch  
 Dept. of the Interior, Canada


*W. J. Johnson*  
 S.A.S.  
 Water Power Branch  
 Dept. of the Interior, Canada

NOTE: Water levels between 0 and 50,000 were taken during the winter months of 1911. Water levels from 50,000 to 60,000 were taken during the open season when the flow is approximately in form of about 10,000 to 15,000 cfs. Distances between measurements on the drawings of the topographic sheets, zeroed on the North-South line of Sec. 25, 16, 10, T. 1 P. Elevations are referred to Mean Sea Level as obtained from the L. M. Atter du Bonnet.



7. 1933) were taken  
 4. 911  
 to 300 ft were taken  
 on the 100 ft is  
 about 100 ft Set. F  
 1911. 1911. 1911. 1911.  
 sheets. 1911. 1911.  
 Set. 25. 1911. 1911.  
 Mean Sea Level. Datur  
 ar du Brunet

Genl. Continuous Profile Water Surface  
 Maximum High Water  
 High Bank Contours  
 Rock Bottom  
 Bench Marks



e  
r  
r  
a  
s  
a  
c  
i  
a  
r  
  
V  
h  
  
a  
s  
M  
M  
h  
to  
d  
s  
a  
t  
to  
  
E  
E  
o

established at the lake outlets in June of 1912, and a most complete series of measurements obtained. These have been co-related with pre-existing gauge records so as to secure a discharge record from 1907 to date.

Wherever possible, continuous records of the water level were secured at points where such information was of value to the power studies. The sparse settlement along the river banks made it difficult to secure gauge readers at all points desired, and this has, to a certain extent, delayed the gathering of certain data which are required to definitely calculate the working conditions in certain reaches. This deficiency is, however, being made good as rapidly as possible, and the information will be available long before it is urgently required in connection with plant operation.

A well-equipped evaporation station was established on the Lake of the Woods near the outlets, and valuable records of the meteorological conditions have been secured.

This summary of the field investigations should not be closed without due acknowledgment of the very efficient and hearty co-operation of the entire field staff of the Manitoba Hydrographic Survey who, under the direction of Mr. D. L. McLean as chief engineer during the early stages of the work, and of Mr. M. C. Hendry during the later stages, gave their services loyally and wholeheartedly to the success of the investigation. Special reference should be made to Mr. S. S. Scovil, assistant chief engineer throughout the greater portion of the investigation, and acting chief for a considerable period, under whose immediate supervision a large part of the field work, particularly in respect to the storage and run-off studies, was conducted. Mr. Scovil's energetic direction, aided by his personal knowledge of the entire district, due to his long residence therein, has been invaluable, not only to the success of the field survey but also to the compilation of this report.

Special mention should also be made of the services in the field of Messrs. E. B. Patterson, W. J. Ireland, S. C. O'Grady, and A. M. Beale; also of Mr. B. E. Norrish, chief draughtsman, in connection with the preparation in this office of the plates illustrating this report.



REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

CHAPTER III.  
METEOROLOGICAL PHENOMENA AND  
RUN-OFF



## CHAPTER III.

### METEOROLOGICAL PHENOMENA AND RUN-OFF.

#### TEMPERATURE.

In a study of hydro-electric development possibilities, the question of temperature conditions must receive careful consideration, particularly in respect to the effect of the same on run-off and on plant operation. Throughout the Dominion of Canada, this phase of power investigation is exceptionally necessary, in view of the low temperatures to be counted on in certain localities during the winter months.


Plate 8 provides a convenient means for comparing the general temperature conditions obtaining in the Winnipeg River watershed, with temperature conditions in other parts of the country. On this plate are plotted the mean maximum monthly and the mean minimum monthly temperatures at Vancouver, Calgary, Winnipeg, Toronto, Montreal, Quebec, St. John, and Halifax. These cities are scattered from the Pacific to the Atlantic coasts, and provide representative points to which the Winnipeg temperatures can be readily compared. The Winnipeg records are sufficiently representative of the temperature conditions on the Winnipeg power reach (some 65 miles distant) for comparative purposes.

Temperatures for two years, 1906 and 1907, are shown, these two years representing, respectively, winters of the more severe and of the milder type in the West. It will be noted that Winnipeg and Calgary are subject to more extreme temperature conditions than are the other cities listed.

The Meteorological Service of Canada is obtaining temperature records throughout the Winnipeg watershed at Dryden, Ignace, Kenora, Rainy river Shoal lake, and Sioux lookout. Fifteen years' observations have been taken at Kenora, and one year at each of the other points. Forty years' records have been secured in Winnipeg. For convenient reference the daily temperature records at Winnipeg for the years 1912 and 1913, and the comparative monthly records at Winnipeg and Kenora for the years 1906 to 1914, inclusive, are attached as tables 48 and 49, respectively, in Appendix VI.

Reference to the tables indicates that the yearly temperature at Winnipeg averages a few degrees higher than at Kenora. The temperatures recorded on the Winnipeg River power reach should not vary to any great extent from the records at these two stations. Winter temperatures of 40 degrees below zero are to be expected in this region, while severe conditions may continue over considerable periods, as is instanced by the month of January, 1907, where the mean temperature for the month was 11.4 degrees below zero, and the average of the minimum daily readings was 21.6 degrees below zero.

## COMPARATIVE TEMPERATURE RECORDS



Relative temperature records at typical points throughout Canada.


Upper Curve:- Mean monthly maximum temperature.

Lower Curve:- Mean monthly minimum temperature.

## INFLUENCE ON RUN-OFF.

The influence of temperature on the run-off of the Winnipeg during the winter season cannot be fully dealt with at the time of writing. The majority of the continuous discharge records available are more or less influenced by storage in the lake of the Woods and in Rainy lake, which, to a certain extent militates against securing records showing the direct relation between temper-

ature range and river discharge. The installation of automatic gauges, ensuring continuous and accurate surface-level records at vital points, will probably remedy this, and render possible a determination of that direct influence which is so much in evidence in the prairie rivers. In comparison with these latter



ivers, the relation between temperature and run-off is largely modified on the Winnipeg, due to the character of the watershed and to the vast number of lakes with which it is supplied.

On plate 9 are plotted the discharge records at Chaudiere falls (Kettle falls) from August, 1912, to June, 1913. These records cover the run-off from

an, at that time, unregulated portion of the basin. With them are plotted the mean daily temperature records at Kenora. It is evident, from a comparison of the curves, that there is no direct daily connection between the temperature and the run-off through the summer months. It is probable, however, that were automatic gauge and temperature records available for this period, a distinct relation would be noted during the winter season. It is apparent, that any such relation as may exist is not to any great extent detrimental to power plant operation on the main river, in so far as the run-off is influenced. The natural balancing reservoirs in the basin are of sufficient capacity and so well distributed as to modify immediate temperature influences.

Temperature has, however, its usual influence in this latitude, in that the periods of minimum flow are to be looked for during the winter season. Reference to the mean monthly temperatures and run-offs on plate 9 plainly shows this connection.

While the low winter temperatures have the effect of lowering the winter discharge, the excellent natural reservoir system provided by the innumerable lakes, effectually prevents the extreme low flows which are experienced in rivers in this region not provided with headwater lakes. The minimum low flow recorded to date is 11,700 cubic feet per second. While this is influenced by the artificial regulation in the Lake of the Woods and Rainy lake, the influence of the natural lakes is also very evident. The Whitemouth river, tributary to the Winnipeg just below the Seven Sisters falls, drains some 1,400 square miles of watershed, almost wholly deficient in lake area. The minimum flow recorded to date is 15 cubic feet per second. This is particularly illustrative both of the influence of the low winter temperature on the run-off, and also, by contrast, of the benefits which, under these conditions, accrue to a basin well supplied with natural reservoirs.

Apart from the influence of low temperature on the run-off is the question of ice troubles in plant operation. Where the winter run-off is as dependable as is that of the Winnipeg, this question becomes the more important of the two.

#### ICE CONDITIONS ON THE WINNIPEG RIVER.

In a country where the prevailing temperatures are as low during the winter season as in Canada, the most careful attention must be given to the proper protection of hydro-electric installations from ice troubles. This is particularly the case in the western provinces east of the Rocky mountains, throughout the section which is now being rapidly settled, and where hydro-electric development is being aggressively prosecuted.

The troubles, which have been experienced in the past in connection with the operation of power undertakings in northern latitudes, were for a long period considered a necessary evil and a prevailing condition beyond hope of permanent remedy, and only to be met by the yearly employment of local help in blasting and ice-cutting operations. The fact, however, that certain plants were comparatively free from ice troubles, while others were practically closed, under and following certain temperature conditions, proved an incentive to a

closer study of the actual underlying causes and processes of ice formation. Many papers have been prepared and books compiled on this interesting subject, the most authoritative being probably that on "Ice Formation" by Prof. H. T. Barnes, Associate Professor of Physics, McGill University, Montreal.

Following this recent fuller appreciation of the underlying causes of ice troubles, the construction of hydro-electric undertakings, in climates where extreme winter conditions prevail, in such a manner that their successful operation throughout the cold season is assured, has largely become a matter of proper forethought and care in location, layout, and design. The successful and uninterrupted operation of the Point du Bois plant of the city of Winnipeg on the Winnipeg river, throughout the past three winter seasons, is sufficient assurance that no adverse ice troubles need be anticipated in connection with the development and operation of the projected sites on the river, providing proper foresight is displayed in their design and construction.

In this report it is not intended to give any detailed study to the origin of and protection against ice troubles in hydro-electric development. In view, however, of the conditions which must be encountered in power-plant construction and operation along the Winnipeg river, it is considered advisable that a general synopsis should be given of the troubles to be anticipated and of the measures which have been taken to eliminate the same.

It is intended to refer only briefly to the three varieties of ice which affect power plant construction and operation, i.e., sheet ice, frazil ice, and anchor ice, with particular attention to the conditions tending to and produced by their respective formation, and which are found and may be anticipated along the Winnipeg river. Reference to the preceding section dealing with the winter temperatures of the Winnipeg basin will disclose the extreme conditions which prevail and which must be combated.

*Sheet Ice.*—What is commonly known as sheet ice is the ordinary ice covering of ponds, quiet rivers, and protected waters of all descriptions. In its formation and continuance throughout the winter season it has no direct adverse influence on power-plant operation. On the contrary, a broad sheet of ice cover above a power station is directly beneficial to its successful operation, in that it forms a protective covering which prevents the local formation of frazil and anchor ice. The, at times, adverse influence of sheet ice in connection with hydro-electric development is of two natures; first, the pressure exerted on permanent structures; and, second, the combined effects of floods and ice jams during break-up in the spring.

Much has been written and many divergent views expressed regarding the nature and intensity of ice pressure as developed in the formation of sheet ice on lakes and reservoirs. Ice, after its formation is still subject to expansion and contraction accompanying a rise or fall in temperature. The contraction due to lower temperatures results in cracks throughout the ice cover. These cracks at once fill with water from below which freezes and renews the continuous ice sheet. A rise in temperature causes the whole mass to expand with a resulting pressure which must find relief. The extreme limit of pressure would, of course, be found in the crushing strength of ice. Such a condition, however, need not usually be anticipated on a reservoir or pond surface. Relief may be found in

several ways, according to the locality; sloping and shelving shore lines permit the ice sheet to slide or push its way beyond the limits of the water surface. The effects and, in fact, the actual operation of this action can be frequently observed along the borders of large ponds and lakes where long ridges of gravel, boulders, and masses of rock, frequently of surprising size, are formed by the ice push. Wide expanses of water surface, with abrupt shore lines preventing the above action, find relief from ice compression by the buckling or, at times, crushing of the ice sheet.

The general conditions which tend to endanger from ice thrust, permanent structures, such as dams, etc., are found in narrow waters, where the ice is confined between the structure on one side and an abruptly vertical shore line on the other. In such cases there is an undoubted and heavy thrust, acting horizontally against the face of the structure at water level. A heavy ice covering freezing solidly to the face of a dam, followed by a lowering of water in the reservoir also produces strains of magnitude and character dependent on local conditions. A rise in the water level in cold weather following the conditions produced by the above drop, undoubtedly results in a strong leverage thrusting against the dam.

Among other causes of ice pressure might be mentioned the action of winds on ice cover. Ice thrust and movement from this source is frequently very marked. Conditions seldom lend themselves, to the full concentration of such pressure on dams and permanent works; irregular shore line, islands, etc., usually mitigating the same.

An overflow dam, so long as it acts as such, does not experience the above adverse influences from ice cover, since, while there is sufficient overflow, the ice will not attach to the crest. Non-overflow dams, retaining walls, and embankments will, however, experience ice thrust under the climatic conditions of the Winnipeg river, where local measures of relief, whether natural or artificial, are not available or applied. Cutting the ice along the face of the dam is frequently resorted to in order to relieve pressure of this nature.

No hard and fast rule can be laid down fixing a definite ice thrust which must be anticipated and allowed for in the design of dams located in extreme climates. The Board of Experts commissioned in 1884 to design the proposed Quaker Bridge dam on the Croton river, in connection with the water supply of New York city, advised that an ice thrust of 43,000 pounds per lineal foot at the highest ice line should be provided for. This recommendation was not adopted in the actual construction of the dam, which was finally built at a site 3 miles farther up stream, under the name of the New Croton dam. The recommendation has, however, been frequently quoted in discussion on safeguarding against ice thrust. The Wachusett dam, built in Massachusetts in 1900 to 1906, was designed to withstand an ice pressure of 47,000 pounds per lineal foot at the highest ice line. Other ice thrusts which have been allowed in the design of dams actually built in recent years are: Croton Falls dam in the Croton watershed, 30,000 pounds; Cross River dam, also in the Croton watershed, 24,000 pounds; Olive Bridge dam, New York state, 47,000 pounds; Kensico dam, New York state, 47,000 pounds.

The above dams were all of the reservoir, non-overflow type, and the variation in ice pressure allowed was due to variation in local conditions as affecting the use and operation of the reservoirs, and as resulting from the location.

The proposed dams along the Winnipeg river are of a combined free spillway and sluice control type. It is intended that the reaches shall be maintained by sluice control at regulated level throughout the year, and that the spillway shall come into use only as a safeguarding measure, in caring for sudden or extreme floods. Under these conditions, the ice cover will attach itself to the crest and face of the dam at pond level. A thickness of from 2 to 3 feet of ice may be counted on in the undisturbed reaches of the Winnipeg river, where the ice cover has not been protected by a snow covering. In general, the dams will not be subject to extreme adverse ice thrust conditions. No general rule can be laid down as establishing a uniform safety factor to be applied to the design of the structures. Local conditions, as affecting each site, can only be studied individually, and corresponding precautionary measures adopted. The general question of ice thrust must, however, be given careful consideration in the design of the proposed power stations, and contingent structures.<sup>1</sup>

The break-up of the sheet ice in the spring is frequently the cause of inconvenience and sometimes of disaster in power-plant operation. In a river where large blocks and masses of ice, together with other miscellaneous drift, are carried down stream in flood time, there is always a tendency towards the formation of ice jams, with a consequent backing up of water until the increasing pressure bursts the obstruction, and the whole mass is discharged down stream. Such conditions are the frequent cause of the destruction of bridges, dams, and other obstructions in the natural stream bed. Jams below a power station have the adverse affect of raising the tailwater and of possibly flooding out the plant.

The Winnipeg river does not, however, give rise to conditions favourable to the formation of ice jams. The river, as a whole, consists of large lake-like expanses, with deep water and practically no current, connected to each other by abrupt falls or short stretches of rapids. In the spring the ice on these reaches as a rule slowly melts and disappears. Where ice breaks away and discharges over the falls and rapids it is not generally in sufficient mass to form a jam. The slow rise of the spring flood also has a tendency to reduce the liability to ice-jam formation, and to assist in the quiet melting and disposal of the ice cover.

After the construction of the proposed system of hydro-electric plants, the present excellent conditions in this respect will be greatly improved. Above each site there has been provided a large expanse of pondage, extending frequently many miles up stream. The finally completed system will transform the river into a series of ponds or lakes, with the falls and rapids totally flooded out. These pondages, both collectively and individually, will do away with any slight tendencies which may at present exist towards the formation of jams.

<sup>1</sup> An interesting discussion on the question of ice thrust in relation to the design of dams is to be found in the Transactions of the American Society of Civil Engineers, volume lxxv, 1912, wherein are submitted the opinions of several widely known engineers.

*Frazil ice.*—Frazil ice or, as it is sometimes called, slush ice has a much more direct bearing on water-power plant operation than has sheet ice. It is a surface-formed ice, its formation occurring in open channels where a too swiftly flowing current prevents the formation of an ice cover. While a smooth surface permits the formation of frazil ice in the form of thin plates, an agitated surface offers much more favourable conditions. This disturbance may be caused by wind action. It is always present to excess in rapids and falls. The ice itself under these conditions forms in fine needle-like crystals, which grow and accumulate with great rapidity when weather conditions are favourable.

The combination of long periods of intense cold with the disturbed water in the rapids and falls of the Winnipeg river, offers ideal conditions for frazil-ice formation. These conditions are, however, largely counterbalanced by the extensive ice-covered reaches.

Throughout the winter season, vast quantities of frazil are formed in the falls along the river, and are carried down stream and lodged beneath the ice sheets which are practically always found below. This condition was very evident in the soundings taken along the lower reach of the river by Mr. B. E. Norrish, an engineer of the department, during the winter of 1909-10, prior to the organization of the survey. Deposits of slush ice beneath the ice cover were found below all falls and disturbed stretches of open water. In places, these deposits were from 25 to 30 feet in depth, and there is every reason to suppose that greater depths were reached where conditions for formation and accumulation were favourable. The natural result of this condition was a blocking of the river channel, with a consequent rise in the water level above. This condition was particularly observed below the Little du Bonnet falls, where the accumulations of frazil ice resulted in a rise of several feet in the water level. This slow rise would continue until the rising head was sufficient to clear out the accumulations and to open an under-ice channel, and permit normal flow conditions to resume, after which the gradual choking up would again commence. Under-ice deposits of the above nature were met from a quarter to half a mile below the various falls.

That this frazil ice may prove extremely detrimental to satisfactory plant operation is illustrated in the Pinawa channel of the Winnipeg river, where, in certain reaches, a narrow and winding channel with rapid current prevents ice cover forming, and is particularly favourable to the production of frazil ice during periods of extreme cold. The deposition and accumulation of these frazil crystals on the under surface of the sheet ice in the quieter reaches at times assumes large proportions and frequently partially blocks the river channel, necessitating constant vigilance and frequent resort to blasting operations in order to clear both the approach to and the discharge from the power station. It might be repeated here, however, that the Pinawa channel differs in character from the main channel of the Winnipeg river.

*Anchor ice.*—Although the two terms, anchor ice and frazil ice, are frequently used indiscriminately, the two varieties are entirely distinctive in source, although in some respects they may, after formation, possess somewhat similar characteristics. Differing from frazil ice, which is surface formed, anchor ice has its origin and growth on the stream or river bed at depths seldom exceeding 30 or 40 feet. While turbulent water and low temperature always favours the formation

of frazil crystals, irrespective of other conditions, a smooth water surface exposed to a clear sky, combined with low temperature, forms the ideal conditions for the formation of anchor ice. From Professor Barnes' comprehensive work on the subject, it is apparent that radiation is the prime cause of anchor-ice formation. A clear calm night, with little or no air currents, is particularly conducive to radiation, and on such nights the formation of anchor ice goes on rapidly. A cloudy night is never accompanied by anchor ice formation. A bridge cover will prevent the ice forming in the river bed beneath, whereas on the same night on the stream above and below, large masses accumulate. Sunshine and a clear sky counteracts radiation by day, and not only prevents new anchor ice forming, but loosens the masses previously formed, causing them to rise



Ice Conditions on Pinawa Channel.

to the surface, often carrying with them boulders of surprising size. In short, anything which is conducive to the radiation of heat from the river-bed to the colder air above will tend to the formation of anchor ice, while anything which interferes with or cuts off such radiation immediately stops or tends to stop its formation. Frazil ice, after depositing on submerged structures, or on masses of anchor ice, becomes for all practical purposes of the same nature as anchor ice, and it is this circumstance which leads to the common confusion of the terms. Anchor ice is, however, granular in structure, and readily distinguishable from frazil.

*Effects of frazil and anchor ice on power plant operation.*—Where conditions are favourable to the formation of frazil crystals, the question of power station operation must receive careful consideration. Frazil is a much greater menace to successful winter operation than is anchor ice. The crystals attach themselves most readily to heat-conducting structures. Among the most vulnerable

parts of a station in this regard are the racks. Here the metal, more especially where it projects above the water surface into the cold outside air, forms a ready surface for the accumulation of ice crystals, with a consequent partial or complete closing off of the water from the turbines. This is, at times, accompanied by the collapse of the racks, due to the pressure of the headwater. The gates are also objects of attack, as are also the wheels themselves. The accumulation of ice masses in the wheel pit has frequently been the cause of the complete blocking of the turbines, and the consequent closing down of the plant.

Various remedies have been applied to combat conditions of the above nature. These remedies have, as their basis, the application of heat to the parts affected, i. e., to the racks, gates, and turbines. The success which has fol-



Ice Conditions below Du Bonnet Falls.

lowed such experiments is founded on the fact that the raising of the temperature of the racks and parts affected by even one-thousandth of a degree, will prevent the initial attaching of the ice crystals, and their consequent accumulation.

In the layout of new plants in localities where the winter conditions are such that frazil and anchor ice are to be anticipated, forethought in the design will largely mitigate, and frequently entirely prevent, ice troubles. In the layouts of the proposed plants along the Winnipeg river, care has been taken to provide conditions in all respects unfavourable to the formation of either frazil or anchor ice. The extensive ponds provided will form an ice sheet sufficiently extensive to not only prevent the formation of the ice in question, but also to arrest and accumulate on its under surface any frazil which may be formed in undeveloped rapids or falls above. In general, the wheels draw water direct and undisturbed from the pond without an intervening head-race, and where such has been necessary, easy curves and ample sections have been provided in order that a quiet and undisturbed current may reach the

racks. The ice cover of the pond will in all cases reach to the protecting curtain along the face of the racks.

Under these conditions, no ice troubles need be anticipated. This is abundantly proved by the successful winter operation of the municipal plant of the city of Winnipeg at Point du Bois on the same river. No ice troubles of any description have been experienced here during the three winters in which the plant has been in operation.<sup>1</sup>

#### PRECIPITATION.

A study of the rainfall records of any watershed is at all times interesting, more particularly in regard to the relation between the precipitation and the run-off. Where actual discharge records are not available, precipitation records will often afford a basis upon which run-off may be deduced. Such calculations must, however, be approached with caution. While the relation between the precipitation and run-off is direct, the deduction of its exact ratio necessitates much more accurate and more comprehensive data than are generally available. Stream run-off is influenced by so many complex conditions apart from precipitation such as: nature of soil, slope of surface, area and configuration of catchment basin, geologic structure of basin, forests, winds, evaporation, etc., that an arbitrary deduction as to the run-off, based on some general and average ratio already established in more or less similar basins, is liable to result in considerable error. This is particularly the case in endeavouring to establish, from precipitation records alone, the extent and duration of minimum flow in connection with hydro-electric power studies.

In view of the numerous conflicting conditions which influence the run-off from any particular watershed, it may be assumed that until the ratio between the precipitation and run-off has been definitely established by careful and prolonged observation, backed by actual records and comprehensive data, any deductions which may be made as to the relation existing must be considered as more or less approximate. It is recognized that, in this relation, every stream is a law unto itself.

In the Winnipeg River basin there are sufficient continuous run-off records available to permit of a fairly satisfactory study of the discharge conditions, and dependence on the precipitation records is not therefore necessary.

#### RECORDS AVAILABLE.

Within the Winnipeg River watershed, precipitation records have been secured by the Meteorological Service of Canada at Dryden, Fort Frances, Ignace, Kenora, Sioux Lookout, and Savanne. Of the above stations, two only, i.e., Kenora and Savanne, extend over a series of years. Kenora, located at the outlet of the Lake of the Woods, furnishes records from 1900 to date, and Savanne, located near the eastern limit of the watershed, from 1886 to 1906. These records are neither of sufficient extent nor sufficiently widespread to permit a study of precipitation and run-off phenomena.

More prolonged series of precipitation records are available at points a short distance outside the limits of the basin. At Winnipeg, records have

<sup>1</sup>For a full and complete study of the question of ice formation, the reader is referred to the book of "Ice Formation" by Howard T. Barnes, M.A.Sc., Associate Professor of Physics, McGill University, Montreal.

**DOMINION WATER POWER BRANCH**  
**J. B. CHALLIES Superintendent**  
**PRECIPITATION IN WINNIPEG RIVER WATERSHED AND VICINITY**


To accompany a report on  
**POWER AND STORAGE INVESTIGATIONS**  
 by J. T. JOHNSTON B.S.C.

Precipitation in inches

March 1st 1910




Annual Precipitation of Winnipeg




Mean Monthly Distribution

Precipitation in inches

Mean for period 1874-1913 21.50 in.




Annual Precipitation at Winnipeg




Mean Monthly Distribution

Precipitation in inches

Proportionate Mean 1874-1913 25.70 in.




Annual Precipitation at Savanna




Mean Monthly Distribution

Precipitation in inches

Proportionate Mean 1874-1913 23.98 in.



Annual Precipitation at Port Arthur



Mean Monthly Distribution

been secured since 1874. At Port Arthur, on lake Superior, records are available since 1877. For convenient reference, these records, together with those for Kenora and Savanne, are represented on plate 10, and are tabulated in table 59, Appendix VI.

It is not intended in this report to attempt any analysis of the ratio existing between precipitation and run-off in the Winnipeg River basin. The precipitation data available are not sufficient to permit of other than the most general deductions being drawn, while the run-off data on hand have been largely influenced by artificial conditions of storage. The above records are, however, published as of general interest to the subject-matter covered in this report.

#### EVAPORATION.

Evaporation usually, but not always, forms the greatest source of loss to the run-off from any watershed. The rate of evaporation differs widely in



Evaporation Station on the Lake of the Woods.

different climates, and varies also with different classes of vegetation and with different classes of land surface. It is practically impossible to secure an accurate estimate of what precipitation loss is due to evaporation over a drainage basin as a whole, owing to the other losses by percolation and seepage. It is possible to secure a reasonably close estimate of the loss due to evaporation from open-water surfaces. This is particularly pertinent to the Winnipeg River watershed, where so large a proportion of the basin is lake area.

In order to secure definite data as to the rate of evaporation from water-surface area in the Winnipeg River watershed, an evaporation station was established on the Lake of the Woods in the vicinity of the town of Keewatin. This station is centrally located in the western portion of the Winnipeg basin, and in view of the lake being by far the largest and most important of the

regulating reservoirs, it furnishes data which are of particular interest to the general storage question.

#### EVAPORATION STATION.

The evaporation station was established on May 1, 1913, the equipment consisting of one galvanized evaporation tank, with brass pointer and measuring cups; one Howard rain gauge; one thermometer for water temperatures; one recording thermometer; one recording barometer; one wind gauge of the Robertson type; and one hydrometer. This equipment is fitted to record all atmospheric phenomena which will affect the extent of evaporation, as well as to measure its actual rate.

The tank is of galvanized iron and is 35 inches by 31 inches by 18 inches deep, braced externally by diagonals of 1 inch by 1 inch galvanized angle iron riveted to the tank. The sides are turned over at the top to form a 3-inch lip in order to prevent the inflow of wave wash. In the centre of the tank, and soldered to the bottom, is a brass pointer 14 inches in height. The tank is supported on a raft consisting of four 4-inch by 4-inch by 16-foot timbers spiked together at the corners. The supports in the centre of this raft are 2-inch by 10-inch timbers placed parallel on either side of the tank, and capped by 2-inch by 4-inch timbers to catch its edge. The raft is fastened to the shore, but is free to move with the waves. The rain gauge is supported by a 2-inch by 10-inch plank spiked to the raft. Plate 11 illustrates the installation.

The recording thermometer and barometer are placed in a suitable shelter, close at hand. The wind gauge has been placed on the top of the Lake of the Woods Milling Company's Mill C, about one-half mile from the raft.

#### RECORDS AVAILABLE.

Continuous records of evaporation and of all pertinent meteorological data have been secured since the establishment of the station in May, 1913. The evaporation observations were, of course, discontinued through the winter season. The complete records available are attached in Appendix VI in table 51.

The comparative evaporation and rainfall in inches for the months May to November, 1913, and April to November, 1914, is appended in table 2.

Table 2.—Comparative rainfall and evaporation on the Lake of the Woods.


Month.	1913.		1914.	
	Rainfall in inches.	Evapora- tion in inches.	Rainfall in inches.	Evapora- tion in inches.
April.....	1	1	1.79	50.51
May.....	1.29	1.36	1.87	0.62
June.....	2.09	2.25	4.67	2.46
July.....	3.84	3.39	3.80	2.78
August.....	4.58	3.42	2.07	3.67
September.....	4.01	4.08	4.07	3.01
October.....	3.34	2.15	3.11	2.66
November.....	1.35	20.53	0.31	41.04
Total.....	17.50	17.18	21.69	16.75

<sup>1</sup> No records secured in April, 1913.

<sup>2</sup> Ice formed on November 7, and evaporation records discontinued.

<sup>3</sup> Evaporation records commenced April 20.

<sup>4</sup> Evaporation records discontinued November 14.



It will be noted that during the seven months listed in 1913 the evaporation loss of 17.18 inches practically equalled the 17.5-inch rainfall. In the eight months listed in 1914, the rainfall exceeded the evaporation by 4.94 inches. The records do not as yet cover a sufficient period to permit of an analysis

of the general evaporation phenomena. From the above, it is, however, apparent that evaporation loss from surface water during the open-water season is a very high percentage of the rainfall, and there is little doubt but that in certain seasons it is in excess of the same. An evaporation loss of 17 inches over the surface area of the Lake of the Woods is equivalent to a continuous discharge of 10,000 cubic feet per second for two and one-quarter months. Considering the extent of the lake area in the watershed, the evaporation losses are therefore high.

The high ratio of evaporation from water-surface area does not of course apply to the basin as a whole. The lack of widespread precipitation data with which to compare the run-off from the basin, prevents the setting out herein of any definite general ratio between the two. The precipitation at Kenora for the years beginning October, 1912, and October, 1913, respectively, was 18.96 inches and 25.01 inches. The run-off for the two calendar years of 1913 and 1914 was equivalent to 6.12, and 6.46 inches over the drainage basin. The balance was mainly lost through evaporation and percolation, the larger part undoubtedly being due to evaporation.

#### RUN-OFF.

Run-off in general is dependent on a variety of conditions of which the controlling features are: precipitation, topography, vegetation, and climate. These features have a paramount bearing on the seasonal limits of maximum and minimum discharge. The seasons of, and the ratio between, high and low water, and the facilities for partially or wholly equalizing the run-off in extreme cases, are phases of preliminary investigation which must receive thorough study and consideration in all water-power investigations. Accordingly, one of the earliest steps taken at the inception of the power and storage investigations in the Winnipeg basin was to secure and collate all existing records of temperature, rainfall, run-off, and water levels, etc., throughout the watershed, while an aggressive campaign was started to augment these by further first-hand records, secured by departmental field officers.

The Manitoba Hydrographic Survey was established in 1912 as a sub-organization of the Dominion Water Power Branch, and as a logical outgrowth of the Winnipeg River power survey work. An aggressive campaign of stream measurement work along the river and throughout the province was at once commenced. During the earlier stages, the power and stream measurement organizations were closely intermingled, and the respective staffs transferred from one survey to the other as the exigencies of the work demanded. As time passed, it was possible to organize a more permanent staff and to place the stream measurement work on a more satisfactory basis. The two surveys have at all times been carried on under the direction of one chief engineer.

The run-off records from the commencement of 1907, which are now available, indicate the exceptionally well-regulated character of the river basin. Under present conditions the highest flood flow in a normal year seldom exceeds four times the minimum, a condition which is vastly different from the rivers of the prairie farther west. Typical of the latter might be mentioned the North

Saskatchewan at Edmonton, where the maximum flow has at times exceeded 180 times the minimum. This favourable feature of the Winnipeg renders it peculiarly adapted to hydro-electric development, and is due to the extensive lake areas with which the larger portion of the watershed is supplied. These lakes form equalizing reservoirs, collecting the surplus waters in times of flood, and gradually discharging the same during the low-water season. Owing to these favourable conditions, the Winnipeg is not subject to sudden or extreme floods, and the question of regulating the various pond levels at the proposed plants presents no difficulties.

Table 3, herewith, illustrates concisely the highly uniform character of the river flow.

Table 3.—Percentage of variation of the flow of the Winnipeg river at Slave falls from the mean flow of the seven-year cycle.

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	Mean.
	Per cent.							
January.....	+ 4.27	+42.63	- 4.17	- 2.30	-42.67	-22.35	+ 8.28	- 2.33
February.....	-11.47	+41.73	- 6.48	- 6.09	-48.63	-34.87	+ 1.12	- 9.24
March.....	-33.00	+21.37	-27.20	- 7.84	-51.53	-46.55	-26.14	-24.41
April.....	-43.55	+10.23	-35.41	+54.33	-52.10	-47.53	-30.98	-20.71
May.....	-37.00	+26.10	-21.48	+104.30	-42.88	-11.81	+ 9.73	+ 3.85
June.....	+ 8.42	+61.05	- 5.01	+88.37	-29.06	+ 8.68	+26.60	+22.72
July.....	+23.85	+66.23	- 4.66	+42.92	-11.43	+ 2.03	+14.11	+19.01
August.....	+21.21	+53.02	- 5.12	- 4.47	+ 1.06	+ 7.18	+ 7.12	+11.43
September.....	+43.66	+38.87	-13.79	-24.09	- 4.04	+13.75	- 2.29	+ 7.44
October.....	+64.47	+27.80	-21.37	-34.24	+ 0.41	+27.91	-29.32	+ 5.09
November.....	+65.07	+ 9.85	-20.83	-44.78	-11.24	+26.15	-39.42	- 2.17
December.....	+52.80	- 9.73	-12.86	-50.03	-25.24	+13.71	-43.07	-10.63
Year Mean.....	+13.23	+32.43	-14.86	+ 9.67	-26.45	- 5.31	- 8.69	

This table is based upon discharges recorded at the Otter and Slave Falls metering stations for the years 1907 to 1913, inclusive, and shows the percentage of variation of the mean monthly discharges from the seven-year mean flow. The largest monthly variation was that for May in the year 1910, when a discharge 104.3 per cent above the average occurred. On the other hand, 52.1 per cent below the average occurring in April, 1911, forms the lowest monthly mean on record. The mean yearly flows show a variation of 32.43 per cent above for 1908, and 26.45 per cent below for 1911.

It is well to note here that the controlled regulation in the Lake of the Woods and Rainy lake has had considerable beneficial effect in equalizing the discharge of the river below Kenora, although such control to date has largely lacked that effectiveness which a careful investigation of the entire run-off conditions would render possible, and which it is hoped will be reached in the future.

#### AVAILABLE RECORDS IN BASIN.

##### *Slave Falls Metering Station.*

During the reconnaissance trip down the Winnipeg river from Kenora to the mouth, taken by the departmental and consulting engineers prior to the

commencement of the detailed power survey work, one of the principal points kept in view was the selection of a metering station suitable for recording the complete run-off from the basin. Any station located along the main river in Manitoba would be satisfactory for this purpose. The site fixed upon as offering the most favourable conditions for metering is located just above Slave falls, about 6 miles below Point du Bois. The river at this point is sufficiently narrow, and the banks, which are of solid granite, sufficiently high to permit the establishment of a cable station. Below this point there is a drainage area of 3,860 square miles, of which the Whitemouth and Bird rivers drain the major portion. Records of the former are available from May 29, 1912, and are published herein. For the purpose of study in this report, the Whitemouth records are omitted from consideration, and the Otter-Slave Falls records are taken as representing the discharge available along the power reach for the entire hydro-electric scheme. Such an assumption simplifies the discussion and does not materially differ from the actual conditions.

At the time of the reconnaissance trip, metering stations had already been established along this reach, both by Messrs. Pratt and Ross, engineers of the Winnipeg Electric Railway Company, and by the engineers of the city of Winnipeg in connection with the municipal power undertaking. The company's engineers made their measurements at Otter falls, located about  $1\frac{1}{2}$  miles above the present diversion weirs. No cable station was established, the readings being secured by boat during the open season, and from ice cover throughout the winter. Measurements were taken at intervals throughout the years 1907 to 1911, inclusive, the gauge heights afterwards being referred to the lower gauge at Point du Bois. The city metering station was located about 10 miles below Point du Bois, several measurements being secured here during the winters of 1910, and 1911.

On the readings secured from these two stations, referred to the Point du Bois gauge, are based the records of the river in Manitoba, up to the date of the regular metering instituted by the Dominion Water Power Branch.

In October, 1911, the cable station at Slave falls was established by the field officers of the power survey. Continuous meterings have since been secured at this station, some 115 measurements being made to the end of 1914. As the river-bed at the station is of permanent rock formation, the gauge readings alone will, once a completely defined rating curve is determined, furnish continuous discharge records. The development of the Slave Falls site will necessitate the establishment of a new station.

The station is under the same disadvantage as were the two established by the city and the company, in that, due to the unsettled nature of the country, no gauge reader is available on the ground. The records have been referred to the city gauge at Point du Bois. This gauge is located in a bay just below the power station, readings having been taken since January 23, 1907, thus rendering available a run-off record from that date onward. The level recorded by the gauge is controlled by the Eight Foot falls, this being the only break between the gauge and the metering station. Until the winter of 1910-11 the Eight Foot falls discharged under natural conditions. During this season an endeavour was made on the part of the municipal engineers to provide

for a better regulation of the tailwater level of the city plant during high-water conditions. To this end, a cut was made through the rock ridge over which the Eight Foot falls occurs. This cut is 120 feet in width and 180 feet in length, with the bottom elevation at 927.1 (Water Power Survey datum) at the upper end, and with a 2 per cent grade. The cut was made on the right river bank immediately adjacent to the channel. A second cut is also contemplated, but



Cable Station at Slave Falls.

as yet no active steps have been taken in this connection. Due to the cutting of this channel, the discharge curve for Otter falls cannot be used later than June, 1911.

The readings of the gauge have, to a certain extent, been influenced by the daily fluctuation of the power-station loads. The pond above is 6,500 acres in area, forming an ample basin for local storage. Sudden increase in the load involves a draw on the pondage, with a consequent higher record on the gauge

than the actual river discharge would register. Similarly, lightening the load involves storage in the pond and lower gauge readings below until equilibrium is restored by the automatic discharge over the free spillways. There is also a slight back-water effect during prolonged periods of very extreme cold, due to ice formation at Eight Foot falls. This is not a frequent occurrence.

While the tailwater gauge readings have been influenced by these conditions since the plant was placed in operation in October, 1911, the errors have largely balanced, and the records secured closely represent actual conditions from month to month. As the turbine installation is increased, the fluctuations, with their adverse influence, will become more marked. An automatic gauge is now being installed at Slave falls to eliminate errors arising from this fluctuation.

*Slave Falls Discharge Records.*—The complete records of the run-off at Otter and Slave falls are to be found in Appendix VII, tables 52, 53, and 54, and in graphical form in plate '2. For convenience of reference the mean monthly flows are published herewith in table 4.

Table 4.—Mean Monthly Discharge of the Winnipeg River at Otter Falls, 1907-10, and at Slave Falls, 1911-14.

[Drainage area above Otter Falls, 59,550 square miles; above Slave Falls, 49,700 square miles.]

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
	Sec.-ft.								
January.....	26,960	36,880	24,770	25,260	14,820	20,080	27,996	13,703	23,809
February.....	22,880	36,650	24,180	24,280	13,280	16,840	26,145	13,253	22,189
March.....	17,320	31,380	18,870	23,830	12,540	13,820	19,095	13,845	18,831
April.....	14,590	28,500	16,700	39,900	12,390	13,570	17,847	14,589	19,761
May.....	16,290	32,600	20,300	52,820	14,770	22,800	28,370	18,745	25,837
June.....	28,030	41,670	24,560	48,690	18,340	28,100	32,733	31,480	31,700
July.....	32,020	42,980	24,650	36,950	22,900	26,380	29,503	34,735	31,265
August.....	31,340	39,560	24,530	24,700	26,130	27,710	27,695	31,550	29,152
September.....	37,140	35,900	22,290	19,630	24,810	29,410	25,263	26,170	27,577
October.....	42,520	33,040	20,330	17,000	25,960	33,070	18,276	24,805	26,875
November.....	42,680	28,400	20,470	14,280	22,950	32,610	15,662	21,230	24,785
December.....	39,500	23,340	22,530	12,920	19,330	29,400	14,722	19,840	22,698
The Year.....	29,272	34,242	22,011	28,355	19,018	24,483	23,609	21,995	25,373
Maximum.....	43,980	43,980	28,480	53,440	27,220	34,780	32,733	35,460	53,440
Minimum.....	14,400	21,660	16,100	12,400	11,700	12,300	14,722	11,700	11,700

NOTE.—The monthly mean for January, 1908, is the mean of the last nine days of the month only. The maximum and minimum discharges refer to daily flow.

Reference to the table indicates the uniform character of the discharges during the eight-year cycle.

A discharge of 25,373 second-feet represents the average flow for the eight-year period. The year 1908 with a mean of 34,242 second-feet, and 1911 with a mean of 19,018 second-feet are, respectively, the years of maximum and minimum flow. The highest monthly mean recorded is 52,820 second-feet in May, 1910, and the lowest, 12,390 second-feet in April, 1911. Slightly more extreme daily flows have occurred, as 53,440 second-feet on May 7, 1910, and 11,700 on several dates in 1911. This low discharge only held for a day at a time, and for all practical purposes, 12,000 second-feet may be taken as the dependable low discharge throughout the period. Undoubtedly had the

ad  
um  
also  
ue

ons  
ely  
om  
ns,  
age  
ia-

at  
54,  
can

10.

---

an.

-ft.

809  
.189  
831  
.761  
837  
.700  
.265  
.152  
.577  
.875  
.785

---

373






.440  
.700



---

num


ges

ht-  
ith  
and  
in  
ore  
and  
a  
cen  
the





— Note —  
For the Years 1907 to 1910 inclusive the records in which the Curves are plotted were secured by utilizing the Gauge heights recorded at the Municipal Power Plant at Point du Bois, together with the discharge measurements taken by Pratt at Otter Falls. Corresponding drainage Area 50,550 Sq. Miles. For the Years 1911 to 1913 inclusive the Point du Bois gauge heights were combined with the discharge measurements taken by the Engineers of the Water Power Branch at Slave Falls Corresponding drainage Area 48,700 Sq. Miles. —



For Uniform Flow in Sec. ft. of.	Necessary Storage in Billions of Cubic Feet.						
	1907	1908	1909	1910	1911	1912	1913
14,000	0	0	0	2.63	10.76	0.71	0
16,000	3.69	0	0	12.46	30.68	10.76	4.23
18,000	15.18	0	3.40	25.54	56.64	22.97	15.09
20,000	30.67	0	11.72	42.20	86.76	36.66	37.67
22,000	46.56	0	35.08	63.12	123.57	56.35	63.62
24,000	63.16	1.73	69.36	84.49	164.06	79.27	88.97
26,000	86.10	6.86	123.30	120.49	213.64	107.79	116.03

**WATER POWER BRANCH**

J. B. Chelley, Superintendent.


**WINNIPEG RIVER**

MASS CURVES OF MEAN MONTHLY DISCHARGE & VOLUME OF RUN-OFF

**SLAVE FALLS**

To accompany report on POWER & STORAGE INVESTIGATIONS

by J. T. JOHNSTON, C. E.



influence of the Lake of the Woods regulation been removed, the high and low limits would have been much more extreme than has been the case.

High-water marks along the banks would indicate a much more serious flood than has taken place during the cycle under discussion, and 100,000 second-feet would more nearly represent the flood discharge which has taken place in the past. This figure, from a careful study of all evidence to hand, is considered the outside limit of flood to be expected under natural conditions in the basin.

*Pinawa Channel Discharge.*

Prior to the construction of the Winnipeg Electric Railway Company's power station, the discharge down the Pinawa channel was only a small



Metering Station on Pinawa Channel.

proportion of the river flow. However, the construction of the company's diversion weirs across the main river channel resulted in a very material change in these conditions, and at the present time a fairly uniform flow is maintained in the channel at all seasons. During periods of low river-run-off, this flow forms a high percentage of the total river discharge.

The discharge down the channel is dependent on the water level above the weirs, which level, owing to the fact that the weirs act as free spillways, is in turn directly dependent on the stage in the river. A control dam near the head of the channel permits the cutting off of the entire Pinawa flow if necessary.

Meterings were taken below the control dam by the engineers of the company during the years 1907 to 1911, inclusive, and by the field officers of the Manitoba Hydrographic Survey during the years following. These measurements have been referred to a gauge located immediately below the control dam, records of which, with the exception of the year 1913, are available since

ely in 1908. Due to the abnormal conditions arising from ice formation, the a-water discharge curve is not applicable during the winter season.

The available records are to be found in tables 55, 56, and 57 in Appendix VII. For the open seasons tabulated the discharge has varied from 4,100 to 11,225 cubic feet per second.

The entire flow is not, as a rule, fully utilized at the plant, there being an almost continuous wastage over the spillway dam. Throughout this report, a flow of 8 000 cubic feet per second has been assumed necessary to properly operate the power station, which figure is based upon a careful rating of the station by the field officers of this branch. It is considered ample to meet the station requirements.

#### *Lake of the Woods Outlets.*

Equally important as the run-off of the power reach of the river is an accurate record of the discharge from the Lake of the Woods. This lake forms the great natural regulating reservoir for the basin above. Its location in the watershed, with reference to both the power reach and to the drainage, rendered a thorough knowledge of its run-off essential to a proper power and storage study; hence early steps were taken to obtain the necessary data.

A very complicated situation exists at the outlets of the lake, as will be seen by reference to plate 13. Some description of the same is therefore necessary in order to convey a proper appreciation of the involved nature of the stream measurement work required.

The lake discharges through several outlets, both natural and artificial, all of which are now subject to artificial control. The two main and natural outlets called respectively the East and West Branches, are located within the town limits of Kenora. The East Branch is now closed by the municipal power station of the town of Kenora (plate 37), developing a drop of some 20 feet under normal conditions. The approach to the power-house is by a somewhat narrow channel, in which there is a slight current of strength depending on the load on the turbines and the surface level of the lake.

The power station completely closes the channel, with the exception of the log slide adjacent to the left bank. It contains bays for six main and two exciter units, four of the main units, together with the exciters, being now installed. The station is more fully described in chapter V. The present controlled East Branch discharge is carried through the turbines, with the exception of a small amount passed through the log slide.

The West Branch discharge leaves the lake about 2,500 feet west of the eastern outlet. Between the two branches lies what is known as Tunnel island. Leaving the lake in a north-easterly direction, the channel is spanned by a traffic bridge and by two bridges of the Canadian Pacific Railway. Turning through considerably more than a right angle it flows in a westerly direction to the end of Tunnel island, midway in which reach is located the Norman dam. Rounding Tunnel island the channel turns again to the northeast and joins the East Branch, the length of the total course being some  $2\frac{3}{4}$  miles. The Norman dam (plate 38) is a solidly built masonry structure, designed on the principle of stoplog control, with discharging capacity sufficient to regulate the lake level

as desired. It was originally constructed for power purposes, and power sluices have been left at either end. The central section of the dam consists of a rock-fill, backed on the upstream side by finer material. This section of the dam has never been impervious, due probably to the fact that no power construction has been proceeded with, and the necessity for making the structure water-tight has not been pressing. The leakage through the rock-fill is continuous, and reaches high proportions, varying with the lake level from about 2,000 to 4,500 second-feet at times of low and high water, respectively.

Both the power and the regulating sluices are closed by stoplogs, and up to date have been available for regulating purposes. Under normal conditions there is considerable leakage through the sluices, due to the use of old logs and the difficulty of properly placing the same. As, however, there has been at practically all times up to the present, a surplus of water over that required for power purposes at the outlets from the lake, this leakage has not been of importance, and has not merited attention by the power users. The only exception to this condition occurred in the year 1911, when, due to the extremely low water in the lake, combined with a period of low general run-off, it became necessary to conserve the available water. To this end the logs of the sluiceways were tightened, and straw was used to choke the remaining leaks. Mats were also sunk above the stone fill for the same purpose. The dam is referred to in greater detail in chapter V.

Farther west along the lake shore, is located Portage bay, on the shores of which is built the town of Keewatin. This bay is separated from the river below by a rock ridge, through which three outlets now discharge waters from the lake. Of these outlets, two are entirely artificial and have been constructed for power and industrial purposes. The third outlet probably discharged naturally during extreme high water in the lake.

The most easterly cut was made in 1881, the power being used for the operation of a saw-mill. Discharge through this cut has not been continuous, it being closed for long periods, at different times, due to lack of demand for the power, and to change of ownership. In 1905 the site was acquired by the Keewatin Flour Milling Company, and the flume was nearly doubled in size. The following year the Keewatin Flour Milling Company was purchased by the Lake of the Woods Milling Company, and in May, 1907, the present mill "C" was put in operation. From this date onward, the mill has been operated and the discharge through the cut continuous. The entire flow through this channel is utilized by the mill. The discharge from the turbines is conveyed to the river below by a tail-race excavated through the solid rock below the mill.

About 480 feet westerly along the shore from the above channel, a second intake has been cut, also in connection with the milling industry. This cut was made in 1887 by the Lake of the Woods Milling Company, in connection with mill "A." The discharge through the channel has been constant since that date. The entire flow through the channel is utilized by the mill. The discharge from the turbines takes place directly into the river below. These mills are more fully covered in chapter V.

The third outlet from Portage bay is known as the Keewatin Lumber and Manufacturing Company outlet, and leads from the extreme westerly end of

the bay. This end was formerly blocked with muskeg and by a ridge of rock, which prevented outflow, excepting possibly during times of high water in the lake.

In 1879, a power-house, together with a head-race some 400 feet in length and 40 feet in width in its narrowest part, was constructed by the Keewatin Lumber and Manufacturing Company. The head-race was a timber structure partially in earth excavation, with the exception of a small rock cut immediately above the power-house. The mill was placed in operation in June, 1880, and the mill-race deepened in 1885. The tail-race discharges into Mink bay, and, at approximately 1 mile west of Keewatin, Mink bay discharges into Darlington bay, an inlet of the Winnipeg river, through a tunnel cut in solid rock through the Canadian Pacific Railway right of way.

The power developed was used in the operation of a saw-mill, together with a planing-mill. The saw-mill was destroyed by fire in the fall of 1905, and was never rebuilt. The planing-mill was operated in 1906, but since that date the outlet has been closed by stop logs.

*Meterings at Outlets of the Lake of the Woods.*—The above brief description of the outlets of the lake is sufficient to indicate that the work of securing satisfactory discharge measurements is somewhat involved. This is particularly the case in attempting to analyse the past flows through the various outlets. Difficulty was also experienced in locating a satisfactory station to record the combined discharge from the lake, due to the channel below being broken by islands, and widening into large lake-like areas.

Prior to the stream gaugings of the Dominion Water Power Branch, little discharge data had been secured around the lake outlets, and no attempt had been made to obtain continuous discharge records.

The first measurement secured on the Eastern Branch was taken on July 29, 1903, by Pringle & Sons, engineers in charge of the construction of the Kenora power station. The discharge recorded was 4,122 cubic feet per second, with lake at elevation 1,059.3, Water Power Survey datum.<sup>1</sup> Two meterings were made by the officers of the Hydro-Electric Power Commission of Ontario on October 14, 1905, and April 8, 1906, the discharges secured being 5,320 and 4,490 cubic feet per second, respectively, with the lake level approximately 1,060.1 and 1,059.4.

In order to secure a record of the past discharge through this outlet the power station has been rated. During the summer and fall of 1912, discharge measurements were made by the field engineers of the Water Power Branch, at a section below the power house and lying between Old Fort island and the main shore. This section was discontinued, due to the channel being altered by blasting and excavation on the part of the Dominion Public Works Department, and also due to the fact that the discharge, on account of a large bay intervening and tending to equalize the flow, did not respond rapidly to a change in the discharge at the power station.

In February, 1913, a station was established above the new power-house and at approximately the crest of the old Ka-ka-be-kitchewan falls, now flooded out by the power plant forebay. Up to December 31, 1914, some 125 discharge measurements have been taken at this section. Readings of forebay

<sup>1</sup>Level of Water Power Survey datum is equal to 1.31 of the United States Coast and Geodetic Survey datum.

and tail race gauges, together with load and valve readings, were made while the meterings were in progress, and a rating of the power station secured. Included in the meterings was the discharge through a V-shaped spillway or log chute. This log chute has been kept partially open in order to maintain sufficient water in the tail-race. The discharge through this chute has been calculated, and the net discharge through the power-house obtained. The meterings on which the rating curve is based are published in Appendix VII, table 60.

The new power station commenced operation on February 9, 1907, the wheel installation at this date being three 40-inch Sampson twin horizontal turbines, connected to the generators, and two 30-inch Sampson twin turbines connected to the exciters. No further additions were made to the station until 1913. The discharge through the station has shown a fairly constant, if slow, growth. Commencing in August of 1907, the water required averaged about 550 second-feet, which during the following winter with the consequent heavier load increased to 780. During the following years, increases were recorded from time to time the flow reaching as high as 1,700 second-feet in February of 1912. This was an extreme condition, the average flow required at present being more in the neighbourhood of 1,300 second-feet.

On the western outlet, but few measurements were secured prior to the work of the Water Power Branch engineers. In connection with the construction of the Norman dam, Mr. William Kennedy secured two meterings of this outlet, the first on November 11, 1892, and recording 22,563 cubic feet per second, and the second on May 26, 1893, recording 15,937 cubic feet per second. On October 18, 1905, the officers of the Hydro-Electric Power Commission of Ontario secured a gauging of 22,000 second-feet at the Norman dam. In June, 1912, a station was established at the Norman traffic bridge, at the entrance to the channel. Twenty-eight meterings were secured here by officers of the survey staff, throughout 1912 and 1913.

This station was established in order to secure a record of the leakage through the Norman dam, under various conditions of lake level. Since the discharge through this channel is dependent on two controlling conditions, i.e., the lake level and the number of logs in place at the dam, both of which are constantly changing, the station was not suitable for securing permanent daily records of the run-off. It has been maintained to serve as a check on the station north of Tunnel island, at which station the flow through the Norman dam, as well as that through the three western outlets, is recorded.

Early steps were taken to secure records of the water used by the Keewatin mills. A station was established on the intake to mill "C" on July 17, 1912. To the end of 1914, some ninety-seven measurements have been secured by the hydrographic field officers, the discharge varying from 600 to 1,100 second-feet, with an average of about 700. Under ordinary conditions, the load on the mill is fairly constant, and the fluctuation is slight. There are no records from which the past discharges might be deduced.

In the intake to mill "A," a station was also established by Mr. Scovil, Assistant Chief Engineer of the Manitoba Hydrographic Survey, on December 23, 1912, and continuous meterings secured. Under usual conditions of load the discharge remains fairly constant at about 850 cubic feet per second. A low flow of 200 second-feet usually occurs on Sunday, when the generators only are being

operated. A discharge measurement secured at this mill on October 16, 1906, by the officers of the Hydro-Electric Power Commission of Ontario showed a flow of 899 second-feet.

The old Keewatin Lumber and Milling Company outlet has also been carefully metered. The discharge at present consists of the leakage through the stoplogs closing the old intake. The metering station established in July, 1912, is located at the entrance to the tunnel under the Canadian Pacific Railway embankment, and records, in addition to the leakage, the drainage from a small area tributary to Mink bay. The records have shown a gradual increase in discharge from 95 to 130 cubic feet per second. A measurement obtained



Old Keewatin Lumber Co. Outlet from the Lake of the Woods.

here on October 16, 1905, by the officers of the Hydro-Electric Power Commission of Ontario while the plant was in operation, showed a flow of 400 second-feet.

The total discharge from the three Keewatin outlets, and from the West Branch, is carried to the north of Tunnel island, where the main metering station has been established. The gauge is bolted to the solid rock shore at the south end of the traffic bridge below Keewatin, while the metering section is located about 1 mile down stream. The station was established by Mr. Scovil on June 28, 1912, since which date continuous measurements have been and are being secured, upwards of 280 being obtained to the end of 1914.

In view of the importance of the records at this place, especial care has been exercised in the metering, and the results are considered to be satisfactory. The discharge records have been carried back to the beginning of 1907 by means of the gauge records of the Ontario Department of Public Works. Since the establishment of the regular station, independent gauge readings have been secured by the survey staff.

The flow is largely dependent on the operation of the Norman dam and of the Lake of the Woods Milling Company's mills at Keewatin.

Some 12 miles down stream from the station, the river enters a gorge and forms what are known as the Dalles rapids. These consist in reality of little more than swift-flowing water. In times of high water a back channel comes into play just above the Dalles, and a portion of the flow is discharged through the same, the entrance going under the name of the Throat rapids. Some 28 miles below the Dalles there is a series of rapids and falls known as the White Dog. The White Dog, Dalles, and Throat rapids form the control of the river reach extending back upstream to Kenora. This is a most important consideration, since the river expansion between the Dalles and Kenora is 20 square miles in area, and between White Dog and the Dalles, 65 square miles. These areas require considerable time to adjust the surface elevation to meet sudden changes in discharge, due to the operation of the Norman dam. Backwater effects are consequently experienced at the gauging station. The unsettled nature of the country prevented the early establishment of a permanent station farther down the river. Such a station will, however, be established in the near future.

The backwater effect is now being thoroughly investigated by Mr. S. S. Scovil of the Lake of the Woods Technical Board, with a view to making whatever corrections may be necessary on the present records, and on those which have been deduced back to 1907. Any such corrections as may be applied will not alter, to any marked extent, the totals published herein, and it is not considered advisable to delay the publication of this report until such time as the revision is complete. The corrected results will be published when prepared in a future Water Resources Paper.

The total discharge from the lake is secured by totalling the records of the North Tunnel Island station with those of the Kenora power-house station.

*Lake of the Woods Discharge Records.*—The complete records of the total run-off from the Lake of the Woods are to be found in Appendix VII, tables 58, and 59, and in graphical form on plate 14. For convenience of reference, the mean monthly flows are published herewith in table 5.

Table 5.—Mean Monthly Discharge of the Winnipeg River at the Outlet of the Lake of the Woods at Kenora.

[Drainage area 26,409 square miles.]

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
	Sec.-ft.								
January.....	11,790	12,190	9,970	11,650	7,709	5,555	11,560	8,030	10,682
February.....	11,250	18,239	10,049	11,793	7,119	5,795	9,570	8,380	10,271
March.....	10,649	17,349	10,910	12,259	6,835	6,010	6,990	10,320	10,413
April.....	10,280	16,909	10,870	22,129	8,935	6,270	8,550	9,780	11,721
May.....	11,170	18,470	11,049	21,629	8,770	6,505	18,370	12,339	13,914
June.....	14,030	22,839	11,770	21,870	8,945	5,435	20,109	18,450	15,425
July.....	11,055	21,800	11,850	15,299	8,770	4,870	15,020	19,910	14,071
August.....	12,730	20,309	11,695	13,270	7,985	5,439	14,880	18,200	13,061
September.....	17,080	18,220	11,940	11,750	6,715	5,425	13,139	13,520	12,215
October.....	20,790	15,420	12,095	10,189	5,945	9,720	8,180	11,460	11,712
November.....	21,075	12,810	12,029	8,785	5,615	10,920	8,090	9,990	11,161
December.....	19,730	10,580	11,925	8,110	5,530	11,520	8,050	9,850	10,661
The Year.....	14,560	17,670	11,345	14,570	7,410	6,955	11,872	12,508	12,109
Maximum.....	21,672	23,944	12,450	25,238	9,387	12,010	20,896	20,476	25,238
Minimum.....	10,100	10,118	9,465	7,654	5,078	4,125	5,847	7,077	4,425

NOTE.—The maximum and minimum discharges refer to daily flow.

Reference to the table indicates a discharge which apparently has, in the majority of the years, been little influenced by the seasons. This has been due to the artificial control exercised at the Norman dam. The year 1907 shows the highest discharges in the months of October, November, and December; 1908 is more normal, although the winter months are high; 1909 has a practically uniform flow throughout; 1910 shows the usual influence of the seasons; 1911 is fairly uniform throughout; 1912 shows the highest flow during the months of October, November, and December; while 1913, and 1914 show the normal high-water period in its proper season. These discharges can be profitably studied in conjunction with the elevations of the lake surface throughout the period, as shown in table 20. This influence is discussed more fully in connection with the question of storage in the lake, and the results are tabulated in table 21. It is sufficient at this stage to make note of the very marked influence which the control of the lake has had on the recorded discharges. While the discharges during the individual years do not follow the seasonal periods of high and low water, the eight-year means of the various months, as may be seen graphically in figure 2, plate 16, show up more satisfactorily.

The average eight-year flow from the lake has been 12,109 second-feet. The years of highest and lowest discharge are 1908 and 1912, respectively, and the maximum daily discharge recorded was 25,238 on May 4 in 1910, with a minimum of 4,425 on July 21 in 1912. This maximum discharge coincides closely with the time of maximum at Slave falls.

#### *Fort Frances Metering Station.*

The third location at which has been secured a series of discharge measurements of prime value in studying the run-off of the basin, is at Fort Frances, at the outlet of Rainy lake. Past records are available here from March 1, 1907.

The metering station is located a short distance below the Ontario and Minnesota Power Company's dam at Fort Frances. It was established on March 1, 1907, by the Power Company, who furnished the gauge heights to the United States Geological Survey until the spring of 1910. The gauge was originally located on the United States side, but in the spring of 1910, was moved to the Canadian side and located in the tail-race of the power plant. The operation of the turbines at this point affects the water surface to such an extent that it is not always a true index of the flow, and accordingly the station was discontinued. Immediately following, on April 20, 1911, a new gauge was installed by the United States Geological Survey at the American steamboat dock below the falls.

The field officers of the Department of Public Works of the Dominion Government established a metering station at the same location as that used by the United States engineers. At the same time, the turbines in the power stations on both sides of the river were carefully rated. Records of the discharge past the dam and power stations have in this manner been daily recorded to date, and have been checked by monthly meterings at the station below the dam. Measurements have also been taken at this station by the field officers of the Dominion Water Power Branch during the years 1912, and 1913.

The Department of Public Works has under way a topographic survey of the entire Rainy river and banks, a considerable portion of which is now completed.

*Fort Frances Discharge Records.*—The records published herein from March 1, 1907, to November 30, 1912, have been secured from the records of the United States Geological Survey as published in Water Supply Paper 305, to which have been applied the percentage corrections submitted in Water Supply Paper 325 by Mr. Adolph Meyer, consulting engineer of the International Joint Commission. The previously published results were subsequently found to be inaccurate, primarily due to back-water effects from ice cover and flood discharge of the Little and Big Fork rivers. The records herein from December 1, 1912, to date have been supplied by the engineers of the Department of Public Works. The above records are appended in complete form in tables 61, and 62, in Appendix VII, and in graphical form in plate 15. For convenience of reference the mean monthly discharges are given herewith in table 6.

Table 6.—Mean Monthly Discharge of the Rainy River at Fort Frances.

[Drainage area 11,100 square miles.]

Month	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
	Sec.-ft.								
January	5,883	12,000	5,170	9,689	2,860	5,330	6,620	6,718	6,783
February	3,641	8,410	4,740	9,680	2,380	4,830	6,561	6,823	5,883
March	4,910	7,030	5,500	10,750	2,530	4,740	6,420	6,707	6,073
April	4,955	7,020	3,250	10,630	3,020	4,850	6,405	6,694	5,721
May	6,070	7,910	4,220	10,600	4,600	6,090	6,620	6,866	6,626
June	10,200	7,430	6,850	10,090	5,740	6,020	7,274	8,464	8,247
July	13,000	13,360	10,600	6,630	3,970	7,680	12,597	10,464	9,750
August	17,470	12,680	10,600	5,280	6,560	8,120	8,544	10,044	9,912
September	20,110	10,740	9,250	5,080	5,900	7,360	6,770	9,749	9,381
October	19,760	9,680	9,050	5,120	5,210	6,880	5,318	9,787	8,963
November	17,700	7,510	5,400	5,280	5,410	6,731	6,129	9,927	8,011
December	13,000	5,701	10,000	4,300	5,900	6,231	6,300	8,991	7,561
The Year	11,391	9,350	7,052	7,750	4,514	6,213	7,214	8,436	7,744
Maximum	20,110	13,050	10,600	11,750	6,560	8,120	12,597	10,464	110
Minimum	3,611	6,020	3,250	4,300	2,380	4,740	6,120	6,694	389

NOTE.—No records were available at Fort Frances for the months January and February in 1907, and the discharges used were deduced from Kenora records by proportional areas.

The maximum and minimum discharges refer to mean monthly flows.

Reference to the table and to plate 15 indicates that, as was the case in the Lake of the Woods, the use of the lake in conjunction with the hydro-electric and industrial undertakings at the outlet has largely interfered with the normal seasonal influences on the run-off. A reference to the eight-year monthly means in column 10 above, indicates that the average flow has followed the seasonal changes more closely than have the individual years.

The eight-year mean flow was 7,744 second-feet. The years of maximum and minimum flow were 1907 and 1911, with a mean of 11,390 and 4,514 second-feet, respectively, while the monthly maximum and minimum was 20,110 and 2,380 second-feet, respectively.

The theoretical inflow, as tabulated in table 25, discloses a much closer relation between the run-off and the seasons.

*Chaudière Falls (Kettle Falls) Metering Station.*

The metering station of next importance to the study of the run-off conditions in the basin is that at Chaudière or Kettle falls. These falls are located at the outlet of Namakan lake where the outflow drops direct into Rainy lake. At the falls the river is divided by an island into two channels, the Canadian and International, respectively. The normal drop was about 8 feet under natural conditions. The station was established by the field officers of the Dominion Water Power Branch in August, 1912. Owing to the shortness of the period over which the work has extended, there are insufficient records to permit a detailed study of the run-off.

Two metering sections were established, one on each channel. The combined flow gives the total discharge from Namakan lake, a body of water 100 square miles in area with a tributary drainage of 7,060 square miles. The gauge was placed on the Canadian main shore, 200 feet above the Canadian falls, and was not affected by backwater. The station was discontinued in June, 1913, and the subsequent construction of the storage dams referred to in chapter V has destroyed the natural run-off conditions previously existing. The combined records are attached in tables 63, 64, and 65, Appendix VII.

*Miscellaneous stations and records.*

Run-off measurements have been made by the officers of the Manitoba Hydrographic Survey on certain of the lesser tributary rivers, the Whitemouth river being the only one on which continuous records are available.

*Whitemouth River.*—The Whitemouth river rises near the international boundary and flows north, entering the Winnipeg from the south just below the lowest pitch of the Seven Sisters falls. It drains an area of 1,400 square miles, the great proportion of which is entirely unsupplied with lakes. A station was established on this river by the Manitoba Hydrographic Survey in May, 1912, and the records are attached in Appendix VII, tables 66, 67, and 68.

The maximum flow recorded since the establishment of the station has been 2,250 second-feet on June 4, 1914, while a minimum of 16 second-feet was metered on January 20 of the same year. Attention is called to the extreme low winter flow of the river. This flow is particularly striking in view of the extent of the drainage area, and is illustrative of the winter run-off conditions which must be anticipated from those portions of the watershed unsupplied with equalizing lakes. Low run-off may also be experienced in the summer season, as is instanced in the records for August, and September in the year 1914, when the average flow of only 136, and 174 second-feet, respectively, was maintained.

Numerous individual meterings have been secured from time to time on various streams throughout the basin. These have been collected and grouped and are attached in Appendix VII, table 69.

There is available no continuous record of the English River flow. This river drains the entire northern portion of the basin, in all some 21,570 square miles. Isolated measurements have been secured, but owing to its inaccessibility, no attempt has been made until recently to record its continuous discharge. The Ontario Hydro-Electric Commission is taking steps to secure permanent records. At present the best that can be done in studying the run-off and storage conditions of the English river is to deduce a discharge by proportional areas.

#### *Ontario Hydro-Electric Power Commission Discharge Records.*

The Hydro-Electric Power Commission of Ontario has recently instituted energetic measures to secure adequate and reliable stream run-off records throughout that portion of the Winnipeg watershed lying within the province of Ontario. Permanent metering stations have been established on the Seine, Turtle, Manitou, Footprint, Wabigoon, Eagle, and English rivers. As has also been the case in other portions of the basin, considerable difficulty has been experienced in securing gauge readers in connection with this work. The inaccessible nature of the district, coupled with this lack of suitable recorders, has added largely to the difficulties attendant on the maintenance and enlargement of the sphere of operations. A comprehensive programme has, however, been mapped out and is being energetically prosecuted.

Through the courtesy of the commission, the Dominion Water Power Branch is enabled to publish the discharge records which have been secured throughout the watershed. These records are appended in tables 70 to 91, Appendix VII.

#### *United States Geological Survey Discharge Records.*

Throughout that section of the Winnipeg River basin lying in Minnesota, stream measurement work has been carried on for several years by the officers of the United States Geological Survey. Through the courtesy of the Director of the Survey, it has been possible to incorporate in this report the run-off data available.

*Big Fork River.*—The Big Fork river is located entirely in Minnesota, and is the second largest tributary of the Rainy river from the south. It rises in Jessie lake, in township 147 north, range 25 west, in Itaska county, at an elevation of about 1,320 feet above sea-level. It flows into Bowstring lake, thence north into Wabatawangang lake, and thence east and north into Rainy river near Laurel. The entire length is about 175 miles. Stream measurement work is carried on by the officers of the Water Resources Branch of the United States Geological Survey, and records are available from August 27, 1909, to November 12, 1910. On account of the interference by backwater from a log jam during the years 1911, and 1912, no daily or monthly records for these years are published. The published records are attached in Appendix VII, tables 92, 93, and 94.

*Little Fork River.*<sup>1</sup>—The Little Fork river, the largest tributary of the Rainy river from the Minnesota side, rises in the central part of St. Louis county, a few miles south of Vermilion lake, at an elevation of about 1,440 feet above sea-level, and flows westward and then northwestward to its junction with Rainy river, about 12 miles below International Falls. The total length of the river is about 160 miles. Records secured by the United States Geological Survey officers are available from June 23, 1909, to December 31, 1914, and are attached in Appendix VII, tables 95, 96, and 97.

*Vermilion River.*<sup>1</sup>—The Vermilion river, which rises in Vermilion lake, has its ultimate source in Pike river, which rises in the southern part of township 58 north, range 17 west. From Vermilion lake the general course of the Vermilion river is southwest and then northeast, emptying into Crane lake, which in turn empties into Sand Point lake, and then into Namakan lake. From Vermilion lake to Crane lake, the length of the river is 42.5 miles. Throughout its course, the river falls 245 feet, through a series of rapids interspersed with small lakes and level stretches. Records secured through the United States Geological Survey are available from May 17, 1911, to December 31, 1914, and are attached in Appendix VII, tables 98, 99, and 100.


*Kawishiwi River.*<sup>1</sup>—The Kawishiwi river rises in Syenite lake in the eastern part of township 62 north, range 6 west, in Lake county, and flows north and west through a chain of lakes, the chief ones being Polly, Boulder, Alice Wilder, and Crab lakes. In the southwest corner of township 63 north, range 10 west, the river divides, one fork known as the North Kawishiwi, continuing westward through Friday and Farm lakes into Garden (or Eve) lake. The other fork, known as the South Kawishiwi or Birch river, flows southwest through Copeland lake into Birch lake, where it runs northward and flows through White Iron lake into Garden lake, joining the North Kawishiwi. From Garden lake, the Kawishiwi flows northward through Fall and Newton lakes into Basswood lake, a tributary of Rainy river. The south Kawishiwi is the larger of the two forks. Records of the run-off of the Kawishiwi river are available from June 21, 1905, to June 30, 1907. These records were compiled by the Minnesota Canal and Power Company and published in the Report of Water Resources Investigation of Minnesota, 1909-12, by the State Drainage Commission. Records are also available from October 14, 1912, to December 31, 1914, secured through the International Joint Commission co-operating with the United States Geological Survey. The records are attached in appendix VII, tables 101, and 102.

#### GENERAL RUN-OFF.

For the purpose of general study of the run-off conditions of the Winnipeg river, reference may be made to plates 16, 17, and 18.

The curves on plate 16 are plotted from the average eight-year monthly discharges at Slave falls, Kenora, Fort Frances, and of the English river at its mouth and at the outlet from Lac Seul. It will be noted that in these average curves the discharge follows the seasonal variations much more closely than do

<sup>1</sup> For the above descriptive data on the Big Fork, Little Fork, Vermilion, and Kawishiwi rivers, the writer is indebted to the Report of Water Resources Investigations of Minnesota, 1909-12, by the State Drainage Commission







Department of the Interior, Canada  
 GEORGE W. H. WATSON, Engineer  
 W. H. GIBB, Chief, District Engineer  
 Water Power Branch  
 J. G. GIBB, Superintendent

**WINNIPEG RIVER POWER SURVEY.**  
**OUTLETS OF**  
**THE LAKE OF THE WOODS**



By permission a reprint of this map and related correspondence  
 by A. L. GIBBING, C.E., 1917

*L*

Rainy  
county  
above  
with F  
of the  
Geolog  
1914, 1

*V*

its ult  
58 nor  
Verni  
which  
Verni  
its con  
small  
Geolog  
are at

*K*

part o  
west t  
and C  
the riv  
throug  
as the  
Birch  
Garde  
flows :  
of Ra  
of the  
30, 19  
Comp  
Minne  
availa  
Intern  
Surve

*F*

river,

*T*


disch.  
moutl  
curve

<sup>1</sup> F  
indebtec




1907

①




1908

②




1909

MONTHLY DISCHARGE IN CU FT PER SEC




1911

⑤




1912

⑥




1913

MONTHLY DISCHARGE IN CU FT PER SEC




1909

③



1910

④




NOTE.

The discharge records from which these curves are plotted were secured by the Engineers of the Dominion Water Power Branch by totalling the Records from the East and West branches of the Winnipeg River at Kenora. The East branch records were obtained by rating the Kenora Power Station. The West Branch Records were obtained by a metering station North of Tunnel Island, referred to gauge records of the Ontario Department of Public Works. Drainage Area - 26,400 Square miles.

1913

⑦



For Uniform Flow in Sec. Ft. of	Necessary Storage in Billions of Cubic Feet.						
	1907	1908	1909	1910	1911	1912	1913
6,000	0	0	0	0	2.38	9.14	0
7,000	0	0	0	0	11.42	30.64	0.26
8,000	0	0	0	0	27.66	54.21	2.64
9,000	0	0	0	2.89	49.69	77.78	13.46
10,000	0	0	7.8	8.13	81.24	102.08	27.68
11,000	2.82	1.10	5.79	15.51	112.73	128.53	43.41
12,000	12.74	3.72	20.93	25.45	144.05	158.31	59.11

WATER POWER BRANCH

J. B. Chailles, Superintendent

WINNIPEG RIVER

MASS CURVES OF MEAN MONTHLY DISCHARGE & VOLUME OF RUN-OFF

at

KENORA

To accompany report on POWER & STORAGE INVESTIGATIONS

by J. T. JOHNSTON, B. A. Sc.

Rair  
 coun  
 abea  
 with  
 of t  
 Geol  
 1914







its u  
 58 n  
 Vern  
 whic  
 Vern  
 its co  
 small  
 Geol  
 are a

part  
 west  
 and  
 the r  
 throu  
 as the  
 Birch  
 Gard  
 flows  
 of Ra  
 of the  
 30, 1'  
 Com  
 Minn  
 availa  
 Intern  
 Surve

F  
 river.  
 T  
 discha  
 moutl  
 curves


<sup>1</sup> Fo  
 indebted






909

③



1910

④




NOTE

From March 1907 to November 1912 inclusive the records on which these curves are plotted are taken from the published records of the Water Resource Branch of the U.S. Geo. Survey. The records from November 30, 1912, have been supplied by the field officers of the Department of Public Works of the Dominion Government.  
Drainage Area - 14,400 sq. miles.

1913

⑦



For Uniform Flow in Sec Ft	Necessary Storage in Billions of Cubic Feet						
	1907	1908	1909	1910	1911	1912	1913
4,000	0.87	0	1.95	0	13.76	0	0
5,000	3.65	0	7.27	1.65	27.96	1.50	0
6,000	11.64	0.97	20.11	13.09	46.35	10.96	0
7,000	24.50	6.02	36.12	27.32	76.41	29.27	12.66
8,000	37.54	15.34	54.35	43.22	109.95	55.37	36.16

DOMINION WATER POWER BRANCH

J. B. CHALLIES, Superintendent

RAINY RIVER

MASS CURVES OF MEAN MONTHLY DISCHARGE AND VOLUME OF RUNOFF

- at -

FORT FRANCES

To accompany a report on POWER AND STORAGE INVESTIGATIONS  
by J. T. JOHNSTON, B.A.Sc.

Rain  
count  
above  
with  
of t  
Geol  
1914

its u  
58 n  
Vern  
whic  
Vern  
its ec  
small  
Geol  
are a

part  
west  
and t  
the r  
throu  
as the  
Birch  
Gard  
flows  
of Ra  
of th  
30, 1'  
Comj  
Minn  
availa  
Interi  
Surve

F  
river,

T  
discha  
moutl  
curves






<sup>1</sup> Fo  
indebted

DOMINION WATER POWER BRANCH

WINNIPEG RIVER BASIN






WINNIPEG RIVER BASIN

... ..  
 and the ... ..  
 ... ..  
 ... ..  
 ... ..  
 ... ..





NOTE: These curves have been plotted from stream gage records and are subject to errors.



DOMINION WATER POWER BRANCH  
 J. B. CHALLIS Superintendent


WINNEPEG RIVER BASIN

Discharge Curves of monthly discharges at  
 SLAVE FALLS OUTLET OF THE LAKE OF THE WOODS BAINY RIVER AT FORT FRANCES  
 & ENGLISH RIVER AT MOUTH AND OUTLET OF LAC SEUL  
 For 6 yrs. year 1907-1912





To accompany a report on WEEDS AND STORAGE INVESTIGATIONS  
 by J. T. JENNIFER C.E.S.


April 1912





**DOMINION WATER POWER BRANCH**  
**WINSTON-SALEM, CANADA**  
 Note: This chart is based on the data of the Dominion Water Power Branch, Ottawa, Ontario, Canada, and is not to be used for any other purpose without the permission of the Dominion Water Power Branch, Ottawa, Ontario, Canada.





the individual yearly records, the inequalities due to the regulation which has been maintained being more or less modified.

The curves on plate 17 are plotted from the mean monthly discharges at the above points, and illustrate the proportionate volume of run-off to be anticipated from eight years' records. The mass curves on plate 18 are of interest as depicting the total volume of discharge at the five principal points studied along the river.

Tables 7, 8, and 9, listing the estimated monthly discharges in cubic feet per second per square mile at Slave falls, Kenora, and Fort Frances, respectively; together with tables 10, 11, and 12, listing the equivalent depth in inches on the drainage areas of the monthly discharge at Slave falls, Kenora, and Fort Frances, are appended for reference purposes.

Table 7. Estimated Monthly Discharge of the Winnipeg River at Otter Falls from 1907-10 and at Slave Falls 1911-14, in cubic feet per second per square mile of the Drainage Area.

[Drainage area at Otter Falls 50,550 square miles; above Slave Falls 49,700 square miles]

Month	1907	1908	1909	1910	1911	1912	1913	1914	Mean
January	0.534	0.729	0.490	0.499	0.298	0.404	0.564	0.276	0.474
February	0.454	0.725	0.478	0.480	0.267	0.349	0.536	0.267	0.412
March	0.343	0.621	0.372	0.472	0.253	0.278	0.584	0.279	0.375
April	0.289	0.564	0.330	0.789	0.249	0.273	0.500	0.294	0.404
May	0.322	0.615	0.403	1.045	0.297	0.459	0.500	0.377	0.515
June	0.555	0.824	0.486	0.964	0.369	0.566	0.600	0.633	0.642
July	0.634	0.850	0.488	0.731	0.361	0.531	0.500	0.698	0.624
August	0.620	0.783	0.485	0.489	0.526	0.558	0.550	0.635	0.581
September	0.735	0.710	0.441	0.388	0.499	0.592	0.508	0.526	0.550
October	0.841	0.651	0.402	0.116	0.517	0.665	0.568	0.499	0.545
November	0.844	0.562	0.405	0.284	0.467	0.656	0.115	0.328	0.494
December	0.782	0.462	0.415	0.256	0.389	0.592	0.296	0.599	0.452
The Year	0.578	0.677	0.445	0.561	0.381	0.491	0.475	0.443	0.505
Maximum	0.844	0.850	0.490	1.045	0.526	0.665	0.658	0.698	1.045
Minimum	0.289	0.462	0.330	0.256	0.249	0.273	0.296	0.267	0.249

Note.—The maximum and minimum discharges refer to mean monthly flows.

Table 8. Estimated Monthly Discharge of the Winnipeg River at Kenora in cubic feet per second per square mile of Drainage Area.

[Drainage area 1,267,000 square miles]

Month	1907	1908	1909	1910	1911	1912	1913	1914	Mean
January	0.447	0.727	0.438	0.314	0.292	0.211	0.438	0.404	0.405
February	0.426	0.690	0.481	0.347	0.269	0.220	0.463	0.317	0.389
March	0.303	0.657	0.473	0.510	0.259	0.238	0.265	0.391	0.491
April	0.189	0.600	0.422	0.839	0.311	0.241	0.324	0.361	0.444
May	0.423	0.700	0.418	0.935	0.342	0.247	0.696	0.466	0.527
June	0.540	0.865	0.416	0.828	0.349	0.296	0.761	0.698	0.584
July	0.532	0.836	0.442	0.617	0.343	0.185	0.569	0.781	0.543
August	0.647	0.768	0.413	0.503	0.303	0.209	0.363	0.682	0.490
September	0.182	0.682	0.452	0.415	0.254	0.205	0.296	0.512	0.365
October	0.787	0.584	0.434	0.285	0.225	0.368	0.293	0.431	0.413
November	0.798	0.485	0.355	0.433	0.213	0.416	0.290	0.465	0.403
December	0.748	0.440	0.352	0.497	0.213	0.436	0.300	0.513	0.400
The Year	0.551	0.700	0.449	0.500	0.381	0.264	0.449	0.464	0.460
Maximum	0.798	0.865	0.455	1.045	0.511	0.665	0.761	0.781	1.045
Minimum	0.182	0.490	0.378	0.256	0.210	0.180	0.290	0.267	0.210

Note.—The maximum and minimum discharges refer to mean monthly flows.

Table 9.—Estimated Monthly Discharge of the Rainy River at Fort Frances in cubic feet per second per square mile of the Drainage Area.

[Drainage area, 14,400 square miles.]

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
January	0.109	0.831	0.359	0.672	0.199	0.370	0.460	0.467	0.471
February	0.253	0.584	0.329	0.672	0.165	0.436	0.456	0.474	0.409
March	0.341	0.489	0.382	0.748	0.176	0.329	0.446	0.466	0.422
April	0.341	0.418	0.226	0.736	0.210	0.337	0.445	0.465	0.398
May	0.422	0.552	0.293	0.736	0.320	0.423	0.161	0.177	0.460
June	0.709	0.794	0.476	0.695	0.399	0.448	0.506	0.588	0.573
July	0.904	0.908	0.736	0.461	0.276	0.531	0.876	0.727	0.678
August	1.214	0.882	0.736	0.367	0.156	0.564	0.594	0.698	0.689
September	1.398	0.747	0.613	0.353	0.416	0.512	0.170	0.677	0.652
October	1.373	0.672	0.628	0.356	0.362	0.478	0.439	0.680	0.623
November	1.230	0.512	0.375	0.367	0.376	0.468	0.426	0.690	0.557
December	0.904	0.396	0.695	0.299	0.410	0.436	0.448	0.625	0.525
The Year	0.792	0.650	0.490	0.539	0.314	0.434	0.501	0.586	0.538
Maximum	1.398	0.908	0.736	0.748	0.456	0.564	0.876	0.727	1.398
Minimum	0.253	0.396	0.226	0.299	0.165	0.329	0.426	0.465	0.165

NOTE.—The maximum and minimum discharges refer to mean monthly flows.

Table 10.—Estimated Equivalent Depth in Inches on the Drainage area, of the Monthly Discharge of the Winnipeg River at Otter Falls 1907-10 and at Slave Falls, 1911-14.

[Drainage area above Otter Falls, 50,556 square miles; above Slave Falls, 49,700 square miles.]

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
January	0.615	0.811	0.565	0.576	0.341	0.466	0.649	0.318	0.547
February	0.471	0.755	0.498	0.500	0.278	0.353	0.518	0.278	0.460
March	0.395	0.716	0.429	0.544	0.291	0.321	0.443	0.421	0.433
April	0.322	0.630	0.369	0.882	0.279	0.305	0.401	0.328	0.439
May	0.372	0.743	0.463	1.205	0.343	0.529	0.658	0.435	0.594
June	0.619	0.921	0.542	1.075	0.442	0.632	0.736	0.708	0.707
July	0.731	0.980	0.562	0.843	0.531	0.612	0.684	0.806	0.719
August	0.715	0.902	0.560	0.864	0.676	0.646	0.642	0.732	0.671
September	0.820	0.793	0.492	0.431	0.558	0.655	0.568	0.588	0.614
October	0.970	0.754	0.464	0.488	0.602	0.767	0.424	0.575	0.618
November	0.913	0.627	0.452	0.315	0.516	0.732	0.352	0.477	0.552
December	0.901	0.542	0.511	0.295	0.448	0.682	0.342	0.460	0.522
The Year	7.87	9.20	5.91	7.62	5.21	6.70	6.45	6.03	6.88
Maximum	0.970	0.980	0.565	1.205	0.606	0.767	0.736	0.806	1.205
Minimum	0.322	0.531	0.369	0.295	0.278	0.305	0.312	0.278	0.278

NOTE.—The maximum and minimum depths refer to the mean monthly flows.

Table 11. -Estimated Equivalent Depth in Inches on the Drainage Area, of the Monthly Discharge of the Winnipeg River at Kenora.

[Drainage area, 26,400 square miles.]

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
January	0.515	0.839	0.436	0.510	0.335	0.243	0.505	0.351	0.467
February	0.441	0.720	0.397	0.466	0.281	0.229	0.478	0.333	0.406
March	0.465	0.758	0.477	0.623	0.299	0.263	0.435	0.451	0.455
April	0.435	0.715	0.469	0.936	0.389	0.265	0.363	0.411	0.496
May	0.438	0.807	0.482	1.078	0.383	0.234	0.803	0.538	0.608
June	0.592	0.966	0.498	0.925	0.378	0.230	0.850	0.789	0.652
July	0.611	0.953	0.518	0.712	0.383	0.213	0.653	0.870	0.615
August	0.556	0.887	0.511	0.589	0.349	0.237	0.650	0.796	0.571
September	0.723	0.770	0.505	0.497	0.383	0.229	0.551	0.572	0.517
October	0.908	0.671	0.574	0.445	0.260	0.125	0.357	0.501	0.512
November	0.892	0.512	0.508	0.371	0.237	0.165	0.342	0.419	0.472
December	0.862	0.462	0.521	0.354	0.242	0.503	0.352	0.430	0.466
The Year	7.49	9.09	5.84	7.50	3.81	3.59	6.42	6.45	6.24
Maximum	0.908	0.966	0.521	1.078	0.383	0.503	0.850	0.870	1.078
Minimum	0.435	0.462	0.397	0.354	0.233	0.213	0.335	0.331	0.213

NOTE.-The maximum and minimum depths refer to mean monthly flows.

Table 12. -Estimated Equivalent Depth in Inches on the Drainage Area, of the Monthly Discharge of the Rainy River at Fort Frances.

[Drainage area, 11,400 square miles.]

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
January	0.472	0.962	0.411	0.776	0.229	0.427	0.539	0.538	0.514
February	0.263	0.608	0.313	0.709	0.172	0.312	0.474	0.493	0.475
March	0.391	0.561	0.411	0.812	0.203	0.380	0.514	0.538	0.487
April	0.534	0.463	0.252	0.892	0.253	0.333	0.447	0.519	0.441
May	0.487	0.636	0.338	0.850	0.369	0.433	0.531	0.551	0.514
June	0.491	0.886	0.534	0.778	0.445	0.466	0.534	0.656	0.519
July	1.042	1.041	0.891	0.532	0.318	0.616	1.111	0.839	0.822
August	1.003	1.317	0.850	0.423	0.576	0.651	0.785	0.805	0.778
September	1.039	0.832	0.711	0.491	0.464	0.509	0.835	0.753	0.727
October	1.581	0.776	0.779	0.410	0.418	0.532	0.536	0.784	0.719
November	1.312	0.582	0.419	0.439	0.419	0.522	0.435	0.710	0.621
December	1.032	0.457	0.809	0.315	0.473	0.503	0.503	0.721	0.606
The Year	10.79	8.83	6.68	7.30	4.75	5.91	6.82	7.96	7.32
Maximum	1.581	1.047	0.850	0.862	0.526	0.651	1.013	0.839	1.581
Minimum	0.263	0.457	0.252	0.315	0.172	0.339	0.471	0.493	0.172


NOTE.-The maximum and minimum depths refer to mean monthly flows.



REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

---

CHAPTER IV.  
STORAGE



## CHAPTER IV.

### STORAGE.

An accurate analysis of the storage situation in the Winnipeg River basin, covering both the conditions which have held during past years and the conditions which theoretically might have been maintained under a properly supervised control is, in view of the character and scarcity of the data on which the study must be based, a matter of some difficulty.

The discharge data which are available for the study of the run-off consist principally of records at Slave falls, Kenora, and Fort Frances, continuous since the beginning of 1907.

These discharge records do not represent the run-off under natural conditions in the basin. The stations record measurements which are influenced to a greater or less extent by the storage in, and draw from, the Lake of the Woods and Rainy lake. They will, however, furnish a fairly satisfactory basis on which to found a storage policy. Continuous gauge records of the surface level on both these lakes are available for reference throughout the period. While run-off records are published in Appendix VII for the years 1907-14, inclusive, the seven-year period from 1907-13 is considered in connection with certain analyses herein. The records for 1914 were not available in time to permit a revision of these calculations. The deductions drawn in such cases are not, however, to any appreciable degree, affected by the omission of the 1914 records.

Natural reservoirs available throughout the basin largely simplify the question of regulating the river in a satisfactory manner. The distribution of these possible sources of storage is on the whole favourable to a fairly complete measure of river control, although certain areas, more especially in the western portion, are unprovided with suitable lake area.

It is possible to deal fairly definitely with the Lake of the Woods, Rainy lake, lake Namakan, and certain of the smaller lakes, in so far as their capacities for storage are concerned, since definite information as to the banks, outlet facilities and possible flooding is to hand, or is now being secured. With regard to the majority of the lesser lakes it is only possible to treat the same in general terms since, as yet, no systematic study of their capacities has been made.

Throughout the following study of the storage question, it will be necessary to refer continuously to the lesser lakes and to the general drainage and reservoir areas. The storage discussion is therefore prefaced by a summary of these lakes, together with their surface and tributary drainage areas.

## LAKE AND DRAINAGE AREAS OF THE WINNIPEG WATERSHED.

In consequence of the Winnipeg River basin lying in the two provinces of Manitoba and Ontario, and also of the southern portion lying in the United States, it was difficult to secure a uniform plan covering the entire watershed. Various large-scale maps were available covering different sections, but co-ordination was necessary before a suitable working plan for the whole was available.

The topographic maps of the Rainy and English River districts published by the Dominion Government were taken as the basic foundation of a new plan, since they contained the best and most complete information extant covering the major part of the basin, and were, in addition, published to a convenient scale. Such sections of the watershed as were not included on these two sheets were taken by pantograph from the best obtainable published maps of Manitoba and Minnesota, the pantograph work being carefully checked by means of the lines of latitude and longitude. The completed plan is published herein as plate 3. In order to simplify the study of the natural reservoirs and their relation to the drainage system, plate 19, a diagrammatic representation of the watershed, has been prepared.


The lake areas have been taken off the best available published maps by planimeter. In view of the usually irregular character of the shore lines, and of the almost innumerable islands and islets, as well as of the incomplete character of the surveys of a number of these lakes, the areas published herein cannot be considered as entirely accurate. The areas are, however, sufficiently close to permit a general discussion of the use of the lakes as storage basins. Whenever larger scale plans of the lesser lakes were available, they were used for securing areas in preference to the smaller scale topographic plans. The larger lake areas can be considered as fairly accurate.

The above remarks apply equally to the drainage area as a whole and to the lesser basins adjacent to the lesser lakes. The boundaries of these latter sub-basins can be only approximated from the general direction of the run-off as shown on the plans. The areas are therefore used only for drawing general conclusions. All areas have been carefully checked, and the sub-areas adjusted.

The areas used throughout the report are given hereunder in tables 13, 14, 15, 16, 17, and 18. Table 13 lists the more important drainage areas useful for reference and use in considering the run-off of the watershed.

Table 13.—Principal Areas of the Winnipeg River Watershed.

River.	Limits.	Area in square miles.	Remarks.
1	2	3	4
Winnipeg river	Above mouth	53,536	
" "	Above Otter falls	50,548	Otter falls was the original metering station.
" "	Above Slave falls	49,677	Slave falls is the present metering station.
" basin	Above English river	49,096	Including English river.
" river	Above English river	27,522	Omitting English river.
" "	Above Kenora	26,393	Lake of the Woods basin.
Rainy river	Above Fort Frances	14,387	Rainy Lake basin.
" "	Above Kettle falls	7,056	Namakan Lake basin.
English river	Above mouth	21,573	
" "	Above Lac Seul	11,728	Lac Seul basin.



Note: The Lakes are located in their approximate relative position in the basin




TABLE OF LAKE AREAS		
SEQ. NO.	NAME OF LAKE	AREA OF LAKE
1	CLAY	24 96
2	BULL	1
3	CRONIN	7
4	DOULDER	0
5	DEW LICK	0
6	EDGE	0
7	EDGE	0
8	EDGE	0
9	EDGE	0
10	EDGE	0
11	EDGE	0
12	EDGE	0
13	EDGE	0
14	EDGE	0
15	EDGE	0
16	EDGE	0
17	EDGE	0
18	EDGE	0
19	EDGE	0
20	EDGE	0
21	EDGE	0
22	EDGE	0
23	LAKE OF THE WOODS	100
24	EDGE	0
25	EDGE	0
26	EDGE	0
27	EDGE	0
28	EDGE	0
29	EDGE	0
30	EDGE	0
31	EDGE	0
32	EDGE	0
33	EDGE	0
34	EDGE	0
35	EDGE	0
36	EDGE	0
37	EDGE	0
38	EDGE	0
39	EDGE	0
40	EDGE	0
41	EDGE	0
42	EDGE	0
43	EDGE	0
44	EDGE	0
45	EDGE	0
46	EDGE	0
47	EDGE	0
48	EDGE	0
49	EDGE	0
50	EDGE	0
51	EDGE	0
52	EDGE	0
53	EDGE	0
54	EDGE	0
55	EDGE	0
56	EDGE	0
57	EDGE	0
58	EDGE	0
59	EDGE	0
60	EDGE	0
61	EDGE	0
62	EDGE	0
63	EDGE	0
64	EDGE	0
65	EDGE	0
66	EDGE	0
67	EDGE	0
68	EDGE	0
69	EDGE	0
70	EDGE	0
71	EDGE	0
72	EDGE	0
73	EDGE	0
74	EDGE	0
75	EDGE	0
76	EDGE	0
77	EDGE	0
78	EDGE	0
79	EDGE	0
80	EDGE	0
81	EDGE	0
82	EDGE	0
83	EDGE	0
84	EDGE	0
85	EDGE	0
86	EDGE	0
87	EDGE	0
88	EDGE	0
89	EDGE	0
90	EDGE	0
91	EDGE	0
92	EDGE	0
93	EDGE	0
94	EDGE	0
95	EDGE	0
96	EDGE	0
97	EDGE	0
98	EDGE	0
99	EDGE	0
100	EDGE	0
101	EDGE	0
102	EDGE	0
103	EDGE	0
104	EDGE	0
105	EDGE	0
106	EDGE	0
107	EDGE	0
108	EDGE	0
109	EDGE	0
110	EDGE	0
111	EDGE	0


Department of the Interior, Canada  
 MINISTRE DES TERRES ET DES RESSOURCES NATURELLES  
 Water Power Branch  
 110 Laurier Street, Ottawa, Ontario

### WINNIPEG RIVER POWER SURVEY.

#### HELIODRAMMATIC PLAN OF WINNIPEG RIVER BASIN

RELATION OF THE LAKE AREAS TO THE RIVER SYSTEM

1. QUANTITATIVE RELATIONSHIP BETWEEN LAKE AND RIVER SYSTEMS  
 2. QUALITATIVE RELATIONSHIP BETWEEN LAKE AND RIVER SYSTEMS








Table 14—Storage Possibilities of the Winnipeg River Watershed in the Lakes tributary to the Lake of the Woods and below Rainy Lake.

No.	Lake or River.	BASIN.			RESERVOIR.			Remarks.				
		AREA IN SQUARE MILES.		AVERAGE DEPTH IN FEET.	AREA IN SQUARE MILES.	DEPTH OF STORAGE IN FEET TO HOLD ONE AVERAGE YEAR'S RUN-OFF.	BILLIONS OF CUBIC FEET IN LAKE ASSUMING STORAGE.					
		To outlet of	Ad- jacent Area.						Total.	Sec.-ft.	Billions of Cu. Ft.	Name.
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.	11.	12.	
6-0	Winnipeg River.	Lake of the Woods		26,491	13,600	429.00	Lake of the Woods	15	1,500	10.25	209.30	Total area above Kenora
6-1	Dogtooth Lake.	Dogtooth Lake.		134	69	2.18	Dogtooth Lake	4	4			
6-2	Dryberry Lake.	Dryberry Lake.		246	127	4.00	Dryberry Lake	4	21	3.72	22.18	3.72 feet storage.
6-3	Whitfish Lake.		1144		74	2.53	Whitfish Lake	4	47	3.05	34.00	3.05 feet storage.
6-31	Atikwa Lake.		1192		99	3.12	Atikwa Lake	19	19	4.32	23.34	4.32 feet storage.
6-32	Rowan Lake.		1351		181	5.71	Rowan Lake	22	24	4.66	33.12	4.66 feet storage.
6-33	Kakagi Lake.	Kakagi Lake.	1112		58	1.82	Shumawa Lake	4	49	5.24	5.44	5.44
6-34	Big Pine Lake.	Big Pine Lake.		799	412	12.99	Kakagi Lake	4	44	1.48	21.82	31.48 feet storage.
6-4				145	75	2.36	Big Pine Lake	2	5			
							Kottinagamak Lake.	6				
							Keshkattena Lake.	6				
							One Subed Lake.	3				

<sup>1</sup>Drainage areas immediately adjacent to lakes listed in column 3.  
<sup>2</sup>These lake areas are taken from large scale maps.  
<sup>3</sup>Average year's run-off equivalent to less than 5 feet on the reservoir area.  
 The results in column 11 are based on an average annual run-off of 2 inches.

Table 15.—Storage Possibilities of the Winnipeg River Watershed in the Lakes tributary to Rainy Lake and below Lake Namakan.

No.	Lake or River.	AREA IN SQUARE MILES.			RUN-OFF AVERAGE IN YEAR.			Name.	RESERVOIR AREA IN SQUARE MILES.	Depth of Storage in feet to hold one average year's run-off.	Billions of cubic feet in Lake, assuming 5 ft. Storage.	Remarks.
		To Outlet of Basin.	Adjacent to Basin.	Total.	No. ft. of Run-off.	Billions of Cubic Feet.						
1.	1.	6.	4.	5.	6.	7.	8.	9.	10.	11.	12.	13.
7-0	Rainy River			14 887	7 430	233 80	Rainy Lake	340	25 40	46 01	Total area above Rainy Lake.	
7-1	Footprint Lake			478	195	6 14	Footprint Lake	4				
							Deer Lake	6				
							Clearwater Lake	13				
							Pipestone Lake	12				
							Jacksfish Lake	8				
							Loom Lake	9				
7-2	Manitou Lake			361	188	5 92	Kistarskans Lake	57	4 87	36 14	10 feet storage permissible.	
							Manitou Lake	28				
							Manitowish Lake	20				
7-3	Oukamungon Lake.			438	226	7 12	Manitowish Lake	17	4 42	35 92	4 42 feet storage.	
7-4	Turtle River		669	348	448	16 87	Turtle Lake	9	15 02	2 47	40 ft. storage permissible.	
							Turtle Lake	19	13 94	3 91		
7-41	Turtle River		318	71	71	2 24	Martins Lake	5				
							Whitfish Lake	4				
							Manitowish Lake	8				
7-42	Turtle River		1559	288	288	9 69	Turtle Lake	14	5 75	1 95		
							Richard Lake	5				
							Richard Lake	5				
7-43	Turtle River		1803	187	187	4 93	Reading Lake	5	13 03	3 40	7 ft. storage permissible.	
							White Otter Lake	42			5 69 feet storage.	
7-44	Turtle River		1107	85	85	1 74	Sandford Lake	10	3 6	1 93	4 68 feet storage.	
7-45	Saine River		11 611	841	916	26 22	Clearwater West Lake	17	3 68	1 74	4 68 feet storage.	
							Shoal Lake	11				
7-51	Saine River		1140	57	57	1 79	Shoal Lake	18	52 20	3 51	8 feet storage.	
7-52	Saine River		4682	381	381	11 99	Red Vermilion Lake	14	4 38	1 79	8 feet storage.	
7-53	(Total)		2 403	1 239	39 30		La des Mills Lake	67	5 91	9 55	4 ft. storage permissible.	

Drainage areas immediately adjacent to lakes in column 4.

Drainage areas are taken from large-scale maps.

Average run-off is assumed equivalent to less than 8 feet on the reservoir.

The results in column 11 are based on an average annual run-off of 7 inches.



Table 17.—Storage Possibilities of the Winnipeg River Watershed in the Lakes tributary to the English River below Lac Seul.

No.	Lake of River.	BASIN.			RESERVOIR.			Remarks.
		AREA IN SQUARE MILES.	RUN-OFF IN AVERAGE YEAR.	NAME.	AREA IN SQUARE MILES.	DEPTH OF STORAGE IN FEET TO HOLD ONE AVERAGE YEAR'S RUN-OFF.	BILLIONS OF CUBIC FEET IN LAKE, ASSUMING 5 FT. STORAGE.	
		To Outlet of	Sec.-ft.		Total.			
1.		3.	6.	8.	9.	11.	12.	13.
4-0	English River	Mouth	11,120	Clay Lake	23	17-35	4-18	Total area above mouth.
4-1	Wabigoon River	Clay Lake	460	14-52	17	30	4-18	
4-11	Canon River	Canon Lake	177	5-58	11	32	4-46	Includes lesser lakes.
4-12	Eagle River	Eagle Lake	489	15-43	6	127	313-43	34-36 feet storage.
4-13	Wabigoon River	Wabigoon Lake	525	16-58	57	77	10-73	With Diiorwaie Lake.
4-1	(Total)		1,651	52-11	12	30	34-82	
4-2	Long-legged River	Long-legged Lake	121	3-82	80	4-57	32-54	34-57 feet storage.
4-3	Cedar River	Clearwater Lake	80	2-54	22	4-13	34-13	34-13 feet storage.
4-4	Cedar River	Wabaskang Lake	299	9-48	14	38	5-30	
4-5	Red Lake River	Pakwash Lake	474	13-36	12	37	8-91	
4-51	Red Lake River	Gull Rock Lake	149	4-37	10	55	8-71	
4-52	Red Lake River	Red Lake	542	17-10	3	67	9-77	
4-53	Trout Lake River	Trout Lake	215	6-80	5	62	9-68	
4-5	(Total)		1,320	41-63	118	135	31-81	31-81 foot storage.

Drainage areas immediately adjacent to lakes listed in column 3.

<sup>1</sup>These lake areas are taken from large scale maps.

<sup>2</sup>Average year's run-off equivalent to less than 5 feet on the reservoir area.

<sup>3</sup>The results in column 11 are based on an average run-off of 7 in./in.

Table 18.—Storage Possibilities of the Winnipeg River Watershed in the Lakes tributary to the English River above Lac Seul.

No.	Lake or River	BASINS			RUN-OFF IN AVERAGE YEAR			Name	RESERVOIR		Billions of cubic feet in Lake, assuming Storage.	Depth of Storage in feet to average 3 ft. run-off.	Remarks.
		To Outlet of	Adjacent Area.	Total.	Sec.-ft.	Bill. Cu.-ft.	Area in Square Miles		Total.				
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.	11.	12.	13.	
9-0	English River	Lac Seul		411,728	6,048	190.70	Lac Seul	340	30.40	47.42	Total area above Lac Seul.		
9-1	Rock Lake	Rock Lake		128	66	2.68	Rock Lake	9	8.30	1.25			
9-2	Vermilion Lake	Vermilion Lake		176	92	2.91	Vermilion Lake	40	47	32.91	2.82 feet storage.		
9-3	English River	Mimutaki Lake.	12,434		1,255	39.61	Little Vermilion Lake Mimutaki Lake	94					
9-31	Sandy Lake	Sandy Lake	1,101		52	1.63	Barrel Lake	14	143	39.95			
9-32	Kukukus Lake	Kukukus Lake	1,240		124	3.90	Blue Lake	14	11	1.63	14.21 feet storage.		
9-33	Indian Lake	Indian Lake	1,439		180	5.67	Basket Lake	40	63	33.90	12.22 feet storage.		
9-34	English River	Shukog Lake	1,299		154	4.86	Indian Lake	18	48	35.67	14.24 feet storage.		
9-3	(Total)	Botstord Lake	957	3,423	1,765	55.67	Almangvers Lake	22	38	54.86	11.59 feet storage.		
9-41	Lake of Bays	Lake of Bays	1,205		166	3.33	Bell Lake	19	38	4.59			
9-42	Sturgeon River	Sturgeon Lake	1,477		236	7.76	Botstord Lake	8	27	3.77			
9-4	(Total)	Green Grass Lake	1,251	1,639	845	26.64	Dog Lake	19	27	3.77			
9-5	Green Grass Lake	Green Grass Lake	1,251	572	295	9.30	Lake of Bays	18	25	34.33	4.78 feet storage.		
9-6	Winnasaga River	Bluff Lake	1,161		129	4.08	Pemass Lake	7	92	34.33	13.02 feet storage.		
9-62		Slate Lake	1,236		238	7.50	Sturgeon Lake	47	70	49.40	4.76 feet storage.		
9-6	(Total)	Seskemog Lake	1,236	948	489	15.43	Bluff Lake	33	6	0.84			
							Slate Lake	11	11	1.34			
							Seskemog Lake	16	16	2.23			

<sup>1</sup>Drainage areas immediately adjacent to lakes listed in column 3.  
<sup>2</sup>These lake areas are taken from 1:62,500 maps.  
<sup>3</sup>Average year's run-off equivalent to less than 8 feet on the reservoir.  
 The results in column 11 are based on an average annual run-off of 7 in. less.

Table 14 groups the lakes and drainages tributary to the Lake of the Woods and below Rainy lake; table 15 those tributary to Rainy lake and below lake Namakan; 16 those tributary to lake Namakan; 17 those tributary to the English river below Lac Seul; and 18 those tributary to Lac Seul.

In these tables, columns 2 to 7 refer to drainage basins. Column 1 lists the number which has been used to designate the drainage basin; the decimal system has been used to permit future expansion without interfering with the series. Column 2 designates the drainage basin, while column 3 gives the limits considered in each case; column 4 lists the area immediately adjacent to the basin designated and defined in columns 2 and 3; column 5, the total drainage area of the basin designated and defined in columns 2 and 3; column 6, the run-off in cubic feet per second for an average year, from the areas of columns 4 and 5; column 7, the same run-off in billions of cubic feet. Columns 8 to 12 refer to the reservoirs available to store the run-off from the basins defined in columns 2 and 3; column 8 lists the name of the reservoir. It will be noted that at times several lakes are taken in the one basin. Column 9 lists the individual lake area, and column 10 the totals of the areas where more than one are taken in the same basin. Column 11 lists the depth in feet to which an average year's total run-off (equivalent to 7 inches) from the drainage areas of columns 4 and 5 would fill the lakes, assuming no run-off at the outlet during the period. It will be noted that where more than one lake has been considered in one basin, the depth is given in terms of the total lake area. This is not strictly in accordance with what would be experienced in actual practice, as the lakes are not, as a rule, distributed in such a way as to collect the run-off uniformly. It, however, serves the purpose for general discussion. Column 12 lists the volume of storage in billions of cubic feet which would be provided by 5 feet of storage on the lakes, or by such depth as would store an average year's run-off.

It should be noted that a large number of smaller lakes are not included in the tabulation.

The entire watershed is well supplied with lakes, the use of which for storage purposes will well repay investigation. These lakes naturally and with good effect play their part in regulating the yearly run-off. Comparatively little expenditure is necessary to convert many of them into reservoirs of greater or less capacity. At the outlets of many lakes, lumber dams have been constructed in the past, of which some are yet in operation, and others have been allowed to fall into decay. It was beyond the scope of the general storage investigation carried on by the Dominion Water Power Branch to make any detail study of these lesser lakes. A certain amount of information has, however, been collected by the Hydro-electric Power Commission of the province of Ontario with regard to some of the more important lakes. The following quotations have been taken direct from the Sixth Annual Report of this commission, covering the year ending October 31, 1913:

ONTARIO HYDRO-ELECTRIC POWER COMMISSION REPORT 1913.

"*Manitou lakes.* The drainage area of these lakes is about 446 square miles, and the area of the lakes themselves is about 66 square miles.

"A storage draft of 7 feet off these lakes would provide approximately 13,000 million cubic feet of storage, which would probably be more than sufficient to control the entire mean annual run-off of the tributary watershed.

"At present there is a government dam at the foot of the lower lake that would hold a storage head of 9.9 feet if it were in good condition.

"The shores of the lake are for the most part rock, with large patches of good jack pine here and there, but this is all well up from the lake. The present dam did practically no damage to timber, and the damage caused by a dam that would raise the water 3 feet higher than at present would be very small.

"The sill of the log chute of the present dam is sufficiently low to let the water run as low as the controlling ledge at Cedar rapids, which is above the dam. The present dam had the stoplogs in when the dam was inspected, but it was leaking about 150 second-feet, partly through and partly underneath. A cross-section parallel and similar to the one taken exists 50 feet below the present dam.

"No building sand was observed on this lake. The buildings around the lake are high enough to permit of a rise of 3 feet above high-water mark. These are only log shacks, not used at present.

"The present dam is not built on solid rock, but the banks of the river are solid rock, with large boulders and gravel bottom in the river-bed.

"The lumbermen who remembered this dam from its installation had never known the lake to be filled to the top of the dam.

"*Otukamawan lake.* The drainage area of the lake above a possible dam site is about 500 square miles, and the area of lake surface above this site is about 18 square miles.

"A dam at this point holding 30 feet of water on the sills would impound a run-off of 12 inches from the tributary watershed. This figure is probably greater than the actual mean annual run-off.

"There is evidence at the outlet of the lake to show that there existed at one time a small dam probably holding a 2- or 3 foot head of water, but no impounding action is caused by the fragments which now remain.

"The foundations at this point are all solid rock. There is a controlling rock ledge at the outlet which is only 4.5 feet below present water level, and which would necessitate keeping all the storage head above this level unless the ledge was blown out.

"There is sand of good quality on the shores of the lake at various points; and also gravel, but the surface gravel is not free from dirt.

"The shores of the lake have, as a general rule, steep slopes and

The drainage connection with the Manitowish, Otukamawan, Lac Seul, M.P., Lac Seul, and Lac Seul water lakes, have been quoted directly from the Sixth Annual Report of the Hydro-Electric Power Commission of the Province of Ontario.

in many places are precipitous, but there is nevertheless some good pine of tie size and larger that would suffer damage by flooding. This is confined, however, to a very narrow strip parallel to the water line.

"The map used of this lake shows all the islands, as far as could be judged, except the very small ones. This lake is sometimes called Trout lake. A 30-foot rise in level on this lake would add very little to its area.

"*Lac des Mille Lacs.*—The drainage area of this lake is about 620 square miles, and the area of the lake surface is 90 square miles.

"Assuming 4 feet of storage draught available through raising the level and deepening the outlet, this lake would have an impounding capacity of about 10,000 million cubic feet. This volume of storage would be provided by a mean annual run-off of 7 inches from the tributary watershed.

"The raising of the level of this lake to any great extent will drown large tracts of muskeg, but without serious damage to timber, most of the low-lying timber being tamarack, which is still alive but not liable to damage by flooding. The valuable timber on the lake stands sufficiently high to be outside of any possible flooded area.

"The lumber camps on the lake are of no value.

"Damage to property by raising the level of this lake would occur at two places:

"(1) *Hogans' Mill.*—Hogan Brothers, of Savanne, are the owners of most of the timber limits on the lake, and are the proprietors of a large saw-mill on the lake shore 2 miles west of Savanne station, on the Canadian Pacific railway. The saw-mill is fully equipped with a complete outfit for lumber, lath, and shingles, and is connected by a mile spur line to the Canadian Pacific railway, besides having more than half a mile of track through the piling yard. There is a bush road from Hogans' mills to Savanne.

"An increase of 3.5 feet over the present level of the lake would not damage the mill. Any higher level than this would affect the boiler room of the mill and also the piling yard track, and a 500-foot wharf and storehouse.

"The other buildings, residences, storehouses, offices, etc., belonging to the mill are all between 10 and 12 feet above the level of the lake.

"(2) *At Savanne.*—Taking the level of the lake as 100, the elevations of buildings and railway at Savanne are given below:—

Canadian Pacific Railway, bridge over creek	Base of rail	110.9
	Bottom of girder	107.7
F. Edward's store and post office	Floor elevation	105.0
	Cellar floor elevation	101.0
	Floor of warehouse elevation	103.0
	Two barns	103.0
Ice-house	Elevation of floor	102.5
Station lavatories	Elevation of floor	103.0
Other Canadian Pacific Railway buildings, station, tool houses, section house, et	Elevation of floors	108-110
Road bridge, 150 feet long	Elevation of floor	103.8
Canadian Pacific Railway track, 1 mile each side of the river to rising grade	Base of rail	110.9
Six frame and log houses	Elevation of floors	104-105
One log house south of Canadian Pacific Railway track	Elevation of floor	104.5

"The above list includes all the habitable or used buildings at

Savanne. The buildings on the Indian reserve are all above any possible flood level. The residents at Savanne state that the river level varies a foot in elevation with changes in the wind. Some of the above-mentioned houses have cellars which are at present below the ordinary spring flood level.

"The muskeg surrounding that branch of the river passing under the Canadian Pacific Railway bridge extends  $2\frac{1}{2}$  miles north of the Canadian Pacific railway, at an elevation of 2 feet to 3 feet above the present level of the lake.

"*White Otter or Big Clearwater Lake.* The drainage area of this lake above the present dam is about 320 square miles, and the area of the lake above the dam is about 50 square miles. With 7 feet of storage draught on this lake there would probably be more than sufficient capacity to impound the mean annual run-off of the tributary watershed.

"Within the last two years a dam has been erected at the outlet of this lake capable of holding at least 7 feet of water on the sills, but a controlling ledge of rock in the outlet just above the dam makes it doubtful if the lake could be drained as low as the sill.

"The timber on this lake is practically all above any damage from flood water. There are a few old lumber camps on the lake, but these are also above any possible storage level. There is a gully not far from the present dam that would permit the water to flow out before the water would rise to the crest of the present dam. There are several low places above the present dam without timber which would be flooded, but high ground is close in every case.

"*East Clearwater Lake.* The drainage area of the lake is about 75 square miles, and the area of the lake surface above the outlet is about 12.4 square miles.

"There is a storage dam at present at the lake which was built at the time of the installation of the power plant of the Hammond Reef Mine, some thousand feet below the dam.

"The dam is in good condition, though the sluice-gate screw block is damaged and the gate has to be levered up and down. The dam is built of stone-filled cribs and well backed with dry masonry, all on rock foundations. The sluice-gate is a single steel plate, braced with angle steel, and was operated by a screw-block above the gate.

"The extreme high-water mark is below the level of the top of the dam, which has more than sufficient capacity to hold all the water delivered to the lake.

"The shores of the lake are steep sloping rock, with no good timber at all near the water-line."

#### THE OTTER SLAVE FALLS DISCHARGE RECORDS.

The station at Slave falls measures the discharge from 49,700 square miles of drainage basin, and for all practical purposes can be taken as representing the flow which is available throughout the power reach of the river in Manitoba.

While the discharges from month to month are affected by the storage already in operation, and do not therefore represent natural conditions or furnish a correct estimate of the actual run-off from the basin for any one month, they nevertheless balance up satisfactorily in the seven-year cycle.

#### MAINTENANCE OF THE SEVEN YEAR MEAN FLOW.


The mean monthly flow for the seven-year period from 1907 to 1913, inclusive, was 25,855 second-feet. It will be illuminative of the general conditions of run-off to look into what would have been involved in the maintenance of this mean flow throughout the cycle, had the means for storage been available. To this end, plate 20 has been prepared.

Little explanation of plate 20 is required. The monthly volumes of discharge in billions of cubic feet are plotted above and below the mean 25,855 second-foot line. The continuous volume available from month to month from the beginning of the period is plotted as a curve referred to the scale to the right of the diagram.

During the earlier portion of the year 1907, as might naturally be anticipated, a deficit of some 85 billions of cubic feet occurs between January 31 and May 31. To make this good would have necessitated drawing storage from the preceding year. Following May 31 comes a prolonged period of high run-off in the river, the discharge in no place falling below the mean until November 30, 1908. At this date the volume available for storage purposes from the commencement of the period amounted to 378 billions of cubic feet over and above the mean flow, or 460 billions of cubic feet, assuming that the first deficit was made good from the previous year. Following November 30 is a period of low water lasting until March 31 of 1910, involving a draw of 138 billions of cubic feet from the available storage. The months of April, May, June, and July, 1910, show another period of surplus discharge, adding 197 billions to the preceding volume, and bringing the net total for storage to date up to 437 billions. Following July 31, there is a practically continuous draw until May 31, 1912, at which date the surplus from the beginning of the period is reduced to 4 billions of cubic feet. From this date until the end of 1913, there is an alternate rise and fall in the volume available, the same dropping to zero at the end of the cycle.

It is worthy of note that after the initial deficit is made good, there is at all times throughout the cycle a sufficient volume of water to maintain the uniform mean flow of 25,855 second-feet. The curve of available volume approaches close to the mean line in 1912, but falls below at only one point during the period, i.e., during the initial deficit. That there should have been throughout the entire period, with the single exception noted, sufficient water to maintain the uniform seven-year mean flow is due to the exceptionally heavy run-offs during the first years of the cycle. These full years are followed in 1911 by an exceptionally slack year, the tiding over of which places a severe strain on the entire storage system.

The above analysis shows that storage reservoirs to the capacity of 437 billions of cubic feet would have been required to ensure a complete uniform flow during the seven years. Upon examining the basin, however, it will be





noted that there are practically no reservoirs available in an area of about 3,800 square miles above Slave falls. This area in an average year would have a run-off of nearly 1950 cubic feet per second. Imperfect distribution of reservoirs to meet the full requirements of the run-off, together with the extensive area of the basin and the inaccessible nature of portions of it, also tend to prevent such regulation being attained.

MAINTENANCE OF A 20,000 SECOND-FOOT MINIMUM FLOW.

The series of designs and estimates of the projected power plants along the river considered in this report, has been developed for an initial installation, based on a minimum flow of 12,000 cubic feet per second, such as is at present available on the river, and for a final installation based on a flow regulated to a minimum of 20,000 cubic feet per second. A full investigation into the questions involved in maintaining this latter flow is therefore desirable. The mass curve shown on plate 21 analyses this question.

Plate 21 is plotted by taking as abscissa the time in months, and as ordinate the volume available for storage from month to month. The curve furnishes the following information as to discharge and storage conditions. The crests and hollows indicate the instants of time when the supply is exactly equal to the 20,000 second-foot demand. The rising portions of the curve indicate a surplus of supply over demand, while a falling portion indicates the reverse, the volume of such surplus or deficit between any two dates being secured by scaling off the ordinate between the same. A tangent drawn horizontally from any of the high points on the curve until it intersects the rising curve, measures the period during which the reservoir would be drawn below the high-water line, and the maximum draft drawn from such tangent to the curve indicates the necessary capacity of the reservoir to maintain the demand during the period. To ensure a full reservoir it is necessary that a parallel tangent drawn backwards from the low points shall intersect the supply curve at some point below.

At only one point throughout the seven-year period is there any insufficiency of water to maintain a 20,000 second-foot flow. A slight slack period occurs in May, 1907, and is due to the low winter flow during the earlier part of the year. Following this discrepancy is a continuous series of months to February, 1909, during which there is a surplus flow in the river, totalling 768 billions of cubic feet, all of which is available for storage. Two months slack water are again followed by ample discharge lasting until the end of August, 1910, and rendering available another 313 billions of cubic feet. Following this date comes the period of low water which calls for the most extensive storage provision in the seven-year cycle. By the end of June, 1911, the curve indicates that a continuous flow of 20,000 second-feet would require a draw on storage to the extent of 131 billions of cubic feet, while the water in the reservoirs would be drawn below highwater mark from August, 1910, until November, 1912, at which date the surplus flow available from April 1 of the latter year would be sufficient to make good the draw. For the balance of the period the run-off conditions are more uniform and the draws from storage less extensive. If the Lake of the Woods were immediately available for the


**DOMINION WATER POWER BRANCH**  
 J. B. CHALLIES, Superintendent

**WINNIPEG RIVER**  
**AT SLAVE FALLS**

MASS CURVE OF RUNOFF ABOVE 30,000 CUBIC FEET  
 PER SECOND

Total capacity report on POWER AND STORAGE  
 INVESTIGATIONS by J. T. JOHNSTON B.A.S.

May 1916



disposed of the surplus run-off, sufficient storage for bridging the above critical period would be a simple matter, since 3.1 feet on the Lake would supply the maximum draw, and would bridge the entire low-water period. The lake, however, can deal only with the waters from the basin above its outlets, and must, in addition, provide for power plants operating at its outlets.

Table 19 appended is of interest as showing to what extent storage would have been necessary to maintain various limiting minimum flows throughout the cycle. For the sake also of illustrating the capacity of the Lake of the Woods as a storage reservoir, the corresponding depths on the lake necessary to accommodate this storage for the different stages are also tabulated. As already stated, it is not possible to utilize the lake as advantageously as the table would indicate.

Table 19. Storage Conditions which would have been necessary to maintain various Minimum Flows on the Winnipeg River at Slave Falls from 1907 to 1913.

To ensure minimum flows in Sec. 11 of	Volume of Storage required in Billions of Cubic Feet	Depth in Feet on the Lake of the Woods to store Volumes in col. 2.	To ensure minimum flows in Sec. 11 of	Volume of Storage required in Billions of Cubic Feet.	Depth in Feet on the Lake of the Woods to store Volumes in col. 2.
1	2	3	1	2	3
13,000	4	0.07	20,000	128	3.06
14,000	16	0.34	21,000	168	4.02
15,000	32	0.77	22,000	222	5.31
16,000	48	0.85	23,000	277	6.59
17,000	65	1.55	24,000	335	7.78
18,000	80	1.91	25,000	420	10.04
19,000	107	2.56	26,000	510	12.92

To sum up, it may be said that the general run-off conditions in the power reach of the river would warrant the assumption that a fairly complete regulation of the river can be attained.

#### THE LAKE OF THE WOODS.

A glance at the drainage basin of the Winnipeg river (plate 3) immediately calls attention to the outstanding position of the Lake of the Woods. A study of the physical features of the basin emphasizes even more strongly the commanding position of the lake in relation to storage and power. This relation is somewhat complex and, in view of the conditions of regulation and control which have existed during the cycle over which records are available, its discussion requires careful analysis.


In the eight-year cycle over which records are available, there is a period of ample flow preceding a period of unusually low flow, thus forming a combination which readily lends itself to an effective study.

The manifest advantages of the lake as a reservoir have long been recognized by the power undertakings at the outlets. Since, however, the water utilized



# MICROCOPY RESOLUTION TEST CHART

(ANSI and ISO TEST CHART No. 2)



APPLIED IMAGE Inc

1653 East Main Street  
Rochester, New York 14609 USA  
(716) 482-0300 - Phone  
(716) 288-5989 - Fax

for power has at all times to the date of writing been considerably below the run-off available, careful conservation has hitherto been unnecessary. This condition is rapidly becoming a thing of the past. The development of hydroelectric plants on the lower river in Manitoba has already resulted in an urgent demand for auxiliary flow during the low months. Through the agency of the Dominion Water Power Branch a special arrangement was reached with the Ontario Government and the power users at the lake outlets, whereby the lake was drawn upon during the winter of 1913-14, and a critical power situation on the lower river thereby relieved. Similar conditions prevailed during the winter of 1914-15 necessitating a similar draw on the lake storage. Such demands for raising the minimum flow on the lower river will become more pressing in the immediate future. The Lake of the Woods is the logical first source of such storage supply, in that it is already existent as a storage basin, and is of adequate capacity to meet all demands for a considerable time to come.

As the use of the Lake of the Woods for storage purposes has become international owing to a reference regarding the levels of the lake having been submitted to the International Joint Commission, the importance and necessity to the power interests of the Winnipeg river in Manitoba, of the use of the Lake of the Woods for reservoir purposes, is treated in more detail in chapter IX of this report.

#### GENERAL RELATION OF THE LAKE TO THE BASIN.

The Lake of the Woods has a surface area of some 1,500 square miles. The accurate determination of its area is a matter of considerable difficulty as it is dotted with the innumerable islets and islands characteristic of lakes in territory of similar geological formation. On the entire northern and eastern shores of the lake, the exposed granite forms in general, abruptly sloping banks, with here and there short intervening stretches of shore and muskeg land. Along the southern and western shores the natural features are entirely different. The general country is of a flat alluvial description, with low-lying and swampy areas, especially along the Minnesota shore. Throughout the southwestern section of the lake, the island formation disappears, and open water prevails.

Four outstanding features combine to render the Lake of the Woods a reservoir which is invaluable to the power interests on the river below. These features may be summarized as: the great surface area of the lake, its large tributary watershed area, the great dependable power opportunities below, and the existing controlling works at the outlets. The surface area has already been referred to. Twenty-six thousand four hundred square miles of drainage area above the lake forms a supply basin in keeping with the great capacity of the reservoir. Below the lake, there is a drop of 77 feet to the boundary of Manitoba, practically all of which can be developed. Within the latter province is a total drop of 270 feet, of which 250 feet is now being, or can be developed. The outlets of the lake have been very fully referred to in chapter III, and a reference to plate 13 will render the situation there clear.

## OUTLETS FROM THE LAKE OF THE WOODS.

All the outlets are now artificially controlled, three for power purposes, one by means of an old intake structure at present kept permanently closed by stop-logs, and the fifth by the Norman dam.

The Norman dam, more fully described in chapter V, spans the western outlet and was originally built as a combined control and power dam, incorporating eight 21-foot power sluices with sills at elevation 1,040.6 (Water Power Survey datum), four being adjacent to either bank, and twelve 15.5-foot regulating sluices with sills at elevation 1,038.7. All control is by means of stoplogs. Up to the present no power development construction has been undertaken in connection with the dam, and the entire twenty sluices have been available for regulation purposes.

This dam is the crucial feature, not only in the regulation of the Lake of the Woods as a unit, but in its proper and permanent control in the interests of hydro-electric development along the entire river below.

Under an agreement dated June 22, 1898, between the Ontario Government and the Keewatin Power Company, the regulation of the lake in the interests of navigation is placed under the control of the Minister of Public Works of the province of Ontario. Should the company proceed with the contemplated power development in conjunction with the dam, it may, if it sees fit, terminate the above agreement, guaranteeing, however, to maintain the water in the lake at ordinary summer level for navigation purposes at all proper times.

Since the completion of the Norman dam the regulation of the lake level has been at times unsatisfactory to practically all the interests concerned. This has been due almost entirely to an insufficient grasp of the magnitude and diversity of the interests affected, and to the lack of run-off data upon which the capacity and resources of the lake and watershed could be established and properly conserved. It is hoped that the information compiled and presented in this report and which is being continually augmented by further field study, will supply this deficiency.

The importance of, and necessity for placing the control of the regulation of the Norman dam in the hands of an impartial central authority will become more apparent as the relation of the lake to the basin as a whole is analysed.

## SURFACE LEVELS OF THE LAKE OF THE WOODS.

It is not the purpose here to go into a detailed study of the past surface levels of the Lake of the Woods. An exhaustive investigation into this question is now being carried on by Mr. S. S. Scovil of the Lake of the Woods Technical Board, and a comprehensive report will soon be possible. It is necessary, however, to discuss the general conditions which have existed during the past few years, in order to properly appreciate what will be involved by a regulation of the lake in the interests of the power plants and projects on the river below. To this end, table 20 of mean monthly elevations is appended.

Table 20.—Mean Monthly Elevations of the Surface of the Lake of the Woods.

Month.	1899.	1900.	1901.	1902.	1903.	1904.	1905.	1906.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
January	1,059.0	1,059.2	1,060.1	1,058.0	1,059.1	1,057.9	1,057.5	1,060.3	1,057.9	1,060.4	1,058.4	1,059.3	1,056.5	1,055.4	1,059.2	1,058.8	1,058.6
February	1,058.0	1,058.6	1,059.8	1,057.8	1,059.2	1,057.7	1,057.1	1,060.2	1,057.7	1,060.2	1,058.2	1,059.4	1,056.3	1,055.3	1,059.1	1,058.8	1,058.4
March	1,058.0	1,058.2	1,059.0	1,057.7	1,058.9	1,057.5	1,056.9	1,059.5	1,057.5	1,059.9	1,057.9	1,059.3	1,055.8	1,056.2	1,059.4	1,058.7	1,058.1
April	1,058.4	1,058.0	1,059.0	1,057.5	1,059.0	1,057.3	1,056.9	1,059.3	1,057.2	1,059.6	1,057.7	1,060.0	1,055.8	1,056.9	1,059.7	1,059.3	1,058.6
May	1,059.2	1,058.1	1,059.6	1,058.6	1,059.8	1,058.2	1,057.8	1,059.9	1,057.6	1,059.9	1,058.5	1,059.4	1,056.0	1,056.9	1,059.6	1,060.0	1,059.0
June	1,060.0	1,058.1	1,059.7	1,058.1	1,060.0	1,058.8	1,058.7	1,059.8	1,058.4	1,060.9	1,058.5	1,058.8	1,056.0	1,057.5	1,059.6	1,060.0	1,059.0
July	1,060.8	1,057.9	1,060.0	1,059.2	1,059.5	1,059.3	1,060.1	1,059.8	1,058.3	1,059.5	1,058.6	1,058.1	1,055.7	1,058.2	1,059.5	1,059.9	1,059.0
August	1,060.0	1,057.6	1,059.5	1,059.3	1,059.1	1,059.2	1,060.7	1,059.6	1,060.0	1,059.2	1,058.6	1,057.6	1,055.6	1,058.7	1,058.9	1,059.1	1,058.9
September	1,059.5	1,058.9	1,059.3	1,059.4	1,058.7	1,058.7	1,060.9	1,058.5	1,060.8	1,058.9	1,058.7	1,057.1	1,055.6	1,059.4	1,058.7	1,059.3	1,058.8
October	1,059.8	1,060.4	1,058.8	1,059.1	1,058.6	1,058.5	1,058.1	1,058.3	1,060.7	1,058.6	1,058.9	1,056.9	1,055.6	1,059.5	1,058.8	1,059.4	1,058.8
November	1,059.8	1,060.7	1,058.2	1,059.0	1,058.3	1,058.3	1,060.1	1,058.3	1,060.7	1,058.6	1,058.7	1,056.8	1,055.6	1,059.5	1,058.8	1,059.4	1,058.8
December	1,059.6	1,060.4	1,058.0	1,058.6	1,058.7	1,057.7	1,060.3	1,058.0	1,060.6	1,058.5	1,059.1	1,056.8	1,055.5	1,059.3	1,058.8	1,059.5	1,058.6
Yearly Mean	1,059.5	1,058.9	1,059.3	1,058.6	1,059.0	1,058.2	1,058.9	1,059.4	1,058.4	1,059.6	1,058.4	1,058.6	1,055.9	1,057.6	1,059.2	1,059.2	1,058.7
Maximum	1,060.8	1,060.7	1,060.1	1,059.3	1,060.0	1,059.3	1,060.7	1,060.3	1,060.8	1,060.4	1,059.1	1,060.1	1,056.9	1,059.5	1,059.7	1,060.0	1,060.8
Minimum	1,058.4	1,057.6	1,058.8	1,057.5	1,058.1	1,057.3	1,056.9	1,058.0	1,057.2	1,058.5	1,057.7	1,056.8	1,055.9	1,055.4	1,058.7	1,058.6	1,055.4

NOTE.—The above elevations are based on the gauge records of the Ontario Department of Public Works taken at the Kewatin traffic bridge, to which have been applied certain corrections based upon a comparison of the gauge records around the lake.

Elevations are given to W.P.S. datum. Zero Water Power Survey Datum is equal to 1.31 United States Coast and Geodetic Survey Datum.

The above figures from 1899 (given to Water Power Station datum) show a considerable and a decidedly irregular range. In following the surface levels from year to year there is ample evidence that no continuous and systematic policy dictated the operation of the control, other than efforts to better immediate and local conditions at times when the same became unsatisfactory to the power and navigation interests. This irregular control was the result of a lack of run-off data with which to measure the actual discharging capacity of the river, and also of the fact that in general there was ample water available for local needs at the outlets of the lake. The year 1911, during which the mean elevation was 1055.9, was the period of most adverse conditions for both power and navigation. On the other hand, lake levels above elevation 1060 are common, twenty-one months showing mean records above this limit. These levels represent average monthly elevations. Daily records show more extreme conditions.

#### THEORETICAL INFLOW AVAILABLE AT OUTLET FOR POWER AND STORAGE.

From a consideration of the lake levels, it is readily possible, by making allowance for the rise and fall in the lake from month to month, to deduce the conditions of storage and draw which have maintained during the past seven years. In undertaking a calculation of this nature, it was not deemed advisable to base the same on single readings at the beginning and end of each month, nor was it advisable to depend only on a single series of gauge readings, where others were available. The lake level is subject to influence by sudden storms and by prevailing winds. In order to eliminate so far as possible all such influences affecting the surface level, a mean of eight days' records, four at the end and four at the commencement of each month, was taken of the Keewatin gauge readings, and combined with a similar mean of the records secured at the forebay of the Kenora power-house, and at Warroad, on the southwest shore of the lake, whenever such records were available or considered reliable. Thus the average of the gauge records each month end was utilized, and the result is considered to indicate fairly accurately the actual lake level from which the past storage conditions can be deduced from month to month. Based upon these monthly changes of level, the theoretical inflow into the lake has been calculated. While the resulting figures indicate the monthly inflow into the lake which would have taken place had its surface been maintained at a uniform level, they do not indicate the theoretical outflow which would have taken place from the lake had there been no artificial regulation at the outlets, since the lake would under such conditions have varied in surface elevation according to various stages of flow. However, the deduced theoretical inflow gives the water which would have been available for use at the outlet.

Again, during the period under discussion, Rainy lake, in the basin above, was artificially regulated, and the flow therefrom consequently affected the monthly inflow into the Lake of the Woods. As a result, the deduced theoretical inflow does not represent wholly natural conditions on the basin. It is considered, however, that the two sets of figures in table 21 hereunder, representing as they do, the actual monthly outflow from the lake, and the theoretical monthly inflow into the lake, will serve as a fair basis on which to discuss its general storage possibilities.

Table 21.—Comparison of the Actual Outflow from the Lake of the Woods and the Theoretical Inflow deduced by taking into account the rise and fall of the lake from month to month.

Month.	1907.		1908.		1909.		1910.		1911.		1912.		1913.		Mean.	
	Outflow	Inflow.	Outflow.	Inflow.												
	Sec.-ft.															
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.	11.	12.	13.	14.	15.	16.	17.
January.....	11,700	10,073	19,190	16,770	9,970	7,238	11,660	14,860	7,700	3,407	5,555	3,214	11,560	9,219	11,061	9,254
February.....	11,750	6,265	15,730	13,993	10,940	5,738	13,790	13,802	7,110	3,408	3,765	6,454	5,790	9,211	10,571	8,628
March.....	10,640	8,260	12,340	12,341	10,910	6,617	14,760	19,960	6,815	3,153	6,010	6,010	6,990	21,040	10,421	10,624
April.....	10,280	8,344	16,900	12,787	10,870	4,820	22,120	28,008	8,995	6,560	6,270	16,680	18,370	17,670	11,998	14,695
May.....	11,170	22,410	18,470	23,700	11,040	23,060	24,690	16,490	8,770	10,721	6,505	21,990	18,370	12,125	14,145	18,571
June.....	14,000	23,760	22,830	24,847	11,770	16,045	21,870	16,870	8,945	13,544	5,435	9,307	30,100	15,986	14,993	17,194
July.....	14,055	17,645	21,800	15,866	11,850	13,958	16,290	2,720	8,770	4,087	7,446	7,446	15,070	17,830	13,246	11,375
August.....	12,730	24,830	20,300	12,339	11,695	12,087	13,270	7,729	7,985	5,430	5,430	11,209	14,880	9,180	12,327	11,871
September.....	17,080	31,120	18,200	15,780	11,940	13,150	11,750	5,052	6,715	5,183	5,425	18,735	13,100	12,030	13,251	12,309
October.....	20,790	25,319	15,420	10,190	12,005	15,925	10,180	3,938	5,945	7,819	9,720	13,936	8,180	9,039	11,749	12,307
November.....	21,075	18,977	12,810	8,777	12,020	12,262	8,785	9,833	5,615	5,615	16,990	10,425	8,090	9,058	11,441	10,707
December.....	19,730	17,700	10,580	10,424	11,915	16,208	8,110	5,690	5,530	6,467	11,520	9,490	8,050	7,269	10,776	10,464
The Year.....	14,560	17,724	17,670	15,235	11,345	12,257	14,570	12,076	7,410	6,646	6,955	11,166	11,872	11,789	12,052	12,413
Maximum.....	21,672	31,120	23,944	24,847	12,450	23,060	25,238	28,008	9,387	13,544	12,010	21,490	20,806	21,040	25,238	31,120
Minimum.....	10,500	6,235	10,118	8,777	9,465	4,820	7,634	2,790	5,078	2,153	4,425	3,214	5,847	3,740	4,425	2,150

A comparison of the mean monthly seven-year outflow and inflow as recorded in columns 16 and 17 illustrates at once the more natural conditions which are apparent in the inflow. The low-flow period, as is to be expected, occurs during the late fall and winter months, and is followed by the rise to flood flow in April, May, and June. That the two columns do not altogether balance is apparent from the mean flows for the cycle, i.e., 12,052 second-feet outflow and 12,413 second-feet inflow. A portion of this difference is accounted for by the fact that at the end of the period the lake stood at 0.7 foot higher elevation than on January 1, 1907, and the volume equivalent to this depth was not available as outflow. This volume would supply a continuous run-off of 132 second-feet for seven years, which practically makes the two mean flows, 12,184 and 12,413 second-feet outflow and inflow respectively. The remaining balance of 229 second-feet, amounting to less than 2 per cent of the seven-year mean, must be put down to inaccurate gauge records, since the actual discharge on which the whole is based remains the same throughout.

Evaporation losses do not enter into the calculation, since, whether a rising or a falling stage is in question, the net result of considering the rise or fall recorded by the gauge as the equivalent of actual inflow or outflow, is that the evaporation loss is eliminated.

A glance through the table indicates that full natural conditions are not shown by the deduced inflow. Abnormal figures may be the result of incorrect run-off data, poor gauge records, storage operations in Rainy lake above, or of a combination of these conditions. The general results, however, balance up well for the cycle as a whole. It is therefore on the theoretical inflow, rather than on the actual measured discharge, that the following discussion has been based.

In a lake of the area of the Lake of the Woods, a few inches storage or draw has a very marked effect on the outflow, and the changes of level which have occurred during the past seven years have exercised a very modifying influence on the discharge. A reference to the records year by year in table 21, and to mean monthly flows of the cycle as recorded in columns 16 and 17 illustrates this concisely.

#### STORAGE POSSIBILITIES OF THE LAKE OF THE WOODS.

The total drainage area above the Lake of the Woods is 26,400 square miles, of which about 10,400 square miles immediately adjacent to the lake and lying principally to the south, can be served by no reservoir other than the Lake of the Woods. The maximum storage requirement as deduced from the Rainy lake run-off data, is 0.174 billions of cubic feet per square mile. The Rainy lake run-off, as less influenced by storage in the upper reaches, is more nearly representative of natural run-off conditions than is that of the Lake of the Woods. On this basin it is essential, if a uniform mean flow is to be maintained from the outlets, that the Lake of the Woods provide storage capacity for 181 billions of cubic feet, calling for a storage depth of 4.32 feet. This assumes that the capacity and distribution of the lakes serving the balance of the watershed is such that they can fully and satisfactorily regulate the run-off of the same.

A study of the watershed will show that this assumption is not warranted.

The analysis of the Rainy Lake watershed shows the exhaustive nature of the regulation necessary to ensure a uniform mean discharge past Fort Frances. To ensure satisfactory regulation, it is therefore necessary to consider a greater storage depth than 4.32 feet on the Lake of the Woods. To this end, 5 feet has been made the basis of the following analysis.

The past conditions of discharge from and inflow into the lake, form a logical basis from which to draw conclusions as to the measure of its effectiveness as a reservoir. This is covered hereunder; first, year by year, and afterwards for the seven-year cycle as a whole. Water years are considered as giving better conditions of flow from a regulation standpoint.

*Yearly regulation, 1907-13.*—Table 22 hereunder deduced from yearly mass curves, presents the various minimum flows which might have maintained during the different years, together with the storage and depths on the lake necessary to secure the same. The theoretical inflow into the lake forms the basis of the table. It is recognized that for any one year, it would be impossible to foretell the maximum regulated flow which the year's run-off would permit. A consideration of the possibilities is, however, serviceable as indicating the exceptional storage facilities of the lake.

Table 22.—Storage Conditions which would have been necessary on the Lake of the Woods in order to maintain various Minimum Flows from year to year.

Water Year.	Mean Yearly Flow in Sec. ft.	Minimum to be maintained in Sec. ft.	STORAGE IN BILLIONS OF CU. FT.			DEPTH IN FEET.	
			Required at the beginning of the year.	Maximum supplied from the year's flow at any one time.	Total Volume Required.	Required at the beginning of the year.	Maximum Required at any one time.
1.	2.	3.	4.	5.	6.	8.	
1907-'08	19,434	19,434	30.0	48.0	78.0		1.91
		18,000	26.0	27.5	53.5		0.65
		16,000	21.0	15.0	36.0		0.50
		14,000	16.0	5.0	21.0		0.38
		<sup>1</sup> 12,442	12.5	0.0	12.5		0.29
		12,000	11.0	0.0	11.0	0.26	0.26
		10,000	6.0	0.0	6.0	0.14	0.14
1908-'09	13,274	13,274	0.0	80.0	83.0	0.0	1.92
		<sup>1</sup> 12,442	0.0	67.5	67.5	0.0	1.62
		12,000	0.0	62.5	62.5	0.0	1.50
		10,000	0.0	29.0	32.0	0.0	0.69
		8,000	0.0	13.0	13.0	0.0	0.30
		6,000	0.0	2.5	2.5	0.0	0.06
1909-'10	14,669	14,669	26.0	25.0	60.5	0.62	0.62
		14,000	24.0	12.5	49.5	0.57	0.57
		<sup>1</sup> 12,442	20.0	5.0	25.0	0.48	0.48
		12,000	17.5	3.0	20.5	0.41	0.41
		10,000	13.0	0.0	13.0	0.31	0.31
		8,000	8.0	0.0	8.0	0.19	0.19
		6,000	3.5	0.0	3.5	0.08	0.08
1910-'11	8,952	<sup>1</sup> 12,442	112.0	62.5	174.5	2.68	4.17
		12,000	95.0	67.5	162.5	2.28	3.90
		10,000	32.5	82.5	115.0	0.76	2.76
		8,952	0.0	89.0	92.0	0.0	2.14
		8,000	0.0	67.0	72.5	0.0	1.61
		6,000	0.0	19.0	35.0	0.0	0.45
		4,000	0.0	5.0	11.0	0.0	0.12

<sup>1</sup>Mean of seven water years.

Table 22. Storage Conditions which would have been necessary, etc. — Con.

Water Year.	Mean Yearly Flow in Sec.-ft.	Minimum to be maintained in Sec. ft.	STORAGE IN BILLIONS OF CUB. FT.			DEPTH IN FEET.	
			Required at the beginning of the year.	Maximum supplied from the year's flow at any one time.	Total Volume Required.	Required at the beginning of the year.	Maximum Required at any one time.
1.	2.	3.	4.	5.	6.	7.	8.
1911 '12	7,000	12,412	175.0	2.0	177.0	4.48	1.18
		12,000	151.0	4.0	158.0	3.65	3.65
		10,000	93.5	11.5	107.0	2.21	2.51
		8,000	31.0	27.5	58.5	0.71	1.40
		7,000	0.0	33.0	35.0	0.00	0.78
		6,000	0.0	11.5	17.5	0.00	0.27
1912 '13	13,191	14,000	0.0	2.5	2.5	0.00	0.00
		14,191	20.0	36.0	68.0	0.48	1.29
		12,442	6.0	28.5	52.5	0.14	0.68
		12,000	0.0	25.0	47.0	0.00	0.59
		10,000	0.0	0.0	14.0	0.00	0.21
		8,000	0.0	1.5	1.5	0.00	0.03
1913 '14	10,579	12,412	58.0	46.0	91.0	1.39	2.26
		12,000	42.5	42.0	84.5	1.02	2.03
		10,579	0.0	55.0	55.0	0.00	1.34
		10,000	0.0	42.5	42.5	0.00	1.20
		8,000	0.0	12.5	12.5	0.00	0.29
		6,000	0.0	7.5	7.5	0.00	0.18

<sup>1</sup>Mean of seven water years.

The water year covering the period from April 1, 1907, to April 1, 1908, was the year of most ample flow in the cycle. A mean flow of 19,434 second-feet was recorded. Little trouble would have been experienced in maintaining this throughout the year. The month of April was slack, there being only 8,344 second-feet available, involving a storage requirement of 30.0 billions of cubic feet, or a depth of 0.71 foot on the lake on the first of the month. Assuming this to have been available, the lake surface would have been reduced to zero level by May 1. Following came a period of ample flow, continuing till the end of October, during which time a surplus volume to the extent of 78 billions of cubic feet was available for storage, calling for a rise of 1.91 in the surface level. This would have been the greatest storage depth necessary throughout the year. From October 31 to the end of the water year on April 1, 1908, there was a constant slackness in run-off, requiring a steady draw on the storage until the lake level was reduced to 0.71 on the latter date. In short, starting with 0.71 foot on the lake on April 1, 1907, the lake level, reduced to zero by April 30, would have risen to 1.91 foot on October 31, and fallen gradually to 0.71 at the end of the year, maintaining throughout the period a uniform discharge of 19,434 second-feet.

In the year 1908-9 a sufficient water supply was again available to permit a substantial discharge being maintained and with but little variation of the lake levels. The mean flow of the year, 13,274 second-feet, involved no initial slack period at the commencement of the year, such as was required in the previous year. With the exception of a slight shortage in the month of August, there was a continuous surplus flow available until September 30, by which date it would have amounted to 80 billions of cubic feet and have raised the lake level (assuming zero at beginning) 1.92 foot. The slack discharge which followed would have lowered the lake to zero by the end of the water year.

The year of 1909-10 was also a year of high run-off, a mean of 14,669 second-feet being recorded. The month of April was below the mean, recording 4,820 second-feet, and necessitating an initial storage of 0.62 foot on the lake. Throughout the year, the flow was slightly more irregular than in the two years discussed above. In order to maintain the 14,669 second-feet, regulation of the lake surface would have been necessary only between every narrow limits. The maximum storage depth required would have been the 0.62 foot at the beginning of the year.

The year 1910-11 was a year of reduced run-off, the mean flow being 8,952 second-feet. To maintain this discharge from the lake would have called for a storage depth of 2.14 feet, this maximum occurring on June 30. After this date came a period of continuous low flow, calling for a steady draw on the lake until the end of the year. In all, 92 billions of cubic feet storage would have been required.

Assuming that surplus water was available from previous years, it will serve a purpose to look into the question of maintaining the seven-year mean uniform flow of 12,442 second-feet. With the existing run-off conditions, a maximum storage requirement of 174.5 billions of cubic feet would have been necessary in order to supply the deficiencies throughout the year, and would have involved a maximum depth of 4.17 feet on the lake, of which 2.68 feet should have been available at the commencement of the year. The date of highest water would have been June 30, and of low water, the winter months of January, February, and March.

The year 1911-12 supplied a mean run-off of 7000 cubic feet per second. The maintenance of this flow would have involved a maximum storage of 33 billions of cubic feet, and a storage depth of 0.78 foot on the lake. To have ensured 12,442 second-feet throughout the year would have required an initial storage of 175 billions of cubic feet or a depth of 4.18 feet, which would, with the exception of the month of June, have been continuously drawn upon throughout the year and reduced to zero by the end of the following March.

The year 1912-13 supplied a mean flow of 13,191 second-feet, somewhat above the seven-year average. To have rendered this flow available at the outlets during the entire year required a storage depth of 1.29 foot on the lake. An initial storage depth of 0.48 foot would have been necessary.


The year 1913-14 was below the mean discharge, 10,579 second-feet being available. To secure this uniformly, required a storage volume of 55 billions of cubic feet and a depth of 1.33 foot. No initial storage would have been necessary. To maintain the seven-year mean, i.e., 12,442 second-feet, called for a storage volume of 94 billions of cubic feet, and a maximum depth of 2.26 feet, 1.39 foot of which was necessary at the beginning of the year. Highest water would have occurred on July 31.

This review definitely emphasizes the value of the lake for reservoir purposes, and when paralleled with the conditions of run-off which actually maintained, forms a direct argument for the necessity of control.

*Regulation over the seven-year cycle.*—Turning to the seven-year cycle, it is of interest to look into the run-off from the standpoint of maintaining fixed uniform discharges from the lake throughout the entire period. Plate 22


RUNOFF ABOVE AND BELOW  
SEVEN YEAR MEAN  
OF  
WINNIPEG RIVER  
AT  
KENORA

Drainage Area - 26,400 Sq. Mi.  
Volume of Runoff above mean



BILLIONS OF CUBIC FEET

BILLIONS OF CUBIC FEET PER MONTH.



depicts the discharge conditions above and below the seven-year average. Table 23 herewith lists the storage conditions in the Lake of the Woods incident to maintaining continuously average discharges of varying limits, considering the lake as the only reservoir available.

Table 23. Storage Conditions which would have been necessary on the Lake of the Woods in order to maintain various Minimum Discharges from April 1, 1907 to March 31, 1911.

Flow in Sec. ft.	PERIOD OF MAXIMUM DRAW		Volume required in Billions of Cu. Ft.	Equivalent depth of Lake in Ft.	Total Volume of storage used, in Billions of Cu. Ft.
	Dates.				
1.	2.		3.	4.	5.
12,442	July 1, 1910, to Mar. 31, 1911		380	9.08	625
12,000	" " "		323	7.73	569
11,000	" " "		265	6.34	419
10,000	" " "		210	5.04	318
9,000	July 1, 1910, to Aug. 24, 1913		155	3.71	251
8,000	July 1, 1910, to Sept. 26, 1912		94	2.25	169
7,000	July 1, 1910, to May 8, 1912		40	0.96	101
6,000	Jan. 1, 1911, to May 21, 1911		21	0.50	57

<sup>1</sup>Mean of seven water years.

Table 2\* is compiled from a mass curve study; column 3 lists the maximum volume of storage capacity necessary to meet the most adverse conditions in the cycle; column 5 lists the total volume of water withdrawn from the reservoir throughout the period.



Analysing the maintenance of 12,442 second-feet more fully from the mass curve (plate 23) shows that, with three insignificant exceptions, there is a large surplus of water continuously available until October 1, 1908, at which date a slack period sets in, lasting until the following May. Ninety billions of cubic feet from storage, reducing the lake level by 2.16 feet only, would maintain the required flow over this gap, while the surplus flow commencing May 1, 1909, would refill the lake by the end of March, 1910, and supply a further 69 billions of cubic feet to the upper storage reservoirs by the end of June.

At this date, there has been a surplus flow totalling 380 billions of cubic feet, which, providing suitable reservoirs are in reserve, should be available to augment the prolonged period of slack and variable flow which follows.

Commencing July 1, 1910, a period of more or less continuous low flow follows, lasting until March 31, 1912. Assuming 5 feet storage available on the Lake of the Woods leaves the lake at its lowest limit by about the middle of August, 1911, immediately after which date a further draw of 139 billions is required. This must be furnished from other reservoirs.

March 31 is followed by a series of alternating surplus- and low-flow months, until the end of the cycle on March 31, 1914, by which date a further draw of 32 billions has been necessary from the upper reservoirs. The end of the cycle should find the entire reservoir system empty.

The above analysis indicates that a storage capacity of 380 billions of cubic feet is required if a flow of 12,442 second-feet is to be maintained throughout the seven-year cycle. Considering the entire basin above the Lake of the



**DOMINION WATER POWER BRANCH**  
 J. B. CHALLIES, Superintendent  
**MASS CURVE OF RUNOFF**  
 OF THE  
**WINNIPEG RIVER**  
 AT KENORA

To accompany a report on POWER AND STORAGE INVESTIGATIONS by J. T. JOHNSTON, B.A.Sc.

January, 1915

Woods available for the location of suitable reservoirs, indicates how this storage might be obtained. Five feet on Lake of the Woods will supply 209 billions of cubic feet; 5 feet on Rainy lake, 46 billions; 12 feet on lake Namakan 33 billions, leaving 92 billions of cubic feet to be supplied from the lesser reservoirs. Referring to tables 14, 15, and 16, wherein are listed the principal lesser lakes of the basin, shows a storage capacity of 120 billions, assuming 5 feet storage permissible on each lake, or sufficient depth to carry an entire average year's run-off where the same amounts to less than an equivalent of 5 feet. Storage in these lakes would necessitate the construction of some 60 dams.

However, it is not possible, to assume that the storage reservoirs of Rainy and Namakan lakes and of the lesser lakes in the basin above Fort Frances can be used unreservedly for the maintenance of a uniform discharge at the outlet of the Lake of the Woods. In view of the industrial and power developments at the outlet of Rainy lake, and of their present urgent demand for increased minimum flow, the storage available in Rainy, Namakan, and the upper lakes must be primarily used in bettering the discharge past Fort Frances. Regulation at this point will, of course, have its immediate and direct effect on the Lake of the Woods regulation.

The principal lesser lakes below Fort Frances and directly available to the Lake of the Woods are tabulated in table 14. The storage capacity of these lakes under the conditions listed in columns 12 and 13, is 21 billions of cubic feet, which could be used to directly supplement the lake storage. It should be again noted, however, that existing lumbering, fishing, milling, and other interests may prevent the full utilization of these smaller lakes for a general regulation scheme, and that the construction of some 15 dams is involved.

From the above it is clear that in order to maintain the full mean flow from the Lake of the Woods, supplementary storage is necessary in the upper lakes even assuming 5 feet storage in the lake itself. It is doubtful whether such complete regulation is economically valuable or practically feasible on account of the low efficiency in a general storage sense, of a large number of comparatively small and scattered reservoirs. The maintenance of a minimum flow of 10,500 second feet should be readily feasible under a properly systemized control.

Assuming that no reservoirs were available other than the Lake of the Woods, would necessitate a storage depth of over 10 feet on the lake in order to maintain a uniform flow from the outlets.

*Five-foot Storage on the Lake of the Woods.*—Considering for a moment that 5 feet storage or 209 billions of cubic feet is available on the Lake of the Woods, with no auxiliary storage, the actual inflow into the lake would have been sufficient to maintain a uniform outflow of at least 13,600 second-feet from May 1, 1907, to June 30, 1910. During this period a maximum draw of 141 billions of cubic feet would be required, or 2.67 feet on the lake. Ample water was available to supply the storage necessary, and to leave the lake surface at its upper limit on the latter date. Following June 30 came the prolonged period of low discharge previously referred to. Five-foot draw on the lake would permit the maintenance of a uniform discharge of practically 10,000 second-feet from the above date to the end of the cycle, the lake reaching its

lowest point on March 31, 1912, and being replenished to the extent of 120 billions of cubic feet or to a depth of 2.87 feet by the end of the period.

It should be pointed out that there is no method by which it could be foretold that 10,000 second-feet would be the limit of regulated run-off for that portion of the cycle following June 30, 1910. The discussion is therefore only of interest as a theoretical analysis of past possibilities in as far as can be judged from records now available.

*Regulation on the Lake of the Woods in the interests of the Manitoba Power Reach.*—The foregoing discussion has dealt with the maintenance of various limiting minimum flows from the outlets of the Lake of the Woods. The direct utilization of the lake as a storage reservoir for bettering the run-off conditions on the power reach in Manitoba and, at the same time, maintaining sufficient run-off to properly operate the power plants and mills at the outlets is of particular interest to the subject of this report, i.e., power resources of the Winnipeg river in Manitoba.

While the run-off records available are influenced by past control, and the deductions are consequently thereby affected, the general beneficial influence which could have been exerted by the lake under a systematic and properly operated regulation can be gathered from the following.

Plate 24 represents the run-off, storage and draw, and the surface-level conditions which would have maintained had the Lake of the Woods been utilized as a direct regulating reservoir for the maintenance of a minimum flow of 20,000 cubic feet per second in the Manitoba power reach, and at the same time provided sufficient discharge to properly operate the industrial and power undertakings at the outlets.

For the purposes of the analysis, elevation 1,061.0 (Water Power Survey datum) was assumed to be the upper limit of permissible storage, and on reaching this level it was assumed that the surplus water was discharged down the river. The lower surface level curve represents the actual mean monthly lake level during the period. The upper surface level curve represents the lake level which could have been maintained under a systematically controlled regulation, which ensured, at the same time, sufficient water to properly operate the plants at the outlets of the lake, and a flow of 20,000 cubic feet per second in the Manitoba power reach.

An analysis of the curve shows that the two initial months of 1907 would supply a surplus of 25 billions of cubic feet for storage; the three following months would draw to the extent of 31 billions, after which a period of ample flow lasting until the end of February, 1909, would supply a total of 715 billions available for storage. Of this total 130 billions are stored, and the balance wasted, the lake reaching elevation 1,061 on October 7, 1907. The curve shows the period of greatest draw extending from September, 1910, to the end of June, 1911, requiring 131 billions of cubic feet. The lake reaches its lowest level in June, 1911, i.e., elevation 1,057.9. A series of storage and draw periods following leaves the lake full on December 31, 1914.

The two surface-level curves indicate the more uniform and regular conditions which would have been maintained on the lake throughout the cycle had systematic regulation been carried on. In place of an actual difference in

lake level of 5.4 feet (or somewhat in excess of this if daily elevations are considered) there need only have been a difference of 3.1 feet. At the same time, in place of the actual low flow of 11,700 second-feet on the power reach, a flow of 20,000 second-feet would have been ensured.

The analysis on plate 25 is along the same lines as the above with the exception that a minimum discharge of 22,000 second-feet is maintained in the power reach in Manitoba. Under these conditions, the lowest lake level is elevation 1,056, occurring in April, 1912, that is to say, a maximum variation of 5 feet occurs during the eight years considered. The lake rises to elevation 1,059.2 at the end of 1914.

It is apparent that under the present conditions of power utilization at the outlets of the lake, it would be possible to secure a very high degree of regulation in the Manitoba power reach by the direct and properly controlled use of the lake of the Woods alone as a reservoir, and at the same time to greatly better past surface-level conditions. Upon the increased development of power at the lake outlets, necessitating the use of more water than has been required to date, the use of the lake in this manner will become more limited, and it must be devoted more exclusively to the maintenance of higher minimum outflows at all seasons. Its influence on the Manitoba reach under these conditions will be entirely beneficial, but not as direct as that shown in the analysis on plates 24 and 25. As hydro-electric development progresses in Kenora and Keewatin, it will become necessary to secure supplementary storage along the English river, in order to ensure 20,000 cubic feet per second in Manitoba at all seasons.

---

To sum it may be said that in whatever manner regulation of the run-off may be desired, a substantial measure of regulation in the lake of the Woods is essential. The records now available show that this measure of regulation should not be less than 5 feet, in order to ensure from year to year the desired run-off conditions from the lake and on the lower river. It is desirable to emphasize here that the necessity for lowering the lake to its low limit would arise only at intervals of a number of years.

#### RAINY LAKE WATERSHED.

The watershed draining into Rainy lake has an area of 14,400 square miles, and is plentifully interspersed with lakes of areas varying from a few square miles up to 100 square miles. The discharge records at Fort Frances at the outlet of the lake form the only consecutive series in this region extending back to the beginning of 1907. Such records as are available in the upper basin are not sufficiently complete to warrant more than passing reference. In consequence of this, the basin above Fort Frances is treated as a unit in considering the regulation of its outflow. The large industrial undertakings at the outlet of the lake, dependent for power on the run-off, already demand that the minimum flow be raised to the highest feasible limit.

#### RAINY LAKE.

Rainy lake, lying centrally in the lake of the Woods drainage basin, is a body of water some 330 square miles in area, plentifully dotted with islands,

and is inclosed on all sides by a rockbound shore. The tributary drainage basin is of the same general geological character and is, in consequence, plentifully interspersed with lakes.

Rainy lake forms a most valuable storage reservoir, both locally and in relation to the basin as a whole. The hydro-electric and pulp-mill installation of the Ontario and Minnesota Power Company, which harnesses the original Koochiching falls, about  $2\frac{1}{2}$  miles below the outlet of the lake, demands as complete a regulation as possible of the entire run-off from the basin above. The low-water conditions which have been experienced since these works were first projected have forced the company to pursue an aggressive storage policy. To this end, storage rights are stated to have been acquired on lakes Namakan, Lower Manitou, and Big Turtle in the basin above, in addition to the storage which is locally available in Rainy lake, which lake forms the direct headwater pond of the plant.

The dam which is more fully referred to in chapter V, consists of a masonry spillway section flanked on the Canadian side by ten gate-controlled sluices. The spillway crest is at elevation 497, based on an arbitrary datum<sup>1</sup> established by the Dominion Department of Public Works, to which the governing levels in the vicinity have been referred, and which is fixed by permanent bench-marks in the locality. The normal level in the lake prior to the construction of the works at the outlet has been placed at 488.6, although no gauge records are available.

Numerous complaints have been made at different times as to the manner in which the company have operated the regulation of the lake. These complaints have been in the main of two natures: first, that at certain seasons water has been conserved to such an extent that the flow from the river below has been cut off, and navigation and power interests adversely affected; and second, that the same conservation has resulted in abnormally high-water conditions on the lake, with consequent damage to various interests. The only restriction which has been placed upon the company with regard to the regulation of the lake is that by the Department of Public Works, which requires that at no time during the navigation season shall the flow past the dam fall below 5,000 cubic feet per second.

This measure of control is not sufficient to protect all the interests which are affected to a greater or less extent by the storage of water in the lake. Throughout the following discussion it has been assumed that 5 feet storage is available on the lake.

#### NAMAKAN LAKE.

Lake Namakan lies immediately above Rainy lake, and is possessed of similar characteristics. The Namakan level may be said to discharge directly into the Rainy Lake level over a rock ridge crossing the river-bed and forming Chaudière falls (Kettle falls), a natural and fairly abrupt drop of about 8 feet under normal conditions. At the falls the river is divided by an island into two channels. Namakan lake has been taken at 100 square miles in area. This area includes the lakes Namakan, Sand Point, Kapetogamuk, Crane, and Little

<sup>1</sup> 610-30 Water Power Survey datum = 0.0 Department of Public Works datum.


**DOMINION WATER POWER BRANCH**  
**J. B. CHALLIES, Superintendent**

**MASS CURVE STUDY OF THE 1918**  
**LAKE OF THE WOODS AS A REGULATING RESERVOIR**  
**AND THE EFFECT OF SUCH REGULATION**  
**ON THE MURRAYE LEVELS.**

To accompany a report on POWER AND STORAGE INVESTIGATIONS  
 by J. T. JOHNSTON, B.A.Sc.

**NOTE:**  
 In this analysis it has been assumed that a minimum flow of 20,000 second feet is maintained throughout the power reach of the Winnipeg River in Manitoba, by means of regulations in the Lake of the Woods reservoir alone. At the same time sufficient water has been discharged at all times to properly operate the power installations at the lake outlets.

- LEGEND**
- Surplus water available for storage
  - Water drawn from Storage
  - Required from the Lake of the Woods to maintain 20,000 second feet flow and actually discharged
  - Discharge necessary to operate the Power installations at the Outlets of the Lake





Vermilion, all of which are closely connected and at practically the same level. The tributary drainage basin is 7,056 square miles in area, practically one-half of the entire Rainy Lake watershed. Namakan lake, like Rainy lake, forms a most important storage reservoir both locally and in relation to the entire basin.

The lowest level recorded by the gauge readings of the Dominion Water Power Branch, covering the period from August, 1912, to June, 1913, was 497.9, occurring on March 31, 1913. This series of records was taken before any work was done on the storage dam. The maximum high-water level, as shown by water marks, is placed at elevation 508.5.

In the grant made by the Ontario Government to the company, authority was given to raise the water in the lake "to a point no higher than the high-water mark." Before commencing construction operations, it was necessary that the Department of Public Works approve the plans, since the lake and river affected came under the classification of navigable waterways.

One of the conditions of the departmental approval of the plans was:—

"That the company agree that the control of the flow past that section shall be regulated solely by such officers or persons as may be hereafter appointed for the purpose by the Minister of Public Works, and that, in case of any difference of opinion, the ruling of the Minister of Public Works for Canada shall prevail."

In accordance with this clause, Mr. S. J. Chapleau, District Engineer of the Department of Public Works, was authorized to arrange for the control of the flow and, after consultation with the United States engineers and other parties if necessary, to fix the extreme high-water level. Following this, an arrangement was made and agreed to, between Mr. Chapleau as representing the Dominion Department of Public Works, and Col. C. L. Potter, of the Corps of Engineers, representing the United States interests, whereby the high limit of lake regulation was fixed at elevation 508.5, subject to reconsideration by either Government or by the International Joint Commission.

This secures a regulation between 508.5 and the 497, or lower, should Rainy lake be drawn down.

The sluice-ways of the dam (plate 40) as constructed, are stoplog controlled, and of the following openings:—

Canadian channel—

1-14 foot sluice, sill elevation 498.15.

1-14 foot sluice, sill elevation 496.15.

2-14 foot sluices, sills at elevation 495.15.

International channel—

4-14 foot sluices, sills at elevation 490.15.

Throughout the cycle under discussion, lake Namakan was not subject to artificial control at the outlet, and except for the operation of lumber storage dams in the upper basin, it discharged the natural run-off under natural conditions. Systematic meterings at Chaudière falls were commenced in August, 1912, and are attached in tables 63, 64, and 65, Appendix VII. No gauge records of any description are available from which the run-off of previous years might be deduced.

## REGULATION OF THE RAINY LAKE BASIN RUN OFF.

*Surface levels of Rainy lake.*—As was the case in studying the past condition maintained on the lake of the Woods, it is here necessary to look into the past surface levels on Rainy lake. Since the completion of the hydro-electric and pulp and paper undertakings at Fort Frances, the lake has been maintained at artificial levels in an effort to equalize the annual flow. A continuous record of the forebay levels of the plant has been kept since early in 1907 by the engineers of the Ontario and Minnesota Power Company. This has been supplemented since August, 1911, by lake-level readings secured by the field officers of the Department of Public Works. The forebay readings do not represent true lake level as there is an hydraulic gradient between the lake and the dam, varying with the lake stage and the draught through the power plant. However the rise and fall in the forebay due to storage in the lake approximates the corresponding rise and fall in the lake itself. Table 24 has been compounded from the various sources available, and can be taken as representing the mean monthly elevations of the lake during the period covered.

Table 24.—Mean Monthly Elevation of the Surface Level of Rainy Lake.

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
January		490.2	486.9	495.7	488.3	491.7	491.4	495.2	
February		488.0	486.4	494.8	488.2	491.0	493.5	494.6	
March	486.7	488.0	485.5	493.5	487.9	490.3	492.4	493.5	489.7
April	486.5	487.6	486.4	493.1	488.2	489.9	491.8	493.9	489.8
May	487.2	488.4	489.4	491.6	489.2	491.5	493.0	493.4	490.8
June	489.6	489.9	492.7	494.0	490.0	494.2	496.0	495.4	492.8
July	491.8	492.1	493.8	493.2	492.6	496.0	497.2	497.1	494.2
August	493.1	492.1	494.1	492.6	493.5	496.2	497.3	496.9	494.5
September	494.5	490.9	494.5	491.8	493.3	496.2	497.2	496.5	494.5
October	494.4	489.4	493.3	490.7	493.1	496.1	496.6		494.4
November	493.3	488.2	495.1	489.1	492.7	495.7	496.6		
December	491.6	487.3	495.0	488.4	492.3	495.1	496.1		
The Year		489.4	491.2	492.7	490.9	493.7	495.2		

NOTE.—The elevations from March, 1907, to July, 1911, inclusive, record the water level above the dam at Fort Frances. The elevations from August, 1911, to September, 1914, inclusive, record the water level of Rainy lake at Ramier. The readings at the dam record lower than those at Ramier, the drop depending on the flow in the river, and the draught through the power plant. The elevation for September, 1914, is the mean of the first eleven days of the month only. The elevations are recorded to Department of Public Works datum.

*Theoretical inflow available at outlet for power and storage.*—A consideration of the above levels renders possible a close estimate of the theoretical inflow into the lake for the period. In dealing similarly with the lake of the Woods, more numerous gauge readings were available, and a more accurate determination of the mean lake level from day to day was possible. The records which are here available, and which form the basis of table 25 are, however, sufficiently representative of actual conditions to enable a fair estimate being made.

During the period under discussion, no storage operations were carried on in the upper portion of the basin, with the exception of those necessary in connection with logging operations. The theoretical inflow which is deduced by assuming a uniform level throughout the period, will therefore represent closely the natural run-off from the basin. Table 25, hereunder, records side by side the actual outflow from the lake, and the actual inflow into the lake, or rather the water available at the outlets, as deduced from a consideration of the outflow combined with the lake levels. The monthly outflow discharges from the lake are tabulated in full in tables 61 and 62, Appendix VII.

Table 25.—Comparison of the Actual Outflow from Rainy Lake and the Theoretical Inflow deduced by taking into account the rise and fall of the lake surface from month to month.

Month.	1907.		1908.		1909.		1910.		1911.		1912.		1913.		Mean.	
	1907.		1908.		1909.		1910.		1911.		1912.		1913.		Mean.	
	Outflow.	Inflow.														
January.....	5,883	5,884	12,009	6,676	5,170	4,311	9,680	7,963	2,860	1,840	5,440	3,720	6,620	3,838	6,792	4,746
February.....	3,641	3,641	8,410	4,607	4,740	2,269	9,680	4,975	1,429	1,429	4,840	2,540	6,560	2,823	2,719	3,049
March.....	4,958	4,951	7,030	4,969	5,509	699	10,750	8,175	2,380	985	4,740	1,830	6,420	2,153	5,583	3,259
April.....	6,070	4,985	9,020	7,617	3,250	12,835	15,391	15,391	3,020	7,943	4,850	6,574	6,405	7,154	5,586	12,013
May.....	10,200	19,663	17,940	11,891	4,220	18,304	10,690	10,257	4,660	6,317	6,090	11,699	6,620	14,180	6,570	12,820
June.....	13,000	17,293	14,660	19,063	6,830	14,128	10,030	6,097	5,749	13,260	6,020	14,963	7,274	17,036	8,210	14,529
July.....	17,470	24,823	13,680	9,921	10,660	12,145	6,630	5,256	3,970	6,292	7,680	11,011	12,597	12,975	9,648	11,579
August.....	20,110	24,883	10,740	6,126	9,580	4,694	3,280	2,876	6,550	7,599	8,120	8,017	8,544	8,887	9,893	10,596
September.....	19,760	17,012	9,680	5,214	9,050	9,050	5,080	2,449	5,990	4,677	7,360	7,005	6,770	5,670	9,439	7,970
October.....	17,700	12,553	7,510	3,607	5,400	10,725	5,180	311	5,210	4,111	6,890	6,193	6,318	5,847	8,860	6,818
November.....	13,000	7,332	5,701	3,640	10,000	4,343	4,300	4,128	3,410	4,416	6,730	4,677	6,129	5,109	7,737	5,937
December.....	11,491	12,510	9,350	8,291	7,052	9,666	7,750	5,506	4,514	5,255	6,243	7,013	7,214	7,588	7,356	5,452
The Year.....	20,110	24,823	13,060	19,063	10,660	18,304	10,750	15,390	13,260	14,269	8,120	11,963	12,597	17,036	20,110	23,823
Maximum.....	3,641	3,641	6,020	3,607	3,250	690	4,300	3,311	2,380	985	4,740	1,820	6,129	2,125	2,380	1,311

Probably attributable to poor gauge records.

A glance through the table shows that in spite of obviously incorrect figures for certain months (due to poor gauge records) the general character of the theoretical inflow conforms more closely to what is to be expected under natural conditions, than do the actual outflow records. This is brought out more definitely in the columns of averages, 16 and 17.

It will be noted that the mean seven-year outflow of 7,645 cubic feet per second does not balance with the 7,984 cubic feet per second inflow. The greater portion of this difference is occasioned by the fact that the water level at the end of the period was 9.27 feet higher than at the commencement, this being equivalent to a seven-year average flow of 386 second-feet. Adding this to the mean outflow gives an equivalent total of 8,031 second-feet, or 47 above the mean inflow. This balance is probably due to inaccurate gauge reading. The difference is less than 0.6 per cent.

In discussing the storage possibilities of the past seven years, the theoretical inflow is utilized, rather than the measured discharges from the lake.

The Ontario and Minnesota Power Company has, in recent years, exercised control over the run-off from Rainy lake for the purpose of increasing the minimum flow. While a considerable degree of success has been attained, there is still much to be done before a complete conservation of the run-off is attained. The company is fully aware of this, as is evidenced by the extent of the storage works which it now has under construction and in prospect. In so far as the minimum dependable flow is being increased through the construction and operation of these storage reservoirs, the best interests of the powers of the lower river are being served.


*Regulation over the seven-year cycle.*—The general storage conditions necessary to maintain uniform discharges of various limits from the outlet of Rainy lake throughout the seven year cycle are concisely set out in table 26 hereunder.

This table is compiled from a mass curve study (plate 26). Column 3 lists the maximum volume of storage capacity necessary to meet the conditions; column 5 lists the total volume of water withdrawn from reservoirs throughout the period.

Table 26.—Storage Conditions which would have been necessary in order to maintain various Minimum Flows from Rainy Lake from April 1, 1907 to March 31, 1914.

Flow in Sec.-ft.	PERIOD OF MAXIMUM DRAW.			Total Volume of storage used, in Billions of Cu.-ft.
	Dates.	Volume required in Billions of Cu.-ft.	Equivalent depth on Rainy lake in feet.	
1.	2.	3.	4.	5.
17,962	May 31, 1910, to Mar. 31, 1914.....	250	27.18	493
7,000	May 31, 1910, to Mar. 31, 1914.....	168	18.26	363
6,000	June 30, 1910, to Jan. 20, 1913.....	106	11.52	255
5,000	July 31, 1910, to June 24, 1912.....	68	7.39	150
4,000	July 31, 1910, to July 31, 1911.....	47	5.11	89

<sup>1</sup>Mean of seven water years.



**DOMINION WATER POWER BRANCH**  
 J. B. CHALLIES Superintendent  
 HANS LUTHE OF HUNDT  
 OF THE  
**RAINY RIVER**  
 AT FORT FRANCIS

To accompany a report on POWER AND STORAGE INVESTIGATIONS by J. Y. JOHNSON, O.S.A.

January, 1916

Regulation of the watershed above the outlet of Rainy lake to ensure a continuous average flow of 7,962 cubic feet per second throughout the seven-year cycle would have required a maximum storage capacity of 247 billions of cubic feet, which total should have been in storage and ready for use on May 31, 1910.

Analysing the storage and discharge data on the basis of maintaining the above average flow shows the following, the results being based on a mass curve study, and being therefore somewhat approximate.

The flow for April, 1907, i.e., the first month of the cycle, is slightly below the mean, requiring a draw on storage of about 7 billions of cubic feet. This storage must be provided from previous years' surplus, and would be made good by the end of May. Assuming, then, that 7 billions of cubic feet only are available at the beginning of April, the end of the month shows all reservoirs empty. Following this date there is a continuous surplus flow till November 30, amounting to, in all, 182 billions of cubic feet. Of this amount, 46 billions can be stored in Rainy lake, assuming 5 foot storage, and 33 billions in lake Namakan, assuming 12 foot storage. These lakes would be filled early in August, and the balance must be cared for in the upper lakes. November is followed by a slack period lasting until April 30, 1908, by which date 25 billions of cubic feet would be drawn from storage, preferably from lakes Rainy and Namakan, thus leaving them prepared to store surplus water from any part of the basin at whatever time the same should be available. Following April 30 is a surplus-flow period, replenishing the reservoirs towards the middle of June, 1908, and continuing until August 31, adding a further 43 billions of cubic feet to the reserve storage.

August 31 is followed by a slack period lasting until March 31, 1909, by which date 79 billions of cubic feet will have been withdrawn from storage. The two lakes, Rainy and Namakan, could have supplied this volume. A period of ample flow follows, replenishing the storage reservoirs by the end of August, and continuing until January 31, 1910, adds an additional 17 billions of cubic feet to the volume of available storage. February is slack and draws 10 billions from the reservoirs, which, however, are filled again about the middle of April, and a further 12 billions added by May 31.

By May 31, 1910, surplus flow totalling 254 billions of cubic feet has occurred and, providing reservoirs are available, should be on hand to supply the prolonged period of slack and variable flow which follows.

Assuming that the Rainy and Namakan reservoirs are first utilized to replenish this draw, shows them empty, or 79 billions of cubic feet utilized by November 30, immediately following which comes a further draw of 67 billions of cubic feet from the upper lakes, lasting until May 31, 1911. This continuous and rapid draw would have the effect of emptying a large number of the reservoirs, and leaving them ready for the storage of any surplus in the months following. June is a month of surplus flow, adding 12 billions to storage. This is, however, withdrawn by the end of September, following which is a continuous draw until April 30, 1912, by which time a further 77 billions of cubic feet has been withdrawn.

Four months' surplus flow follows, adding 46 billions of cubic feet to storage by August 31. This is required by the middle of February, 1913, and an additional 24 billions by the end of April. Following April are three months' surplus flow adding 55 billions of cubic feet to the reservoir by the end of July. From this date, there is a continuous draw totalling 55 billions, until the end of the cycle, at which date 7 billions of cubic feet are in the reservoirs, the equivalent of the initial supply.

Briefly, the above analysis indicates that a storage capacity of 247 billions of cubic feet is necessary in order to maintain a flow of 7,962 second-feet throughout the seven-year cycle. Of this total, 79 billions are supplied by 5 feet on Rainy lake and 12 feet on lake Namakan, leaving 168 billions to be provided from other sources. Referring to tables 14 and 15, which list a number of the more important lesser lakes in the Rainy lake watershed, it will be noted that column 12 lists the volume of storage which could be secured, assuming a permissible depth of 5 feet available in each lake where the annual run-off is sufficient to supply the necessary volume, and full storage where such is not the case. Storage to the extent of 98 billions of cubic feet could be secured in this way on these assumptions, by the construction of some 47 dams, leaving 70 billions to be elsewhere provided.

It might be noted that the sills of the Chaudière falls dam are at 490.15 and will in times of emergency allow Namakan lake to be drawn several feet below the low limit considered above, and hence add further storage to the volume available. There are undoubtedly numerous lakes not listed in the tables, which might be suitable for reservoir purposes. Also, there is little doubt that the 5-foot limit on many lakes could be exceeded, as, for instance, 10 feet is permissible on Maniton lake, 30 feet on Otukanamawan lake, 7 feet on White Otter lake, according to the Sixth Annual Report of the Ontario Hydro-Electric Commission. Against this, must be placed in some cases the lack of sufficient catchment area to supply the run-off necessary to fill the reservoir, also the necessity of providing run-off for logging purposes, for the possible future operation of small water-powers, and for the maintenance of fishing interests. The 70 billions additional storage would undoubtedly strain the reservoir capacities of the watershed to the limit, leaving out of consideration the question of the economic feasibility of a storage system involving an excessive number of lesser reservoirs.

Referring again to the mass curve, it is noted that 79 billions of cubic feet storage would practically maintain the mean flow from the beginning of the cycle to the end of November, 1910; also, that 115 billions of cubic feet would maintain the same flow from the middle of March, 1911, to March 31, 1914, storage capacity for which quantity could very readily be found. The prolonged period of low flow commencing in the spring of 1910 is responsible for the excessive storage requirements noted above. To bridge this gap necessitates carrying water over from the year 1907 and the succeeding two years.

It is of interest to note briefly what general conditions of run-off might have been maintained throughout the cycle, assuming that the 79 billions of cubic feet storage capacity which is now available for power storage purposes in Rainy and Namakan lakes had been available at all times, with no auxiliary

storage in the upper lakes. No difficulty would have been experienced in maintaining the mean 7,962 second-feet flow to the end of May, 1910. Throughout the prolonged slack period which followed, the 79 billions of storage would, however, only be sufficient to maintain a flow of about 5,500 second-feet. Under this condition of run-off the basins would be empty by March 31, 1911, and filled again by the middle of September, 1912, after which date no difficulty would be experienced in maintaining 7,962 second-feet to the end of the cycle.

It would seem from the foregoing that in normal years the maintenance of the mean flow, 7,962 second-feet, does not require excessive storage provision, but that in order to ensure its continuance over exceptional and prolonged periods of low flow, a very complete system of storage is required throughout the basin. It is recognized that the period over which discharge data are available does not cover a sufficient number of years to permit positive statements being made as to what absolute extremes are to be anticipated. More extreme conditions than are covered herein may undoubtedly occur. The long period of low flow which has been experienced forms, however, an excellent example, of the abnormal conditions which may be expected, and which must be ensured against.

To sum up it may be said that to maintain an average flow of 7,900 cubic feet per second at all seasons will require a most exhaustive system of storage reservoirs among the lesser lakes. Economic considerations will militate against the development of the lesser reservoirs beyond reasonable limits and a complete regulation of the run-off from this section of the watershed is not considered feasible. The measure of its practicability can only be finally ascertained by a detailed study of the lakes and basin. A dependable flow of 6,000 second feet can be readily ensured.

This phase of the Rainy river regulation is particularly important in relation to the question of diverting a portion of the tributary drainage into the St. Louis river and utilizing it for the development of power in the neighbourhood of Duluth, under what is known as the Birch Lake Diversion Project. This matter is covered in detail in chapter IX.

#### ENGLISH RIVER WATERSHED.

The English river drains an area of 21,600 square miles, comprising the entire northern portion of the Winnipeg watershed, which portion is very similar in general characteristics to the southern section. It is plentifully supplied with lakes of all sizes up to Lac Seul of 340 square miles area.

For purposes of storage and regulation study, the English River basin can be most readily considered from two standpoints; first, the regulation of the entire basin as a unit so as to secure the best run-off conditions at the mouth of the river; and second, the regulation of the basin above Lac Seul with the object of securing the best run-off conditions at the lake outlet. The first method of regulation has more direct bearing on the bettering of run-off conditions along the power reach of Manitoba, while the second would be more beneficial to a future hydro-electric scheme along the English river, and at the same time equally as desirable from a standpoint of bettering the Manitoba conditions.

Lac Seul is the largest lake in the basin. While little information has as yet been collected by the engineers of the Dominion Water Power Branch with respect to its adaptability to use as a storage reservoir, and the extent of flooding which would be involved in various storage depths, it is at least certain that limited storage is available. Throughout the following, 10 feet has been considered as the limit permissible. While a theoretical discussion of the lesser lakes would indicate that less than 10 feet on Lac Seul would probably still permit of a satisfactory regulation of the run-off, it is important that its reservoir capacity be as great as possible, in order that it may serve as a balancing reservoir for the lakes above. As was previously noted, the distance of the upper lakes from the reach at which regulation is desired, places practical difficulties in the way of efficient control.

*Run-off conditions.*— No continuous records of discharge have been secured to date along the English river, due to difficulty of access. Steps are being taken at present by the Hydro-Electric Power Commission of Ontario to secure such a record in the immediate future. Miscellaneous measurements taken in the past will be found in Appendix VII, tables 86 to 91.

In the meantime, the only run-off data available on which to base a study of the regulation of the river, are the continuous records taken by the engineers of the Dominion Water Power Branch at Otter-Slave falls station on the Winnipeg, and at the outlets from the Lake of the Woods at Kenora. The difference between these records, reduced in proportion to the area of the drainage basins, has been used in the analysis hereunder.

The mean monthly discharges deduced as above are listed in table 27.

Table 27. Mean Monthly Discharge of the English River at its junction with the Winnipeg.

[Drainage area, 21,600 square miles.]

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
	Sec. ft.								
January	11,056	16,392	13,711	12,602	6,597	13,459	15,240	5,257	12,163
February	10,776	17,068	13,103	11,573	5,717	10,231	15,358	1,515	11,043
March	6,190	13,009	7,329	8,857	8,285	7,237	11,216	3,269	7,800
April	3,994	10,749	5,402	16,175	3,146	6,751	8,615	1,456	7,150
May	1,711	14,093	8,580	26,065	5,569	15,099	9,260	5,992	11,017
June	13,000	17,357	11,851	24,851	8,795	21,001	11,706	12,074	15,081
July	16,616	19,625	11,860	19,113	13,093	19,931	13,120	13,737	15,942
August	17,211	17,816	11,893	10,591	16,813	20,611	11,874	12,370	14,099
September	18,587	16,301	9,590	7,302	16,767	22,225	11,270	11,721	14,233
October	20,135	16,327	7,711	6,319	18,516	21,636	9,355	12,365	11,050
November	20,019	11,416	7,830	5,092	16,063	20,033	7,016	10,198	12,625
December	18,319	11,823	9,836	4,457	12,787	16,568	6,182	9,257	11,151
The Year	13,612	15,353	9,892	12,778	10,757	16,239	10,878	8,791	12,291
Maximum	20,135	19,625	13,714	26,065	18,516	22,225	15,358	13,737	26,065
Minimum	3,994	10,749	5,402	4,157	3,146	6,761	6,182	3,266	3,146

NOTE.— Discharges are deduced by taking the difference between the Otter-Slave Falls and the Kenora records, and reducing the same in proportion to the areas of the drainage basins. The maximum and minimum flows refer to the mean monthly flows.

The mean flow for the eight-year cycle, according to the above table, is 12,291 cubic feet per second. This average must represent very closely the actual discharge from the basin over the period in question.

For the purpose of analysing the run-off conditions as shown by table 27, a mass curve has been plotted, see plate 27. In this curve, water years have been used in keeping with the previously considered curves of the Lake of the Woods and the Rainy lake discharge. The mean run-off over the seven water years is 12,576 cubic feet per second.

*Regulation over the seven-year cycle.*—In the English river basin there is, so far as can be judged from existing maps, an area of some 3,000 square miles immediately adjacent to the river, which is either poorly or entirely unsupplied with lake area suitable for storage reservoir purposes. While exploration may result in the discovery of lesser lakes in portions of this section, it is necessary to consider such at this stage as non-existent. No control is therefore counted on over the run-off from this portion of the watershed. This run-off would, in a normal year, average 1,750 cubic feet per second. Omitting this flow from the seven-year mean, leaves 10,826 cubic feet per second to be maintained by regulation.

The general storage conditions which would be necessary in order to maintain uniform discharges of various limits at the mouth of English river throughout the cycle are concisely set out in table 28 hereunder.

This table is compiled from a mass curve study. Column 3 lists the maximum volume of storage capacity necessary to meet the conditions; column 5 lists the total volume of water withdrawn from reservoirs throughout the period.


Table 28.—Storage Conditions which would have been necessary in order to maintain various Minimum Flows on the English River from April 1, 1907, to March 31, 1914.

Flow in Sec.-ft.	PERIOD OF MAXIMUM DRAW.			Total volume of storage used, in billions cu.-ft.
	Dates.	Volume required in billions cu.-ft.	Equivalent depth on Lac Seul in feet.	
1.	2.	3.	4.	5.
12,576	August 1, 1910 to end of period.	183	19.32	483
10,826	Aug. 1, 1910 to Aug. 15, 1912	134	14.14	331
10,000	Sept. 1, 1910 to June 10, 1912	109	11.51	256
9,000	Sept. 1, 1910 to av. 8, 1911	82	8.66	187
8,000	Sept. 1, 1910 to Sept. 20, 1911	59	6.23	129
7,000	Nov. 1, 1910 to Aug. 15, 1911	34	3.59	73

Analysing the discharge records from the mass curve (plate 27) on the basis of maintaining a mean flow of 10,826 second-feet shows the following.

The months of April and May, 1907, are slack and require an initial storage of 30 billions of cubic feet, which it is assumed are available from the previous year, and which 3.17 feet on Lac Seul would have provided. A period of surplus flow commences on June 1, restoring the 30 billions of cubic feet by about the middle of August, and continuing with only one slack month (April, 1908) until

the end of February, 1909, by which date a further 245, or 275 billions of cubic feet in all, has been available for storage. Of this amount, 10 feet on Lac Seul can accommodate 95 billions. Following February is a period of alternate



slack and surplus flow lasting until March 31, 1910. The greatest draw during this period is 44 billions of cubic feet, which could be readily supplied from Lac Seul with a draw of 4.66 feet, the lowest stage occurring on March 31, 1910.

The surplus-flow period immediately following replenishes the lake towards the middle of the following May, and continues until the end of July, by which date a further 74 billions is available for storage.

Commencing with August 1, 1910, is the longest period of low flow encountered during the cycle. This slack period lasts until the end of June, 1911, and requires a draw from storage to the extent of 135 billions of cubic feet to maintain the required discharge. Lac Seul is emptied by March 31, leaving 40 billions to be supplied from the lesser lakes.

From the end of June, 1911, there is a long period of surplus flow, with but two minor slack periods, lasting until the end of September, 1913. This surplus flow would replenish Lac Seul towards the end of June, 1912, and the 40 billions from the lesser lakes by the middle of August of the same year, and would supply an additional 140 billions for storage purposes. September, 1913, is followed by a slack period which requires 77 billions of cubic feet from storage by March 31, 1914, the end of the seven-year cycle. This can be drawn from Lac Seul, leaving 18 billions in the lake, or a depth of 1.9 foot.

In reviewing the above it is noted that, assuming 30 billions available from previous years to bridge the initial slack period, there is a surplus of 489 billions of cubic feet available for storage purposes after providing for a discharge of 10,826 second-feet. The greatest draw during this period is 135 billions, of which it has been assumed that 95 billions are supplied by 10 feet on Lac Seul, the remaining 40 billions to be supplied by the lesser lakes.

Referring to tables 17 and 18, listing respectively the lesser lakes throughout the English River watershed below and above Lac Seul, it will be noted that the basin is well supplied with possible reservoirs. The total lake area tabulated in table 17 is 635 square miles. These lakes, 21 in number, would, under the conditions defined in columns 11 and 12 provide storage to the extent of 73 billions of cubic feet. Similarly, 25 lesser lakes above Lac Seul 599 square miles in total area, would provide for an additional 69 billions of storage. As has been noted previously, however, other interests may prevent these lakes being used for the sole purpose of maintaining satisfactory regulation for power purposes, and too great reliance must not be placed on a theoretical discussion, also there is a limit to the number of lesser reservoirs which can be economically constructed and maintained in a practical system of river regulation.

It would nevertheless appear from the above that, assuming 10 foot storage on Lac Seul, there is sufficient reservoir capacity in the English river watershed to maintain, if properly controlled, a mean run-off at the mouth of the river of 10,826 second-feet. A low limit of 10,000 second-feet should at least be feasible. To secure this end would necessitate holding a portion of the storage for a period of two years.

In the above analysis, 3,000 square miles of the watershed have been omitted from consideration on account of lack of reservoirs. Should a series of hydro-electric plants be in future installed along the English river, the local pondage basins of the same will partially rectify this condition. Under present conditions, 0.14 cubic foot per second per square mile can probably be depended on from this section as a minimum flow, i.e., a run-off of 420 cubic feet : and.

This would increase the minimum at the mouth of the river and render more dependable the 10,000 cubic feet per second referred to above.

REGULATION OF THE WATERSHED ABOVE LAC SEUL.

Lac Seul bears much the same relation to the English river as does the Lake of the Woods to the Winnipeg river. From the lake to its junction with the Winnipeg the English river drops through a series of more or less abrupt falls and rapids. That these rapids and falls are capable of concentration after the manner of those on the Winnipeg, there is no room for doubt. Hydro-electric development along this river will take place just as soon as the market conditions are favourable. When this takes place, the question of regulation in Lac Seul and the upper waters will become more acute. The extent to which this regulation can be attained is briefly outlined hereunder, in so far as the basin run-off data available will permit.

*Run-off conditions.*—As was the case in considering the English river as a whole, the run-off data on which the following analysis must be made is deduced from the continuous records secured at the Otter-Slave Falls station on the Winnipeg, and at the outlets of the Lake of the Woods at Kenora. The difference between these records, reduced in proportion to the drainage areas, forms the basis of the theoretical discussion hereunder, and the deductions therefrom can serve as an indication of what is to be expected under natural run-off conditions.

The mean monthly discharges deduced ... are listed in table 29.


Table 29.—Mean Monthly Discharge of the English River at the outlet of Lac Seul.

[Drainage area, 11,709 square miles.]

Month.	1907.	1908.	1909.	1910.	1911.	1912.	1913.	1914.	Mean.
	Sec.-ft.								
January	7,641	8,910	7,455	6,850	3,586	7,316	8,279	2,857	6,612
February	5,858	9,278	7,122	6,291	3,198	5,563	8,319	2,155	6,003
March	3,465	7,074	3,981	4,820	2,871	3,934	6,097	1,776	4,241
April	2,171	5,843	2,937	8,956	1,710	3,677	4,683	2,422	4,019
May	2,579	7,117	4,664	14,169	3,022	8,238	5,037	3,216	6,005
June	7,067	9,490	6,442	13,509	4,732	11,416	6,363	6,563	8,198
July	9,049	10,668	6,447	10,405	7,117	10,835	7,295	7,467	8,661
August	9,374	9,701	6,465	5,757	9,149	11,222	6,455	6,724	8,105
September	10,104	8,915	5,213	3,969	9,111	12,081	6,125	6,372	7,737
October	10,945	8,875	4,193	3,435	10,082	11,761	5,085	6,722	7,637
November	10,882	7,853	4,256	2,768	8,732	10,899	3,811	5,707	6,863
December	9,958	6,427	5,347	2,423	6,951	9,006	3,351	5,032	6,063
The Year	7,416	8,346	5,377	6,946	5,847	8,826	5,912	4,779	6,681
Maximum	10,945	10,668	7,455	14,169	10,082	12,081	8,319	7,467	11,169
Minimum	2,171	5,843	2,937	2,423	1,710	3,677	3,351	1,776	1,710

NOTE.—Discharges are deduced by taking the difference between the Otter-Slave Falls and the Kenora records and reducing the same in proportion to the areas of the drainage basins. The maximum and minimum flows refer to the mean monthly flows.

The mean flow for the eight-year cycle, according to the above table, is 6,681 cubic feet per second. This figure must closely represent the actual discharge from the lake over the period in question.



The mass curve, plate 28, is based on the above table. In plotting this curve, water years have been utilized in keeping with the practice adopted in

other portions of the basin. The mean flow for the seven-year cycle of water years is 6,836 cubic feet per second.

*Regulation over the seven-year cycle.*—The general storage conditions which would be necessary in order to maintain uniform discharges of various limits at the outlet of Lac Seul are concisely set out in table 30 hereunder.

This table is compiled from a mass curve study. Column 3 lists the maximum volume of storage capacity necessary to meet the conditions; column 5 lists the total volume of water withdrawn from reservoirs throughout the period.

Table 30.—Storage Conditions which would have been necessary in order to maintain various Minimum Flows on the English River at the outlet of Lac Seul from April 1, 1907 to March 31, 1914.

Flow in sec.-ft.	PERIOD OF MAXIMUM DRAW.			Total volume of storage used, in billions cu.-ft.
	Dates.	Volume required in billions cu.-ft.	Equivalent depth on Lac Seul in ft.	
1.	2.	3.	4.	5.
6,836	Mar. 1, 1910 to end of period	104	16	267
6,000	Aug. 1, 1910 to Aug. 15, 1912	71	11	188
5,000	Sept. 1, 1910 to Nov. 15, 1911	48	5.06	112
4,000	Sept. 1, 1910 to Sept. 1, 1911	24	2.53	56
3,000	Nov. 1, 1913 to end of period	6	0.63	19
2,000	April 1, 1907 to May 15, 1907	1	0.11	2

Analysing the discharge records from the mass curve, plate 28, on the basis of maintaining a mean flow of 6,836 cubic feet per second shows the following.

The months of April and May, 1907, are below the mean flow, and require an initial storage of 23 billions of cubic feet, which volume is assumed to be available from previous years, and which 2.43 feet on Lac Seul would provide. The lake would be refilled early in October of the same year, while the continued high flow would provide an additional 77 billions of cubic feet by the end of February, 1909. Ten-foot storage on Lac Seul would accommodate 95 billions of this volume, leaving 5 billions to be stored in the lesser lakes.

Following February, 1909, is a continuous low-flow period until the end of March, 1910, by which date 55 billions of cubic feet are withdrawn from the reservoir. March is followed by ample flow until the end of July, by which date the storage basins are replenished by 53 billions of cubic feet.

With August 1, 1910, commences the greatest slack period in the cycle, lasting until the end of June, 1911, and requiring a withdrawal of 101 billions of cubic feet from storage to bridge the gap with the required mean flow. The net storage available from the commencement of the cycle to meet this draw is 98 billions, hence necessitating an additional three billions available and carried over from previous years.

Following June 30 is a period of alternate surplus and deficit, with the former predominating, lasting until the end of February, 1913. By this date

a net total of 95 billions is available for storage. By the end of the cycle, i.e., March 31, 1914, this storage has been reduced by 69 billions, leaving 26 billions available.

In reviewing the above, it is noted that a total of 26 billions of cubic feet is required at the commencement of the cycle, and that the maximum storage required at any one time is 101 billions. This storage could probably be provided. Ten feet on Lac Seul will supply 95 billions of cubic feet. The lesser lakes listed in table 18 will accommodate, under the limitations of columns 11 and 12, a total of 69 billions.

There is therefore, under the above conditions of flow, and assuming 10 foot storage on Lac Seul, sufficient reservoir area for the storage capacity required. It must be repeated, that the discussion is theoretical and is not based on actual run-off measurements on the English river but on deduced records from the Winnipeg river. However, after making allowance for these considerations there is good ground for believing that if the upper lakes provide reasonable reservoir facilities, the discharge from Lac Seul can be uniformly regulated under a properly operated system of control, and a discharge of 6,800 cubic feet per second maintained.

*Effect of Regulation of the Lac Seul Watershed on the Powers of the English River.*—It is advisable to here briefly outline the influence which a controlled flow on the English river would have on the river's power possibilities. In dealing with this, no attempt is made to combine or concentrate the various rapids and falls. Each is considered as a separate power prospect. Undoubtedly an investigation of the river would indicate concentrations such as are possible on the Winnipeg river. The falls and rapids with their respective drops used hereunder, are taken from the Fifth Report of the Hydro-Electric Power Commission of Ontario, issued in 1907, covering Algoma, Thunder Bay, and Rainy River districts.

The minimum flow to be anticipated under natural conditions along the English river varies considerably from the outlet of Lac Seul to the mouth of the river, there being 9,846 square miles of tributary drainage basin added in this distance. From table 27 the minimum mean monthly run-off on record is 3,146 cubic feet per second, occurring in April, 1911. This figure is checked by means of the deduced minimum inflow into the lake of the Woods during the seven-year cycle. At the rate of 0.14 cubic foot per square mile, the minimum monthly run-off of the English river at the mouth would be 3,045 cubic feet per second. The general characteristics of the Lake of the Woods and the English River basins are very similar, and the minimum run-off conditions should not vary greatly. It would not therefore be advisable under present conditions to depend on a higher minimum flow than 3,100 cubic feet per second at the mouth of the English river. At the outlet of Lac Seul this would be reduced to 1,685, or, in view of the natural balancing effect of Lac Seul, say 2,000 cubic feet per second. With a minimum of 2,000 second feet at Lac Seul and 3,100 second feet at the mouth of the river, the minimum dependable flow at the rapids and falls has been assumed to increase with their respective distances from Lac Seul. This assumption is sufficiently close to actual conditions to

permit a reasonable comparison being made between power conditions under regulated and non-regulated run-off.

The analysis of the flow of the English river shows a mean flow of 6,836 cubic feet per second, from a regulation of the Lac Seul basin. A consideration of the whole basin shows a mean flow of 12,576 second-feet. In reviewing the conditions rendering this latter flow possible, it will be noted that the storage required can probably all be obtained above the Lac Seul outlet. Considering this, and the presence of the possible storage reservoirs tributary to the river just below the lake, it will be conservative to assume for comparative purposes a minimum flow of 8,000 second-feet throughout the English river under a properly controlled system of storage.

On this basis, table 31 hereunder has been deduced, i.e., an unregulated minimum flow varying from 2,000 second-feet to 3,100 second-feet from Lac Seul to the mouth of the river, and a regulated minimum of 8,000 second-feet throughout the reach.

Table 31. —Effect of Properly Controlled Regulation in the English River Watershed on the undeveloped powers of the English river below Lac Seul.

Site.	Head in feet.	POWER IN TERMS OF 24-HOUR H.P. 75% EFFICIENCY.	
		At estimated minimum flow under natural conditions.	At estimated regulated flow.
1.	2.	3.	4.
Ear Rapids.....	29	4,910	19,800
Manitou chute.....	28	5,100	19,100
" fall.....	15	2,730	10,200
" rapids.....	6	1,270	4,090
" fall.....	10	2,120	6,800
" rapids.....	6	1,270	4,090
" rapids.....	6	1,270	4,090
Kettle falls.....	19	4,670	13,000
" rapids.....	15	4,670	10,200
Caribou rapids.....	6	1,590	4,090
Total.....	140	28,630	95,460

From the above table the total power available, under estimated minimum conditions of flow, is 28,630 horse-power, while under a regulated flow this would be increased to 95,460 horse-power or by 233 per cent. It is apparent, therefore, that so soon as hydro-electric development becomes commercially feasible on the English river, the question of controlling the flow will likewise become active, so that, omitting all consideration of the power reach in Manitoba, the local needs of the English river will demand as complete regulation in the upper waters as the reservoir capacity will permit. Such regulation will be entirely beneficial to the Manitoba reach.

In reviewing the question of regulating the English River flow, it appears feasible by properly exercised control to ensure a minimum flow of 6,800 cubic feet per second at the outlet of Lac Seul, and 10,000 at the mouth of the river.

It is essential that the control and regulation when instituted shall be in independent and impartial hands.

#### SUMMARY OF THE RESULTS TO BE OBTAINED FROM STORAGE.

A review of the storage discussion can best be summarized under the natural run-off divisions of the watershed.

#### LAKE OF THE WOODS AND TRIBUTARY DRAINAGE.

The maintenance of the seven-year mean flow from Rainy lake (7,962 cubic feet per second) can only be ensured at all seasons by a most exhaustive and complete system of storage reservoirs among the lesser lakes, and is not considered to be practically feasible. A flow of 6,000 cubic feet can be readily ensured with the reservoirs now in operation.

The seven-year mean flow from the lake of the Woods (12,442 cubic feet per second) can theoretically be maintained at all seasons, but only if the lake of the Woods storage is supplemented by a very full measure of regulation in the upper basin. A discharge of 12,000 second-feet under a complete system of storage reservoirs and careful control may be ultimately practicable. A minimum of over 10,500 second-feet can be ensured with 5-foot regulation on the lake, and with the reservoirs now in operation in the upper basin. The full 5-foot limit on the lake of the Woods need only be drawn upon at intervals of years.

#### ENGLISH RIVER AND TRIBUTARY DRAINAGE.

The seven-year mean flow from Lac Seul (6,836 cubic feet per second) may possibly be maintained at all seasons. It is probable that little difficulty would be experienced in ensuring from 6,000 to 6,500 second-feet discharge in practical operation.

The seven-year mean flow of the English river at its mouth (12,576 cubic feet per second) cannot apparently be fully maintained, due to lack of suitable reservoirs in portions of the watershed. A discharge of 10,000 second-feet should be ensured by a full measure of practical control.

#### POWER REACH IN MANITOBA.

From the foregoing it would appear that the maintenance of a flow of 20,000 cubic feet per second in the power reach in Manitoba should be quite practicable. At the same time it would be well to emphasize here that the foregoing calculations should be revised from time to time, as later and more exact data become available both as to the storage capacities of the upper lakes and as to the general run-off of the basin. This is particularly true in respect to the English river, since it has been necessary in the foregoing to base its run-off on deductions from existing records on the Winnipeg. The systematic gauging operations now maintained on the English river by the Hydro-Electric Power Commission of Ontario will provide reliable data for checking and, if necessary, revising the conclusions now submitted covering the northern portion of the watershed.

Under present conditions of hydro-electric development in the upper watershed, 20,000 second-feet in the power reach can be secured from a proper control of the Lake of the Woods reservoir alone. With the increase in power utilized at Kenora and Keewatin, storage works must be installed in the English River basin, in order to ensure 20,000 second-feet in Manitoba at all seasons.

The increased use of power at the outlets of the lake of the Woods will necessarily involve a more regular outflow from the lake or, in other words, a raising of the present permissible minimum discharge. While this will be directly beneficial to the power reach, it will not meet the requirements of 20,000 cubic feet per second throughout the winter season.

Assuming that under conditions of greater power development at the lake outlets, 12,000 cubic feet per second were ensured from the lake of the Woods, it would not be possible to depend on a natural supplementary flow from the English river of more than 3,000 to 4,000 cubic feet per second, or say 16,000 cubic feet per second on the power reach. Lac Seul is the obvious source from which the extra 4,000 cubic feet per second to make up the required 20,000 must be secured.

It is altogether probable that the next considerable storage reservoir established in the watershed will be Lac Seul. Its waters can be used for the direct benefit of the Winnipeg reach until such time as power development takes place on the English river.

#### GENERAL PRINCIPLES OF REGULATION.

It is not possible to do more than theorize about the future course of development throughout the basin, and hence it is impracticable to lay down final principles which should control future regulation. It is possible, however, to enunciate a few general principles which should be kept in mind.

The Fort Frances power undertakings require the fullest measure of regulation attainable in the Rainy Lake watershed. All efforts must therefore be made to secure the highest feasible minimum flow, and to conserve to the greatest degree possible the entire run-off. It is scarcely probable that it will be feasible or desirable to establish sufficient reservoirs in the upper lakes to fully regulate the run-off from all portions of the basin. Rainy lake, as receiving the entire upper drainage, is the natural balancing reservoir for the power works. At such times and under such conditions as it is necessary to conserve the run-off to the utmost, it will therefore be necessary to maintain the lake level below the spillway crest of the control dam, in order to provide storage capacity for unexpected run-offs from uncontrolled sections of the basin, and to prevent possible waste.

Namakan lake likewise acts as a balancing reservoir for the lakes in the basin above, and should be utilized to regulate, so far as possible, the flow from the uncontrolled portions of the tributary drainage. The filling and emptying of such reservoirs as may be established in the upper basin is altogether a matter dependent on their location, capacities, and most advantageous use. In any event, Rainy lake will be utilized as the final balancing reservoir for the power works.

The present power used at the outlets of the lake of the Woods does not normally require more than 3,000 cubic feet per second for satisfactory operation. This flow can be readily secured, and at the same time the lake be utilized as a balancing reservoir for the Manitoba reach. As shown on plates 29 and 24, 20,000 cubic feet per second in Manitoba can thereby be readily maintained.

So long as there is ample flow available, it will not be necessary to exercise control over the discharge other than to keep the lake as nearly full as possible at all seasons, and draw from it only at such times as the power interests on the lower river demand. In other words, the lake storage must be kept at all times available as an insurance against low run-off conditions. These may practically always be counted on during the winter season. In normal years, the lake should be full throughout the summer and navigation season, and drawn down throughout the winter.

When the power demand at the lake outlets becomes more pressing and requires a flow approaching the average run-off from the lake, the control of the regulation will require a much greater degree of care, and will aim at a minimum of waste. Under these conditions, the lake must be maintained at an elevation sufficiently below the upper limit to permit the storing of the surplus run-off from the south and west, where no reservoir capacity other than the lake is available, and to make provision for extreme floods. At the same time, the lake must be filled to upper level before the commencement of the low-water season. Proper control, with these ends successfully attained, can only be insured by a thorough and intelligent study of past run-off conditions, and by the careful recording and analysis of similar data from year to year. The control of the lake must be supplemented by regulation of the watershed above Fort Frances.

#### CONTROL OF REGULATION.

A review of the magnitude and diversity of the power interests of the Winnipeg River watershed, emphasizes the outstanding importance of the control of its run-off through the operation of storage reservoirs. It is immediately apparent that if these reservoirs are in private hands and are operated solely to meet local needs, the general power interests of the basin and the particular interests of competing undertakings are certain to suffer. For example, assume that the regulation of the lake of the Woods is wholly in the hands of a private firm developing power at the outlets. Closing the regulating sluices at the lake outlets would completely shut off the flow from the lake, possibly for weeks at a time, and thereby reduce the flow in the Winnipeg power reach by at least one-half. Even under ordinary operating conditions at the lake outlets, it would at all times be possible to so control the lake as to adversely affect power developments on the lower river.

Other examples could be given. The above is sufficient to illustrate the impossibility of private control over storage reservoirs on a river such as the Winnipeg, where a large number of independent power establishments are in operation, all of which are equally dependent on the run-off.

This question of control is again dealt with in chapter VI in connection with the interdependence of the projected power concentrations and the existing

FIG. 1 NATURAL FLOW





FIG. 2 INFLUENCE OF THE LAKE




Legend for Fig. 2

- Water stored
- Water drawn
- Natural flow
- Flood water

B.C.F. = Billions of C

Fig. 3 Regulated Flow resulting fr




DOMINION WATER POWER BRANCH

J. B. CHALLES, Assistant

HYDROGRAPHS SHOWING THE POSSIBLE  
REGULATING EFFECT OF THE LAKE OF THE WOODS


FIG. 1. NATURAL FLOW



WINNIPEG RIVER FLOW AT SLAVE FALLS  
WITH PROPERLY CONTROLLED REGULATION


WATER RESOURCES, POWER AND STORAGE INVESTIGATIONS  
BY J. T. JOHNSTON, B.A.Sc.

FIG. 2. INFLUENCE OF THE LAKE OF THE WOODS STORAGE ON THE NATURAL FLOW



Legend for Fig. 2. Water stored from Natural flow  
 Water drawn from Storage  
 Natural fluctuation of flow exclusive of flood water  
 Flood water wasted  
 B.C.F. = Billions of Cubic Feet

FIG. 3. Regulated Flow resulting from systematic control of the Lake of the Woods





plants on the Manitoba power reach, and the impracticability and unfeasibility of private regulation for purely local needs at each site is again clearly in evidence.

In addition to the power questions affected, the lumbering, fishing, navigation, and other interests must also receive their proper consideration in the general question of river regulation.

#### GOVERNMENT CONSTRUCTION OF RESERVOIRS.

If all interests dependent on and affected by the run-off are to be ensured satisfactory operating conditions, it is clearly apparent that there must be some central supervising control of the entire regulation of the river. The regulation of the basin must be in the interests of all concerned, as well as in the interests of each undertaking.

This being the case, it is evident that the establishment of storage reservoirs should be undertaken by the Government. The expense of their construction, maintenance, and operation should be shared among the various power users benefiting from their installation, and shared in proportion to the benefit received. Under these conditions, the proportionate charge on each power undertaking would be small. On the other hand, the private establishment of a reservoir throws the entire capital and operating costs on the particular company constructing the same, while the benefits derived from its moderating effect on the river flow are equally shared by all plants below. In view of this aspect, it should not be difficult for the Government and the power users to reach a mutually satisfactory basis of agreement with regard to the construction of necessary reservoirs, and to arrange for a proper sharing of the cost, maintenance, and operating expenses, among all parties benefited.

#### REGULATING AUTHORITY.

The operation of the regulation to the satisfaction of all can only be ensured by its being placed in charge of a responsible central control, to whom all questions pertaining to river regulation can be referred. It is considered that this central control could be best exercised through the joint action of the Dominion Water Power Branch and the Hydro-Electric Power Commission of the province of Ontario, or failing this, through some central governmental board or commission. To ensure satisfactory operation of the regulation, the controlling organization must possess the following primary qualifications:—

(1) It must possess the confidence of the various power and other interests affected by any phase of the regulation.

(2) It must be so constituted as to enable instant action being taken upon complaint or demand being made, that is to say, it must be represented on the ground, and immediately and at all times accessible to all parties interested in, or affected by the run-off regulation.

(3) It must at all times be in full possession of all data necessary to adjudge any question of regulation which may arise.

(4) It must have entire authority and direct charge over the operation of all storage reservoirs, and supervising control over the local regulation maintained by each hydro-electric and industrial undertaking utilizing the river run-off as a source of power.

## METHOD OF CONTROL.

In order to fulfil the actual requirements of operation, it will be necessary for the controlling body to appoint and maintain a permanent and responsible regulating engineer in sole and direct charge of the regulation of the entire run-off. This officer, established in a central office, should be in daily receipt of full information as to the discharge of the river at all vital points, and as to the loads carried and water wasted at all hydro-electric and industrial plants along the river.

The satisfactory carrying out of the regulation will necessitate the careful rating of all power plants and dams throughout the basin, as well as full investigation into the time taken by the discharge from the various storage reservoirs to reach the different centres of development. Fairly complete data of this nature have already been gathered by the engineers of the Dominion Water Power Branch, and further investigations are being proceeded with. It is only by a thorough and continuous study of all run-off, storage, and load requirement data, that a control can be inaugurated which will, from its commencement, be satisfactory to all interests affected. Steps have already been taken by the Water Power Branch to carry out such a study.

In reviewing the entire situation as it now stands in the Winnipeg basin, and considering the conflicting interests which are at present affected by the question of regulation, as well as the importance of the future industrial development which must take place and is dependent on the river power, it is apparent that some such system of control as that outlined above must be instituted if the full benefit of the river flow is to be ensured to all. That this central control will be satisfactory to the interests affected and to the public at large, and will be vastly more efficient than haphazard regulation to meet immediate local needs, without regard to other interests and future requirements, is obvious to all who give the question serious consideration.


ry  
ble  
ire  
pt  
to  
ts

ful  
ill  
ge  
ta  
on  
h.  
ad  
ts  
ly

n,  
ne  
al  
is  
oc  
is  
ic  
et  
-

REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

CHAPTER V.  
EXISTING POWER AND INDUSTRIAL PLANTS.



## CHAPTER V.

### EXISTING POWER AND INDUSTRIAL PLANTS.

Before entering into a detailed study of the various units which go to make up the proposed scheme of hydro-electric development along the Winnipeg river in Manitoba, it will be advisable to deal briefly with the existing power plants and storage dams now constructed in the basin. Two large power stations are now in operation on the river in Manitoba, the Winnipeg Electric Railway plant on the Pinawa channel, and the city of Winnipeg municipal plant at Point du Bois. These plants and their safeguarding, formed controlling features which required first consideration in laying down a general scheme of development for the river. The entire reach of the river in Manitoba above Lac du Bonnet was more or less affected by the head- and tailwaters of, and the diversion conditions resulting from, the two existing undertakings. The river reach below Lac du Bonnet was undisturbed by existing structures, and offered full scope to development along maximum advantageous lines.



Pine Falls, Old Headrace.

#### FIRST DEVELOPMENT ON THE WINNIPEG RIVER IN MANITOBA.

What was probably the first power installation on the Manitoba reach of the Winnipeg river was undertaken some forty years ago at Pine falls. The river as a whole does not lend itself to small developments, and it is only by taking advantage of particular local opportunities that such developments are even feasible.

At Pine falls, advantage was taken of the rock and shore formation on the left river bank to blast a power raceway for the purpose of carrying the head-water level to a lumber and shingle mill located some 900 feet below. A head of about 9 feet was available. No diversion dam was constructed in connection with the head-race, the natural shore line providing of itself all the facilities which were necessary in this direction.

The mill was in continuous operation about thirteen years, was then shut down, and some five or six years afterwards destroyed by fire. The old turbine runner is still on the site, and is an interesting reminder of early industrial days on the river.

### WINNIPEG ELECTRIC RAILWAY COMPANY'S PLANT.

#### HISTORICAL.

The first large hydro-electric development constructed in Manitoba was that undertaken by the Winnipeg General Power Company on the Winnipeg river. This company was organized in 1901 for the purpose of developing power for distribution in Winnipeg. The Winnipeg Electric Railway Company was incorporated in 1904, and amalgamated the interests of the Winnipeg General Power Company with those of the Winnipeg Electric Street Railway Company. This latter company operated the street railway system of Winnipeg, and also distributed power for domestic and industrial use, supplying the same from a steam station located in the city.

The site selected for the construction of the plant is located on the Pinawa channel, in section 32, township 14, range 12, east Principal meridian, about 58 miles in a direct line from the city of Winnipeg. The general scheme proposed called for the diversion into the Pinawa channel of a portion of the Winnipeg River flow, by means of diversion weirs across the main channel, and the concentration and development of a 40-foot head.

#### CONSTRUCTION.

The site of the power station (plate 2) is 7 miles distant from the village of Lac du Bonnet, which at the time of construction gave the nearest railway connection. The city of Winnipeg tramway line now runs within 4 miles of the station. The construction of the plant required the installation of a ferry at Lac du Bonnet, where the river is somewhat less than a mile in width, and the construction of a traffic road. The heavier portion of the transport was carried during the winter season.

Operations on the excavation of the dam and tail-race began in the spring of 1902, the previous winter having been devoted to transporting the necessary plant to the ground, and the construction of the plant was practically completed by June, 1906.

The late Dr. F. S. Pearson, consulting engineer of New York, with Mr. L. J. Hirt, C.E., had charge of the design and construction of the entire work.



Winnipeg Electric Railway Company, Main Weir.



Fishway and Log Slide at Main Weir.




Winnipeg Electric Railway Company, Secondary Weir.



Winnipeg Electric Railway Company, Spillway on Loon River.



Winnipeg Electric Railway Company, Construction of Control Dam.



Winnipeg Electric Railway Company Control Dam.

## DIVERSION WEIRS AND CONTROL DAM.

Three diversion weirs cross the main and secondary channels of the Winnipeg river at the head of the Pinawa channel (plate 30). The main weir consists of a 1,379-foot concrete capped, rock-fill structure, with crest at elevation 105.5, company's datum, or 897.44 Water Power Survey datum,<sup>1</sup> connected with the river banks on either side by concrete spillways with crests at 897.44, bringing the total length of the main weir up to 1,652 feet. This rock-fill section is not entirely water-tight, but fulfils the purpose for which it was constructed, i.e., raising the water level above to a sufficient elevation to divert the necessary flow down the Pinawa. A fish ladder and log slide are located at the west abutment of this weir. Two secondary weirs, one of timber, length 120 feet, crest at 396.94, and the other of concrete, length 535, crest at 895.94, spanning two secondary channels, complete the diversion system.

The discharge down the Pinawa to the plant is governed by a control dam, consisting of eighteen 9-foot and one 13½-foot stoplog sluice-ways, with sills at elevation 881.94. Above the control dam and the diversion weirs there is a pondage area of approximately 5,800 acres, extending up stream to the foot of Slave falls.

## HEAD-RACE.

From the control dam to the power station pond some 2½ miles below, the head-race follows a somewhat winding route, which in places has been extensively improved, widened and straightened by excavation. The current is rapid, and the water surface, which above the weirs varies from elevation 898 to 901, drops to elevation 881 in the pond above the power dam. The tail-race presents conditions largely similar to those in the head-race, and the water finally rejoins the main river in Lac du Bonnet, about 13 miles below the station.

## POWER STATION.

In the general layout of the plant (plate 31), the power station is placed on the west bank of the channel. The power-house building is 330 feet in length, 32 feet in width and 29 feet 9 inches from generator floor to top of roof truss. The generator floor is at elevation 851.44, with the bottom of the tail-race at 826.94. The intake dam is placed 95 feet upstream from the upstream side of the power station, the water being led to the turbines through 14-foot steel penstocks housed for protection against frost, and with their entrances guarded by the customary gates and racks. The transformer house lies to the north, and is an extension of the power-house. Its dimensions are; length 176 feet, width 53 feet, height 36 feet 9 inches. The entire building is of fireproof construction, being built of brick and structural steel throughout.

<sup>1</sup> 791.94 Water Power Survey datum = 0.0 Winnipeg Electric Railway Company datum.



Winnipeg River. Winnipeg Electric Railway Power House, Finawa Channel.

## INSTALLATION.

The hydraulic installation consists of nine main units, four of 2,595 h.-p. and five of 4,788 h.-p. (manufacturers' rating at 39-foot head). Each unit consists of four horizontal inward-flow runners mounted in pairs and located longitudinally in the penstocks. The draught tubes drop vertically into the tail-race, with the water seal at elevation 832.69. The turbines are direct connected to the generators, and are equipped with Lombard governors. The electrical installation consists of four 1,000-k.w. and five 2,000-k.w. revolving field, 60-cycle, 2,300-volt, three-phase generators. The smallest machines run at 200 and the larger at 180 revolutions per minute. The generators are guaranteed to operate at full load at 95.5 per cent efficiency. Excitation is provided by two 100-k.w., 125-volt direct-current machines coupled to two 200-horsepower McCormick turbines, and operating at 600 revolutions per minute; and by two 175-k.w. 125-volt exciters coupled to three-phase 2,300-volt induction motors, operating at 514 revolutions per minute.

Table 32 lists the station equipment.

Table 32.—Machine Installation of Winnipeg Electric Railway Company in Pinawa Channel Plant.

Number of Units.	Turbine.	Gene- rator.	Speed.	Voltage.
	H.-p.	K.w.	r.p.m.	
4 .....	2,595 <sup>1</sup>	1,000	200	2,300
5 .....	4,788 <sup>1</sup>	2,000	180	2,300
2 .....	200	100	600	125
2 .....	Motor driven.	175	514	125

<sup>1</sup> Manufacturers' rating at 39-foot head.

Fifteen transformers raise the voltage to 60,000 for transmission to Winnipeg.

A summary of the machine installation of the Winnipeg Electric Railway would not be complete without reference to the steam and storage battery plants operating in conjunction with the Pinawa station.

Prior to the year 1906, when hydro-electric power was first used in Winnipeg, all electric light and power was supplied from a steam plant on Assiniboine avenue in Winnipeg, owned by the Winnipeg Electric Street Railway Company. This plant had a capacity of about 5,000 brake horse-power. In the year 1910 the capacity of the Assiniboine Avenue power-house was increased by 1,000 horse-power. In the year 1911 an auxiliary steam plant of 12,000 horse-power capacity was constructed at Mill street adjoining the company's main substation. During the year 1913 the company built a storage battery house adjoining the Mill street substation, and installed a 5,000 ampere hour storage battery. At the present time (March, 1915) the Mill street station is capable of producing 16,000 horse-power, and the Assiniboine Avenue plant approximately 6,000 horse-power. At certain seasons of the year all of the company's steam power and the storage battery plant is in use and operated to capacity.

-p.  
nit  
ed  
he  
ect  
he  
ing  
run  
are  
is  
wo  
per  
olt

*in*

---


stage.

---

2,300  
2,300  
125  
125


peg.  
way  
ants

peg,  
bine  
any.  
1910  
,000  
ower  
main  
ouse  
rage  
able  
plant  
the  
d to



**GENERAL KEY PLAN**

Scale of Miles




**KEY PLAN OF WEIRS**

Scale of Miles




**WEIR 'C'**

Scale of feet



**PLAN OF TIMBER CHUTE AND FISH LADDER**

Scale of feet




**SECTION X-X WEIR 'C'**

Scale of feet



**NOTE**





PLAN BASED ON BLUE PRINTS FILED BY THE WINNIPEG ELECTRIC RAILWAY COMPANY



**CONTROL DAM**

Scale of feet







Department of the Interior Canada  
 MINISTRE DES TERRES ET DES RESSOURCES  
 WATER POWER BRANCH  
 © 1914 by the Government of Canada

**WINNIPEG RIVER POWER SURVEY.**  
**DIVERSION WEIRS and CONTROL DAM**  
 CONSTRUCTED BY THE WINNIPEG ELECTRIC RAILWAY COMPANY  
 AT THE HEAD OF THE PINAWA CHANNEL

Prepared by the WINNIPEG RIVER POWER AND STORAGE INVESTIGATION  
 by J. F. JOHNSON, P. E.








**SECTIONAL PLAN**

Scale of feet  
 0 10 20 30 40 50 60





**TYPICAL SECTION OF INTAKE DAM, PENSTOCK & POWER HOUSE**

Scale of feet  
 0 5 10 20 30 40

El. 791.94 W.P. Station - 0.0 Winnipeg Electric Ry Co datum

NOT  
 P  
 S  
 W



**GENERAL KEY PLAN**

Scale of miles  
 0 1 2 3 4



**GENERAL LAYOUT**

Scale of feet  
 0 500 1000

Department of the Inland Canals  
 HONOURABLE W. J. ROBEY, M.C.  
 W. W. BERRY, C.E.S., Deputy M.C.  
 Water Power Branch  
 J. B. LITTLE, Superintendent

**WINNIPEG RIVER POWER SURVEY.**

**WINNIPEG ELECTRIC RAILWAY  
 POWER STATION**

CONSTRUCTED BY THE WINNIPEG ELECTRIC RAILWAY COMPANY  
 ON THE PINAWA CHANNEL.


FOR INFORMATION & REPORT ON POWER AND STORAGE INVESTIGATIONS  
 BY J. T. JOHNSON, C.E.S.

**NOTE**  
 PLAN BASED ON BLUE PRINTS FILED  
 BY THE WINNIPEG ELECTRIC RAIL-  
 WAY COMPANY





Winnipeg Electric Railway Company, Model of Plant.



Winnipeg Electric Railway Company, Interior of Power Station.

The total power available for distribution in the city is in the neighborhood of 45,000 horse-power.

POWER DAM.

A free spillway, curved in plan, and 429 feet in length, with crest at elevation 879.44, crosses the old river-bed along what was previously the crest of a natural



Winnipeg Electric Railway Company, Power Dam.

fall, and connects with the left bank. Low earth embankments with top at elevation 883 are located on either bank. All headworks are constructed to withstand a pond level of 882.

HEAD AVAILABLE.

The head available for power purposes varies considerably, depending on the season and the flow in the channel.

The original crest of the spillway was at elevation 875.67. This was raised in 1907 and again in 1910 to its present elevation, 879.51, by the placing of tiers of timbers along the crest. The average head available at the plant is 39 feet.

TRANSMISSION.

The entire output of the station is transmitted to Winnipeg at 60,000 volts, over a 65-mile duplicate transmission line. The line is supported on standard steel towers, 40 feet high and spaced at 500-foot intervals. It crosses the main Winnipeg river with a span of 760 feet, on 72-foot towers, and the Red river with a span of 1,100 feet on 105-foot towers.

The power is delivered to substations and distributed in the cities of Winnipeg and St. Boniface, the towns of Transcona, Stony Mountain, and Stonewall, the rural municipalities of Fort Garry, Assiniboia, East Kildonan, West Kildonan, St. Andrews, St. Vital, St. Pauls and Rockwood, and is supplied in bulk to the West Selkirk municipal plant.



Winter Conditions at Power Dam.

OPERATION.

Due to the long winding head-race, with its rapid and in places disturbed current, ice conditions have given considerable trouble. In the severe temperatures which prevail during the winter season, accumulations of frazil ice at times partially chokes the head-race, with a consequent reduction of the flow, and the use of explosives is sometimes necessary. Similar conditions are sometimes met with in the tail-race, and the choking of the channel results in backing up the tail-water with a consequent reduction of head. While these

conditions result in considerable inconvenience, and require attention on the part of the company, they have not seriously interfered with the operation of the plant, and past experience enables the management to take prompt and efficient measures to combat adverse conditions as they arise.

#### FLOW REQUIRED.

In view of the fact that with a properly controlled run-off the surplus flow passing over the diversion weirs and down the main channel can be profitably developed on the Seven Sisters reach, a study of the flow in the Pinawa necessary to properly operate the company's plant, and also of the actual flow conditions since the plant was placed in operation, is of considerable importance.

As a result of the adverse ice conditions which occur during the winter season, and which produce sudden and considerable changes in the flow, and also from the fact that, until recently, no continuous systematic effort was made to secure a full record of the discharge, a determination of past conditions of flow at all seasons is a matter of considerable difficulty. A metering station was established by the field staff of the Dominion Water Power Branch in May, 1912, immediately below the control dam, and continuous records have been secured. This, combined with the existing gauge records provides a fairly accurate rating for summer conditions, but gives no data from which previous winter flows can be correctly determined. In order to secure this information it was necessary to rate the plant and to carefully study and utilize the load records.

While the final collation and reduction of the results secured is not yet completed, sufficient has been accomplished to indicate that the 8,000 cubic feet per second which has been utilized throughout this report as the flow necessary to properly operate the plant is amply sufficient for the requirements of the present installation.

The open-season discharge records of the channel are appended in tables 55, 56, and 57, Appendix VII. It will be noted that the discharge frequently exceeds 8,000 cubic feet per second. However, there is generally a considerable automatic discharge over the free spillway of the plant.

### CITY OF WINNIPEG'S MUNICIPAL PLANT.<sup>1</sup>

#### HISTORICAL.

In order to meet the power demands of a rapidly growing population, and also for the purpose of creating, competitive conditions in the power market, the citizens of Winnipeg, after a prolonged consideration of the various phases of the matter, finally determined upon the construction of a municipally owned and operated power station on the Winnipeg river. In the year 1905, engineers were asked to examine the river with a view to selecting the best site available for the location of the proposed plant. A careful examination was made of

<sup>1</sup> In preparing the subject-matter for this section on the city plant, the writer is indebted to a paper read by Mr. W. G. Chace before the Canadian Society of Civil Engineers, and also to an article published in *Engineering*, July 26, and August 2, 1912, by the Vickers, Ltd., descriptive of the installation.



City of Winnipeg Municipal Plant, Power Station under construction.



City of Winnipeg Municipal Plant, Power Station under Con.

the hydraulic resources of the river, and the report presented justified the city authorities in having contour surveys made of the three most promising power sites. These surveys were carried out during the following winter, and the site finally selected was that at Point du Bois falls, at which point there was a natural fall of from 28 to 33 feet.

The final report, including the estimated cost of development, was submitted in April 1906, and in June the citizens voted \$3,250,000 towards the construction of the plant. Designs and plans were begun in October of the same year, and it was then intended to complete the works within two and one-half years. Delay was occasioned, chiefly by the financial stringency of 1907, but tenders were finally called in August of that year for the construction of the plant. No contract was let at that date, but in the following spring work was commenced on the spur railway connection to Lac du Bonnet. In January 1909, contracts were let for the construction of the plant and the transmission line, and later in the year for other necessary construction and equipment. The plant was completed and the initial installation placed in operation in October, 1911.

The design and superintendence of the development was entrusted to Mr. C. B. Smith in the autumn of 1906, and was by him personally conducted until November, 1908, at which date the duties were assumed by Mr. W. G. Chace, as partner of the engineering firm of Smith, Kerry and Chace, resident in Winnipeg. There were engaged as a Board of Consulting Engineers, Col. H. N. Ruttan, City Engineer of Winnipeg; Professor Herdt, of McGill University, and William Kennedy, jr., of Montreal.

#### SCHEME OF DEVELOPMENT.

The Point du Bois falls are located 75 miles in a direct line from Winnipeg, in section 36, township 15, range 14, east principal meridian, and 22 miles from the nearest railway connection. This is at the village of Lac du Bonnet, referred to above. The spur line, or city tramway as it has since been called, is of standard-gauge construction, and crosses the main river by means of a wooden truss bridge at a point 2 miles below Lac du Bonnet station. A steel bridge carries the line across the Pinawa channel,  $4\frac{1}{2}$  miles below the plant of the Winnipeg Electric Railway Company.

At the Point du Bois falls the river pitches rather abruptly over two natural rock barriers, which, together with the smaller drops, rapids, and disturbed water, gave under natural conditions, a normal 30-foot drop in a distance of about 1,400 feet. The narrowest point of the river channel is at the crest of the falls. This location was selected as the site of the dam.

The layout is shown on plate 32. The dam spanning the main channel of the river is a rock-fill structure with crest at elevation 214, city datum, or 983.1 Water Power Survey datum.<sup>1</sup> This section is 700 feet long, and at present is not water-tight; it can be made so without much difficulty when occasion demands. At present the load carried has not reached the point at which the full minimum flow of the river is required.

<sup>1</sup> 769.1 Water Power datum = 0.0 city datum.




Winnipeg River. Point du Bois Falls. Showing Dam of City of Winnipeg Power Plant in distance.



City of Winnipeg Municipal Plant, Model of Plant.

At the western end of the rock-fill section, the fishway and log slide have been located. To the west of this again, and crossing a bedrock island, is 550 feet of free concrete spillway with crest at elevation 975.7, connecting with the main shore.

PLATE 32.



Plan of Layout of City of Winnipeg Plant, Point du Bois, Winnipeg River. Elevations given to City Datum. Zero of City Datum = 769.1 Water Power Survey Datum.

A second section of spillway, 480 feet in length with crest at 975.7, spans a slight depression a short distance to the west of the main dam, while a third section, 245 feet in length, forms part of the canal wall immediately above the intake. The pond created is about 6,500 acres in extent, and floods the river back as far as Lamprey falls, about 7 miles above.

#### FOREBAY.

A forebay canal on the western side of the river, 1,600 feet in length, conveys the water from the pond to the power station. This canal is formed partially by excavation and partially by means of a retaining river wall (plate 33) with top at elevation 981.1. Two hundred and twenty-five feet of this wall acts as a free spillway, with crest at 975.7. The forebay has been excavated to 959.1, wherever necessary to provide sufficient section.

The entrance to the forebay canal is guarded by a control dam, regulated by twelve 17-foot stoplog sluices, sills at 959.1.

#### POWER STATION.

The completed power station (see plates 34 and 35) will be 442 feet in length, and will provide for seventeen bays. At present the nine bays adjacent

to the river have been completely constructed, together with the headworks, rack supports, and the upstream half of the wheel pits for the remaining eight. The insertion of stoplogs above the wheel-pit entrance makes this section of the power station a provisional dam until such time as the market conditions demand the completion of the plant. The finished section of the building is 105 feet in width from the nose of the entrance piers to the exit from the draught tubes. The highest point of the roof is at elevation 1,013.3, or about 62 feet above the centre line of the turbines.

The building is constructed of concrete and steel, and is founded directly on the natural granite which is found practically on the surface over the entire



City of Winnipeg Municipal Plant, Power Station.

site. The wheel pits, galleries, and roofs are of reinforced concrete, while the main walls are of plain concrete.

The gate room, 34 feet in width, running along the upstream side of the power-house, has its floor at elevation 783.1, and provides protection for the handling of the screens, and the operation of the stoplogs and the emergency gates with which each unit is provided. Such protection is very necessary during the severe winter conditions prevalent in this latitude. The gate room is supported on concrete piers, 14 feet centre to centre, which piers also support the stoplogs and gates.

An upward sloping, strongly supported, reinforced concrete apron floors the bays between the piers, and forms the foundation for the screens, with their supporting struts, and for the gate and stoplog sills. This apron is designed to gradually increase the velocity of the water and to prevent the abrupt change which would otherwise take place at the entrance to the wheel pit. This

entrance is 16 feet by 20 feet clear. The head gates are lifted by means of vertical screw shafts, 40 feet long, which rise through motor-driven nuts placed in the gate motor room. Each lifting motor operates any one of four gates. Stoplog gains are placed upstream from the gates.

Above the wheel pit is the turbine room, with floor at elevation 983·1. This is fitted with a 20-ton electric travelling crane of 29 feet span, with which the turbine parts can be readily handled. The wheel pits are elliptical



City of Winnipeg Municipal Plant, Headgate Room.


in plan, with floor at elevation 943·6. The double-runner horizontal turbine unit is placed with centre line at elevation 951·5, the discharge from the runners taking place axially into a common draught chest, and thence through a concrete moulded draught tube into the tail-race below the generator room, all changes of direction of flow being gradual and smooth. The water seal of the draught tube is at elevation 925·1.

The generator room is 36½ feet in width, and 51 feet in height, with floor at elevation 946·1. It is fitted with a 40-ton electric travelling crane. The transformer room is immediately downstream from the generator room, with floor at the same elevation.

## INSTALLATION.

The original installation, completed in April, 1913, consisted of five units. Each of these original hydraulic units consists of a double-runner turbine of 5,200 horse-power, which, operating under a 45-foot head, passes 1,250 cubic feet of water per second. The turbines operate at 164 revolutions per minute,

PLATE 33




Section of Retaining Dam, City of  
Winnipeg Plant, Point du Bois,  
Winnipeg river.  
Elevations given to City Datum. Zero  
of City Datum = 769.1 Water  
Power Survey Datum.

and have a guaranteed efficiency of 84 per cent at full load. They were supplied by Messrs. Jens, Orten-Boving & Company, London. The turbines have at times developed 5,900 horse-power per unit, but this is above their effective rating.

The turbine units are direct connected to 3,000-kilowatt generators, which generate three-phase current at 60 cycles and 6,600 volts, and which are of standard horizontal shaft, rotating field type. The machines were supplied by Messrs. Vickers, Limited, of River Don works, Sheffield.

The original machine installation was completed by two exciter units, each of 250-kilowatt capacity, and driven by water turbines running at 500 revolutions per minute. The transformers are of oil-immersed water-cooled type, and are situated in independent concrete compartments, delivering the power at 66,000 volts for transmission to Winnipeg.

In the year 1914, three additional main turbine units of different design to the original units were installed. These units are of the double-runner, horizontal-shaft type, but are of larger capacity than the initial units. Official tests give an output of 7,220 brake horse-power at 80 per cent gate opening and 46-foot head, or say 7,000 horse-power at 45 feet. The new turbines are direct connected to 5,000-k.v.a. Westinghouse generators, three-phase, 6,600 volts, 60 cycles, revolving fields.




Plan of Power Station, City of Winnipeg Plant, Point du Bois, Winnipeg River. Elevations given to City Datum. Zero of City Datum = 769.1 Water Power Survey Datum.

The effective turbine installation to date of writing consists of the five initial units of 5,200 horse-power each, and three additional units of 7,000 horse-power each, or a total of 47,000 horse-power.

Assuming that the eight bays in the uncompleted section of the power station are equipped with units of similar output to these last installed, will give to the station a total water-wheel capacity of 103,000 horse-power, with some considerable additional overload capacity.

PLATE 35



Section of Power Station, City of Winnipeg Plant, Point du Bois, Winnipeg River.  
Elevations given to City Datum.  
Zero of City Datum = 769.1 Water Lower Survey Datum.

#### HEAD AVAILABLE.

While the headwater elevation of the city plant can to a certain extent be regulated by the control dam at the head of the canal, at least to the end of keeping the level down in times of extreme flood should the same be desirable or necessary, the river walls and dams have been designed as free spillways which results in an automatic change in the pond level responding to the changes in the river stage. Under present conditions, the tailwater of the plant is subject to similar changes from the natural control at Eight Foot falls. The net result is that the head varies at different seasons. The normal head is 45 feet.

#### TRANSMISSION AND DISTRIBUTION.

The transmission line is built over a municipally owned right of way, 100 feet wide. It is 77 miles in length, and traverses a varied country, the

eastern section being typically Laurentian rock, muskeg, and scattered areas of arable soil, the western section crossing a prairie and farming country, several miles of which are closely wooded. Two lines of double-circuit towers and a separate telephone line are to occupy this right of way. Up to the present one line only has been built. The first transmission circuit was placed in operation in October, 1911; the second circuit was erected on the existing line in 1914, bringing up the transmission capacity to 35,000 horse-power.



Winnipeg River. City of Winnipeg Development. Generator Room.

Steps are being taken toward the construction of the second line, the necessary funds having already been voted by the ratepayers. A 12-foot patrol road also occupies the right of way.

The line is supported by steel towers set on concrete foundations, bearing two three-phase aluminum circuits, the wires of which are at 6-foot centres. The towers are of two general types, braced and flexible, 42 feet high, and spaced generally 1,200 feet apart.

The three-phase, 60-cycle, 6,600-volt current delivered by the generators is transformed up to 66,000 volts, and delivered to the terminal station located on the river front on Point Douglas. The pressure is here stepped down to 12,000 volts for distribution to sub-stations in lead covered cables laid in conduits. Three sub-stations are now in use in the city, and one in Transcona, a town of 2,500 population, 7 miles east of Winnipeg.

Distribution to consumers from the sub-stations is by underground conduits in the principal down-town streets, and by overhead lines on wood poles in all other localities.

Direct current power is distributed in the business portion of the city mainly for operating elevators. Alternating current for both power and lighting is available at all parts of the distribution system.

#### OPERATION.

A pond area of some 6,500 acres which has been created above the plant has had the beneficial effect of protecting the station from ice troubles. The water is drawn from this pond into a head-race of such dimensions as to maintain a quiet and undisturbed current to the power-house, and it finally passes into the turbines with a minimum of disturbance. A free discharge from, and open water below the station prevents any choking of the tail-race, and no ice troubles have been experienced in the operation of the plant since its completion in 1911.

#### FLOW REQUIRED.

The station, with its present eight units in full operation, requires a flow of some 11,000 cubic feet per second, or practically the minimum flow of the river under present conditions. The eight additional units in the uncompleted section of the station will, if of the same capacity as the three units just installed, require some 13,000 cubic feet per second, or 24,000 cubic feet per second for the entire plant.

#### POWER.

The Point du Bois plant can draw on the entire flow of the Winnipeg river, and a discussion covering its power capacities must keep this constantly in view. At the time the plant was projected the lowest recorded flow of the Winnipeg river was 16,000 second-feet. The design of the plant was based upon this flow combined with local pondage and load considerations. At 75 per cent efficiency, and with a 45-foot head, the 24-hour power available on this basis was 61,400 horse-power. The actual capacity for which the plant was designed is 48,000 k.w. in generators, driven by turbines of maximum capacity of 83,200 horse-power, an output well within reason for the site and conditions.

Since the plant has been constructed, river measurements have recorded discharges as low as 11,700 second-feet. Throughout this report the minimum flow is taken at 12,000 second-feet, or just three-quarters of the previously



Winnipeg River. Panoramic View, City of Winnipeg Development at Point du Bois Falls.

considered low flow. Were this condition without remedy, it would appear that the city plant, when completed, would be overdeveloped, since 12,000 second-feet will only supply 46,100 24-hour power, in place of the 61,400 horse-power previously assumed.

Regulation of the river flow provides a ready and feasible remedy for this condition. A certain measure of regulation is at present maintained in the Lake of the Woods, and this has very materially benefited the river flow past the Point du Bois plant. A more systematic regulation based on the run-off data now available, and carried on in the interests of all the powers on the Winnipeg river below the lake, including those at the outlets of the lake, would vastly better the low winter flows now to be expected.

The rapid growth of the power market, as is evidenced by the three additional units just installed, following the placing in operation of the first units barely three years ago, emphasizes the fact that the question of regulation is of immediate concern.

Plate 36 illustrates in a power-percentage of time curve, the continuous 24-hour power available on a 75 per cent efficiency basis.

#### BENEFICIAL EFFECT OF REGULATION.

Throughout this report, the calculations for the power available at the located sites have been based on an initial installation capable of utilizing fully the minimum flow of 12,000 second-feet, and a final installation which will utilize a regulated flow of 20,000 second-feet. In chapter IV the question of regulating the river with a view to increasing the minimum flow is discussed. The mean flow for the eight years from 1907 to 1914, inclusive, has been 25,373 second-feet. It is entirely feasible to so control the run-off that the low flow will never fall below 20,000 second-feet, providing supervised control of the entire basin is maintained by some properly constituted authority. While 20,000 is taken as the low regulated flow, there is at certain seasons a very great surplus available over and above this.


With 20,000 second-feet under a 45-foot head and at 75 per cent efficiency, 76,800 24-hour power is available. With the advantages of a 6,500-acre pond for the peak load use, the actual power available for distribution and sale in a market such as is served by this plant is greatly in excess of this. The pondage facilities would readily permit a peak load development of 125,000 horse-power. A four-hour peak of 125,000 horse-power would draw on the local pondage to the extent of 0.6 foot only.

A regulation of the river to a 20,000 second-foot minimum, will therefore give to this site a considerably larger measure of dependable power than was contemplated in the design of the present power station, and will vastly better the power capacity as dependent on the present known minimum of 12,000 second-feet.

The general results of the above two limiting low flows are summarized as follows.

Under present conditions of river flow, with a known minimum of 12,000 second-feet, the dependable power available is 46,100 24-hour power. The

development of this power will require only nine of the sixteen units provided for in the power station. The development of the sixteen units



will, under present conditions of river discharge, necessitate a steam auxiliary plant in the city to ensure dependable power during the low-water season.

With a minimum flow of 20,000 second-feet, the power available will be 76,800 24-hour power, with a peak load capacity of 125,000 horse-power

The development of this power will require the full utilization of the Point du Bois power station.

It is apparent from the above that the question of river regulation is of vital interest to the future of the municipal power undertaking.

#### OTHER DEVELOPMENTS IN THE BASIN.

While the two developments of the Winnipeg Street Railway and the city of Winnipeg, respectively, constitute the only hydro-electric plants in operation on the Winnipeg river in Manitoba, other undertakings in the upper portion of the basin must be referred to in order to properly understand and study the general run-off conditions and their relation to storage. To this end a brief description of the more important plants, power-using industries, and control structures is appended.

#### MUNICIPAL POWER PLANT OF KENORA.

In the year 1892 certain citizens of Kenora, after considerable investigation, undertook the construction of a small hydro-electric plant on the eastern outlet from the Lake of the Woods. Natural conditions at the outlets from the Lake could not be bettered for the construction of economic low-head plants. There is an abrupt drop of from 18 to 20 feet between the lake level and the river below, which drop can be readily developed at several different locations. Added to this are the almost unequalled pondage and storage facilities afforded by the lake which forms the direct head-water reservoir. The eastern outlet offered particularly inviting conditions for power-development. The waters discharged through a narrow and somewhat winding channel, with an abrupt and concentrated drop at the narrowest point formerly known as the Ka-ka-be-kitchewan falls.

The station, constructed and placed in operation in 1892 from designs by Col. H. N. Ruttan, afterward city engineer of Winnipeg, was not intended to utilize the entire flow through the outlet. A head-race partly in excavation and partly consisting of a masonry flume, about 10 feet by 10 feet in section, carried the water from above the falls on the right bank to the frame power station located below the pitch. The discharge from the turbines was protected by a wing dam from the effects of the rapid water below the falls. The first installation consisted of one 66-inch special Sampson vertical turbine, rated on a 17-foot head at 279 horse-power, 85 revolutions per minute, and 170 cubic feet per second.

In the following year a new penstock was constructed, and in 1894 a second turbine was installed. This wheel was a Standard Vertical Sampson, rated on a 17-foot head at 245 horse-power, 85 revolutions per minute, and 151 cubic feet per second. The head-race was enlarged to 20 feet total width. In 1896 or 1897 a third turbine was installed, being a 62-inch vertical turbine of the "Boss" type, and built by the William Hamilton Manufacturing Company.

In the year 1902, the municipal authorities considered the question of further enlarging the capacity of the plant to utilize the entire flow through the channel,



Kenora Power Station.



Kenora Power Station, Interior.

and engaged the engineering firm of T. Pringle & Sons to report on the proposed development, the power to be secured, and the cost of the works. Legal entanglements in connection with the land required on the left shore for this new construction delayed operations until 1906. In April of this year actual construction work was commenced, based on plans furnished by Pringle & Sons, under whose supervision the development work was carried on. The old power station and flume was removed, and on February 9 of the following year the new plant was placed in operation (plate 37). The installation at the opening was as follows:—

Three 40-inch Sampson twin horizontal turbines direct connected to generators, and supplied by the William Hamilton Manufacturing Company. Units 900 horse-power each (manufacturers' rating).

Two 30-inch Sampson twin horizontal turbines connected to exciter units, and supplied by the William Hamilton Manufacturing Company.

Three 625-k.w. generators, three-phase, 2,400 volts, 60 cycle, 150 revolutions per minute.

Two exciters, 120 volts, 175 revolutions per minute.

In the year 1913 a fourth 900 horse-power unit was installed, consisting of one 40-inch Sampson twin horizontal turbine supplied by the William Hamilton Company, direct connected to a 625-k.w. generator, three-phase, 60 cycle, 150 revolutions per minute, 2,400 volts. The governor installation consists of three hydraulic Lombard type N, and one hydraulic Allis Chalmers type C, governors, with two mechanical Woodward Compensating governors on the exciter turbines.

The power-house, which combines in itself the dam, is designed for six main units, and spans the entire channel, with the exception of a small space left for a log slide immediately adjacent to the left bank. The substructure is of mass concrete, and consists of a series of six arched bays forming the tail-races of the respective main units, and two lesser arched bays in the centre providing for the exciter units. The tail-water in these bays is maintained above elevation 76.0,<sup>1</sup> the water seal of the draught tubes, by a submerged weir constructed across the tail-race. The generator and turbine floor is at elevation 80.50, with the centre line of the machinery shaft at 88.83. The generator room is 35 feet by 158 feet, allowing 22 feet, centre to centre, for the main units. It is of brick construction and is covered with a peaked truss roof. The turbine chambers are covered with a 5-inch concrete roof which acts as a floor or platform giving ready access to the head gates.

The inflow to the turbines is controlled by hand-operated gates, with stoplog auxiliary apparatus for use if necessary. The racks, consisting of the regulation bar iron supported on 15-inch I-beams, rest on solid concrete sills, built up from the bedrock, immediately above the head gates.

Records of the load carried by the plant have been kept since August 21, 1907, at which time the total load was about 115 k.w. This increased to a peak of nearly 600 k.w. during the following winter. Since commencing operations the load has shown a steady growth reaching as high as 1,700 k.w. The

<sup>1</sup> An arbitrary datum of 100.0 has been used in the construction of the power house, and the establishment of the gauges. Zero of the Kenora power house datum is 961.42 Water Power Survey datum.

average load carried is in the neighbourhood of 1,300 k.w. The power is used in Kenora, Norman, and Keewatin for both lighting and industrial purposes.

No difficulty is experienced from ice troubles in the operation of this plant. The only condition which might lead to trouble in this connection would be abnormally low water in the lake during the winter season, under which circumstances the disturbed water and rapid current in the head-race might have a tendency to form frazil ice. During the summer of 1911, very low water in the lake reacted adversely on the operation of the plant. Elevation 93.7 was recorded in the head-race, due largely to the fact that the low lake level had reduced the section of the head-race, with the result that a very rapid current developed with a consequent drop in the surface level. These conditions resulted from imperfect regulation, and were not due to lack of run-off, since during the entire period some 2,000 second-feet were being wasted at the Norman dam on the western outlet. The condition could also have been remedied by deepening the head-race.

#### LAKE OF THE WOODS MILLING COMPANY'S MILLS AT KEEWATIN.

At the town of Keewatin, 1½ mile west of Kenora, excellent natural facilities exist for economic development. At this place the waters of Portage bay, an arm of Lake of the Woods, lie within 500 feet of, and some 20 feet above, a quiet reach of the Winnipeg river, and are separated therefrom by a rock ridge. The head- and tailwater conditions are similar to those existing at the Kenora power-house.

The first cut through the rock ridge was made in 1881 by a man named McAulay, the power developed being used for the operation of a saw-mill. In the following year, this power site became the property of Dick and Banning, and was used for saw-mill purposes until the year 1893. From this date, the flume was closed until 1899, when it was operated for two years by the Ottawa Gold Mining and Reduction Company, which acquired rights to the same in 1898. In 1900 the flume was again closed. In 1905 the site was acquired by the Keewatin Flour Milling Company, and the flume is stated to have been nearly doubled in size. The Keewatin Flour Milling Company was purchased by the Lake of the Woods Milling Company in 1906, and in May, 1907, the present mill, named mill "C," was put in operation. From 1907 to the present the mill has been in continuous operation.

The installation of mill "C" consists of two 56-inch twin horizontal turbines at 900 horse-power (manufacturers' rating), each at 20-foot head, and supplied by the William Hamilton Company. These two wheels are direct connected to the mill by rope drive. There is also a 45-inch twin horizontal turbine rated at 600 horse-power at 20-foot head, supplied by the William Hamilton Company, and direct connected to a 275-k.w. Allis Chalmers generator. This generator is an auxiliary, and is only used in case of a breakdown at the electric power-house, mill "A." The gate openings for the 56-inch wheels are operated by hand, while the generator-connected turbine is regulated by an automatic Lombard type B hydraulic governor. The electric power is used



Lake of the Woods Milling Company's Mills.

for elevators, hoists, etc. The working load of the mill is uniform in character and of 24-hour duration, and very suitable for direct application of power.

The average power developed is 1,100 horse-power, all of which is used by the company. No difficulty has been experienced in operating the mill, either from ice troubles or from lack of water.

The second cut was made through the ridge in 1887 by the Lake of the Woods Milling Company, for the development of power for use in flour milling. Mill "A" was constructed in connection with this intake, about twenty years before mill "C" was placed in operation.

The power installation consists of two pairs of 60-inch horizontal turbines on one shaft, at 2,400 horse-power, (manufacturers' rating), and supplied by the J. M. Voith Company, and one 22-inch vertical turbine rated at 95 horse-power supplied by the Dayton Globe Iron Works. The above wheels are direct connected to the mill machinery by square rope drive. There are in addition two 33-inch duplex horizontal turbines, each rated at 360 horse-power, and supplied by William Kennedy & Son, direct connected to 240-k.w., 600-volt, three-phase generators, running at 200 revolutions per minute, supplied by the Canadian General Electric Company. A further 33-inch single horizontal turbine rated at 180 horse-power, and supplied by William Kennedy & Son, is direct connected to a fire pump, and completes the installation. All ratings are given for a 20-foot head. The 22-inch wheel is used to drive the machine shop in case the flour mill is closed down, while the generator is used to supply power for elevators, hoists, lighting, etc., in both mills. Two hydraulic Brevette governors regulate the 33-inch wheels while the 60-inch wheels are regulated by hand.

The average power developed is 1,200 horse-power, all of which is used by the company. No difficulty from ice or low-water troubles has been experienced except during low water of 1911.

#### THE NORMAN DAM.

While no power has as yet been developed in conjunction with the Norman dam on the western outlet, its relation to the storage question in the Lake of the Woods is of primary importance.

Prior to the construction of the Norman dam, a timber dam had been built by the Dominion Government for regulation purposes, at the entrance to the western channel. This dam was removed by blasting by the Ontario Department of Public Works, in the year 1899. In the year 1891, the Keewatin Lumber and Manufacturing Company entered into an agreement with the Crown covering the construction of a regulating dam combined with a power-development project on the western outlet, and the following year a preliminary survey was made of the site and a report of the proposed development secured from William Kennedy, of Montreal. In 1893 the Keewatin Power Company took over the rights and obligations of the former company, and construction of the dam was commenced according to plans and designs by William Kennedy. Mr. James C. Kennedy acted as resident engineer during construction.

The general design of the dam (plate 38) called for a central portion composed of a rock-fill, made impervious by depositing graded stone, gravel, and finer materials along the upstream side, abutted on either end by stoplog controlled regulating sluices with piers and sills of granite masonry, and joined to either bank by power sluices, also stoplog controlled. In all, there are eight 21-foot power sluices, four adjacent to either bank with sills at elevation 1,040.6, and twelve 15.5-foot regulating sluices with sills at 1,038.7 (Water Power Survey datum). In plan the regulating sluices and rock-fill section are arched with




Norman Dam, under Construction.

the convex side upstream. A fishway has been constructed at the south end of the rock-fill.

Ideal foundation conditions existed in the form of solid granite, practically on the surface and readily unwatered.

The construction of the dam was commenced in November, 1893, a cofferdam being first built from centre island to the south shore. Masonry construction on the south flume and regulating sluices commenced the following March. During May, the north flume site was coffered, and construction on the northern sluices commenced. By October both power and regulating sluices had been completed. In December the cofferdams were removed and work was commenced on the rock-fill. This was completed in March, 1895. The timber

platform on the piers, and the installation of the track and winches for operating the stoplogs, was delayed until 1898, although a few logs had been placed in all the sluices in 1895. In November, 1898, additional stoplogs were placed in the dam, and control of the regulation and gauge readings was taken over by the Ontario Department of Public Works. Due to the fact that no power development has as yet been undertaken in conjunction with the dam, no definite steps have been taken towards making the rock-fill section impervious, and considerable leakage takes place at all seasons.



Norman Dam.

The Norman dam is the controlling structure in connection with the regulation of the Lake of the Woods, discussed in detail in chapter IV.

#### FORT FRANCIS DAM AND POWER PLANTS.

What were formerly known as the Koochiching falls are located on the Rainy river, about  $2\frac{1}{2}$  miles below Rainy lake. There was here a normal natural drop of about 22 feet, and the site offered an excellent opportunity for successful hydro-electric development. Its attributes in this respect were early recognized by the settlers residing in the vicinity on both sides of the river, but no steps were taken towards active construction until early in 1904. In this year an agreement was entered into between the Ontario and Minnesota



Ontario and Minnesota Power Company's Pulp, Paper and Power Plants at Fort Frances.



Ontario and Minnesota Power Company's Pulp, Paper and Power Plants at Fort Frances from below.

Power Company, represented by W. E. Backus, of Minneapolis, and the Department of Crown Lands of the province of Ontario, looking to the full development of the site. Since the Rainy river is an international waterway, and thereby comes equally under the jurisdiction of Canada and the United States, its resources belonging equally to both countries, specific clauses were inserted stipulating that one-half of the total power capable of development should be at all times retained and reserved for use on the Canadian side.

The particular matter of interest to the subject herein discussed is the relation which the operation of the power plants and the control of the dam bears to the regulation of the basin. The plant was ready for operation in 1910.

The general plan of development called for the construction of two power stations identical in size and capacity, one on either side of the river, connected by a dam of granite masonry which in plan resembled a letter V with the apex pointing upstream (plate 39). Each power-house allowed for the installation of nine units. The apex and left wing of the dam consisted of a concrete-capped free spillway section some 450 feet in length, crest at elevation 497, Department of Public Works datum,<sup>1</sup> and decked to allow ready access from one side of the river to the other.

In the right wing, and adjacent to the Canadian power station, were placed ten 10-foot gate-controlled arched sluiceways, with sills at elevation 477.50, and crown of arch at elevation 490.0. Through these sluiceways the river discharge is controlled, the spillway acting as a safety factor to combat extreme run-offs. Between the Canadian power station and the main river bank is an old excavated canal channel. This is not used for navigation purposes, its upper entrance being closed by head-gates. The American power station is connected to the river bank by a temporary crib dam, it being the intention to here add three additional units to the six now constructed.

The installation of the Canadian power-house at present consists of four 4-runner turbines of 1,700 wheel horse-power, supplied by the Holyoke Machine Company, connected to four 3-phase, 60-cycle, 6,600-volt, 1,250-k.v.a. generators. The greater proportion of the electrical power is transmitted to the United States side of the river. Adjacent to the generator room, and in the same power building, is the pulp-grinding machinery. This consists of five sets of grinders, three to a set, direct connected to horizontal turbines. A head of some 33 feet is developed, the tailwater averaging about elevation 463.

In the American power-house there are at present installed six 4-runner turbines of 2,200 wheel horse-power, supplied by the Morgan-Smith Company, each set connected to four wood-pulp grinders. Space is provided for three additional units. The power output of the entire development is utilized in pulp and paper manufacture, mills being in operation on both sides of the river. The Canadian mill is of recent construction and has about one-half the capacity of the American mill. A small block of power is used for lighting the towns of Fort Frances and International Falls.

The scheme of development as first laid down called for 18,000 horse-power installed turbine capacity in each power-house, or 36,000 horse-power

<sup>1</sup> 610.30 Water Power Survey datum. Zero, Department of Public Works datum.

in all. This would call for a much greater flow in the river than subsequent gaugings have found. The mean run-off past Fort Frances for the past eight years has been in the neighbourhood of 7,700 second-feet.

No difficulty has been experienced from ice troubles in the operation of the plant, but shortage of water at different seasons has, in an unmistakable manner, indicated the necessity for regulation in the upper waters. To this end, the company has investigated the storage possibilities of, and has taken active steps to secure storage rights on, several of the upper lakes.

#### CHAUDIÈRE FALLS DAM.

At Chaudière falls (Kettle falls), the Namakan lake level discharges into Rainy lake, with a normal drop of 8 feet under natural conditions. The



Chaudière (Kettle) Falls, Canadian Channel.

drop takes place in two channels, through the northern of which passes the international boundary, thus placing the dividing island and the south channel in Canadian territory. In February, 1912, plans were submitted to the Dominion Department of Public Works by the Rainy River Improvement Company (an allied interest of the Ontario and Minnesota Power Company) looking to the construction of storage dams across the two channels at Chaudière falls. It was hoped by this construction to secure 12 feet of storage on lake Namakan which, with its connected lakes, is 100 square miles in area. The first proposal called for dams of timber crib construction. Upon the recommendation of the engineers of the Department of Public Works the design was changed to a concrete and masonry structure, and additional discharging capacity was provided. Work on the construction of the dams proceeded throughout the year of 1914, and they are now completed (plate 40).

The International dam across the northern channel consists of four 14-foot stoplog controlled sluices with sills at elevation 490·15 (Department of Public Works datum), one of which is fitted with a timber log slide, with sill at 495·15. The piers rising to elevation 510·15 are of masonry construction with concrete sills. A fishway has been provided adjacent to the United States shore.

The Canadian dam across the southern channel consists of four 14-foot stoplog controlled sluices and a 6-foot fishway abutted on either side by an embanked masonry-face wall with top elevation at 510·15, connecting with the higher ground. The sill elevation of the most southerly sluice is 498·15, of the adjacent sluice, 496·15, and of the remaining two, 495·15. The northerly sluice is fitted with a timber log slide with sill at 500·15. The fishway is adjacent to the island. The general construction is similar to that of the international dam.



Chaudière (Kettie) Falls, International Channel.

It will be noted from the above that it is possible to lower lake Namakan by means of the international dam to a point much below its previous low level.


In conjunction with the above two dams it was necessary to close two gaps which would otherwise provide escape channels when the lake level approached its upper limits. These gaps were closed by the Bear creek and the Gold Portage dams, respectively.

The Bear Creek dam is a small timber-crib stone-filled structure spanning a 60-foot gap, with crest at 510·15, and some 6 feet high at the highest point.

The Gold Portage dam is a longer structure, but of about the same maximum height. It consists of about 200 feet of crib dam and 225 feet of earth-fill. All structures are built to stand regulated high-water level of 508·5.

The storage questions involved are dealt with in chapter IV.

Various timber dams in a greater or less degree of repair are scattered throughout the basin. These dams have been constructed at the outlets of several of the lesser lakes by the lumbering interests, their purpose being to store water for a rapid flushing down of the timber during the log-driving season. Among the lakes so controlled are White Otter, Whitefish, Turtle, Martin, Beaverhouse, and Long.



# MICROCOPY RESOLUTION TEST CHART

(ANSI and ISO TEST CHART No. 2)



1.50



1.8



2.2




2.8



APPLIED IMAGE Inc

1653 East Main Street  
Rochester, New York 14609 USA  
(716) 482 - 0300 - Phone  
(716) 288 - 5989 - Fax











KEY PLAN



EL 104  
LOG SLIDE  
EL 92  
EL 85  
EL 70




NORTH EAST ELEVATION




CROSS SECTION

NOTE  
PLAN  
BY TH  
961:30  
DATUM  
HOUSE



UP STREAM ELEVATION



LONGITUDINAL SECTION

Department of the Interior Canada

Water Power Branch

Water Power Branch

NOTE

PLAN BASED ON PLANS SUPPLIED BY THE TOWN OF KENORA

961-32 WATER POWER SURVEYS DATUM - ZERO OF KENORA POWER HOUSE DATUM

WINNIPEG RIVER POWER SURVEY

KENORA POWER STATION




CONSTRUCTED BY THE TOWN OF KENORA ON THE EASTERN OUTLET OF THE LAKE OF THE WOODS.

ENGINEERS & ARCHITECTS - POWER AND STORAGE INVESTIGATORS


100 - 1000 - 1000












**NOTE**  
 PLAN BASED ON FIELD SURVEYS  
 AND INVESTIGATIONS



Elevation  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_





Department of the Interior, Canada  
 HONOURABLE J. G. BROWN, M.P.  
 MINISTER OF THE INTERIOR  
 Water Power Branch  
 Ottawa, Ontario

**WINNIPEG RIVER POWER SURVEY.**  
**NORMAN DAM**

CONSTRUCTED BY THE REE-MATIN POWER COMPANY  
 ENGINEERS  
 GENERAL CONSTRUCTION FEATURES & DISCHARGING FACILITIES

DESIGNED BY REE-MATIN POWER COMPANY  
 DRAWN BY J. G. BROWN & S. J. BROWN









**KEY PLAN**

Scale of Miles




**GENERAL LAYOUT**

Scale of Feet



**REACH FROM RAINY LAKE TO DAM**

Scale of Feet






**PLAN OF DAM**

Scale of Feet



Note: This plan was compiled from Departmental Maps  
 Plans, Sections, Surveys and Plans furnished by  
 the Canadian and Minnesota Power Company.



Department of the Interior Canada  
 WATERWAYS DIVISION  
 WATER POWER BRANCH  
 J. W. CHAPMAN, CHIEF ENGINEER

**WINNIPEG RIVER POWER SURVEY.**  
**FORT FRANCOIS DAM**

CONSTRUCTED BY THE ONTARIO & MINNESOTA POWER COMPANY  
 Division  
 GENERAL CONSTRUCTION FEATURES & DISCHARGING FACILITIES


For description of dam see POND AND STORAGE INVESTIGATION  
 by J. T. JARVIS, P.E.








ELEV





PLAN OF CANADIAN



ELEVATION




PLAN OF AMERICAN-CANADIAN DAM B




SEC



S





ELEVATION



SECTION Q.R.

Scale of feet  
 0 5 10 15 20 25




SECTION S.T.

Scale of feet  
 0 5 10 15 20 25

NOTE

The information on this Plan was compiled from Departmental Maps and from Plans furnished by the Ontario and Minnesota Power Company.



SECTION W.X.

Scale of feet  
 0 5 10 15 20 25



SECTION U.V.

Scale of feet  
 0 5 10 15 20 25

Department of the Interior, Canada

RESPONSIBLE IN CHARGE, Engineer  
 IN CHARGE, Deputy Minister  
 Water Power Branch  
 J. B. CHAPMAN, Superintendent

WINNIPEG RIVER POWER SURVEY.


KETTLE FALLS DAMS

CONSTRUCTED BY THE ONTARIO & MINNESOTA POWER COMPANY

GENERAL CONSTRUCTION FEATURES & DISCHARGING FACILITIES

FOR COMPANY REPORT ON POWER & STORAGE INVESTIGATIONS

BY J. B. CHAPMAN, P. E.



SECTION Y.Z.

Scale of feet  
 0 5 10 15 20 25



REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

CHAPTER VI.  
POSSIBLE POWER CONCENTRATIONS.



## CHAPTER VI.

### POSSIBLE POWER CONCENTRATIONS.

#### REACH OF THE RIVER DEVELOPED.

The reach of river covered in the power studies extends from lake Winnipeg to the headwaters of the city of Winnipeg municipal plant at Point du Bois, and comprises practically the entire drop of the river in Manitoba. The channel of the Winnipeg river follows the general trend of rivers flowing through this district where the Laurentian granite lies practically on the surface. The river is, to a large extent, composed of deep broad basins with but little current, broken by abrupt changes in level at the various falls and rapids. These pitches take place at, and are occasioned by, granite outcrops, which are invariably in evidence on both river banks and in the stream bed. At such points the bedrock as a rule forms a distinct ridge at a higher elevation than the bed of the river in the pond above, and is in fact the controlling feature governing the level of the lake-like expanses. As a result, the drops are generally well concentrated, and the hydraulic gradient between the various falls and rapids is usually negligible, a combination of circumstances which renders possible the utilization for power purposes of practically the entire fall of the river. The reach below the lower Seven Sisters, together with the Pinawa channel, are the only sections of the river where it has been necessary to sacrifice any considerable portion of the drop.

*Table 33.—Profile of the Winnipeg River under natural conditions, and under proposed system of hydro-electric development.*

NATURAL CONDITIONS.				PROPOSED CONDITIONS.			
Falls.	Tail Water Elev.	Head Water Elev.	Head in feet.	Power Site.	Tail Water Elev.	Head Water Elev.	Head in feet.
1.	2.	3.	4.	5.	6.	7.	8.
Pine.....	713	722	9	Pine.....	713	750	37
Masqua.....	722	727	5				
Silver.....	728	749	21	Du Bonnet.....	752	808	56
Whitemud.....	750	762	12				
Little du Bonnet.....	762	770	8	McArthur.....	809	727	18
Grand du Bonnet.....	770	305	35	Lower Seven Sisters.....	833	870	37
1st McArthur.....	806	812	6				
Lower Seven Sisters.....	812	818	6	Upper Seven Sisters.....	870	899	29
4th Seven Sisters.....	834	850	16				
3rd Seven Sisters.....	851	859	8	Slave Falls.....	902	928	26
2nd Seven Sisters.....	859	867	8	Winnipeg Power Plant.....	931	976	45
1st Seven Sisters.....	867	876	9				
Diversion Weir.....	876	886	10				
Slave.....	888	899	11				
Eight Ft.....	902	921	19				
Point du Bois.....	921	928	7				
Lamprey.....	931	962	31				
	962	978	16				

NOTE.—The plant of the Winnipeg Electric Railway Company on the Pinawa channel is not included in the above table since it is not a link in the main river channel.  
Its head- and tailwater elevations are 880 and 841, respectively.

Table 33 illustrates concisely the natural conditions on the river prior to power-plant construction, and the altered conditions which will result from the development of the available sites. It is proposed to concentrate the at present undeveloped portion of the power reach at seven sites, i.e., Slave falls, Upper Pinawa, Upper Seven Sisters, Lower Seven Sisters, McArthur, Du Bonnet, and Pine falls. Plate 41 graphically illustrates the co-relation of the governing elevations of the various proposed plants.

#### DISCHARGE OF THE RIVER.


A reference to chapter III, covering the run-off, will demonstrate the exceptionally well-regulated character of the Winnipeg River flow under present conditions. Actual meterings since January, 1907, have shown a minimum record of 11,700 cubic feet per second, and a maximum of 53,440, with an average of 25,373 for the past eight years. In a normal year the flood flow seldom exceeds four times the minimum. This favourable condition is of special importance to hydro-electric development in the lower reaches. In view of the excellent storage facilities in the upper watershed it is readily possible to so control the flow as to maintain a minimum of 20,000 cubic feet per second the year round. While regulation to a somewhat higher minimum is feasible, 20,000 second-feet is considered throughout the power discussions in this report, since it can, with supervised control, be secured in the immediate future, with the storage facilities already provided in the upper basin. Another characteristic of the discharge which is favourable to hydro-electric development is the comparatively slow rise of floods, due to the balancing effect of the upper lakes.

#### FLOODING AND PONDAGE.

Since the selection of the sites has been largely governed by the contours of the banks, little flooding is involved along the river. At certain points where special aspects called for consideration and where existing interests introduced special conditions, it has been necessary to provide embankments in order to take full advantage of the fall available. The smallness of the proposed flooded area is largely due to the fact that the banks, as a rule, rise fairly abruptly from the water's edge. A large proportion of the river banks is still Dominion land, and reservation is being made of all such lands affected by the proposed power scheme.


The proposed plants are well provided with local pondage. The pond areas vary from 1,175 acres at the Lower Seven Sisters site to 38 square miles at the McArthur site. At certain sites where the pondage area is comparatively limited, conditions can be bettered by a supervised regulation of larger ponds farther up stream. This is particularly the case in Lac du Bonnet, which will form 38 square miles of pondage for the McArthur plant. This local storage is out of all proportion to the requirements of the McArthur development, and a sympathetic regulation will render the storage benefits immediately available to the Du Bonnet plant located immediately below. Similar conditions, though not so marked, occur at other points along the river.






LOWER SEVEN

END OF SHEET DRAWN BY ...  
 DRAWING NO. 1000-1000-1000  
 NOTE: Reference to Sheet M. 1000-1000-1000



DEPENDABLE 24 HOUR POWER CORRESPONDING TO RATES OF FLOW



UNDEVELOPED POWER SITES

SITE	HEAD FEET	POWER AVAILABLE	
		DEVELOPABLE POWER AT 75% EFF. (KW)	ASSUMED TURBINE UNIT AND BELT EFF. (KW)
Slave Falls	64	37,800	39,375
Point du Bois	64	37,800	39,375
Upper Seven Sisters	32	18,900	19,687
Lower Seven Sisters	32	18,900	19,687
Slave Falls	74	36,600	37,800
Lower Seven Sisters	38	17,500	18,175
<b>TOTAL</b>		<b>178,000</b>	<b>183,500</b>

NOTE: 8000 cfs. flow is assumed to be diverted through the River Channel and the Upper and Lower Seven Sisters Plants are affected thereby.

TOTAL POWER AVAILABLE

	UNDEVELOPED FLOW (CUBIC FEET PER SECOND)	REGULATED FLOW (CUBIC FEET PER SECOND)
UNDEVELOPED AT PROPOSED SITES	178,000	318,800
UNDEVELOPED AT POINT DU BOIS	27,100	51,800
DEVELOPED UP RIVER TO DATE	53,200	53,200
<b>TOTAL</b>	<b>248,300</b>	<b>418,500</b>

Department of the Interior, Canada


Water Power Branch  
Ottawa, Saskatchewan

## WINNIPEG RIVER POWER SURVEY.

### DIAGRAM OF PROPOSED DEVELOPMENT IN MANITOBA

SHOWING RELATION BETWEEN GOVERNING ELEVATIONS OF EXISTING AND PROPOSED PLANTS ON THE MAIN WINNIPEG RIVER

TO ACCOMPANY REPORT ON POWER AND STORAGE INVESTIGATIONS BY J. J. JOHNSON, O.E.S.



LEGEND: DEVELOPED POWER (solid line), UNDEVELOPED POWER (dashed line)

MAXIMUM POWER CAPACITY OF WINNIPEG RIVER WITH REGULATED FLOW OF 18,000 CFS AT 75% EFF. IS 100,000 KW.

NOTE: Based on a Regulated Minimum flow of 20,000 cfs. with undeveloped sites considered at 75% eff. with 24 hr. power.

*J. J. Johnson*  
J. J. JOHNSON, O.E.S.

t  
c  
e  
f  
s  
P  
v  
t  
P  
T  
w  
r  
t  
ic  
d  
a

Table 34 hereunder illustrates concisely the flooding involved at the proposed developments, together with the pondage available at the same. The areas have been scaled off by planimeter from the topographic sheets, and represent the conditions with fair accuracy.

Table 34.—Pondage and flooding area of the proposed power concentrations.

Sites.	Pondage in acres.	Flooding in acres.
Pine	6,642	375
Du Bonnet	1,700	360
McArthur	24,420	2,444
Lower Seven Sisters	1,175	70
Upper Seven Sisters	8,470	404
Slave Falls	1,300	100

#### ICE CONDITIONS.

The question of ice conditions as found on the Winnipeg river has already been discussed at length in chapter III. It is only necessary to repeat here that the northerly latitude in which the Winnipeg river is located necessitates a most careful consideration of possible ice troubles in the design of the hydro-electric plants along the river.

While in past years trouble has been experienced in the operation of power stations under extreme low-temperature conditions, the better understanding of the origin and nature of frazil and anchor ice which has been reached during recent years has resulted in these troubles being largely minimized, and frequently entirely overcome in the more recently designed stations.

The municipal plant of the city of Winnipeg on the Winnipeg river is an excellent example of modern design in this respect. A broad deep pond, some 6,500 acres in area, forms the headwater of the plant and acts as a settling basin for the disturbed water above. The head-race leading from this pond is of sufficient cross-section to maintain a quiet and undisturbed flow to the station. Here particular care has been taken to secure the undisturbed entrance of the water into the wheel pit. The result is an entire freedom from ice troubles.

In the layouts which are herein considered, especial attention has been given to this question, and in no case are ice troubles anticipated. In all designs the power stations draw undisturbed water into the turbines from deep, quiet ponds. The falls and rapids which in a natural state favour the formation of frazil ice will, in the general scheme proposed, be flooded out, and the entire drop in the river will practically take place from one pond to another, over and through the dams at the points of concentration.

Ample provision has been made at each site for drawing off all floating ice and drift. Wherever possible, ice sluices have been so placed that their discharge will produce a cross current along the face of the power station and automatically draw off floating material. The racks and entrance to the water

passages of the turbines are protected by a sloping concrete curtain across the face of the entrance piers, the bottom elevation of which is placed from  $\frac{1}{2}$  to 3 feet below regulated pond level.

#### FOUNDATION CONDITIONS.

Unexcelled foundation conditions are assured at all the proposed plants. The natural granite formation which underlies the entire country is exposed on the surface at all locations selected for hydro-electric development. At several of the sites the rock outcrops throughout the entire layout. In other places it has been necessary to make assumptions as to the rock elevation in the stream-bed, since the nature of the field investigations did not warrant the expense of actual sounding at the crests of falls. This is deemed a proper expenditure for the interests doing actual development work. For the purpose of the present discussion, it is sufficient to ascertain the existence of the bedrock, and its probable elevation. Such assumptions as have been made are based on personal inspection of the site on the ground, and on a consideration of the actual conditions which exist at points along the river where definite data have been secured. The conclusions as to bedrock elevation, as set out in detail at each site, are considered to be conservative.

#### GENERAL BASIS OF DESIGN AND LAYOUT.

The submitted designs and layouts have been worked out in this office on the general basis set out in the following, and have on this basis been approved by Mr. J. B. McRae, consulting engineer to the Dominion Water Power Branch. The designs of the power-houses, dams, and contingent structures, and the proposed hydraulic and electrical equipment, have been developed only in sufficient detail to permit making fairly accurate estimates of the quantities and costs involved. It is not intended that the designs and layout proposed, and the equipment suggested, should be adhered to in all respects by any parties developing the power at these sites. It is intended, however, that the basic elements of the design be maintained as proposed, in the interests of the complete river development scheme. These basic elements are: head- and tailwater elevations, discharging capacity and stability of dams, and stability and sufficiency of power-houses and contingent structures.

The layouts are designed for an initial and for a final installation. At points where the whole flow of the river is available for development, the preliminary installation is designed to utilize 12,000 second-feet (the present minimum flow of the river), with provision for the subsequent addition of sufficient units to properly care for a regulated flow of 20,000 second-feet. The latter is spoken of throughout the report as the final installation.

One feature which should be emphasized in connection with these future additions is that it is inadvisable to carry the construction of unfinished units further than is absolutely necessary to withstand the headwaters. The rapid advances which are being made in the development and settings of hydraulic machinery are such that the interval of even a year or so between the completion

of the initial installation and the subsequent addition of the remaining units, may be sufficient to produce important alterations and improvements in design. It is essential that the unfinished portion of the power station should be left in such shape that the new units can, when installed, incorporate all later improvements in hydraulic installation. The neglect of this feature has proved costly to many plants now in operation throughout the country.

The details of the designs, such as sections and plans of the power-houses, dams, ice sluices, and embankments, etc., have been standardized throughout all the plants, varying of course according to the head and to the equipment at each site. In all cases, single-runner vertical turbines have been adopted. The purpose of this standardization of design is the desirability of having the cost of development at each site reduced to the same basis or measure in order that the comparative merits of the different projects can be ascertained.

It is recognized that nature has particularly favoured the Winnipeg river in supplying an extensive lake area in the upper waters, and that rapid rises and sudden floods such as are experienced in watersheds not so supplied do not take place. In the future, however, when the river is fully regulated, it is reasonable to anticipate a combination of circumstances which will result in more sudden rises and perhaps greater floods than have been so far experienced. Such a combination of circumstances might be a prolonged and widespread period of heavy rain, at a time when the reservoirs in the upper watershed are all filled to high level. The surplus waters would then be discharged at once. For this reason, and in view of the complete system of river development which is contemplated, a larger degree of discharging capacity has been provided at the various plants along the river than past floods in the river would apparently require.

#### HEAD- AND TAILWATER ELEVATION.

It is not intended in this report to unchangeably fix the exact head- and tailwater levels of all the proposed concentrations. These final elevations are dependent on full and complete surface level records under all conditions of discharge. Owing to the comparatively unsettled nature of a large portion of the river banks, it has been very difficult to secure satisfactory and regular gauge readers. As a result, on some reaches of the river the surface level records under different stages are not as complete as is desired. This information is being secured as rapidly as possible, and will be available in sufficient time to deal with any questions of administration which may arise in connection with the development of the reach along the lines set out herein.

The head- and tailwater levels as set out herein are considered to very closely represent the final levels, and any variation which later information may necessitate should not change the present conclusions to any great extent.

#### NAVIGATION.

The Winnipeg river is classed as a navigable stream, and hence any power development thereon must conform to the provisions of the Navigable Waters Protection Act. This phase of the situation was kept constantly in view through-

out the entire power study discussed herein, and reference to profiles on Plates 5 and 6, and to the layouts on Plates 43, 48, 53, 57, 61 and 68 will indicate the comprehensive provision which has been made to meet navigation needs, should the canalization of the river ever become an active issue. After the completion of the power developments, the construction of lockage facilities at the different layouts, together with some necessary dredging and channel improvements, will render the river readily navigable throughout the power reach.

The plans of the completed power scheme were referred to the Dominion Department of Public Works for approval in so far as the navigation features were concerned. This approval has been given for the complete scheme as now submitted, with the necessary reservation that actual construction plans for the development of any particular site must be resubmitted for detail consideration and approval, before active construction is commenced.

#### ESTIMATES OF COST.

The question of the advisability of publishing detail capital and operating cost estimates was at first debated, as it was felt that they might be open to criticism and that conditions changing with the passage of time would possibly very materially alter the published figures. It was thought, however, that the advisability of supplying prospective users of power with some conservative and authoritative measure whereby the economic as well as the engineering merits of the various sites could be readily compared, and with which competing sources of power could be analysed, more than outweighed other considerations. To neutralize possible future criticism of the published estimates, care has been taken to supply such plans and data covering each site as will enable independent estimates being made by any parties interested in its development.

In view of the fact that it is not possible at this stage to foretell which plants along the Winnipeg river will be utilized for the purpose of transmitting power to the industrial centres of Manitoba, and which ones will develop power for local use, the cost estimates place the power on the low tension switchboard in the power station. With the exception of Pine Falls site no allowance has been made for transformation and transmission. The purpose of the estimates has been primarily to arrive at the capital cost of the actual development of the independent sites, and by standardization, both as to design and as to unit prices, to compare the sites with each other from the view point of their economic feasibility. Since the basis of estimates is standardized throughout, a study of the results submitted herewith will be found of interest.

The general costs quoted are based on a 24-hour output, at 75 per cent over-all efficiency, as this forms a uniform and, considering the more than 90 per cent efficiencies claimed for modern turbine runners, conservative measure for comparison. The figures on this basis, scarcely do the developments justice, since in them no account is taken of peak loads and of the re-sale of power such as is always possible in plants projected for the supply of power for general industrial and lighting consumption. In all designs ample machine capacity has been allowed to care for all peak loads which can be reasonably expected, and to supply spare units for emergencies. This over-development has added

largely to the estimated cost of the plants and hence to the unit cost when the latter is based on 24-hour power. On the other hand, costs per horse-power, based on the installation, frequently convey erroneous ideas as to economic efficiencies, since local conditions or an auxiliary steam plant frequently permit the excessive over-development of a particular power site in proportion to the dependable power available from the river. However, in the designs and estimates considered herein, the machinery installed bears, in all cases, a definite ratio to the power in the river, and this ratio cannot be considered too high in plants handling normal industrial and lighting loads. The unit costs based on installation can therefore be profitably studied in conjunction with the unit costs on a 24-hour basis.

In all cases provision has been made for access to the site by rail, or in the case of the Pine Falls plant, by water. In each case 10 per cent has been allowed for contingencies, 5 per cent on this total for engineering and inspection, and  $5\frac{1}{2}$  per cent on the whole for one year for interest during construction.

The actual cost of the construction of the two existing plants on the river has been carefully studied and compared with the estimated costs of the various proposed developments. Independent estimates by private engineering firms have also been found to check closely with the capital costs herein submitted. The estimates may therefore be taken as setting out conservatively and closely the capital construction cost of the proposed sites.

As in the case of the capital costs, the annual operation costs have been estimated to a uniform standard, and hence form a measure whereby the commercial prospects of the different projects can be readily compared.

The operation costs include capital charges and are published in terms of cost per horse power year 24-hour power; cost per horse-power year machinery installed; cost per kilowatt hour at 100 per cent load factor, and cost per kilowatt hour at 50 per cent load factor. These costs represent the operating charges at the power station, and do not include transforming and transmission.

In order to secure a proper understanding of the cost of power in Winnipeg, the estimated cost of transmitting power from the Pine Falls site to Winnipeg has been included.

In view of the involved nature of the storage situation in the upper watershed, the proportionate cost of storage reservoir construction has not been included in the estimates of the various sites. The necessary steps to insure 20,000 second-feet minimum flow are dependent largely upon the course of power development.

#### AESTHETIC TREATMENT.

Considerable attention has recently been given to the aesthetic treatment of public buildings, and with such desirable results that it has been felt that the Dominion Government should encourage in every reasonable way the architectural embellishment of power-houses constructed under Dominion authority, and especially where the location is, or is likely to be, accessible to the general public. While it is not proposed to compel power companies to adopt a scheme of architectural treatment of power-house design which would entail an unnecessary or unreasonable extra expense, it is proposed to insist upon the

design of important structures being given such consideration from an aesthetic standpoint as will conform to modern conceptions of architectural treatment.

As the water-powers of the Winnipeg river are so close to the city of Winnipeg, and as this river offers many attractions to the traveller and the pleasure seeker, it is certain that the river will receive an increasing number of visitors. Looking to the future, it will not be long before power-houses will succeed one another from lake Winnipeg to the eastern boundary of the province of Manitoba, and with proper foresight and with advantage taken of the opportunities for architectural treatment of these power-house structures, and also of the landscape treatment of the surroundings, this river will in future generations form one of the most interesting features of the district, both from an engineering and from an aesthetic standpoint.

Consistent with this policy, arrangements have been made for the special architectural study of the various power-house structures which have been worked out in connection with the investigations described herein from an engineering standpoint. The students of the Architectural Department of Toronto University were invited to compete for a small prize in connection with a suitable design of a typical power-house. The results of this competition are indicated in the accompanying illustrations, and while it is not the purpose of the branch to insist upon any of the designs submitted being accepted by a company contemplating the construction of one of the power developments worked out along the Winnipeg river, still it is proposed to insist that the suggestions offered by these designs be given serious consideration, and that the architectural treatment of the power-house structures shall receive due attention.


#### LAKE WINNIPEG TO LAC DU BONNET REACH.

Upon the completion of the topographic field plans, Nos. 1 to 10, covering that section of the river from Lake Winnipeg to Lac du Bonnet, a careful study of the whole reach and of various aspects requiring consideration made it apparent that three concentrations were necessary to fully utilize the fall available. The governing elevation at the lower end of this reach was the surface level of Lake Winnipeg, and that at the upper end was the maximum high water limit of Lac du Bonnet.


Tentative layouts, covering the three concentrations were prepared, and the proposed sites at Pine, du Bonnet and McArthur falls, were again visited by the writer in September, 1913, and were examined in detail with a view to determining the general fitness of the contemplated layouts and designs to the selected locations. Following this, the final plans and estimates have been prepared, and are submitted herewith.

#### Pine Falls Site.

A study of the reach showed that in order to secure the full drop available in three heads, it was necessary to concentrate at the Pine falls the highest head feasible. Reference to Plates 43, 44 and 45 will illustrate the following discussion.



Competiti e Power Station Designs.



Competitive Power Station Designs.

## SPECIAL CONSIDERATIONS AT PINE FALLS.

The disposal of Whitemud falls required careful consideration. The more profitable course, had physical conditions permitted, would have been to flood out the drop at these falls and combine the head with the Pine Falls development. The contours of the river banks above Pine and below Silver falls, do not, however, allow the raising of the headwater level above that proposed hereunder, except at the cost of excessive flooding or embanking. Since the land along this section of the river has been taken up and is under cultivation, it is not desirable to incur any more flooding than is necessary. The headwaters of the proposed plant have been raised to what is considered the highest permissible limit in view of the interests which will be affected. The disposal of Whitemud falls is covered in the discussion on the Du Bonnet site.

## REACH OF RIVER DEVELOPED.

The reach of the river developed by the Pine Falls concentration extends from Pine falls to the foot of Whitemud falls, drowning out the Masqua rapids



Winnipeg River below Masqua Rapids.

and Silver falls, and raising the normal water level above the latter by some  $2\frac{1}{2}$  feet. The river banks throughout the reach rise fairly abruptly from the water, and the flooding will be confined to the natural river channel.

*Masqua rapids.*—The Masqua rapids are situated about  $1\frac{3}{4}$  mile above Pine falls, just above the mouth of the Masqua river. There is a normal drop here of slightly over 2 feet, broken by granite outcrops which are more or less submerged during the high-water season. About three-quarters of a mile below the Masqua rapids another slight drop of about  $1\frac{1}{2}$  foot takes place over a second

granite ridge. This ridge forms a fairly large island in the centre of the channel, and in several other places rises above the water surface.

*Silver falls.*—The Silver falls are located about  $5\frac{1}{2}$  miles above Pine Falls. There is here a drop of some 22 feet in three well-defined pitches, taking place in a total distance of about 1,500 feet. The banks are high and abrupt, and the Silver falls would of itself form an economic development. It can, however, be more profitably combined with the Pine Falls site.



Silver Falls.

#### HEAD- AND TAILWATER ELEVATION.

It is proposed to regulate the headwater to elevation 750 (Water Power Survey datum). This elevation is about  $2\frac{1}{2}$  feet above the normal water level at the head of Silver falls, and backs up to about the same extent on the White-mud falls. When the river is fully developed as proposed, the headwater level of the Pine Falls development will be carried to the foot of the Little du Bonnet falls, and will, allowing for the necessary hydraulic gradient, form the tailwater of the Du Bonnet plant. Contour 750 is wholly confined within the natural river banks, with the exception of about 2,300 feet on the left bank of the river just above the power station. Here embankment will be required. The general river banks will permit a rise of at least 5 feet above this level without any considerable flooding.

The tailwater of the Pine Falls concentration is practically Lake Winnipeg level and will be affected by the fluctuation of the lake. A maximum high-water elevation of 719 is in evidence on the rocks in the river channel below. This would probably indicate the extreme conditions which may be anticipated. The lake level varies from year to year; it also varies from day to day, depending

on the direction and force of the wind. A normal water level of 713 can be counted upon for the greater part of the time. This has been utilized as the tailwater level throughout the present discussion, and gives a head of 37 feet available at the Pine Falls site.

#### FLOODING.

Flooding is entirely confined by the immediate banks to the river channel. Between Pine and Silver falls the land bordering the river has been settled and is under cultivation. As the banks rise rather abruptly from the water's edge, little of this land will be flooded by the proposed development. Above Silver falls the banks are steep and rise to a higher elevation, while the land is unsettled, the whole being covered with a thick growth of poplar, spruce, and birch. In all about 375 acres of steeply sloping land will be submerged by the raising of the water level. An item covering this is inserted in the estimates.

The Pine Falls site offers fair pondage facilities, there being an area of 2,598 acres of water surface from the plant to the foot of the Whitemud falls. This will be increased by an additional 1,044 acres after the Whitemud head has been added to the Du Bonnet site, and will provide satisfactory facilities for handling peak loads. The value of this pondage to the plant can best be illustrated by stating that 1 foot draw will, in conjunction with 20,000 second feet regular flow, carry a four-hour peak load equivalent to the full extent of the proposed ultimate installation, i.e., 100,000 horse-power. In this connection it is advisable to emphasize the necessity of some degree of Crown supervision over any dam or power development controlling the outlet of Lac du Bonnet, 19 miles above Pine falls, since an abrupt storage of water in this lake will most adversely affect the powers on the river below. On the other hand, properly supervised regulation will result in material aid to these powers.

#### ICE CONDITIONS.

The proposed Pine Falls plant will draw water from a deep quiet pond direct into the turbines, with a minimum disturbance. This pond, ice covered in winter, and varying from  $\frac{1}{8}$  to  $\frac{3}{4}$  of a mile in width and from 55 to 60 feet in depth for the first 6 miles, extends up the river to the foot of Whitemud falls, drowning out all intermediate falls and rapids, and hence doing away with the present tendency to form frazil ice at these points. Any such ice which may be formed at the Whitemud falls, either before or after the construction of the proposed channel, cannot affect the Pine Falls plant, 9 miles below. The discharge from the power station takes place directly downstream, and the unobstructed channel should prevent any choking of the current by the formation of ice jams or barriers.

The layout proposed will tend to naturally discharge all floating ice and drift through the four ice sluices provided on the left bank, and the sloping concrete curtain with bottom elevation 2 feet below regulated pond level, will amply protect the racks from all such floating material.

It is considered that the operation of the Pine Falls plant will prove to be entirely free from ice troubles.

## FOUNDATION CONDITIONS.

Granite formation is in evidence on both river banks and in the bed of the channel throughout the entire length covered by the layout. On the right bank, rock has been assumed at elevation 740 beneath the section of the spillway extending over the high ground. The outcrop along the shore warrants this assumption. In the river-bed the rock has been considered at elevation 695 to 715, and is on the surface or in evidence at different points along the route of the dam. The assumptions which have been made are the result of a careful inspection on the ground, and on unwatering should be found to represent closely



Pine Falls, Site of Proposed Power Station.

actual conditions. The granite is in direct evidence through the entire length of the power-house site. Plate 45 depicts the rock elevations which have been utilized in the estimates.

## LAYOUT.

Various layouts were considered at this site, and the one finally decided upon as being the most economical as well as making the most advantageous use of the natural features of the location is shown on plate 43. The general layout of ice sluices, power-house, and dam forms a straight line running diagonally across the river, the power-house being located on an island close to the left bank and below the lowest pitch of the Pine falls. The sluiceway and spillway section of the dam extend in a direct line towards the high ground on the right bank. On the left bank a short embankment is provided to protect the land to the rear, should it be necessary to raise the pond above the regulated level.

This is not anticipated since ample discharging capacity is provided below the crest of the spillway. All structures have been designed in massive concrete.

*Spillway section of dam.*—In order that there may be sufficient spillway capacity to automatically care for such sudden floods as may occur at times when for any reason the sluices may be neglected, advantage has been taken of the gully on the right bank. The spillway, with crest at 750, has been prolonged over the high ground to a total length of 775 feet. The gully formed by the creek below the spillway provides a channel whereby all discharge which may occur over the same can be carried to the river below. Above the spillway the overlying material has been excavated down to 745, or 5 feet below water level. Below the spillway the larger part of the excavation necessary to provide an unobstructed discharge can be left to the action of the water. Over the high



Model of Proposed Pine Falls Layout.

ground the rock has been assumed at elevation 740, or from 10 to 15 feet below the natural surface. This assumption is fully warranted by the formation of the natural granite which outcrops on the surface about 100 feet upstream from and parallel to the spillway, and outcrops also in the gully below.

*Fish ladder and Log slide.*—A fish ladder and log slide are located at the junction between the spillways and the sluiceways, and are accessible by means of the platform over the latter. Suitable provision can readily be made for booming logs to this point on the dam.

*Sluiceway section of dam.*—The sluiceway section of the dam, consisting of twenty 20-foot sluices with sills at elevation 735 (plate 45), is located adjacent to the power station. A motor-driven winch for handling stoplogs is included in the estimates. The sluiceway deck has its bottom elevation at 755.5, allowing 5½ feet clear above the regulated pond level.

Rock has been assumed at elevation 715 to 695, the lowest section being adjacent to the power station. At this point the set of the current indicates considerable depth, and the assumptions made have taken note of the same.

*Power station*—The power station (plan) has been designed for single-runner vertical turbines of 10,000 horse-power capacity at full gate. The design has been developed only in sufficient detail to determine the size of the water passages necessary to carry the water to and from the turbines at permissible velocities. The electrical and regulating equipment have been assumed for estimating purposes only.

The racks and headworks have been housed, and a sloping concrete curtain around the face of the entrance piers forms a protection against floating ice and drift. The floor of the headworks house at elevation 757 is connected with the left bank by means of four decked ice sluices and a corewall embankment. The generator floor at elevation 741 is connected with the river bank by means of a steel bridge spanning the channel below the ice sluices. The first pier of these sluices has been extended down stream, and the generator floor has been produced out over the same, creating additional floor space in the power-house for the disposition of machinery, etc. The draught tube seal is at elevation 708, the discharge taking place directly down the river.

The estimates for the power station have been calculated for two stages of development:—

(1) *Initial development*.—This consists of the six outer units. The turbines considered have a capacity of 10,000 horse-power at full gate, and the electrical installation has been selected with the normal full load corresponding to  $\frac{1}{10}$  gate opening on the turbines. The initial installation of six units supplies sufficient machine capacity to utilize 12,000 second-feet at 37-foot head with turbines at 85 per cent efficiency and  $\frac{1}{10}$  gate, and leaves one unit as a spare for emergencies. The output available on the low tension switchboard on a 75 per cent over-all efficiency and a 24-hour basis is 37,000 horse-power. The estimates for the initial development include the construction of the headworks of the remaining four units to a sufficient degree to support the stoplogs, leaving the balance of the bays to be completed when required.

(2) *Final development*.—This will consist of ten 10,000 horse-power units, the four additional being added to the landward end of the first installation. The ten units will supply machine capacity for the utilization of 20,000 second-feet at 37-foot head, with turbines considered at  $\frac{1}{10}$  gate. This installation will under these conditions provide a spare unit for emergencies. The output at the switchboard at 75 per cent efficiency and on a 24-hour basis is 63,100 horse power.

*Ice sluices and roadway*.—Connecting the power station with the left bank are four ice sluices, followed by a corewall embankment. The location of these sluices is such that their operation will produce a current along the face of the power station, tending to automatically clear the forebay of floating material. The main floor of the generator room is connected with the high ground by means of a steel bridge spanning the discharge channel below the sluices.

*Embankment*.—The contours of the left bank necessitate the construction of a low embankment upstream for a distance of about 2,300 feet, to connect with contour 755. While this embankment may not be necessary with the pond at regulated level, it is required to protect the land to the rear at times when the pond is above normal level. In the layout submitted it has been made to serve the purpose of a sailing bank, leading to the upper entrance of the lock.

A more accurate and detailed survey on the ground may show that this embankment is not required. Provision has been allowed for it in the estimates. Drainage of the land to the rear is a simple matter.



Pine Falls, Main Drop.



Pine Falls, Main Drop.

DISCHARGE CAPACITY.


At regulated pond level the sluiceways of the dam will discharge 92,000 second-feet. In addition to this the discharge through the power station amounts to 12,000 second-feet in the initial and 20,000 second-feet in the final installation.

**DOMINION WATER POWER BRANCH**  
 J. B. CHALLIES, Superintendent


**POWER-PERCENTAGE OF TIME CURVES**  
 at the  
**PINE FALLS POWER SITE**  
 on the  
**WINNING RIVER.**

HEAD 37 FEET POWER AT 75% EFFICIENCY  
 PERIOD 1907-1914 INCLUSIVE.

To accompany a report on POWER AND STORAGE  
 INVESTIGATIONS by J. T. JOHNSTON, B.A.Sc.  
 March 5th 1915



11  
12  
13  
14  
15  
16  
17  
18



Department of the Interior, Canada  
 HONOURABLE W. J. ROCHE, MINISTER  
 W. W. CORY, C.M.G. DEPUTY MINISTER  
 Water Power Branch  
 J. B. CHALLICE, SUPERINTENDENT

**WINNIPEG RIVER POWER SURVEY  
 PROPOSED SCHEME OF DEVELOPMENT  
 AT  
 PINE FALLS**

By *J. Y. Johnston*  
 Hydraulic Engineer  
 Water Power Branch

Approved by *J. B. Challice*  
 Consulting Engineer  
 Water Power Branch

Scale in feet  
 0 50 100 150 200 250 300 350 400 450 500

Based on Field Surveys made under direction of  
 D.L. Maxwell, Chief Eng. Mar. Hyd. & Power Surveys  
 Feb 7 1914



Twp. 18, Rge. 10, E. 1M


PLATE No. 43

Lot 45

Lot 44



H. P.




REAR ELEVATION


WINNIE, HATH TUMPER BERRY  
 PROPOSED SCHEME OF DEVELOPMENT

AT  
 PINE FALLS

CHARLES F. W. TOWNSEND, ARCHT. & ENGR.  
 100 N. 10th St., St. Paul, Minn.  
 1917





SECTION B-B



PLAN ON LINE A-A







While this latter is not considered to be a source of discharge available at all times, it nevertheless forms an additional factor of safety.

Although the above provides ample sluiceway discharge, it would not be wise to depend wholly on mechanical or manual operation to care for the fluctuations of the river flow. A 775-foot spillway, with crest at 750, gives the necessary automatic check on the pond level. Three feet over the crest will discharge 13,000 second-feet. The total discharging capacity at this latter elevation, with all sluices open and the power station in full operation, is 135,000 second-feet. The river is not subject to sudden floods.

#### UNWATERING.

Alternative schemes of unwatering may be adopted in the construction of this plant, the selection of the method depending largely upon the problems of construction which will arise when actual operations are started. Sufficient cofferdam yardage, together with ample provision for pumping, has been allowed in the estimates to cover this work. No special difficulties are anticipated in this connection.

#### NAVIGATION.

At the Pine Falls site no difficulty will be experienced in installing future lockage facilities on the left bank below the power-house, should the same ever become necessary. A sailing bank, built up from the material excavated from the approach to the lock, will protect the upper entrance from the effects of any draw towards the power station. The lock depicted is 300 feet by 40 feet, with 15 feet of water on the sills; a larger lock could as conveniently be constructed.

The lock, with approaches, can be constructed at any time in the future without in any way interfering with the operation of the power plant, nor will the provision for it incur any extra expenditure in the present construction of the plant. On the other hand, the present construction of the power installation will not place any obstacles in the way of the future construction or operation of the lock. No portion of the cost of the lock or approaches is included in the estimates for the power development.

#### ESTIMATES OF COST.

The following estimates of the cost of the initial and final installations place the power on the low tension switchboard in the power station. The estimates are considered to be amply conservative and all assumptions which have been necessary are fully warranted by the conditions on the ground. It is understood that a railway has been projected and partially located from Winnipeg to the vicinity of Pine falls. Should this railway be built before construction operations on the power plant are started, it will, of course, be utilized in connection with the same. Should, on the other hand, the railway not be built, a direct connection with Winnipeg is to be had by water transportation. It is understood that 10-foot navigation is available up the river to the tail-water of the plant. An item has been placed in the estimates for the construction of a dock, with the necessary apparatus for landing heavy material and for transporting the same to the site of construction operations.

Ten per cent has been allowed in the estimates for contingencies, 5 per cent of this total for engineering and inspection, and 5½ per cent of the whole for one year, for interest during construction.

The annual operation costs include capital charges, and represent the operating charges at the power station. They do not include transforming and transmission.

The cost of delivering power to Winnipeg from this site is covered towards the end of this chapter.

(1) Initial Development.—(six 10,000-horsepower units.)

(1) Capital Cost of Installation.

Dam and equipment.....	\$481,000
Ice sluices.....	61,000
Power station and equipment.....	695,000
Hydraulic installation.....	540,000
Electrical installation.....	720,000
Dockage facilities.....	50,000
Permanent quarters.....	20,000
Contingencies, 10 per cent.....	247,000
Engineering and inspection, 5 per cent.....	146,000
Interest during construction, 5½ per cent.....	157,000
Flooding damages.....	50,000
<b>Total initial cost.....</b>	<b>\$3,057,000</b>

Twenty-four hour power available at 75 per cent over-all efficiency, 37,900 horsepower.

Capital cost per 24-hour horsepower.....	\$80.66
Capital cost per installed horsepower.....	\$50.95

(2) Annual Cost of Operation.

Interest, sinking fund, and depreciation charges—	
Interest, 5½ per cent on \$3,057,000.....	\$ 168,000
Sinking fund, 4 per cent (40-year bonds).....	32,000
Depreciation—	
1 per cent on permanent works.....	\$ 10,000
4 per cent on machinery, etc.....	56,000
	66,000
Operation charges—	
Staff.....	\$ 21,000
Supplies.....	16,000
	37,000
<b>Total annual charge.....</b>	<b>\$ 303,000</b>

Annual cost per horsepower year, 24-hour power.....	\$8.00
Annual cost per horsepower year, machinery installed.....	\$5.05

Annual cost per Kilowatt hour.....	0.122 cent.
Annual cost per Kilowatt hour on basis of 50 per cent load factor.....	0.244 cent.

(2) Final Development.—(Ten 10,000-horsepower units.)

(1) Capital Cost of Installation.

Dam and equipment.....	\$ 381,000
Ice sluices.....	61,000
Power station and equipment.....	958,000
Hydraulic installation.....	900,000
Electrical installation.....	1,200,000
Dockage facilities.....	50,000
Permanent quarters.....	25,000
Contingencies, 10 per cent.....	358,000
Engineering and inspection, 5 per cent.....	197,000
Interest during construction, 5½ per cent.....	227,000
Flooding damages.....	50,000
<b>Total final cost.....</b>	<b>\$4,407,000</b>

Twenty-four hour power available at 75 per cent over-all efficiency, 63,100 horsepower.

Capital cost per 24-hour horsepower.....	\$ 69.84
Capital cost per installed horsepower.....	44.07

(2) Final Development.—(Ten 10,000-horsepower units) — *Con.*

(2) Annual Cost of Operation.

Interest, sinking fund, and depreciation charges—	
Interest, 5½ per cent on \$1,107,000	\$ 212,000
Sinking fund 4 per cent (40-year bonds)	16,000
Depreciation—	
1 per cent on permanent works	\$ 12,000
4 per cent on machinery, etc.	90,000
	102,000
Operation charges—	
Staff	\$ 29,000
Supplies	28,000
	57,000
Total annual charge	\$ 417,000
Annual cost per horsepower year, 24-hour power	\$ 7.08
Annual cost per horsepower year, machinery installed	4.47
Annual cost per Kilowatt hour	0.108 cent.
Annual cost per Kilowatt hour on basis of 50 per cent load factor	0.216 cent.

**Du Bonnet Falls Site.**

Pressing power applications before the department called for a field survey of the Du Bonnet falls as the first step in the systematic study of the whole river. This work was carried on throughout the winter season of 1911-12. A comprehensive study of the best means of controlling and developing the Du Bonnet falls was not possible without including in the field work the entire reach from Lake Winnipeg level to Lac du Bonnet. It was necessary, in order to conserve the full power of the river, and to assure the most efficient development of the entire head available, that each concentration should be considered not only from the standpoint of its individual economic development, but also as forming a component part of a complete hydro-electric system. Hence the permissible head- and tailwater levels of the Du Bonnet site were largely dependent on the limiting water levels of possible concentrations of head both above and below. This consideration was particularly pressing in view of the nature of the power applications before the department covering this reach of the river.

SPECIAL CONSIDERATIONS AT DU BONNET FALLS.

At the commencement of the field investigations, an application was before the department looking to the concentration at Du Bonnet falls of the entire drop of the river below. The method proposed was to blast away the rock ridges at Whitemud falls, Silver falls, Masqua rapids, and Pine falls, and thereby lower the Du Bonnet tailwater. The proposal was not based on field surveys, but was deemed feasible by the applicants because of the deep lake-like expanses which occur between each fall, and because of the distinct rock ridge which is in evidence at each drop. The preliminary inspection trip by the department engineers was sufficient to determine the impracticability of this proposal. The best disposal of Whitemud falls was a matter requiring more detailed consideration before being finally determined.

A second application before the department involved the raising of the headwater of the Du Bonnet falls (normally 804) to 815.5. Such a development would leave at the McArthur falls an unused head of 11.5 feet which could not be economically developed.

<sup>1</sup>This site is being developed by the Winnipeg River Power Company, see appendix II.

One of the principal ends kept in view by the field engineers was to ascertain the possibility of completely flooding out the two McArthur falls and of concentrating their drop at the Du Bonnet falls, thus securing a head of some 75 feet. The results of the surveys, as can be seen by reference to topographic sheets 7, 8, 9, and 10, Volume II of this report, definitely determined that this was impracticable, the elevation and nature of the ground on both river banks being entirely unsuited to the project, and necessitating the construction of a very extensive system of heavy embankments.

The raising of the headwater level to elevation 815.5, as proposed in the second application referred to above, was for similar reasons considered impracticable. A full study of all the conditions and interests involved resulted in the layout and governing elevations submitted herein.



Little du Bonnet Falls.

#### REACH OF THE RIVER DEVELOPED.

The reach of the river developed by the Du Bonnet falls concentration includes Whitemud falls, Little Du Bonnet falls, the four drops of the Grand du Bonnet falls, and the raising of the normal headwaters of the latter about 3 feet. The power station has been placed immediately below the Little du Bonnet falls, with the dam spanning the river along the crest of the pitch. The Whitemud Falls drop is added to the developed head by blasting out a channel through the rock ridge. The total drop of the upper falls is secured by flooding back from the dam.

*Whitemud falls.*—Whitemud falls are located about 3 miles above Silver falls. There is here a normal drop of 14 feet, practically all of which takes place in a distance of 900 feet. The banks rise abruptly from 20 to 25 feet above the water surface. The natural granite outcrop is continuously in evidence on both river banks, and also throughout the river-bed.

*Little du Bonnet falls.*—The Little du Bonnet falls occur about 3 miles above Whitemud falls, there being here a normal drop of 8 feet. The drop is abrupt, practically the whole taking place in one pitch. Rapid and broken water extends about 300 feet above the main drop. The usual granite formation is in evidence, with the banks rising to 35 feet above the water in the immediate vicinity of the river, and to 50 and 60 feet a short distance inland.

*Grand du Bonnet falls.*—The lowest pitch of the Grand du Bonnet falls takes place three-quarters of a mile above the Little du Bonnet falls. There is here a total drop of 35 feet, occurring in four distinct pitches of 5 feet, 13 feet, 8 feet, and 7 feet, respectively, with broken and rapid water between. The whole drop takes place in a distance of 4,000 feet, measured along the centre line of the river channel, and forms the most compact group of falls on the lower river. A few islands of varying size break up the falls.

Towards the lower portion of the falls the banks are steep and vary from 35 to 40 feet in height in the immediate vicinity of the river. Above the upper pitch the banks are from 8 to 10 feet above the water surface. The usual rock formation is in evidence on all sides.

#### DISPOSAL OF WHITEMUD FALLS.

The disposal of Whitemud falls has been briefly referred to in the discussion on the Pine Falls site. It was there pointed out that the contours immediately above Pine falls prevented the incorporation of the Whitemud drop with the head developed at the Pine Falls site.

The river banks above Silver falls would permit raising the water level to elevation 875, giving a head of about 48 feet. Such an elevation would flood out Whitemud falls, Little du Bonnet falls, and the lowest pitch of the Grand du Bonnet falls. This would undoubtedly form a very profitable development, considered as an individual project without reference to the balance of the river. It would, on the other hand, leave only some 12 feet to be developed at Pine falls. This of itself would not be commercially attractive in view of the competing sites in the river. At the same time there would be left some 52 feet between elevation 875 and the high level of Lac du Bonnet, which could only be developed in two heads of 33 and 18 feet, respectively. The net result on this reach of the river of concentrating development at Silver falls would therefore be four concentrations of 12 feet, 48 feet, 33 feet, and 18 feet, as opposed to the three concentrations of 37 feet, 56 feet, and 18 feet, which are recommended herein.

The 14-foot head available at Whitemud falls would render feasible the development of the falls as a unit should no other disposition of the drop be available, although on account of the low head such a utilization could only be made at a high unit cost. A careful study and detailed field survey of the falls show, however, that the drop can be practically eliminated by means of a channel (plate 46) cut through the ridge forming the river-bed through the falls. That this proposal is practical is due to the typical rock formation of the reach. The basin above the falls is in places 70 feet in depth, and except at one point referred to hereafter, will permit without any ill effects, the surface drop contemplated.

The soundings which have been secured above and throughout the falls clearly and definitely locate this rock ridge, and are sufficiently complete to permit of an estimate of the quantities involved, and to assure the feasibility of the construction of a channel of sufficient dimensions to lower the upper reach and add the drop to the Du Bonnet concentration.

The south side of the river appears to offer the better opportunities for the excavation of such a channel. Estimates have been made covering the cost of a cut 150 feet in width, and of sufficient depth to carry 25,000 second-feet at a velocity of about 4 feet per second. This channel will be 1,700 feet in length, and will involve the removal of 263,000 cubic yards of rock. Under conditions of normal flow it should carry the discharge with a drop of about 0.3 foot.

The removal of the Whitemud falls will result in a rapid current in the vicinity of island No. 2, a short distance below the Little du Bonnet falls. Under present conditions of river run-off, the river channel here becomes choked with accumulations of ice during the winter season. Lowering the reach 10 feet will accentuate the conditions favourable to the deposition of ice at this point. On the other hand the flooding out of the Du Bonnet falls, and the replacing of the same by a deep and extensive pond, will largely reduce the present tendency to produce frazil ice, and tend to better the conditions at island No. 2. Before the effects of lowering the reach 10 feet can be finally determined, a further investigation should be made in the vicinity of the island with a view of determining the nature of the river-bed. Should conditions warrant it, the question of concentrating the head at this point rather than at the Little du Bonnet falls might be advisable, although the capital cost of such a location would be considerably higher than that of the layout discussed herein. Such higher cost might be compensated for by the elimination of possible channel improvement work in the vicinity of island No. 2. The further field investigations into this alternative site should consist of soundings and borings in the river-bed, and are of a character such as can best be undertaken by the parties developing the site.


#### HEAD- AND TAILWATER ELEVATIONS.

The headwater at the proposed Du Bonnet plant has been placed at elevation 808. This will result in a 4-foot rise in the present normal water level at the head of the falls, and will flood back to the foot of the second McArthur falls. This rise in the normal headwater of the Du Bonnet falls will prove sufficient to pass the average flow over what is now the first pitch, at a velocity of from 3 to 4 feet per second. More detailed soundings than are now available are necessary to exactly determine the future conditions here.

According to well-defined water marks, the water level below the Little du Bonnet falls has risen to elevation 767 under extreme conditions. In an average year the level varies from 760 to 764. These conditions will recur in the future until such time as construction work is undertaken at the Whitemud falls. An average elevation of 762 has been assumed as the tailwater level under present conditions.

The regulated level of the Pine Falls site is 750. Upon the excavation of the proposed channel at Whitemud falls, this elevation will control the Du








Department of the Interior Canada  
RESPONSIBLE OFFICER: GEORGE H. BROWN  
BY: C. G. BROWN, S.E. (Geological Engineer)  
Water Power Branch  
J. G. Chisholm, Superintendent

# WINNIPEG RIVER POWER SURVEY. WHITE MUD FALLS SHOWING ROCK EXCAVATIONS IN CONNECTION WITH THE DU BONNET SITE.

April 1913





Bonnet tailwater. Throughout this discussion, 752 has been considered the elevation ultimately obtaining, although the estimates for the channel have considered a section which will pass 25,000 second-feet at a velocity of 4 feet per second with an hydraulic grade of 0.3 foot. Elevation 752 is considered a conservative assumption for the final tailwater level in view of the conditions already referred to as existing around island No. 2.

#### FLOODING.

Little flooding will result from raising the headwater to elevation 808. An embankment is necessary on the west side. This embankment is designed with a 10-foot top at elevation 815, and with  $1\frac{1}{2}$ : 1 slopes. It is 800 feet in length, and at regulated level in the pond will withstand a head of from 5 to 7 feet at its heaviest sections. It can be constructed of the clay in the immediate vicinity. Apart from this section, the natural contours will retain the headwaters with the flooding of some 360 acres.

#### PONDAGE.

A regulated level of 808 will create 1,700 acres of pondage. A draw of 1.7 foot on this pond will supply a 4-hour peak load to the full installation considered, i.e., 140,000 horse-power, assuming a continuous flow of 20,000 second-feet in the river. While this provides very fair pondage facilities, these are not as favourable as the conditions at the majority of the sites proposed along the river.

The advisability of a supervised control of the river regulation can be well illustrated here. The McArthur plant immediately above the Du Bonnet will have as its pond the 1,700-acre miles water surface of Lac du Bonnet. This offers unexcelled facilities for local storage, which can, if properly controlled, be made as readily available to the Du Bonnet as to the McArthur plant. It is only by such control that the maximum power output of this section of the river can be secured.

#### ICE CONDITIONS.

During the winter season the channel in the vicinity of island No. 2, below the Little du Bonnet falls, becomes at times somewhat choked with a deposit of frazil and anchor ice. This is largely due to the long stretch of agitated water in the Grand and Little du Bonnet falls, presenting ideal conditions for the formation of frazil and slush ice. The contracted river channel in the vicinity of the island, together with this formation of frazil, forms a combination favourable to the formation of an ice barrier, and is at times the cause of more or less choking and consequent raising of the water level above.

The layout under consideration will entirely drown out all the falls above the plant, as far back as the lower McArthur drop, and will form an extensive pond, in places 70 feet deep. The water is drawn directly from this pond into the turbines, and no ice troubles in the operation of the plant itself need be anticipated. The flooding out of the falls will also largely do away with the production of the slush ice which leads to the choking of the channel below.

## FOUNDATION CONDITIONS.

Solid red granite underlies the entire site, and is directly exposed over almost the entire layout. The river banks above the exposed rock line are



Grand du Bonnet Falls, Ice Conditions.



Little du Bonnet Falls, Site of Proposed Power Station.

composed of a fairly dense clay. In estimating on the corewall for the embankments, rock was assumed to be 10 feet below the natural surface, it being con-

sidered that the general configuration of the vicinity would warrant this assumption, and that in any event a trench of this depth in the material in question would permit of a tight foundation. Similar assumptions have been made at different points along the river. On the shore line the bare rock is in evidence at all points covered by the proposed structures. Along the line of the dam in the river-bed, the rock was assumed at elevations which were fixed after a careful observation on the ground. It is considered that these elevations are sufficiently close for estimating purposes.

#### LAYOUT.

The general layout (plate 48) connects with contour 815 on the right bank by means of a corewall embankment, ice sluices, and power station joined direct with a sluice and spillway dam of solid gravity section arched in plan



Model of Proposed du Bonnet Layout.

so as to follow the high rock above the falls, and finally closes with the high land on the opposite bank by means of a second embankment. The final location of the dam may be altered when detailed soundings are secured.

It was desirable to locate the power station on the west bank in order that direct rail connection could be secured. The shore-line formation does not, however, lend itself to this end, and such a location would involve extensive tail-race excavation, as well as a draught tube discharge poorly placed in relation to the pitch of the falls. The site selected for the power station provides ideal foundation conditions with a minimum of tail-race excavation, and secures a very favourable discharge.

*East embankment.*—The east embankment has been estimated with a 15-foot top at elevation 815, and  $1\frac{1}{2}$ : 1 slopes, constructed from the material most readily available. Impermeability is secured by a concrete corewall with a 1-foot crest at elevation 814, and a batter of 1 : 12. This core will be bonded

to the bedrock should the latter be within reasonable distance of the surface, and if not, a tight and safe bond can readily be obtained with the clay subsoil.

*Ice sluices.*—Between the east embankment and the power-house are located three 20-foot sluices with sills at elevation 793. These serve the double purpose of providing a suitable ice run and additional discharging capacity to the whole layout. The sluices are so placed as to clear the forebay of ice and drift by tending to produce a current parallel to the line of the power station. It has been assumed that rock will be available for the foundation at elevation 775 under the easternmost sluice, and at 770 under the remaining two. Rock is exposed on the river bank at the latter elevation.

*Power station.*—The power station (plate 49) has been designed for single-runner vertical turbines of 10,000 horse-power at full gate. The section has been developed only in sufficient detail to enable a fairly accurate estimate being made of the quantities involved. This was mainly a question of the size of the water passages to carry the requisite supply at permissible velocity to and from the turbines.

The racks and headworks have been housed in, and a sloping concrete curtain is provided as a protection against floating ice and drift. In conjunction with the ice sluices, this protection should be ample. The floor of the headworks house is at elevation 815, while the generator flood is at elevation 777. The centre line of the turbines is at elevation 766, and the draught tube seal at 748. This seal is placed at a sufficiently low elevation to permit of the projected lowering of the tailwater. The discharge from the draught tubes takes place directly into the river channel.

In view of the necessity of excavating a channel through the Whitemud falls in order to increase the available head from 46 to 56 feet, the estimates have been calculated for three stages of development: the initial, covering 12,000 second-feet at 46-foot head; the intermediate, covering 20,000 second-feet at 46-foot head; and the final, covering 20,000 second-feet at 56-foot head.

(1) *Initial development.*—This consists of the seven 10,000-horsepower units next the dam. It will provide for the utilization of 12,000 second-feet at 46-foot head, with the turbines running at eight-tenth gate and considered at 85 per cent efficiency. The above installation will practically leave one unit as a spare under the conditions stated. The output available at the switchboard on a 75 per cent over-all efficiency on a 24-hour basis is 47,000 horsepower. The headworks of the remaining units will be sufficiently constructed to support the stoplogs provided, leaving the balance of the units to be added when required.

(2) *Intermediate development.*—This consists of twelve 10,000-horsepower units, the additional five being adjacent to the initial installation. Twelve units will provide for the utilization of 20,000 second-feet at a 46-foot head, with the turbines running at eight-tenth gate.

This installation, under the conditions given, will provide a spare unit. The output available at the switchboard at 75 per cent efficiency on a 24-hour basis is 78,500 horsepower.

(3) *Final development.*—This consists of fourteen units which will provide for the utilization of 20,000 second-feet at 56-foot head with turbines at eight-tenth gate. This installation will practically provide a spare unit with the turbines running at eight-tenth gate. The power available at the switchboard at 75 per cent efficiency on a 24-hour basis is 95,500 horsepower.

An ideal sloping foundation of red granite is available at the proposed location of the station.

*Sluiceway section of dam.*—Fifteen 20-foot sluiceways (plate 50), with sills at elevation 793, are immediately adjacent to the power station. The sluiceway deck, with its underside elevation at 813.5, will permit of a 5½-foot rise in the regulated level. Solid rock underlies the sluiceway section. Its elevation has been assumed at 765.

*Spillway section of dam.*—The spillway section of the dam, 400 feet in length, has its crest at elevation 808, and is surmounted by a 10-foot platform supported by three-foot piers, spaced 23 feet, centre to centre. The platform will give ready access to the plant from the rail connection on the west bank. This free spillway section will discharge 14,000 second-feet with headwaters at elevation 813 and, together with the increased capacity of the sluices under these conditions, will automatically safeguard unexpected fluctuations in the river flow.

Rock has been assumed at elevation 758 after a careful inspection on the ground. Its presence is unmistakably in evidence.

*Fish ladder and log slide.*—The fish ladder and log slide are placed adjacent to the west embankment, and away from the power station. Their operation in this location should be satisfactory.

*West embankment.*—The west embankment is of similar design to that on the east side already described. Rock foundation for the corewall should be obtainable throughout its length, or if it is not within economic reach at the higher elevations, a satisfactory foundation can be secured in the clay soil.

#### DISCHARGE CAPACITY.

At regulated level the fifteen sluiceways and three ice sluices will discharge 72,000 second-feet. In addition to this the completed power station will pass an additional 20,000 second-feet, which, although not a source to be relied upon at all seasons, may be considered as a safety factor.

A free spillway, 400 feet in length with crest at 808, provides for automatic regulation. Three feet over this crest, with all sluiceways open and the power station in operation, gives a total discharging capacity of 113,000 second-feet. Five and one-half feet above the spillway crest can be carried by all structures.


#### UNWATERING.

The estimated cost of unwatering has been made on the basis of first unwatering the spillway section of the dam and constructing the same, leaving

<sup>1</sup>Since completing the estimates herein, the Winnipeg River Power Company, now developing this site, has sounded the river-bed along the line of the dam as proposed herein, and rock has been located at elevation 755 to 760.

**DOMINION WATER POWER BRANCH**  
**J. B. CHALLIES, Superintendent**  
**POWER-PERCENTAGE OF TIME CURVES**  
**DU BONNET FALLS POWER SITE**

at the  
**WINNIPEG RIVER,**  
 on the  
**HEAD 84 FEET POWER AT 75% EFFICIENCY**  
**PERIOD 1907-1914 INCLUSIVE**  
 To accompany a report on POWER AND STORAGE  
 INVESTIGATIONS by J. T. JOHNSTON, B.A.Sc.  
 March 5th, 1915



Twenty four hour Horse Power at 75% Eff.

Percentage of Time

89750 Equivalent Continuous Horse Power (over 8 years)

5750 Equivalent Continuous H.P. (over eight years)

WINNIPEG RIVER

HEAD 84 FEET POWER AT 75% EFFICIENCY PERIOD 1907-1914 INCLUSIVE

To accompany a report on POWER AND STORAGE INVESTIGATIONS by J. T. JOHNSTON, B.A.Sc. March 5th, 1915

H. P.

180,000

160,000

140,000

120,000

100,000

80,000

60,000

40,000

20,000

0

0

10

20

30

40

50

60

70

80

90

100

Proposed Installation 140,000 H.P.

Continuous output on basis of 20,000 Sec. feet minimum flow 95,000 twenty four hour power

Continuous output on basis of 12,000 Sec. feet minimum flow 57,500 twenty four hour power

Flow at River after passage through the Rapids

Flow at Base after passage through the Rapids

5750 Equivalent Continuous H.P. (over eight years)

89750 Equivalent Continuous Horse Power (over 8 years)





# W I N N I P E G R I V E R

It is proposed to add Whitemud Falls  
 to the du Sennel development lowering  
 the present tail water to 788




Department of the Interior Canada  
Ministère des Travaux Publics  
Water Power Branch  
J. B. Gaudin, Chief Engineer

# WINNIPEG RIVER POWER SURVEY PROPOSED SCHEME OF DEVELOPMENT AT DU BONNET FALLS

By: *J. B. Gaudin* Approved by: *J. B. Gaudin*  
Hydraulic Engineer Consulting Engineer  
Water Power Branch Water Power Branch



Based on Field Surveys made under the direction of  
D. C. MacLean, Chief Eng. Manitoba Power Survey  
66721-1215



815

810

Clay Bank

March 6, 1916  
Water Level 799.00  
Discharge 142500 Cusec

Normal Required Water Level 808

Sec. 27 Twp. 17 Rge. 11 E. P.M.  
Road Altitude

Sec. 28 Twp. 17 Rge. 11 E. P.M.  
Road Altitude

Clay Bank

Present Shore Line



PLATE No 49







PLATE No 50



f

a sufficient number of temporary discharge sluices therein to discharge the river flow while the sluiceway section is unwatered and built. The temporary sluices can afterwards be closed off with stoplogs and built up to the regular crest level at 808. The power station can be unwatered by sections as built.

Alternative methods can be adopted to suit the method and order of construction. The estimates herein are considered to be amply sufficient to cover whatever method may be adopted.

#### NAVIGATION.

At this site the navigation lock has been located on the east bank below the power station (plate 48). A flight of two locks can be constructed, if desirable. Advantage has been taken of the upper entrance excavation to construct a sailing bank and at the same time protect the approach to the lock from the draw towards the power station. The lock depicted is 300 feet by 40 feet, with 15 feet of water on the sills. No trouble will be experienced in securing suitable foundations for all structures.

Should the installation of lockage facilities become desirable in the future, the construction of this lock, with approaches, and the utilization of the same, will in no way interfere with the operation of the power station. Nor will the present construction of the suggested power development place any obstacles in the way of the future construction or operation of the lock.

The estimates herein do not include any portion of the cost of the lock or approaches.

#### ESTIMATES OF COST.

The estimates place the power on the switchboard in the power station, and do not include transmission. It is considered that the assumptions which have been necessary are more than warranted. Actual construction will possibly lead to a considerable reduction in the totals submitted, as it has been considered advisable at all points where any reason for doubt exists, to make the most liberal provision for eventualities.

The estimates include a 13-mile spur line from the present terminal of the Canadian Pacific railway at Lac du Bonnet. This will bring rail connection to the west bank of the river. An item has been included for the construction of a ferry for the transport of loaded cars across the river to the power station site.

In addition to the above, 10 per cent has been added for contingencies, 5 per cent on this total for engineering and inspection, and 5½ per cent on the whole for one year for interest during construction. The estimated cost of the Whitemud Falls excavation has been inserted as a unit.

The annual operation costs include capital charges, and represent the cost of operation at the power station. They do not include transforming and transmission.

## (1) Initial development.—(Seven 10,000-horsepower units.)

## (1) Capital Cost of Installation.

Dam and equipment.....	\$542,000
Embankment (flood protection).....	5,000
Ice sluices.....	72,000
Power station and equipment.....	657,000
Hydraulic installation.....	665,000
Electrical installation.....	805,000
Railroad.....	156,000
Ferry.....	50,000
Permanent quarters.....	25,000
Contingencies, 10 per cent.....	298,000
Engineering and inspection, 5 per cent.....	164,000
Interest during construction, 5½ per cent.....	189,000
<b>Total initial cost.....</b>	<b>\$3,628,000</b>

Twenty-four hour power available at 75 per cent over-all efficiency, 47,000 horsepower.

Capital cost per 24-hour horsepower.....	\$77.19
Capital cost per installed horsepower.....	51.83

## (2) Annual Cost of Operation.

Interest, sinking fund, and depreciation charges—	
Interest, 5½ per cent on \$3,628,000.....	\$ 200,000
Sinking fund, 4 per cent (40-year bonds).....	38,000
Depreciation—	
1 per cent on permanent works.....	\$ 12,000
4 per cent on machinery, etc.....	64,000
Operation charges—	76,000
Staff.....	\$21,000
Supplies.....	20,000
<b>Total annual charge.....</b>	<b>\$ 355,000</b>

Annual cost per horsepower year, 24-hour power..... \$7.55

Annual cost per horsepower year, machinery installed..... 5.07

Annual cost per kilowatt hour..... 0.115 cent.

Annual cost per kilowatt hour on basis of 50 per cent load factor..... 0.230 cent.

## (2) Intermediate development.—(Twelve 10,000-horsepower units.)

## (1) Capital Cost of Installation.

Dam and equipment.....	\$ 542,000
Embankment (flood protection).....	5,000
Ice sluices and roadway.....	72,000
Power station and equipment.....	926,000
Hydraulic installation.....	1,140,000
Electrical installation.....	1,380,000
Railroad.....	156,000
Ferry.....	50,000
Permanent quarters.....	25,000
Contingencies, 10 per cent.....	430,000
Engineering and inspection, 5 per cent.....	236,000
Interest during construction, 5½ per cent.....	273,000
<b>Total intermediate cost.....</b>	<b>\$5,235,000</b>

Twenty-four hour power available at 75 per cent over-all efficiency, 78,500 horsepower.

Capital cost per 24-hour horsepower.....	\$66.69
Capital cost per installed horsepower.....	43.62

## (2) Annual Cost of Operation.

Interest, sinking fund, and depreciation charges—	
Interest, 5½ per cent on \$5,235,000.....	\$ 288,000
Sinking fund, 4 per cent (40-year bonds).....	55,000
Depreciation—	
1 per cent on permanent works.....	\$ 14,000
4 per cent on machinery, etc.....	106,000
Operation charges—	120,000
Staff.....	\$ 27,000
Supplies.....	32,000
<b>Total annual charge.....</b>	<b>\$ 522,000</b>

Annual cost per horsepower year, 24 hour power..... \$6.65

Annual cost per horsepower year, machinery installed..... 4.35

Annual cost per kilowatt hour..... 0.102 cent.

Annual cost per kilowatt hour on basis of 50 per cent load factor..... 0.204 cent.

(3) Final development.—(Fourteen 10,000-horsepower units.)

(1) Capital Cost of Installation.	
Dam and equipment .....	\$ 542,000
Embankment (flood protection).....	5,000
Ice sluices and roadway .....	72,000
Power station and equipment.....	1,035,000
Hydraulic installation .....	1,330,000
Electrical installation .....	1,610,000
Railroad .....	156,000
Ferry .....	50,000
Permanent quarters .....	25,000
Contingencies, 10 per cent.....	483,000
Engineering and inspection, 5 per cent.....	265,000
Interest during construction, 5½ per cent.....	307,000
Whitemud falls lockout .....	671,000
<b>Total final cost.....</b>	<b>\$6,551,000</b>
Twenty-four hour power available at 75 per cent over all efficiency, 95,500 horsepower.	
Capital cost per 24-hour horsepower .....	\$68.60
Capital cost per installed horsepower .....	\$46.79
(2) Annual Cost of Operation.	
Interest, sinking fund, and depreciation charges—	
Interest, 5½ per cent on \$6,551,000.....	\$ 360,000
Sinking fund, 4 per cent (40-year bonds).....	69,000
Depreciation—	
1 per cent on permanent works .....	\$ 15,000
4 per cent on machinery, etc.....	123,000
Operation charges—	
Staff.....	\$ 30,000
Supplies.....	38,000
<b>Total annual charge.....</b>	
<b>\$ 635,000</b>	
Annual cost per horsepower year, 24-hour power .....	\$6.65
Annual cost per horsepower year, machinery installed.....	4.54
Annual cost per kilowatt hour.....	0.102 cent.
Annual cost per kilowatt hour on basis of 50 per cent load factor.....	0.204 cent.

**McArthur Falls Site.**

The second pitch of the McArthur falls is located about 4½ miles above the Du Bonnet site, and about 26 miles from Winnipeg. The field investigations in the vicinity of this site were completed during the winter of 1911-12, and were supplemented by a reconnaissance of the shores of Lac du Bonnet, with a view to ascertaining its flooding limit. The actual detail survey of the shores of the lake was carried on during the fall of 1912.

A study of the complete field data submits the following general scheme of development as being at once commercially feasible, and as forming a component link in the complete power development scheme.

SPECIAL CONSIDERATIONS AT MCARTHUR FALLS.

The two outstanding features of the proposed hydro-electric development at the McArthur Falls site are the low head and the large local storage in Lac du Bonnet. The lowness of the head naturally has a tendency to increase the capital cost of construction. The natural configuration of the ground has lengthened the dam and necessary embankments, but the latter are low and can be cheaply constructed. The disadvantage of a low head is, to a certain extent, balanced by the unexcelled storage facilities in Lac du Bonnet. By raising this lake to elevation 827, a surface area of 38 square miles is available. This elevation encroaches on the low lands at the west end of the lake, and ample sluiceway

and free spillway capacity is necessary in order to regulate the high water and prevent further flooding.

#### REACH OF THE RIVER DEVELOPED.

The reach of the river developed at this point extends from the lower or second McArthur falls, up to practically the foot of the Seven Sisters falls. In the development the upper or first McArthur falls are drowned out, and Lac du Bonnet is raised to high-water level, the drop of 18 feet being concentrated at the second fall.

*Second McArthur falls.*—The second or lower McArthur falls are located about 3 miles above the first pitch of the Du Bonnet falls. The river is here



Second McArthur Falls, Main Pitch.

divided into two channels by a large island, the major portion of the flow taking place through the right channel. The total normal drop is about  $6\frac{1}{2}$  feet. These falls form the site of the proposed concentration.

*First McArthur falls.*—The first McArthur falls occur about 1 mile above the lower falls. The river is again divided, this time into three channels, by a group of islands. The right channel carries the major portion of the flow. The total drop is about 7 feet. Granite outcrop is in evidence on all sides.

*Lac du Bonnet.*—Lac du Bonnet (plate 51) has a water surface normally some 33 square miles in area, which in times of maximum high water is increased to 38 square miles. The limiting feature preventing further raising without remedial works is a muskeg located to the west of the lake. Its mean surface level is about 829. This muskeg is understood to drain to the southwest into lake Winnipeg, but so far as is known no line of levels has been run to determine this question. It is not essential to the present discussion, since it is not proposed


aise the  
h would  
rovided  
or may  
d level.  
sudden

datum.  
nd will  
ve Lac



Pinawa.  
re main  
ve the  
e upper  
Lower

innipeg  
ther or  
restion-  
posed  
ng and  
s been  
ilwater



1p17R11.F.P.M. 1p17R12.F.P.M.  
1p16R11.F.P.M. 1p16R12.F.P.M.

Proposed Water Level 827

M.H.W. 827.64

M.H.W. 826.78

**- PLAN  
LAC DU BOURGET**

Department of the Interior  
BUREAU OF RECLAMATION  
Water Power Branch  
J. B. CHAMBERLAIN, Chief


This is a report on POWER AND  
by J. T. JOHNSTON

Scale of Feet  
STATES

NOTE COMPILED FROM THE WINNIPEG  
TOPOGRAPHIC SERIES

April 1911

Drawn on the Office of the Chief Draftsman, Dept. of Water Power, Ottawa



Department of the Interior, Canada  
 RESPONSIBLE IN TECHNICAL MATTERS  
 W. GIBBY, C. E. G. G. Survey Division  
 Water Power Branch  
 J. B. CHAMBERLAIN, Surveyor

**PLAN OF -  
 DU BONNET**

POWER AND STORAGE INVESTIGATIONS  
 J. T. JOHNSTON, B.A.Sc.

Scale of Feet  
 0 1000 2000 3000 4000 5000

FROM THE WINNIPEG RIVER POWER SURVEY  
 TOPOGRAPHIC SHEETS.

and free  
prevent

The  
second l  
the dev  
du Bom  
at the s  
*Sec.*  
about 3



divided  
place th  
These fa  
*Fir:*  
lower fa  
group o  
The tota  
*Lac*  
some 33  
to 38 sc  
remedial  
level is ;  
lake Wir  
this ques

to flood above elevation 827. In any event, should it be desired to raise the water above 829, the construction of a low dyke about 1 mile in length would protect the muskeg from the lake. Sufficient discharging capacity is provided in the dam to pass the largest floods which have occurred in the past, or may be anticipated in the future, without raising the surface above regulated level. In addition, 1,725 feet of free spillway will offer automatic protection from sudden floods.

#### HEAD- AND TAILWATER ELEVATIONS.

The headwater is regulated to elevation 827, Water Power Survey datum. This elevation will completely drown out the first McArthur falls, and will raise Lac du Bonnet to practically maximum high-water level. Above Lac



First McArthur Falls, Left Channel.

du Bonnet the river is divided into two channels, the main and the Pinawa. Holding the surface of the lake at elevation 827 will back up the water in the main channel, drown out the small rapid which now exists about 5 miles above the town of Lac du Bonnet, and allowing for the hydraulic gradient in the upper portion of the reach, will control the tail-water elevation of the proposed Lower Seven Sisters development.

The Pinawa channel, on which is located the present plant of the Winnipeg Electric Railway Company, will also be subject to backwater. Whether or not the tailwater of the company's plant will be in any way affected is questionable. Its present normal elevation is about 842, or 15 feet above the proposed level of Lac du Bonnet. The channel below is irregular and winding and obstructed in places by rock-ridges, at which considerable blasting has been carried on by the company to assist the discharge and improve the tailwater conditions at the plant.

It is doubtful whether the raising of Lac du Bonnet to elevation 827 would reduce the head at the power plant to any appreciable extent during the summer season, while, on the other hand, by quieting the flow in the lower reaches and lessening the tendency to accumulate anchor ice, with the consequent backing up of the tailwater, it should prove beneficial during the ice period. In this connection the following quotation from Mr. J. R. Freeman's report following the preliminary reconnaissance is pertinent:—

"It would doubtless be claimed by the railway company that this raising of the lake would impede the discharge from their works on the Pinawa channel, but after having carefully reconnoitred the wasteful rapids near the outlet of the channel, particularly the two pitches, one of about 3 feet at the bridge for the railroad leading to the municipal power plant, and another of nearly 5 feet, where some blasting has been done, at the rocky reef about a mile, more or less, downstream from this railroad bridge; and, moreover, having had the opportunity to observe the effect of back-flowage under somewhat similar conditions, I believe it highly probable that true conservation and the greatest public good would result from this raising of the lake and of this Pinawa outlet level.

"I consider it highly probable that the effect of raising Lac du Bonnet 5 feet would be practically inappreciable at the power-house some 5 miles or more upstream from these two abrupt falls, which, with neighbouring rapids, aggregate nearly 8 feet."

The tailwater of the McArthur concentration is fixed by the headwater elevation of the proposed plant at the Du Bonnet site. The present tailwater of the McArthur falls, with a flow of 20,000 second-feet in the river, is about elevation 806. The headwater level of the Du Bonnet development has been placed at 808 to allow for the drowning out of the first pitch of the falls. Allowing 1 foot for the hydraulic gradient from the Du Bonnet dam to the McArthur tailrace, places the latter at 809. This is a higher elevation than will occur during low and normal water, but it is being used throughout the present discussion as being conservative. Extreme floods will undoubtedly raise the tailwater above this level and reduce the working head. The increased water available for power purposes at such periods will, however, more than counter-balance any such loss.

#### FLOODING.

A reference to plate 51 will illustrate the extent of flooding involved by raising the water level to 827. Between the two McArthur falls a low embankment may be required on the west bank to protect the low land. This embankment will not be more than 5 to 8 feet high, and can be cheaply constructed. Further detailed surveys may show that it is not required. The larger proportion of the land flooded is located at the western end of Lac du Bonnet. It is questionable whether it would be more economical to protect this land by the low embankments necessary, or to buy the land outright. An item for flooding damages has been included in the estimates.

As the records along the shore of the lake show that the water has attained

an elevation of 827 in extreme floods under natural conditions, the question of flooding cannot be considered as introducing entirely new conditions.

#### PONDAGE.

The McArthur site offers the best facilities for local pondage that exist on the full reach of the Winnipeg river in Manitoba. In the contemplated development, Lac du Bonnet forms the pond of the plant, and renders 38 square miles of water surface available for local regulation. This extensive area is a double advantage in that the necessary storage can be obtained without appreciable loss of head, a matter of importance in the McArthur plant. The capacity of the pond can best be illustrated by stating that 1 inch of storage on the lake will provide slightly over 1,000 second-feet continuous run-off for twenty-four hours, or 4,000 second-feet for six hours.

These exceptional facilities for local pondage can be placed equally at the disposal of the Du Bonnet site below, providing some supervising control is exercised by the Crown. *In any event it will not be permissible to give the control of the regulation of Lac du Bonnet to any single interest, since local regulation could for considerable periods completely shut off the water from the plants below.*

#### ICE CONDITIONS.

The prevention of the formation of anchor and frazil ice has been fully taken into account in the layout proposed at this site.

The McArthur plant draws its water from Lac du Bonnet, all the present falls and rapids being flooded out. The water passes directly from the pond to the turbines, and the discharge takes place directly down stream. No ice troubles are anticipated.

A sloping concrete curtain, with bottom elevation 2 feet below regulated pond level, protects the racks from floating ice and drift, and ice sluices at either end of the power station provide means of escape for all such material.

#### FOUNDATION CONDITIONS.

Granite formation is in evidence throughout almost the entire length of the layout. Where it does not lie on the surface, it has been located by means of an iron bar at a depth of a few feet. The only point at which there is any doubt as to its elevation is under the sluiceway section of the dam. This is taken up in more detail in discussing the layout.

Assumptions have been necessary as to the rock elevation along the site of the main spillway dam at the crest of the main pitch of the falls. The elevations assumed are based on actual observation on the ground, and are considered to be conservative. There is no question whatever as to the actual existence of rock formation at this point.

Actual soundings at the site of the power station give the rock elevation as shown on the plans.

## LAYOUT.

The contours and general physical characteristics at the second McArthur falls permit various layouts, no one of which apparently offers any great outstanding advantages. Alternate designs and locations were considered, each offering feasible development opportunities. To determine the most economic



Second McArthur Falls, Site of Proposed Power Station.

of these layouts would require a very careful detailed estimate of each, assisted by further boring and sounding operations in the field. On the whole it is considered that, with the conditions which must be met, the layout suggested herein (plate 53) will form as economic a development as is possible at this site.



Model of Proposed McArthur Layout.

The power station as located spans the western channel, and provides a free discharge with no possibility of ice choking below. The dam consisting of embankment, sluiceways, and free spillway, runs diagonally across the large island, and by a second spillway spans the right channel.

*Spillway section of dam.*—The main spillway section of the dam, 925 feet in length, has been located along the crest of the main pitch of the second

McArthur falls, adjacent to the right bank of the river. The rock surface has been assumed at elevations 800 to 811, and the spillway crest placed at 827.

A second spillway, 750 feet in length, crest at 827, has been included in the dam on the large central island. The granite is here exposed on the surface, and at such elevation that a spillway section can be constructed at but small expense. The free spillway can be lengthened if necessary by replacing the earth embankment. No flashboards or bridge deck have been considered with the spillways, and the discharge above elevation 827 will be entirely automatic.

A fish ladder and log slide are provided at the island end of the main spillway.

*Embankment on Island.*—The greater portion of the dam on the island consists of a corewall embankment with top elevation at 832. This embankment is low over the greater portion of its length, and is based on the exposed granite everywhere in evidence along its route.

*Sluiceway section of dam.*—Fifteen 20-foot sluices, with sills at elevation 812 (plate 55), are located in the shallow gully on the island. The elevation of the rock surface has not been determined over this portion of the layout. It has been assumed at elevation 802. The general character of the formation and contours in the vicinity would warrant this assumption. Should borings show rock to be at too low an elevation to permit the economical construction of the sluiceways at this point, they can be located in the main spillway section, and their present location closed by a continuation of the corewall embankment. The locations of the power station and the sluiceways might also, under these conditions, be profitably interchanged.

The sluiceways have been placed in their present location so as to be within easy operating distance of the power station. As located they will discharge all the surplus water across the island, and away from the tail-race. This is a matter of considerable importance, since the narrow channel below the power station will not pass a discharge much over 20,000 second-feet, without backing up on the tailwater.

*Ice sluices.*—Six 20-foot ice sluices, three at either end of the power station, provide means of clearing the forebay from floating ice and detritus. If desirable the discharge through the easterly sluices can, by means of a rock-fill composed of the excavated material, be diverted across the gully on the island below the power station, and thus be kept free from the tailwater. Both sets of sluices are decked, the easterly to provide means of access to the main sluiceway section of the dam, as well as to operate the stoplogs, and the westerly to provide roadway access to the power station.

*Power station.*—The power station (plate 54) has been designed for single-runner vertical turbines of 2,500-horsepower capacity at full gate. The section has only been developed in sufficient detail to arrive at the size of the water passages necessary to carry the water to and from the turbines at permissible velocities. The electrical and regulating equipment have been assumed for estimating purposes only.

The racks and headworks have been housed in with floor at 832, and a sloping concrete curtain along the face of the entrance piers provides a protection against floating ice and drift. The generator floor is at elevation 827, and is

**DOMINION WATER POWER BRANCH**

J. B. CHALLIES, Superintendent

**POWER-PERCENTAGE OF TIME CURVES**


**MCCARTHUR FALLS POWER SITE**


WINNIPEG RIVER

HEAD 10 FEET. POWER AT 75% EFFICIENCY.  
PERIOD 1907-1914 INCLUSIVE.

To accompany a report on POWER AND STORAGE  
INVESTIGATIONS by J. T. JOHNSTON, B.A.Sc.  
March 6th 1915

PLATE No. 62








Department of the Interior Canada  
 MINISTRE DES TERRES ET DES MINES  
 Water Power Branch  
 J. C. HALL, SUPERVISOR

**WINNIPEG RIVER POWER SURVEY**  
**PROPOSED SCHEME OF DEVELOPMENT**  
**AT**  
**MC ARTHUR FALLS**

Approved by *[Signature]*  
 Consulting Engineer  
 Water Power Branch

Scale of Feet  
 0 20 40 60 80 100 120 140 160 180 200

Based on Field Surveys made under direction of  
 D.L. BROWN, Chief Eng. Water Power Surveys  
 1918-1920



Horizontal scale 1 inch = 100 feet  
 Vertical scale 1 inch = 20 feet  
 Contour interval 10 feet  
 Elevation of bench mark 512.5 feet  
 Datum 1920

Feb 1921  
 Map Level 512.5  
 Datum 1920 8 feet

Normal Regulated Water Level 527


1	1/2	3/4	1	1 1/4	1 1/2	1 3/4	2	2 1/4	2 1/2	2 3/4	3	3 1/4	3 1/2	3 3/4	4	4 1/4	4 1/2	4 3/4	5	5 1/4	5 1/2	5 3/4	6	6 1/4	6 1/2	6 3/4	7	7 1/4	7 1/2	7 3/4	8	8 1/4	8 1/2	8 3/4	9	9 1/4	9 1/2	9 3/4	10
---	-----	-----	---	-------	-------	-------	---	-------	-------	-------	---	-------	-------	-------	---	-------	-------	-------	---	-------	-------	-------	---	-------	-------	-------	---	-------	-------	-------	---	-------	-------	-------	---	-------	-------	-------	----

**DOMINION WATER POWER BRANCH**

J. B. CHALLIES, Superintendent


**POWER-PERCENTAGE OF TIME CURVES**





REAR ELEVATION

WINNIPEG WATERWORKS  
PROPOSED SCHEME OF DEVELOPMENT  
AT  
MC ARTHUR FALLS



SECTION BB




PLAN ON LINE A A



DOMINION WATER POWER BRANCH

J. B. CHARLTON




MINNIE BEVER POWER SEAWAY  
 M. J. DAVIS  
 MARTNOR FALLS  
 1910



# MICROCOPY RESOLUTION TEST CHART

(ANSI and ISO TEST CHART No. 2)



**APPLIED IMAGE Inc**

1653 East Main Street  
Rochester, New York 14609 USA  
(716) 482 - 0300 - Phone  
(716) 288 - 5989 - Fax

WATER BOWER BRANCH

directly connected to the left bank of the river by a roadway over the three westerly ice sluices, and along the embankment leading to the high ground. The draught tube seal is at elevation 804, the discharge taking place directly down the river. The narrow channel, a short distance below the power-house is of sufficient capacity to carry the full discharge of the final installation without adverse backwater effects.

The estimates for the power station have been calculated for two stages of development.

(1) *Initial development.*—This consists of the eleven easterly units. The turbine units considered have a capacity of 2,500 horsepower at full gate, and the electrical installation has been selected with the normal full load corresponding to eight-tenth gate opening on the turbines. The initial installation of eleven units gives a sufficient machine capacity to utilize 12,000 second-feet at 18-foot head, with turbines at 85 per cent efficiency and eight-tenth gate, and at the same time leaves one unit as a spare for emergencies.

The output available on the low tension switchboard on a 75 per cent over-all efficiency on a 24-hour basis, is 18,400 horsepower. The estimates for the initial development includes construction of the headworks of the remaining six bays to a sufficient degree to support the stoplogs, leaving the balance of the bays to be added when required.

(2) *Final development.*—This consists of seventeen 2,500-horsepower units, the six additional being added to the west of the first installation. The seventeen units will supply machine capacity for the utilization of 20,000 second-feet at 18-foot head, with the turbines considered at eight-tenth gate. This installation will, under these conditions, provide a spare unit for emergencies. The output at the switchboard at 75 per cent efficiency on a 24-hour basis is 30,700 horsepower.

#### DISCHARGE CAPACITY.

It is proposed to hold the pond level at elevation 827 at all seasons of the year. The limit of flooding (without embanking) on Lac du Bonnet is elevation 829, this being the level of the muskeg at the westerly end of the lake. It is essential therefore to assure sufficient discharging capacity to meet all possible requirements at regulated level. The twenty-one 20-foot sluices, sills at 812, will provide for the discharge of 81,000 second-feet at pond level of 827. No consideration is here given to the discharge through the power station, which, when in full operation, will be 20,000 second-feet.

In addition to ample sluiceway discharge, it is necessary that there should be an extensive automatic spillway discharge in order that any unexpected rise of the river will be automatically cared for should the sluiceways for any reason be neglected. Spillway to the length of 1,725 feet is provided in the suggested layout, which, with 2 feet over the crest, will discharge 16,000 second-feet. The total discharging capacity with pond at elevation 829, all sluices open and the power station in full operation is 134,000 second-feet.

Exceptional length of spillway is supplied in view of the narrow limits within which the headwaters are to be held. The construction of a dyke con-

necting the higher contours on the west shore of the lake would allow a further raising of the lake level, and might repay further investigation.

#### UNWATERING.

Several methods of unwatering might be adopted in the construction of this plant, the selection of which depends on further investigation on the ground, and the exigencies of construction. In the following estimates, ample yardage for cofferdams and provision for pumping has been allowed. No exceptional difficulties are to be anticipated in this connection.

#### NAVIGATION.

At the McArthur site, provision for lockage facilities, should they become necessary in the future, has been made on the central island (plate 53). There are other feasible locations. The lock depicted is 300 feet by 40 feet, with 15 feet of water on the sills. First-class foundation can be found for all structures.

This lock with approaches, can be constructed at any time in the future without in any way interfering with the operation of the power plant, nor will the provision for it incur any extra expenditure on the present construction of the plant. On the other hand, the present construction of the power installation will not place any obstacles in the way of the future construction or operation of the lock. No portion of the cost of the lock or approaches is included in the estimates for the power development.

#### ESTIMATES OF COST.

The following estimates of the cost of the initial and final installations place the power on the low tension switchboard in the power station. It is considered that the estimates are amply conservative, and that the assumptions which have been made are fully warranted. As it is wholly improbable that the McArthur development will be undertaken before the construction of the Du Bonnet plant, it has not been considered necessary to estimate on the capital cost of a spur line from the town of Lac du Bonnet to the site. It has been assumed that this spur line has already been constructed to the Du Bonnet plant, and the estimates herewith include only sufficient to construct the necessary connecting siding from this spur line.

Ten per cent has been allowed on the estimates for contingencies, 5 per cent on this total for engineering and inspection, and 5½ per cent on the whole for one year for interest during construction.

The annual operation costs include capital charges, and represent the cost of operation at the power station. They do not include transforming and transmission.

(1) Initial development.—(Eleven 2,500-horse power units.)

(1) Capital Cost of Installation.

Dam and equipment.....	\$ 512,000	
Ice sluices.....	52,000	
Power station and equipment.....	581,000	
Hydraulic installation.....	248,000	
Electrical installation.....	385,000	
Railroad.....	12,000	
Permanent quarters.....	15,000	
Contingencies, 10 per cent.....	161,000	
Engineering and inspection, 5 per cent.....	88,000	
Interest during construction, 5½ per cent.....	102,000	
Allowance for flooding damages.....	75,000	
<b>Total initial cost.....</b>		<b>\$2,031,000</b>
Twenty-four hour power available at 75 per cent over-all efficiency, 18,400 horse-power.		
Capital cost per 24-hour horse-power.....		\$110.38
Capital cost per installed horse-power.....		73.88

(2) Annual Cost of Operation.

Interest, sinking fund, and depreciation charges—		
Interest, 5½ per cent on \$2,031,000.....	\$	112,000
Sinking fund, 4 per cent (40-year bonds).....		21,000
Depreciation—		
1 per cent on permanent works.....	\$	7,000
4 per cent on machinery, etc.....		30,000
		37,000
Operation charges—		
Staff.....	\$	21,000
Supplies.....		8,000
		29,000
<b>Total annual charge.....</b>	<b>\$</b>	<b>199,000</b>
Annual cost per horse-power year, 24-hour power.....		
		\$10.82
Annual cost per horse-power year, machinery installed.....		
		7.24
Annual cost per kilowatt hour.....		
		0.166 cent.
Annual cost per kilowatt hour on basis of 50 per cent load factor.....		
		0.332 cent.

(2) Final development.—(Seventeen 2,500-horsepower units.)

(1) Capital Cost of Installation.

Dam and equipment.....	\$ 312,000	
Ice sluices and west embankment.....	52,000	
Power station and equipment.....	793,000	
Hydraulic installation.....	393,000	
Electric installation.....	605,000	
Railroad.....	12,000	
Permanent quarters.....	20,000	
Contingencies, 10 per cent.....	219,000	
Engineering and inspection, 5 per cent.....	120,000	
Interest during construction, 5½ per cent.....	139,000	
Allowance for flooding damages.....	75,000	
<b>Total final cost.....</b>		<b>\$2,740,000</b>
Twenty-four hour power available at 75 per cent over-all efficiency, 30,700 horse-power.		
Capital cost per 24-hour horse-power.....		\$89.25
Capital cost per installed horse-power.....		64.47

(2) Annual Cost of Operation.

Interest, sinking fund, and depreciation charges—		
Interest, 5½ per cent on \$2,740,000.....	\$	151,000
Sinking fund, 4 per cent (40-year bonds).....		29,000
Depreciation—		
1 per cent on permanent works.....	\$	9,000
4 per cent on machinery, etc.....		44,000
		53,000
Operation charges—		
Staff.....	\$	27,000
Supplies.....		12,000
		39,000
<b>Total annual charge.....</b>	<b>\$</b>	<b>272,000</b>
Annual cost per horse-power year, 24-hour power.....		
		\$8.86
Annual cost per horse-power year, machinery installed.....		
		6.40
Annual cost per kilowatt hour.....		
		0.136 cent.
Annual cost per kilowatt hour on basis of 50 per cent load factor.....		
		0.272 cent.

**SEVEN SISTERS REACH.**

About 15 miles above Lac du Bonnet the Winnipeg river is broken into two channels. The western channel, in which are located the Seven Sisters falls, sometimes called the Seven Portages, carries the main portion of the river flow. The eastern or Pinawa channel, under natural conditions carried only a small part of the flow, more especially during the seasons of low water on the river. In connection with the construction of the Winnipeg Electric Railway Company's plant on this channel, diversion weirs were placed across the main and secondary channels for the purpose of diverting sufficient water to properly operate the power station at all seasons.

The discharge of the river over and above what is necessary to so operate the company's plant is available for development throughout the Seven Sisters reach.

Power development on this reach is subject to two governing considerations. The weirs at the head of the reach and the protection of the interests of the Winnipeg Electric Railway Company in respect to the diversion of water must be fully considered in fixing the headwater elevation. The proposed regulated level of Lac du Bonnet will control the tailwater.

The bank contours are not favourable to the development of the entire reach in one concentration. It has been necessary, therefore, to break the drop into two sites called, respectively, the Upper and Lower Seven Sisters.

**Lower Seven Sisters Site.**

Thirty-seven feet have been incorporated in the lower development, called the Lower Seven Sisters, since it includes the five lowest drops of the falls of that name. The proposed site is located about  $1\frac{1}{3}$  mile below the junction of the Whitemouth river with the Winnipeg, and is about 19 miles above the McArthur site and 50 miles from Winnipeg.

There are other feasible points along the reach at which this head might be concentrated. About  $2\frac{1}{2}$  miles below the site proposed there is a second shallow rapid at which rock outcrop is in evidence on both river banks and at various points in the river-bed, indicating the existence of favourable foundation conditions. The location of the plant here would secure a slightly greater head. On the other hand considerably more land will be flooded, and embankments would be required on the right bank to raise the pond to elevation 870.

The plant might also be placed at the foot of the Seven Sisters falls. Suitable foundation conditions are in evidence here, but a considerably longer dam would be required, and some loss of head would be experienced.

These alternative sites are referred to here, as it is recognized that detailed exploration with a view to construction may disclose more favourable foundation conditions at points other than the one which has been selected. The river-bed conditions, on which the layout discussed and estimated herein is based, have been determined solely by sounding through the ice cover, and while these soundings have given evidence of rock along the line of the layout at a suitable elevation, they cannot be taken as final.



River Bank above Lac du Bonnet.



First Rapid above Lac du Bonnet.

The rock outcrops which are in evidence at so many points both at and in the vicinity of the site selected and at the alternative sites referred to, indicate that conditions as favourable as those which have been assumed (where assumption is necessary) can be readily secured. It is considered therefore, that the estimates herein form a fair basis for studying the cost of developing this section of the river.

#### SPECIAL CONSIDERATION AT THE LOWER SEVEN SISTERS SITE.

In consequence of the division of the river into two channels *it will not be profitable to undertake the development of the Seven Sisters reach until such time as the river has been regulated*, since during times of low water the major portion of the flow is diverted down the Pinawa channel. For the purpose of present discussion it has been assumed that an average flow of 8,000 second-feet is diverted from the main river into the Pinawa channel. Under the present run-off conditions on the river, with a minimum flow of 12,000 second-feet, this diversion will leave a balance of only 4,000 second-feet for use on the Seven Sisters reach, while under a regulated condition of 20,000 second-feet, there will be left 12,000 available for use. In connection with plants utilizing the flow of the entire river, the estimates have been made for an initial and final development utilizing 12,000 and 20,000 second-feet respectively. On account of the altered conditions at this site, and the shortage of water as compared with the larger plants, it has been considered that estimates covering the complete development only will be sufficient for the purpose of demonstrating the possibilities of the site.

#### REACH OF THE RIVER DEVELOPED.

The reach of the river developed extends from the site  $1\frac{1}{2}$  mile below the mouth of the Whitemouth river, upstream to the foot of the second drop of the Seven Sisters falls, drowning out the entire reach between these limits.

*Fifth, sixth, and seventh drops of Seven Sisters falls.*—The fifth, sixth, and seventh drops of the Seven Sisters falls take place in a reach about 5,000 feet above the Whitemouth river, comprising a total drop of 16 feet in a reach of about 5,000 feet. The various pitches are irregular and much broken by ledges of various sizes, these being formed by the projection above the water surface of the underlying granite formation. This formation is also in evidence along both shore lines. The three pitches are not clearly defined, but to a certain extent gradually merge into each other. The banks on either side of the river rise fairly abruptly from 45 to 55 feet above the water surface.

*Fourth drop of the Seven Sisters reach.*—The total drop at this point is some 9 feet, with a fairly abrupt pitch taking place over a well-defined ridge. A portion of this ridge rises above the water surface, forming a narrow granite island some 400 feet in length, along the line of the pitch. The river banks rise from 25 to 30 feet above the water surface, and the whole site offers exceptional facilities for the location of a hydro-electric development. The contours of the banks do not, however, fit in with the limiting features governing the development of the whole reach.

and  
rate  
mp-  
the  
ion

be  
as  
ion  
ent  
is  
ent  
his  
en  
will  
ow  
pp-  
he  
th  
ete  
he

he  
ne  
nd  
e-  
t.  
s,  
g  
s.  
ge  
m

he  
A  
e  
rs  
al  
e  
o-



Whitemouth Falls.



Whitemouth Falls.



Seven Sisters Falls, Fourth Fall.



Seven Sisters Falls, Fourth Fall.

*Third drop of the Seven Sisters reach.*— This fall totals some 8 feet, and is not well defined. The pitch is broken by numerous and irregular islands formed of the usual outcropping granite. The granite formation is also in evidence on both shores, with the overlying soil rising to a height of about 25 feet above the water surface.



Seven Sisters Falls, Third Fall.

#### HEAD- AND TAILWATER ELEVATION.

The headwater elevation is governed by the tailwater of the Upper Seven Sisters plant, which has been fixed at elevation 870. A variation of a few feet from this elevation may be advisable when more complete information as to the river-bed is available. Any slight change which may be considered necessary in the final fixing of this elevation will not alter, to any great extent, the estimates which follow hereunder. In times of ordinary low water in the river there should be no appreciable hydraulic gradient between the Lower and the Upper Seven Sisters plants. In times of high water the tailwater of the upper plant will undoubtedly be slightly interfered with. It is to mitigate this interference that the regulated level is at present fixed at 870, this being about 3 feet higher than the normal water level above the third pitch. Any such interference, as may occur, during times of high water will not be excessive, and the surplus water which is available for power purposes at such times will more than make up the small loss in head.

The proposed tailwater level is governed by the regulated level of Lac du Bonnet, that is, elevation 827. There is at present, with Lac du Bonnet at its normal elevation of 820, an hydraulic gradient of some 11 feet between the lake and the power-house site. The river channel is fairly regular in section throughout this reach but is broken by a slight rapids about  $2\frac{1}{2}$  miles below the proposed

site. When Lac du Bonnet is raised to its proposed regulated level there will still remain an hydraulic gradient in the reach but, under normal conditions of flow, the present drop will be greatly reduced. In view of this the tailwater of the proposed plant has been conservatively placed at 833.6 feet above Lac du Bonnet regulated level. A normal head of 37 feet is therefore considered available for development under normal conditions of river flow.

#### FLOODING.

The banks in the immediate vicinity of the site rise to an elevation somewhat above 875, that is, from 6 to 8 feet above regulated level. As one goes upstream, both banks gradually rise, being at all points fairly abrupt. As a result, the flooding involved in the construction of the plant is unimportant and will be limited to the river channel, no embankments being necessary. The White-mouth river will be flooded for a distance of 13 miles upstream, but the flooding will be confined by the natural river banks. In no place will raising the headwaters to 870 militate against a natural and satisfactory drainage of the adjoining lands. In all, some 70 acres will be flooded, consisting entirely of the steeply sloping banks in the immediate vicinity of the river.

#### PONDAGE.

A pond of 1,175 acres extending back to the tailrace of the Upper Seven Sisters plant will be created by the construction of the dam. This acreage will provide excellent pondage facilities for the operation of the plant. A four-hour peak to the full extent of the ultimate proposed installation, 60,000 horsepower will, assuming a continuous discharge of 12,000 second-feet in the reach, only draw 0.9 foot on the pond level. To supplement this there will be at the upper plant a pond area of 8,470 acres, which, with supervised regulation, can if necessary be made equally available to the lower plant.

#### ICE CONDITIONS.

It is considered that full protection against all classes of frazil and anchor ice troubles is provided in the layout submitted herewith, and that ample provision is made for the passage of floating surface ice. The plant will draw its water direct from an expansive pond, of which a very large portion immediately above the site, is from 50 to 60 feet in depth. This pond, varying in width from 500 to 3,200 feet, extends from the lower plant to the upper site, drowning out the five lower pitches of the Seven Sisters falls. Under the proposed regulated conditions the present water surface of the lower three pitches will be submerged from 20 to 35 feet. This will entirely do away with the conditions favourable to the production of frazil ice, which now exist at these points. Any such ice as may be formed farther up the river will have ample opportunity for settling in the ice-covered pond before the power station is reached.

The sluices at the lower end of the power-house are well located to draw off all floating ice and drift lodging against the sloping concrete curtain which

extends across the face of the entrance piers to the power house. The racks are considered to be amply protected by these measures.

#### FOUNDATION CONDITIONS

The whole site, so far as could be determined from inspection and sounding through the ice cover, is underlaid with granite formation. This formation is exposed on both river banks, and rises above the water surface in the channel close to the line of the dam. At points where solid rock was not indicated by sounding, the presence of boulders was in evidence. This feature has already been covered in the general introduction and the remarks as to the foundation conditions in this vicinity and at other available sites, should be again noted.



Model of Proposed Lower Seven Sisters Layout.

#### LAYOUT.

In the layout which has been adopted for the purpose of consideration (plate 57), the power-house has been placed adjacent to the right bank. Leaving the outer end of the power station, the dam curves 67 degrees through the arc of a circle, and is extended as a tangent to the left bank. The line of the dam and power station has been located along the route showing the best evidence of underlying granite.


*Ice sluices and roadway.*—The power station is connected to the right bank by means of three ice sluices in conjunction with a concrete corewall embankment. This gives access to the floor of the headwork's house. Access to the main generator floor of the power station is secured by means of a steel bridge spanning the channel below the ice sluices. The three 20-foot ice sluices with sills at elevation 855, are ideally located for clearing the forebay of the

**DOMINION WATER POWER BRANCH**  
 J. B. CHALLIES, Superintendent


**POWER-PERCENTAGE OF TIME CURVES**  
 at the  
**LOWER SEVEN SISTERS POWER SITE**

on the  
**WINNIPEG RIVER,**  
 HEAD 37 FEET. POWER AT 75% EFFICIENCY  
 PERIOD 1907-1914 INCLUSIVE


To accompany a report on POWER AND STORAGE  
 INVESTIGATIONS by J. T. JOHNSTON, B.A.Sc.  
 March 5th 1915







This map was prepared from a plan of the  
 reservoir area, showing the present shore  
 line, and the normal regulated tail water  
 level, and the normal regulated water level.  
 The map is based on a plan of the reservoir  
 area, showing the present shore line, and  
 the normal regulated tail water level, and  
 the normal regulated water level.



Department of the Interior Canada  
 HONOURABLE W. J. ROCHE MINISTER  
 W. W. COY. C. M. G. DEPT. OF THE MINISTER  
 Water Power Branch  
 J. B. CHALLIS SUPERINTENDENT

**WINNIPEG RIVER POWER SURVEY**  
**PROPOSED SCHEME OF DEVELOPMENT**  
 AT  
**LOWER SEVEN SISTERS FALLS**


By *J. J. Johnston*  
 Consulting Engineer  
 Water Power Branch

Approved by *J. B. Challis*  
 Consulting Engineer  
 Water Power Branch




Based on Field Surveys made under direction of  
 E. L. McLean, Chief Eng. Manitoba Power Surveys  
 March 1914

H.P.  
120000




REAR ELEVATION

WINNIPEG, RIVER FRONTS (PLAN)  
PROPOSED SCHEME OF DEVELOPMENT  
AT  
LOWER SEVEN SISTERS FALLS




SECTION BB



PLAN ON LINE A A



PLATE No 59





power station from all floating ice and drift. The discharge through the sluices finds its way into the river below without interfering with the tailwater.

*Power station.*—The power station (plate 58) is designed to contain six single-runner vertical turbines, each of 10,000 horse-power capacity at full gate. The plan and section have been developed only in sufficient detail to arrive at the size of the water passages necessary to carry the water to and from the turbines at permissible velocities. The electrical and regulating equipment have been assumed for estimating purposes only.

The racks and headworks have been housed, both for ease of operating the stoplogs and racks and for protection during the winter season. The racks are further protected by a sloping concrete curtain, with lower edge 2 feet below regulated level, across the face of the entrance piers. The floor of the headworks house is at elevation 877, or 7 feet above regulated level; the generator floor is at elevation 852. The seal of the draught tube has been placed at 822 and the discharge from the plant takes place across the river. As there is ample river section at this point, there should be no interference between the discharge through the power station and through the sluices of the dam. Should such interference take place, a crib protection for the tailrace could be economically constructed.

(1) *Complete development.*—This will consist of six 10,000 horse-power units supplying machine capacity for the utilization of 12,000 second-feet at a 37-foot head with turbines considered at eight-tenth gate opening and 85 per cent efficiency. Under these conditions the installation will provide a spare unit for emergencies. The output at the switchboard at 75 per cent efficiency on a 24-hour basis is 37,900 horse-power.

*Sluiceway section of dam.*—The sluiceways of the dam are, for convenience of manipulation, located on the arc section adjacent to the power station. The sluices are eighteen in number, 20 feet clear between piers, with sills at elevation 855 (plate 59). A motor-driven winch for handling the stoplogs is included in the estimates. The underside of the sluiceway deck has been placed at elevation 875, allowing 5 feet clear above the regulated pond level. Rock has been assumed at elevation 820 and 825 throughout the length of the sluiceway section.

*Spillway section of the dam.*—The spillway section of the dam connecting the sluiceway section with the left abutment is 700 feet in length with crest at elevation 870. This will provide for such automatic regulation over and above the sluiceway discharge as is necessary to care for sudden rises in the river. The discharge over the spillway will find its way unobstructedly into the river below. Rock has been assumed at elevation 815 and 820 beneath this section.

A fish ladder and log slide are located adjacent to the left abutment. Suitable provision can be made for booming logs to this point of the dam.

#### DISCHARGE CAPACITY.

The layout submitted will discharge 81,000 second-feet through the ice and sluiceway sections at regulated pond level. The power station itself is designed to utilize 12,000 second-feet at normal load, and although this should

not be considered as a permanent source of discharge it forms an additional factor of safety which may be available in an emergency. The Pinawa channel is being considered as drawing an average of 8,000 second-feet from the main river although, in times of high water in the past, this has been increased to above 11,000 second-feet. From the above, the Lower Seven Sisters plant can accommodate a flood of 104,000 second-feet without exceeding the proposed regulated level. This provides for a more extreme flood than the highest recorded water marks along the shore would indicate as having occurred in the past.

Although the above provides for ample discharging capacity, it would not be wise to depend wholly on mechanical or manual operation to care for the fluctuations of the river flow. In order that sudden rises in the stage of the river may be automatically cared for, a 700-foot spillway with crest at elevation 870 is provided. Three feet over this crest, which all the headworks of the plant more than provide for, will discharge 12,000 second-feet. The total discharging capacity at this latter elevation, with all sluices open and the power station in full operation, is 130,000 second-feet, in addition to which there is the discharge down the Pinawa channel.

#### UNWATERING.

As at the other proposed plants along the river, alternative schemes of unwatering may be adopted in the construction of this plant, the selection of which will depend largely upon the general conditions which arise and which must be met when actual construction operations are commenced. Sufficient cofferdam yardage, together with ample provision for pumping, has been allowed in the estimates for this purpose and no special difficulties are anticipated.

#### NAVIGATION.

The winding course and swift current in the Pinawa channel in its present state wholly prevents continuous navigation. That being the case, provision is being made in the Seven Sisters reach for the future inclusion of lockage facilities.

At the Lower Seven Sisters site, future lockage facilities can if necessary be installed on the right bank below the power-house (plate 57). A sailing bank built up from the material excavated from the approach to the lock will protect the entrance from the effects of any draw towards the power station. The lock depicted is 300 feet by 40 feet, with 15 feet of water on the sills.

This lock with approaches can be constructed without in any way interfering with the operation of the power plant, nor will the provision for it incur any extra expenditure in the present construction of the plant. On the other hand, the present construction of the power installation will not place any obstacles in the way of the future construction or operation of the lock. No portion of the cost of the lock or approaches is included in the estimates for the power development.

ESTIMATES OF COST.

The following estimate of cost covers only the cost of a complete installation capable of developing 12,000 second-feet. An item for 7 miles of construction railway to connect the left bank of the river with the Canadian Pacific Railway Lac du Bonnet branch is included. A 10-mile spur line from the right bank adjacent to the power station would connect with the Winnipeg municipal tramway.

Ten per cent has been allowed in the estimates for contingencies, 5 per cent on this total for engineering and inspection, and 5½ per cent on the whole for one year for interest during construction.

The annual operation costs include capital charges and represent the cost of operation at the power station. They do not include transforming and transmission.

(1) Complete development.—(Six 10,000 horse-power units.)

(1) Capital Cost of Installation.

Dam and equipment.....	\$ 668,000
Ice sluices.....	86,000
Power station and equipment.....	679,000
Hydraulic installation.....	540,000
Electrical installation.....	720,000
Permanent quarters.....	20,000
Railroad.....	84,000
Contingencies, 10 per cent.....	280,000
Engineering and inspection, 5 per cent.....	154,000
Interest during construction, 5½ per cent.....	178,000
<b>Total cost.....</b>	<b>\$3,409,000</b>
Two day-four hour power available at 75 per cent over-all efficiency, 37,900 horse-power.	
Capital cost per 24-hour horse-power.....	\$89.95
Capital cost per installed horse-power.....	56.82

(2) Annual Cost of Operation.

Interest, sinking fund, and depreciation charges—	
Interest, 5½ per cent on \$3,409,000.....	\$ 187,000
Sinking fund, 4 per cent (40-year bonds).....	36,000
Depreciation—	
1 per cent on permanent works.....	\$ 13,000
4 per cent on machinery, etc.....	55,000
	<u>68,000</u>
Operation charges—	
Staff.....	\$ 21,000
Supplies.....	16,000
	<u>37,000</u>
<b>Total annual charge.....</b>	<b>\$ 328,000</b>
Annual cost per horse-power year, 24-hour power.....	\$8.65
Annual cost per horse-power year, machinery installed.....	5.47
Annual cost per kilowatt hour.....	0.132 cent.
Annual cost per kilowatt hour on basis of 50 per cent load factor.....	0.264 cent.

Upper Seven Sisters Site.

The upper portion of the Seven Sisters reach of the Winnipeg river has been concentrated at the second drop about 4½ miles above the lower site and about 55 miles from Winnipeg. It has been named the Upper Seven Sisters site. The general conditions governing the development here are the same as at the lower site, the same amount of water being available. The Winnipeg Electric Railway Company's diversion weirs and the tailwater of the Slave falls site about 21 miles upstream are directly affected by the headwaters of this site.

## SPECIAL CONSIDERATIONS AT UPPER SEVEN SISTERS SITE.

As a result of the division of the river into two channels, *it will not be profitable to undertake the development of this reach until such time as the flow of the river has been regulated.* For the purpose of the present discussion it is assumed, as at the Lower site, that 8,000 second-feet are diverted to the Electric Railway Company's plant, leaving a balance of only 4,000 second-feet for the Seven Sisters reach under the present run-off conditions, and 12,000 second-feet available at such time as the river is regulated to 20,000 second-feet minimum flow. On this account, the estimates have been made only for a final development capable of utilizing 12,000 second-feet.

## REACH OF THE RIVER DEVELOPED.

The reach of the river to be developed extends from the second drop of the Seven Sisters falls to the weirs of the Winnipeg Electric Railway Company at the head of the Pinawa channel.

*Second drop of the Seven Sisters falls.*—The layout discussed herein is located along the crest of the Second drop of the Seven Sisters falls. This drop totals some 9 feet under normal conditions. Bed rock is exposed on both banks and above the water surface towards the centre of the stream.

*First drop of Seven Sisters falls.*—The total fall at the first drop of the Seven Sisters falls is 9 feet under normal flow conditions and is, to a large extent, concentrated. The usual granite formation is in evidence on both banks and in the river bed.

*Winnipeg Electric Railway Company's Weirs.*—The necessary diversion of water down the Pinawa channel to the Winnipeg Electric Railway Company's plant is secured by three weirs. (Plate 30.) The main weir consists of 1,379 feet of concrete-capped rock-fill across the main river channel, with crest at elevation 105.5, company's datum, or 897.44 Water Power Survey datum, connected with the river banks on either side by concrete spillways, crest at 897.44. This brings the total length of the main weir up to 1,652 feet. Two secondary weirs, one of timber, length 120 feet, crest at 896.94, the other of concrete, length 535 feet, crest 895.94, complete the system. These weirs operate as free spillways, and the water level above varies with the stage of the river. After the construction of the Upper Seven Sisters plant, the weirs will be submerged.


## HEAD- AND TAILWATER ELEVATION.

The headwater elevation of this site must be considered in the light of several important features which are here briefly outlined.

The discharge down the Pinawa channel varies with the elevation of the water above the weirs, but can be completely shut off by the control dam now in position across the head of the channel. The proposed development on the Pinawa channel, discussed hereunder, will call for the maintenance of the intake water level at a point above elevation 900. The headwater elevation of this reach will also directly affect the tailwater of the proposed Slave falls development.



Seven Sisters Falls, Second Fall.



Seven Sisters Falls, Second Fall.



Seven Sisters Falls, First Fall.



Seven Sisters Falls, First Fall.

At the present time the data on hand covering the various vital features outlined above is not sufficiently complete to permit a detailed analysis of the effects and results of the diverse conditions which must be considered. For the present the headwater elevation of the Upper Seven Sisters has been assumed at elevation 899. This forms a fair basis upon which the site can be investigated, and will result in a somewhat higher elevation above the weirs. The field data necessary to accurately determine the effect of various headwater levels on the conflicting interests affected, are being secured, and will be available before this reach is developed.

The tailwater is controlled by the regulated pond level of the Lower Seven Sisters reach, giving a normal head of 27 feet.

#### FLOODING.

The banks of the river in the vicinity of the site rise abruptly to elevation 898. At this elevation the ground surface becomes approximately level, rising slowly as one goes upstream until, at a point about  $2\frac{1}{4}$  miles up the river, contour 905 is reached, and about 1 mile farther contour 910 is found on both banks of the river.

Regulated level 899, without embankment, will result in a certain amount of flooding immediately above the plant. At the same time, the possibility of excessive floods or abnormal conditions raising the water above regulated level must also be guarded against. For this reason, the estimates cover the cost of an embankment with top at elevation 906 extending from the plant upstream to the high ground on both banks of the river. The material necessary for the construction of these embankments can be excavated in such a manner as to form a ditch for the drainage of the low land to the rear. At regulated water level the embankment will only have to withstand a three foot head at its heaviest portion. As this levee will follow closely the river bank, little or no flooding will result.

#### PONDAGE.

A pond of 2,600 acres will be created between the dam and the Electric Railway Company's weirs, and an additional 5,870 acres will be indirectly available above the same. The latter pondage also supplies the Winnipeg Electric Railway Company's plant on the Pinawa channel.

The utilization of this pondage for peak loads requires careful oversight. As pointed out above, the headwater level will at times be subject to a variety of possibly conflicting influences.

*It is essential, therefore, that the control of the headwaters of the Upper Seven Sisters be kept in the hands of some independent body, such as the Dominion Government, in order that all interests affected may be fully protected and that the river may be regulated for the benefit of all concerned.*

#### REMOVAL OF THE WEIRS.

After the Upper Seven Sisters power plant is placed in operation, the diversion weirs will no longer be necessary. Their removal in whole or in part

will then be beneficial to the power situation, as it will place the headwater of the site in direct control of the pond level above the Pinawa channel, and will prevent the loss of head which must be anticipated during the high stages of the river with the weirs in place as at present. The pondage area above the weirs will also be directly available and readily controllable for use, both at the Upper Seven Sisters and the Upper Pinawa site.

The removal of the entire weir would be expensive, but a portion sufficient to counteract the anticipated submerged action in times of normal water and to reduce it in times of flood, could be removed at comparatively small expense.

It would be a decided advantage to the Winnipeg Electric Railway Company to have the present non-regulating weir, replaced by a regulated and permanent concrete dam. Such a structure would control at all stages the water level above the present intake to the Pinawa channel and would do away with the expensive repairs and renewals which will probably be required in the future on the present weir. It will also make feasible the development of an additional power site on the upper portion of the Pinawa channel.

#### ICE CONDITIONS.

The Upper Seven Sisters power station draws its water direct from a pond varying from 500 feet to a mile in width and extending upstream to the diversion weirs of the Street Railway plant, covering a surface area of some 2,600 acres, and drowning out all intervening falls and rapids. All disturbed points in this stretch of the river which under natural conditions have a tendency to form frazil ice are thus completely submerged and the whole pond will act in winter as an ice covered settling basin for such frazil ice as may be formed.

The sluices at either end of the power-house will serve to draw off all floating ice and drift, while the sloping concrete curtain with bottom elevation 3 feet below regulated pond level, extending across the face of the entrance piers to the power-house, will prevent the drawing of such material against the racks.

#### FOUNDATION CONDITIONS.

The whole site is underlaid with granite formation, exposed on the surface on both banks of the river and projecting above the water in the form of islands at different points along the line of the dam. The general formation indicates the presence of this granite, probably without any overlying material, in all sections of the river bed covered by the line of the dam and power station.

#### LAYOUT.

In the layout (plate 61) which has been considered herein, the power station is placed adjacent to the right bank and forms, with the iceways and sluiceways, a straight line running approximately north and south. At the south end of the sluices, the line of the dam turns to the southeast through an angle of 40 degrees in order to follow the high rock, and forms the spillway section. Long earth embankments parallel both banks of the river up stream from the site, until high ground is reached.

*Spillway section of dam.*—The spillway section of the dam has been extended out over the river bank giving a total length of 600 feet with crest at elevation 899 (plate 63). Rock has been assumed at elevation 885 throughout this extension, such assumption being fully warranted by the outcrop along the shore. The spillway could be further lengthened at comparatively small cost should it be considered desirable. The discharge will find its way into the river below without obstruction.

A fish ladder and log slide are located at the junction between the spillway and the sluiceways, and are accessible by means of the platform over the latter. Suitable provision can be made for booming logs to this point of the dam.




Model of Proposed Upper Seven Sisters Plant.

*Sluiceway section of dam.*—The sluiceway section of the dam consists of seventeen 20-foot sluices with sills at elevation 884, and is located adjacent to the power station for convenience in regulation. A motor-driven winch for handling the stoplogs is included in the estimates. The under-side of the sluiceway deck has been placed at elevation 904.5, allowing 5.5 feet clear above the regulated pond level. Rock has been assumed at elevation 968 to 975 throughout the length of the sluiceway section.

*Power station.*—The power station (plate 62) is designed to contain eight single-runner vertical turbines of 6,000 horse-power capacity at full gate. The section has only been developed in sufficient detail to arrive at the size of the water passages necessary to carry the water to and from the turbines at permissible velocity. The electrical and regulating equipment have been assumed for estimating purposes only.


**DOMINION WATER POWER BRANCH**  
**J. B. CHALLIES, Superintendent**  
**POWER-PERCENTAGE OF TIME CURVES**  
**UPPER SEVEN SISTERS**  
**POWER SITE**

on the  
**WINNIPEG RIVER.**  
**HEAD 26 FEET. POWER AT 75% EFFICIENCY**  
**PERIOD 1907-1914 INCLUSIVE**  
 To accompany a report on POWER AND STORAGE  
 INVESTIGATIONS by J. T. JOHNSTON, B.A.Sc.  
 March 6th, 1915



60-15





Sec 31 T 45 R 10 E 12 E P.M.

Road Allowance

Sec 36 T 45 R 10 E 12 E P.M.

WINNIPEG

WL 876.53  
June 3, 1918

Normal Regulated Water Level 866

WL 876.51  
June 3, 1918

Proposed Dam Line



Department of the Interior, Canada  
HONOURABLE W. J. ROCHE MINISTER  
CORNELIUS DEPUTY MINISTER  
Water Power Branch  
J. B. CHALLIS SUPERINTENDENT

**WINNIPEG RIVER POWER SURVEY  
PROPOSED SCHEME OF DEVELOPMENT  
AT  
UPPER SEVEN SISTERS FALLS**

*J. J. Schmitt*  
Assistant Engineer  
Water Power Branch

Approved by *J. J. Schmitt*  
Consulting Engineer  
Water Power Branch

Scale of Feet  
100 200 300 400 500

Based on field surveys made under direction of  
D. L. McLean, Chief Eng. Man. Hyd. & Power Surveys  
Page 94

WL 866.74  
June 8, 1918




WL 876.1  
June 2, 1976.


R  
I  
V  
E  
R

Road Allowance

Normal Regulated Tail Water Level 870









REAR ELEVATION

WINNEBAGO RIVER POWER PLANT  
PROPOSED SCHEME OF DEVELOPMENT  
AT  
UPPER SEVEN SISTERS FALLS

Scale: 1/4" = 1'-0"  
Date: 1911  
Author: [illegible]  
Engineer: [illegible]




SECTION BB



PLAN ON LINE A A





DESIGNED BY  
 W. S. BROWN  
 1912

UPPER SEVEN SISTERS FALLS



The racks and headworks have been housed in. A sloping concrete curtain around the face of the entrance piers forms a protection against floating ice and drift. The floor of the headworks house is at elevation 903, 4 feet above regulated level, while the generator floor is at elevation 887. The seal of the draught tube has been placed at elevation 861, and the discharge from the plant takes place directly down the river.

(1) *Complete development.*—This consists of eight 6,000 horse-power units, supplying machine capacity for the utilization of 12,000 second-feet at a 29-foot head with turbines considered at eight-tenths gate opening and 85 per cent efficiency. Under these conditions, this installation will provide a spare unit for emergencies. The output at the switchboard at 75 per cent efficiency on a 24-hour basis is 29,600 horse-power.

*Ice sluices and roadway.*—The power station is connected with the right bank by means of the ice sluiceway deck from the headworks house, and by means of a steel bridge from the generator floor. The three 20-foot ice sluices, with sills at elevation 884, will assist in clearing the forebay of floating ice and drift, and the discharge through the same will be carried under the bridge to the river below. The bridge forms a continuation of the roadway whereby direct access may be had to the generator floor.

*Embankments.* The estimates include provision for the construction of two embankments, one on either side of the river. These have been referred to in the section on flooding.

#### DISCHARGE CAPACITY.

The layout submitted will discharge 77,000 second-feet through the ice- and sluiceway sections at regulated level. The power station itself is designed to utilize 12,000 second-feet at normal load, and although this should not be considered as a permanent source of discharge, it forms, nevertheless, an additional source of safety which may be available in an emergency. The Pinawa channel is being considered in this report as drawing an average of 8,000 second-feet from the main river, although in times of high water this has been increased to about 11,000 second-feet. The Upper Seven Sisters layout can accommodate a flood of 100,000 second-feet in the river, without exceeding the proposed regulated level.

Although the above provides for ample discharging capacity, it is not advisable to depend wholly on mechanical or manual operation to care for the fluctuation of the river flow. A 600-foot spillway with crest at elevation 899 is provided in order that sudden rises in the stage of the river may be automatically cared for at such times as, for any reason, the sluice control may be neglected. Three feet over this crest, which all the headworks of the plant more than provide for, will discharge 10,000 second-feet. The total discharging capacity at this elevation, with all sluices open and the power station in full operation, is 126,000 second-feet in addition to the discharge down the Pinawa channel.

## UNWATERING.

As at other plants along the river, alternative schemes of unwatering may be adopted in the construction of this plant, the selection of which will depend largely upon the general conditions which arise and which must be met when actual construction operations are commenced. Sufficient cofferdam yardage, together with ample provision for pumping, has been allowed in the estimates for this purpose and no special difficulties are anticipated.

## NAVIGATION.

The headwaters of this plant will be regulated to the highest permissible limit, keeping in view the effect of the same on the various interests involved. So long as the Winnipeg Electric Railway Company's weirs remain in place, it will be impossible to completely drown out the drop now taking place over the same except perhaps in times of extreme low water. The drop will vary with the stage of the river and with the consequent regulation necessary to protect the tailwater of the Slave falls plant and the discharge down the Pinawa channel. To secure navigation past this point will possibly necessitate the construction of a low-lift lock. On the other hand, the construction of the Upper Seven Sisters plant will render the diversion weirs of the Street Railway Company unnecessary, and the removal of a sufficient section to permit the passage of traffic will be less expensive than lock construction.

At the power site, lockage facilities can be provided on the north bank of the river at any time after the plant is constructed. The lock depicted on the accompanying plan (plate 61) is 300 feet by 40 feet, with 15 feet of water on the sills.

This lock with approaches can be constructed without in any way interfering with the operation of the power plant, nor will the provision for it incur any extra expenditure in the present construction of the plant, while the present construction of the power installation will not place any obstacles in the way of the future construction or operation of the lock. No portion of the cost of the lock or approaches is included in the estimates for the power development.

## ESTIMATES OF COST.

The following estimate of cost covers the capital cost of a complete installation capable of developing a flow of 12,000 second-feet. An item for 12 miles of railway is included. This spur line may be run from the city of Winnipeg municipal tramway on the right bank, or from the main line of the Canadian Pacific railway to the south of the river, the distance being about the same in each case.

Ten per cent has been allowed in the estimates for contingencies, 5 per cent on this total for engineering and inspection, and 5½ per cent on the whole for one year for interest during construction.

The annual operation costs include capital charges and represent the cost of operation at the power station. They do not include transforming and transmission.

(1) Complete development.—(Eight 6,000 horse-power units.)

(1) Capital Cost of Installation.

Dam and equipment	\$ 361,000	
Ice sluices	66,000	
Power station and equipment	585,000	
Hydraulic installation	432,000	
Electrical installation	624,000	
Permanent quarters	20,000	
Railroad	114,000	
Contingencies, 10 per cent	224,000	
Engineering and inspection, 5 per cent	123,000	
Interest during construction, 5½ per cent	112,000	
Total cost		\$2,724,000

Twenty-four hour power available at 75 per cent over-all efficiency, 29,600 horse-power.

Capital cost per 24 hour horse-power	92.04
Capital cost per installed horse-power	56.75

(2) Annual Cost of Operation.

Interest, sinking fund, and depreciation charges—		
Interest, 5½ per cent on \$2,724,000		\$ 150,000
Sinking fund, 4 per cent (40 year bonds)		29,000
Depreciation—		
1 per cent permanent works	\$ 10,000	
4 per cent machinery, etc.	46,000	
		56,000
Operation charges—		
Stall	\$ 20,000	
Supplies	14,000	
		34,000
Total annual charge		\$ 268,000
Annual cost per horse-power year, 24-hour power		\$9.05
Annual cost per horse-power year, machinery installed		5.58
Annual cost per kilowatt hour		0.148 cent
Annual cost per kilowatt hour on basis of 50 per cent load factor		0.276 cent

Upper Pinawa Site.

The contemplated power scheme for the river will, through the replacement of the present non-regulating diversion weirs of the Winnipeg Electric Railway Company by a permanent and controlled dam at the Upper Seven Sisters site, render an additional power site available on the Pinawa channel (plate 64). This new site is located at what is known as the First Rock cut, about 3 miles above the existing power plant. The rock cut was excavated in the widening and deepening operations along the upper portion of the Pinawa channel in connection with the power station below. The physical features of the location lend themselves admirably to the construction of a very attractive power project.

SPECIAL CONSIDERATIONS AT UPPER PINAWA SITE.

The preceding discussion of the power possibilities of the Upper and Lower Seven Sisters sites, has considered an average discharge of 8,000 cubic feet per second down the Pinawa channel to the power station of the Winnipeg Electric Railway Company. This average flow is available also at the Upper Pinawa site under present discharge conditions on the river, and is not dependent on the further control of the river basin run-off.

In consequence of the necessity of maintaining the intake headwater above elevation 900, the development of the new site is scarcely feasible prior to the construction of the Upper Seven Sisters dam, or at least until the present diversion weirs have been either replaced or reconstructed.



First Rock Cut on Pinaua Channel, Site of Proposed Plant.

REACH OF THE RIVER DEVELOPED.

The reach of the Pinawa channel developed by this concentration extends from the first rock cut to the headwaters at the channel intake. The water level at the rock cut will be raised some 18 feet, and the entire lower section of the reach flooded. The control dam of the Electric Railway Company, about  $2\frac{1}{4}$  miles above the site, and elsewhere described, will be flooded to deck level. Inexpensive alterations will permit its continued use as a complete control over the Pinawa flow.



Pinawa Channel, First Rock Cut.

HEAD- AND TAILWATER ELEVATIONS.

The tailwater elevation is controlled by the pond level of the plant below, the free spillway crest of which is at elevation 879.4. The normal tailwater elevation is 881.5.

The headwater elevation is dependent on the elevation to be maintained above the channel intake, and also to some extent on the volume of water taken down the channel.

The crest elevation considered in connection with the Upper Seven Sisters concentration is 899. This elevation is provisional and subject to slight revision upon the completion of river stage records now being secured. It will involve a somewhat higher water level above the diversion weirs, of extent dependent on the river discharge. No difficulty should be experienced in slightly raising this regulated level, should the same be desirable in the interests of the Upper Pinawa site.

The construction of the Upper Seven Sisters dam will convert Loon river into a feeder to the Pinawa, and the increased channel cross-section resulting

will practically do away with the hydraulic gradient from the present intake to the control dam. From the control dam to the proposed power site, a discharge of 8,000 cubic feet per second can be secured with a grade drop of about 1 foot.

The crest level of the Upper Pinawa site has been provisionally placed at 899.5, giving a head of 18 feet. This can be considered as an average head available for development.

#### FLOODING.

The bank contours immediately above the site call for the construction of retaining embankments.

These will prevent any extensive flooding directly above the plant, while above the channel intake, flooding conditions will be practically the same as those now resulting from the diversion weirs. About 425 acres will be flooded between the site and the control dam.

#### PONDAGE.

The pondage above the Upper Seven Sisters site, inclusive of that above the diversion dam, is 8,470 acres. To this will be added 780 acres between the control dam and the proposed Upper Pinawa site, making a total of 9,250 acres. This pondage under a proper control can be made directly available to the proposed plants at the Upper Seven Sisters and the Upper Pinawa sites, and to the existing power station of the Winnipeg Electric Railway Company. Careful regulation is essential here, and can only be properly exercised through impartial central control.

#### ICE CONDITIONS.

The ice conditions which are encountered along this channel are elsewhere described. The development of the Upper Pinawa site will greatly better the present conditions during the winter season, although it is questionable whether ice troubles will be entirely done away with. Long stretches of disturbed water will be entirely flooded out, while the current in the balance of the reach will be quieted and reduced. Winter operating conditions for the Winnipeg Electric Railway Company's plant will be greatly improved.

#### FOUNDATION CONDITIONS.

The entire site of the power station and the dam shows exposed bedrock, providing foundation conditions which could not be bettered. Exploration is required along the route of the embankments but in view of the low heads to be withstood, no difficulty is anticipated in connection with their construction.

#### LAYOUT.

In the layout (plate 65) which has been considered herein, the power station has been placed at the foot of the rock cut. The station is connected with the high ground on the right by a combined sluice and free spillway concrete dam.

*Power station.*—The power station (plate 66) is designed to contain four single-runner vertical turbines of 4,500 horse-power capacity at full gate. The section has been developed for estimating purposes only. The power house floor is placed at elevation 893.5, the centre line of the turbines at 882.0, and the water seal of the draught tube at 874. The discharge takes place directly downstream. The station as a whole has been standardized along the lines of the other stations estimated on in this report. The output at 75 per cent efficiency on a 24-hour basis is 12,300 horse-power.

*Dam.*—Four 20-foot sluiceways with sills at elevation 884.5 have been placed to the east of and adjacent to the power station. The under side of the sluiceway deck is placed at elevation 904.5, allowing 5 feet free discharge above regulated level. The free spillway, 750 feet in length, spans the low-lying shore on the right bank. Bedrock is exposed on the surface throughout the length covered by the dam.



Upper Pinawa Power Site, Line of Proposed Dam.

*Embankments.*—Embankments are required on both river banks. They have been designed with a 15-foot top at elevation 906, and with 2 : 1 slopes. Detail exploration is required as to the most profitable route to be followed, but little difficulty should be encountered in finding a favourable location. About 8,000 feet of embankment is required, of which only about 1,000 feet will be called upon to withstand a greater head than 5 feet, while about 4,000 feet will merely act as a protection against flooding above regulated level. The greatest head to be withstood at regulated level is about 8 feet.

#### DISCHARGE CAPACITY.

At crest level the sluices will have a discharging capacity of 15,000 cubic feet per second, a much greater flow than has as yet been recorded down the

Pinawa channel. Seven hundred and fifty feet of free spillway will provide for automatic regulation. The headworks will withstand a five-foot rise above crest level.

#### UNWATERING.

The physical characteristics of the site simplify the unwatering problems. The estimates hereunder include sufficient cofferdam yardage and pumping allowance to cover the anticipated cost.

#### NAVIGATION.

Navigation interests have been provided for on the main river channel, *i.e.*, along the Seven Sisters reach. In both the Upper and Lower Seven Sisters layouts, lockage facilities can be included at any time in the future. In consequence of this there is no necessity for lockage provision along the Pinawa channel, and none is made at the site under discussion.

#### ESTIMATES OF COST.

The estimate of cost hereunder follows the standardized estimates of the other sites investigated. Eight miles of railway are included, covering a spur from the city tramway line.


Ten per cent has been allowed for contingencies, 5 per cent of this total for engineering and inspection, and  $5\frac{1}{2}$  per cent on the whole for one year for interest during construction.

The annual operation costs include capital charges and represent the cost of operation at the power station. They do not include transforming and transmission.

#### *Complete Development—Four 4,500 horse-power units.*

(1) <i>Capital Cost of Installation.</i>	
Dam and equipment.....	\$ 84,000
Ice sluices.....	25,000
Power station and equipment.....	385,000
Hydraulic installation.....	180,000
Electrical installation.....	270,000
Railroad (8 miles).....	96,000
Permanent quarters.....	10,000
Contingencies, 10 per cent.....	105,000
Engineering and inspection, 5 per cent.....	58,000
Interest during construction, $5\frac{1}{2}$ per cent.....	67,000
<b>Total cost.....</b>	<b>\$1,280,000</b>
Twenty-four hour power available at 75 per cent over-all efficiency, 12,300 horse-power.	
Capital cost per 24-hour horse-power.....	\$104.07
Capital cost per installed horse-power.....	71.11
(2) <i>Annual cost of Operation.</i>	
Interest, sinking fund, and depreciation charges--	
Interest $5\frac{1}{2}$ per cent on \$1,280,000.....	\$70,000
Sinking fund, 4 per cent (40 year bonds).....	13,000
Depreciation--	
1 per cent on permanent works.....	\$ 4,000
4 per cent on machinery, etc.....	20,000
	24,000
Operating charges--	
Staff.....	\$ 16,000
Supplies.....	5,000
	21,000
<b>Total annual charge.....</b>	<b>\$ 128,000</b>
<b>Annual cost per horse-power year, 24-hour power.....</b>	<b>\$10.40</b>
<b>Annual cost per horse-power year, machinery installed.....</b>	<b>7.11</b>
<b>Annual cost per kilowatt hour.....</b>	<b>0.159 cent.</b>
<b>Annual cost per kilowatt hour, on basis of 50 per cent load factor.....</b>	<b>0.318 cent.</b>





Department of the Interior, Canada.

HONOURABLE W. J. ROCHE, Minister  
 W. W. CORY, C.M.G., Deputy Minister

Dominion Water Power Branch.

J. B. Chellise, Superintendent

# Winnipeg River Power Survey.

## GENERAL LAYOUT AT HEAD OF PINAWA CHANNEL


SHOWING EXISTING DAMS AND WEIRS  
 OF WINNIPEG ELECTRIC RAILWAY CO.

To accompany a report on POWER AND STORAGE INVESTIGATIONS  
 by J. T. JOHNSTON, B.A.Sc.

Scale of Feet.  
 1000 0 1000 2000 3000 4000 5000

May, 1916.

*J. T. Johnston*  
 Hydro Engineer, W.P.B.  
*J. Beuckler*  
 Consulting Engineer



Paawa chani  
automatic re  
crest level.

The phy  
The estimate  
allowance to

Navigat  
i.e., along the  
layouts, lock  
quence of th  
channel, and

The est  
other sites in  
from the city

Ten per  
engineering a  
during const

The an  
of operation  
transmission

*Comple*

Dam and  
ice sluice  
Power st  
Hyd  
Elec  
Railroad  
Permane  
Continge  
Engineer  
Interest

Twenty-  
Capital  
Capital

Interest,  
Inte  
Sint  
Deprecit  
1 pt  
4 pt

Operativ  
Stat  
Sup

Annual  
Annual  
Annual  
Annual





Sec 17, T14, R9, 12 E.P.M.

Sec 16, T14, R9, 12 E.P.M.



Department of the Interior Canada  
Geographical Names Branch  
Water Power Branch  
J. B. Charbonneau, Superintendent

**WINNIPEG RIVER POWER SURVEY**  
**PROPOSED SCHEME OF DEVELOPMENT**  
- AT -  
**UPPER PINAWA.**

Scale of Feet  
0 100 200 300 400 500

*J. B. Charbonneau*  
Superintendent  
*J. B. Charbonneau*  
Superintendent

Pinawa cha  
automatic  
crest level.

The pl  
The estima  
allowance t

Navig:  
*i.e.*, along t  
layouts, lo  
quence of  
channel, a

The e  
other sites  
from the c

Ten p  
engineerin  
during cor

The a  
of operati  
transmissi

*Comp*

Dam  
Ice sl  
Pow

Rail  
Perm  
Cont  
Engi  
Inter

Two


Capi  
Capi

Inte

Dep

Ope

Ann  
Ann  
Ann  
Ann



SECTION B.B.

Department of the Interior, Canada  
 MINISTRE DES TERRES ET DES MINES  
 WATER POWER BRANCH  
 1100 - 11th Street, Ottawa, Ontario


WINNIPEG RIVER POWER SURVEY.  
 PROPOSED SCHEME OF DEVELOPMENT AT  
 UPPER PINAWA.

NOTE: COMPILED FOR ESTIMATING PURPOSES ONLY


Scale of Feet  
 0 10 20 30 40 50

*Johnston*  
 Chief Engineer  
 Department of Water Power Branch

*McIntosh*  
 Chief Engineer  
 Department of Water Power Branch



PLAN ON LINE A.A.



### Slave Falls Site.

The Slave falls site is located about 16 miles above the entrance to the Pinawa channel, and 74 miles from Winnipeg. The flow of the river is here confined to one channel, making the whole available for development. The contours of the river bank would permit holding the headwater level to 950, which would render available a head of some 50 feet. A development of this head would have been very attractive, but, due to the location of the municipal plant of the city of Winnipeg immediately above, cannot be considered.

#### SPECIAL CONSIDERATIONS AT SLAVE FALLS SITE.

At the Slave falls due consideration must be given to the effect of the proposed headwater on the present tailwater of the city of Winnipeg's municipal plant at Point du Bois. At the same time, the tailwater of the Slave falls site is directly affected by the Winnipeg Electric Railway Company's diversion weirs across the main river at the entrance to the Pinawa channel and by the contemplated layout developing the Upper Seven Sisters falls.



Water Marks on Rock below Eight Foot Fall.

#### REACH OF THE RIVER DEVELOPED.

The reach of river developed extends from Slave falls to the tailwater of the municipal plant of the city of Winnipeg, and includes the drop at Slave and Eight Foot falls. It is proposed to combine the two at Slave falls.

*Eight Foot Falls and its best disposal.*—As indicated by the name, these falls have a drop of about eight feet. The drop is concentrated and takes place over a well-defined ridge of rock. The banks are high on either side.

The engineers of the city of Winnipeg have endeavoured to lessen ice troubles in connection with the Point du Bois plant by blasting away a portion of this ridge.

The water seal of the draught tubes of the power station is at elevation 925.1, while the normal water level below Eight Foot falls is about 921. The design of the power-house therefore places a distinct limit to blasting operations at these falls. Undoubtedly the high backwater effects which occur in the tailwater during flood period (high-water marks on the rocks hereabouts would indicate an elevation of about 938 or 939 at some time in the past) can, to a certain extent, be remedied by further blasting at the falls. However, unless means are provided for maintaining the tailwater during seasons of low water, at a higher elevation than the water seal above referred to, all such blasting operations must be limited. Such a measure of control will be available in the contemplated dam at the head of Slave falls. The construction of this dam will permit of considerable improvement in the city tailwater elevation during high water, and at the same time maintain the necessary level for the water seal during low water. It is doubtful, whether the advantage to be gained would warrant the expenditure necessary, since, during high-water conditions, the headwaters of the city plant rise and tend to compensate for the rise in the tailwater. Again, the extra water which is available for power purposes at such periods will provide a cheaper means of maintaining the power output than expensive blasting operations at the Eight Foot falls.

The results of the power survey have confirmed the opinion expressed on the ground by Messrs. Freeman and McRae, during the preliminary reconnaissance trip, i.e., that the natural and economic point at which to make use of the Eight Foot fall is at the Slave falls, about  $4\frac{1}{2}$  miles below.

*Slave falls.*—At Slave falls a fairly abrupt drop of about 18 feet occurs. The left bank is abrupt and high, while on the right bank below the tailwater is a low fairly level strip of shore roughly sloping from elevation 915 down to the water's edge, and maintaining this slope, so far as present soundings would indicate, for some distance beyond the shore line. Landward from this low section, the bank rises abruptly to elevation 950. The whole forms a most suitable location for the contemplated power station and head-race.

#### HEAD- AND TAILWATER ELEVATIONS.

A detailed discussion of the effect of the headwater elevation of the Slave falls concentration on the city of Winnipeg plant, and of the effect of the Winnipeg Electric Railway Company's diversion weirs, and of the proposed Upper Seven Sisters development, on the tailwater elevation of the Slave falls plant, cannot be undertaken until the complete gauge records are available. For the present the head- and tailwater elevations are assumed at 928 and 902, respectively. The tailwater will vary in elevation with the stage of the river, due to the free spillway weirs below, and in order to maintain a mean head of 26 feet the headwater elevation must vary in proportion. This can be suitably arranged for, since the headwater of the city plant discharges over a free spillway dam, and hence also varies with the river stage. As a result, the tailwater which will

be directly dependent on the headwater at Slave falls can also be permitted to vary in elevation in keeping with the headwater. Suitable regulation can be maintained at the proposed Slave falls development to ensure the required heads at both plants. This regulation must however be supervised by some independent authority.

#### FLOODING.

The flooding involved by raising the water level to 928 and allowing for a further rise of 5 feet if necessary during high water, will amount to about 100 acres. The banks are abrupt, and the land flooded consists practically entirely of a narrow strip along the immediate shore line of the river.

#### PONDAGE.

Holding the water to elevation 928 will create about 1,300 acres of pondage.

#### ICE CONDITIONS.

In considering a suitable layout for a hydro-electric development at this site, the question of ice conditions during the winter season was given special consideration, in view of the fact that the proposed layout involves a head-race. In the design decided upon (plate 68) it is anticipated that there will be no ice troubles experienced in the operation of the plant. The head-race has been laid out with easy curves, and has been excavated, where necessary, to a practically level bottom. It is designed to carry 12,000 second-feet to the initial development, and 20,000 second-feet to the final development at a rate of about 2.7 feet per second. This will provide an undisturbed approach, leading from a deep pond which extends upstream to the tailwater of the city plant, and which will be largely ice covered during the winter season. The principal conditions tending to the formation of frazil and anchor ice are thus eliminated and the water will be drawn into the plant with practically no disturbance. The discharge from the draught tubes takes place into the open river, which, although somewhat disturbed at this point, due to the discharge over the dam, can be readily protected if necessary by a rock-fill crib.

Floating ice and drift are efficiently cared for in the proposed layout by a log boom suitably placed at the entrance to the head-race, and by the sloping concrete curtain which protects the entrance to the racks in the power station. The three ice sluices at the south end of the power-house will provide both the current and the means of exit, by which all floating material passing the boom may be discharged automatically into the lower river.

#### FOUNDATION CONDITIONS.

Solid granite shows on the surface over practically the entire site, forming an unexcelled foundation for all structures. In carrying the dam across the river along the crest of the falls, it has been necessary to make assumptions as to the elevation of the submerged rock. The means at hand during the power survey did not permit detailed soundings being made along the crest of the falls

for the purpose of determining the exact elevation and location of the highest rock. This was considered to be a matter which could be better determined by whatever interests might develop the power. Sufficient evidence is to hand to show that rock foundation is available, and the assumptions made as to the elevation of the same, after a careful study of the conditions and inspection on the ground, are considered to be sufficiently conservative for estimating purposes.

#### LAYOUT.

The contours in the vicinity of Slave falls lend themselves admirably to the layout adopted (plate 68). The abrupt rise in the rock on the right bank occurs just sufficiently far back from the water's edge to carry the waters of the head-race, at permissible rates of flow, without having to resort to excessive exca-



Model of Proposed Slave Falls Plant.

vation. This natural advantage is not continued to the entrance to the head-race, where a shoulder of rock juts out to the river bank.

In the general scheme of layout, contour 938 on the left bank, is connected with the power station by means of a solid concrete stoplog-controlled dam located along the crest of the falls, and curving in the arc of a circle through 90 degrees to a direction parallel to the river flow. The power station is connected with the right bank by means of a roadway over three ice sluices and a short embankment. In all structures only the most permanent class of construction has been considered.

*Fish ladder and log slide.*—A fish ladder and log slide are provided adjacent to the abutment on the left bank, hence preventing all interference with the operation of the power station from logging operations on the river.

*Sluiceway section of dam.*—Fifteen 20-foot sluiceways with sills at elevation 913 are provided for the control of the river in conjunction with five sluices adjacent to the power-house. The bridge deck over the dam (plate 70) is at

elevation 938, with the underside at elevation 936.5. All headworks of the dam and power-house will stand the additional rise in headwaters. Regulation is secured by means of stoplogs, double gains being provided to simplify manipulation. A power-driven winch will handle the stoplogs. As the discharging length of the dam is limited, three foot piers have been considered. These will require heavy reinforcing.

For estimating purposes the foundation rock for this section has been considered at elevation 905 for a distance of 250 feet from the left bank dropping to elevation 890 below the crest of the falls.

*Spillway section of the dam.*—The spillway section has been designed with crest elevation 925, with provision for flashboards to raise the water to elevation 928 or regulated level. The crest has been placed at elevation 925, not only to provide additional discharging capacity during times of flood, but also to assist in forcing the discharge from the dam towards the left bank, and away from the tail-race. The fact that the main stoplog sluices are not adjacent to the power house, as well as the requirements of flashboard operation, necessitates a bridge over this section. A 10-foot platform is provided, supported by three-foot piers spaced 23 feet centre to centre.

*Ice sluiceways above power station.*—Two 20-foot ice sluices with sills at elevation 913 are provided immediately above the power station. These sluices serve the purpose of an additional safeguard against floating ice and drift, and assist in forcing the current away from the tail-race. An ice fender across the head-race, feeding into these sluices, can be installed if necessary.

*Power station.*—The power station (plate 69) has been designed for single-runner vertical turbines of 5,000 horse-power capacity at full gate. The section has only been developed in sufficient detail to arrive at the size of the water passages to carry the water to and from the turbines at permissible velocities. The electrical and regulating equipment have been assumed for estimating purposes only.

The racks and headworks have been housed in with floor at elevation 936. A sloping concrete curtain along the face of the entrance piers provides a protection against ice and drift. The floor of the generator room is at elevation 926.5, and is connected with the right bank of the river by a roadway over the lower ice sluices. The water seal of the draught tubes is at elevation 898, the discharge taking place directly across the river. The draft tubes can if necessary be protected from backwater effects of the discharge over the dam by a rock-filled crib in the river channel running from the north end of and parallel to the powerhouse.

The estimates for the power station have been calculated for two stages of development.


(1) *Initial development.*—This consists of the eight units adjacent to the dam. The turbines considered have each a capacity of 5,000 horse-power at full gate, and the electrical installation has been selected with the normal full load corresponding to eight-tenth gate opening of the turbines. This will provide sufficient elasticity to take care of peak loads and gives sufficient machine capacity to utilize 12,000 second-feet at 26-foot head, with turbines at 85 per cent efficiency and eight-tenth gate, at the same time leaving one unit as a spare.

**DOMINION WATER POWER BRANCH**  
**J B CHALLIES, Superintendent**

**POWER-PERCENTAGE OF TIME CURVES**  
 at the  
**SLAVE FALLS POWER SITE**  
 on the

WINNIPEX; RIVER.  
 HEAD 20 FEET POWER AT 76% EFFICIENCY  
 PERIOD 1907-1914 INCLUSIVE  
 To accompany a report on POWER AND STORAGE  
 INVESTIGATIONS by J. T. JOHNSTON, S.A.Sc  
 March 9th 1915


PLATE No. 67





Twenty Four hour Horse Power at 75% Eff.

Percentage of Time

4177 Equivalent Continuous Horse Power  
 over eight years








A note on the R. Slave Falls site to the S. of the dam proposed on the R. Slave Falls is at one 5 x 100 ft. and level of 200 feet from water level at 217' and two 50 ft. x 100 ft. with a net discharge of 1000 cfs. The water at E. side of dam has to be added to the water on the R. Slave Falls has provided for further consideration.



Department of the Interior Canada  
 MINISTRE DES TERRES  
 DEPARTMENT OF THE INTERIOR  
 WATER POWER BRANCH  
 J. B. CHALLEN SUPERINTENDENT

**WINNEPEG RIVER POWER SURVEY  
 PROPOSED SCHEME OF DEVELOPMENT  
 AT  
 SLAVE FALLS**

Prepared by *J. B. Challen*  
 Hydraulic Engineer  
 Water Power Branch  
 Approved by *J. B. Challen*  
 Civil Engineering  
 Water Power Branch




Based on Field Surveys made under direction of  
 D. McLean Chief Eng. Manitoba Power Surveys  
 Nov. 21, 1915


90000




DOMINION WATER POWER BRANCH  
J B CHAMBERS



REAR ELEVATION




SECTION BB



PLAN ON LINE A A

THE INSIDE VIEW OF POWER HOUSE NO. 1  
 PROJECTED BY THE BUREAU OF REVENUE  
 1913







The output available on the low tension switchboard on a 75 per cent overall efficiency on a 24-hour basis is 26,600 horse-power. The initial development includes the construction of the headworks of the remaining five units to a sufficient degree to support the stoplogs, leaving the balance of the bays to be added when required.

(2) *Final development.*—This will consist of thirteen 5,000 horse-power units, five additional being added to the south of the first installation. The thirteen units will provide for the utilization of 20,000 second-feet at a 26-foot head, with turbines at eight-tenth gate. This installation will under these conditions provide a spare unit for emergencies. The output at the switchboard at 75 per cent efficiency on a 24-hour basis is 44,400 horse-power.

*Ice sluices below the power station.*—Three ice sluices at right angles to the head-race with sills at elevation 913, followed by a corewall embankment connect the power station with the high land on the right bank. These ice sluices are placed in such a way as to produce a current in the head-race parallel to the powerhouse, and in conjunction with the sloping concrete curtain in front of the racks, should thoroughly protect the machines from all floating ice and detritus. A 20-foot roadway is carried over these sluices, and provides access to the floor of the generator room.

*Head-race.*—In the head-race the natural contours of the site have been utilized to the fullest extent, and the forebay is in a large measure formed by a natural rock ridge on one side, and the dam and power station on the river side. Opposite the power station this ridge turns towards the river and narrows the channel, but not to such an extent as to augment the velocities. At the entrance to the head-race, a rock ridge approaches the natural river bank and its removal constitutes the major portion of the head-race excavation. Excavation to elevation 913 throughout the head-race will provide passageway for the 12,000 second-feet required for the initial installation at a maximum velocity of 2.8 feet per second, while deepening to elevation 900 will provide for 20,000 second-feet at a velocity of 2.7 feet per second. The land site of the head-race has, where excavation is necessary, been laid out in simple curves in such a manner as to provide for a smooth running and undisturbed flow.

#### DISCHARGE CAPACITY.

Owing to the peculiar conditions which must be met here in connection with the headwater elevation and the protection of the interests of the city of Winnipeg in the plant at Point du Bois, particular care has been given to the discharging features of the Slave falls plant.

The layout considered provides fifteen 20-foot sluices with sills at elevation 913 adjacent to the left bank. These are followed by a spillway with thirteen 20-foot sections with crest at elevation 925, and with flashboard provision to elevation 928. Adjacent to the upper end of the power station are two 20-foot sluices with sills at 913. Three similar sluices are located at the lower end of the head-race. In all, a discharging capacity of 82,000 second-feet is provided with the headwaters at elevation 928. In addition to this the power station, when working to its full capacity, will pass 20,000 second-feet. While this has

not been considered as a dependable source of discharge, it may be considered as forming an additional factor of safety.

The maintenance of the 26-foot head at this plant in times of high water will necessitate the raising of the headwaters above 928. This will automatically increase the discharging capacity at the only time when such increased capacity will be required. Elevation 930 in the headwaters will discharge 103,000 second-feet, excluding the discharge through the power-house. The underside of the bridge decks over the sluices being at elevation 936.5 will provide a safety factor sufficient to pass such floods as are to be expected on the river.

The location of the main sluices adjacent to the left bank of the river permits the discharge of the unutilized water down the river, sending no more down the headrace than is required for the operation of the plant, and thereby keeping the velocities therein at a minimum.

Under natural conditions the main set of the current below the falls is away from the right bank of the river, leaving an eddy where the power-house has been located. This is of particular advantage to the draught tube discharge. The general curve of the dam and the location of the sluices is such that an efficient manipulation of the same will tend to force the main body of the current away from the tail-race to an even greater extent than occurs under present conditions.

#### UNWATERING.

Alternative schemes of unwatering, suitable to whatever method or order of construction may be adopted, should not exceed the estimates allowed herein.

#### NAVIGATION.

At the Slave falls site provision has been made for the future construction of lockage facilities on the left bank should the same ever become necessary (plate 68). The lock depicted is 300 feet by 40 feet, with 15 feet of water on the sills.

This lock with approaches can be constructed at any time in the future without interfering with the operation of the power plant, nor will the provision for it incur any extra expenditure in the present construction of the plant. On the other hand, the present construction of the power installation will not place any obstacles in the way of the future construction or operation of the lock. No portion of the cost of the lock or approaches is included in the estimates for the power development.

#### ESTIMATES OF COST.

The estimates of the cost of the initial and final installations place the power on the low tension switchboard in the power station. It is considered that the estimates are amply conservative and that the assumptions which have been made are fully warranted. Seven miles of railroad have been allowed to connect with the city of Winnipeg tramway line.

Ten per cent has been allowed on the estimates for contingencies, 5 per cent on this total for engineering and inspection, and  $5\frac{1}{2}$  per cent on the whole for one year for interest during construction.

The annual operation costs include capital charges, and represent the cost of operation at the power station. They do not include transforming and transmission.

(1.)—Initial Development.—(Eight 5,000 horse-power units.)

(1) Capital Cost of Installation.	
Dam and equipment.....	\$ 276,000
Ice sluices and roadway.....	35,000
Head-race.....	87,000
Power station and equipment.....	533,000
Hydraulic installation.....	360,000
Electrical installation.....	520,000
Railroad.....	84,000
Permanent quarters.....	15,000
Contingencies, 10 per cent.....	191,000
Engineering and inspection, 5 per cent.....	105,000
Interest during construction, 5½ per cent.....	121,000
<b>Total initial cost.....</b>	<b>\$2,327,000</b>
Twenty-four hour power available at 75 per cent over-all efficiency, 26,600 horse-power.	
Capital cost per 24-hour horse-power.....	\$87 50
Capital cost per installed horse-power.....	58 20
(2) Annual Cost of Operation.	
Interest, sinking fund, and depreciation charges—	
Interest, 5½ per cent on \$2,327,000.....	\$ 128,000
Sinking fund, 4 per cent (40-year bonds).....	24,000
Depreciation—	
1 per cent on permanent works.....	\$ 7,000
4 per cent on machinery, etc.....	40,000
<b>Operation charges—</b>	<b>47,000</b>
Staff.....	\$ 19,000
Supplies.....	10,000
<b>Total annual charge.....</b>	<b>\$ 228,000</b>
Annual cost per horse-power year, 24-hour power.....	\$8 58
Annual cost per horse-power year, machinery installed.....	5 70
Annual cost per kilowatt hour.....	0·131 cent
Annual cost per kilowatt hour on basis of 50 per cent load factor.....	0·262 cent

(2.)—Final Development.—(Thirteen 5,000 horse-power units.)

(1) Capital Cost of Installation.	
Dam and equipment.....	\$ 276,000
Ice sluices and roadway.....	35,000
Head-race.....	204,000
Power station and equipment.....	771,000
Hydraulic installation.....	585,000
Electrical installation.....	845,000
Railroad.....	84,000
Permanent quarters.....	20,000
Contingencies, 10 per cent.....	282,000
Engineering and inspection, 5 per cent.....	155,000
Interest during construction, 5½ per cent.....	179,000
<b>Total final cost.....</b>	<b>\$3,436,000</b>
Twenty-four hour power available at 75 per cent over-all efficiency, 44,400 horse-power.	
Capital cost per 24-hour horse-power.....	\$77 39
Capital cost per installed horse-power.....	52 86
(2) Annual Cost of Operation.	
Interest, sinking fund, and depreciation charges—	
Interest, 5½ per cent on \$3,436,000.....	\$ 189,000
Sinking fund, 4 per cent (40-year bonds).....	36,000
Depreciation—	
1 per cent on permanent works.....	\$ 9,000
4 per cent on machinery, etc.....	61,000
<b>Operation charges—</b>	<b>70,000</b>
Staff.....	\$ 26,000
Supplies.....	17,000
<b>Total annual charge.....</b>	<b>\$ 338,000</b>
Annual cost per horse-power year, 24-hour power.....	\$7 62
Annual cost per horse-power year, machinery installed.....	5 21
Annual cost per kilowatt hour.....	0·117 cent
Annual cost per kilowatt hour on basis of 50 per cent load factor.....	0·234 cent

## SUMMARY OF DEPENDABLE POWER.

A summary of the undeveloped power as outlined in the above power studies, together with the total dependable power on the river in Manitoba, including that developed to date, is appended in tables 35 and 36.

Table 35.—Undeveloped Power Sites on the Winnipeg River in Manitoba.

Site.	Distance from Winnipeg in Miles	Head in feet.	POWER AVAILABLE.			
			24 Hour Power at 75% Efficiency.		Turbine Installation (Units considered.)	
			12,000 Sec.-ft.	20,000 Sec.-ft.	12,000 Sec.-ft.	20,000 Sec.-ft.
1.	2.	3.	4.	5.	6.	7.
Pine Falls.....	64	37	37,900	63,100	6—10,000	10—10,000
Du Bonnet Falls.....	64	56	157,300	95,500	10—10,000	14—10,000
McArthur Falls.....	62	18	18,400	30,700	11—2,500	17—2,500
<sup>2</sup> Lower Seven Sisters.....	52	37	12,600	37,900	.....	6—10,000
<sup>2</sup> Upper Seven Sisters.....	55	29	9,900	29,600	.....	8—6,000
<sup>3</sup> Upper Pinawa.....	58	18	12,300	12,300	4—4,500	4—4,500
Slave Falls.....	74	26	26,600	44,400	8—5,000	13—5,000
Total.....			175,000	315,500	235,500	473,500

<sup>1</sup>This tabulation assumes an initial development of the Du Bonnet site utilizing 12,000 second-feet at 56-foot head.

<sup>2</sup>The Upper and Lower Seven Sisters sites are located in the main channel of the Winnipeg river paralleling the Pinawa through which 8,000 second-feet is assumed to be diverted for the operation of the Winnipeg Electric Railway plant.

<sup>3</sup>The Upper Pinawa site is located on the Pinawa channel.

Table 36.—Total Power Developed and Undeveloped on the Winnipeg River in Manitoba.

	Unregulated Flow 12,000 Sec.-ft.	Regulated Flow 20,000 Sec.-ft.
Undeveloped at proposed sites.....	175,000	313,500
Undeveloped at Point Du Bois.....	21,100	51,800
Developed on River to date.....	53,200	53,200
Total.....	249,300	418,500

NOTE.—Power in terms of 24-hour horse-power at 75 per cent efficiency.

The above tables indicate that there is 53,200 horse-power developed to date, 196,100 horse-power undeveloped and available in times of present low water on the river, and 365,300 horse-power undeveloped and available when the river is regulated to a minimum flow of 20,000 second-feet. It must be borne in mind that these totals are given in terms of 24-hour power, and hence give a rather limited estimate of the river's resources. A translation of these totals into shorter range-power will therefore prove of interest.

Table 37.—Dependable Power on Winnipeg River in Manitoba.

	Unregu- lated Flow 12,000 Sec.-ft.	Regu- lated Flow 20,000 Sec.-ft.
Twenty-four hour power.....		
Twenty-hour power.....	249,000	418,000
Sixteen-hour power.....	299,000	502,000
Twelve-hour power.....	373,000	627,000
	498,000	836,000

The above tabulation shows the greater scope of the power resources to meet varying demand, but must only be applied with discrimination. What might be called the dependable commercial power available can be placed at well above the half-million mark.

Plates 71 and 72 graphically indicate the relative power capacities of the different sites and plants under present run-off conditions and under systematically controlled regulation. The total power output of the entire reach in Manitoba is graphically depicted in the power percentage of time diagram, plate 73. This curve is based on eight years' records of run-off, and gives the power in terms of continuous 24-hour power.

SUMMARY OF CAPITAL AND OPERATING COSTS.

The data respecting the estimates of the various schemes have been condensed into tables 38 and 39 for the purpose of ready reference and comparison.

Table 38.—Estimated Capital Cost of developing the proposed power sites on the Winnipeg River in Manitoba. Power placed on the low-tension switchboard in the Power Stations.


Site.	CAPITAL COST ON LOW TENSION SWITCHBOARD IN POWER STATION.					
	Total Cost.		Per H. P. on Basis of 75% Efficiency, 24-hour power.		Per H. P. on Basis of Installation.	
	12,000 Sec.-ft.	20,000 Sec.-ft.	12,000 Sec.-ft.	20,000 Sec.-ft.	12,000 Sec.-ft.	20,000 Sec.-ft.
	2.	3.	4.	5.	6.	7.
	\$	\$	\$ cts.	\$ cts.	\$ cts.	\$ cts.
Pine Falls.....	3,057,000	4,407,000	80 66	69 83	50 95	44 07
Du Bonnet Falls.....	14,624,000	6,551,000	80 70	88 59	53 80	46 79
McArthur Falls.....	2,031,000	2,740,000	110 38	89 25	73 88	64 47
Lower Seven Sisters.....		3,409,000		89 95		56 82
Upper Seven Sisters.....		2,724,000		92 03		56 75
Upper Pinawa.....	1,280,000	1,280,000	104 07	104 07	71 11	71 11
Slave Falls.....	2,327,000	3,436,000	87 50	77 39	58 29	52 46
Total.....						
Mean (based on power output).....	13,319,000	24,547,000	87 30	78 30	56 60	42 80

<sup>1</sup>Proportional capital cost of development of 12,000 second-feet at 56-foot head.

<sup>2</sup>Upper and Lower Seven Sisters sites are not feasible of development until the river flow is more systematically regulated.

**DOMINION WATER POWER BRANCH**

J. B. CHALLIES, Superintendent



LEGEND: Developed Power   
 Undeveloped Power

Total Power Capacity of Winnipeg River with Regulated Flow **249,300 H.P.**  
 Amount Developed to Date **53,200 H.P.**

NOTE: Based on a PRESENT MINIMUM flow of 12,000 Second Feet with undeveloped sites considered at 75% efficiency with 24 hour power.

**DIAGRAM**  
**SHOWING THE DEVELOPED AND UNDEVELOPED POWERS**  
**AT THE VARIOUS SITES ON THE**  
**WINNIPEG RIVER IN MANITOBA.**


To accompany report on POWER AND STORAGE INVESTIGATIONS  
 by J. T. JOHNSTON, S.A.Sc.

March, 1915.

Hydraulic Engineer,  
 Dominion Water Power Branch.

**DOMINION WATER POWER BRANCH**

J. B. CHALLIES, Superintendent



LEGEND: Developed Power  (shaded)  
 Undeveloped Power  (unshaded)

Total Power Capacity of Winnipeg River with Regulated Flow **418,500 H.P.**  
 Amount Developed to Date **53,200 H.P.**

NOTE: Based on a REGULATED MINIMUM flow of 20,000 Second Feet with undeveloped sites considered at 75% efficiency with 24 hour power.


**DIAGRAM**  
**SHOWING THE DEVELOPED AND UNDEVELOPED POWERS**  
**AT THE VARIOUS SITES ON THE**  
**WINNIPEG RIVER IN MANITOBA.**

To accompany a report on POWER AND STORAGE INVESTIGATIONS  
 by J. T. JOHNSTON, B.A.Sc.

March, 1915.

Hydraulic Engineer,  
 Dominion Water Power Branch

**DOMINION WATER POWER BRANCH**  
 J. B. CHALLIES, Superintendent  
**POWER-PERCENTAGE OF TIME CURVES**  
 of the  
**WINNIEG RIVER IN MANITOBA**  
 INCLUDING PRESENT  
 AND PROPOSED DEVELOPMENT.  
 POWER AT 75% EFFICIENCY  
 PERIOD 1907-1914 INCLUSIVE  
 To accompany a report on POWER AND STORAGE  
 INVESTIGATIONS by J. JOHNSTON B.A.Sc.  
 March 5th, 1915



The Du Bonnet plant, in view of its high head, will prove the most economically efficient of the series, the capital cost per horse-power being \$68.60, and the McArthur plant, in view of its low head and the long dam and headworks required, is actually the most costly as measured by its output, the cost being \$89.25 per horse-power. The two Seven Sisters and the Upper Pinawa sites cannot be directly compared with the other four as each receives only a portion of the river flow, with a consequent comparative decrease in the power produced. However, under a regulated flow of 20,000 second-feet in the river their unit capital costs of \$89.95, \$92.93, and \$104.07 respectively, will prove very attractive from a commercial view point.

In view of the uniform and conservative character of the over-development at each site, unit costs have been listed in terms of the horse-power installed, as well as in terms of 24-hour power, and as such can be profitably studied.

A consideration of the above total costs shows the following: The total final output of the seven proposed developments is 313,500 horse-power at a total capital cost of \$24,547,000, i.e., an average cost of \$78.30 per horse-power, or \$12.80 per horse-power based on machinery installed.

The annual operating costs are probably of greater interest than the above capital costs, and are summarised in table 39.

The results tabulated herein bear out the general conclusions as to comparative economic efficiency that have been noted from a discussion of the capital costs. They are listed in terms of initial and final development, corresponding to present regulated run-off, respectively. The costs per kilowatt hour, considering a 50 per cent load factor, as shown in column 11, indicate in all cases highly desirable commercial undertakings.

Care has been taken to supply sufficient physical data in this report to enable independent estimates being made of the construction cost of any of the projects, by parties interested in their development.

While the annual operation costs quoted may appear low, a review of the estimates and of the general underlying principles upon which they are based will establish the conservativeness of the conclusions. The figures represent operating conditions which possibly would not be met upon the immediate completion of the undertakings, that is to say, the initial market would possibly not warrant the initial installation proposed. This would result in higher initial capital and operating costs than are submitted above. At the same time, it would be a simple matter to present the unit costs published herein in a much more favourable light than has been done. Considering the ample pondage facilities which exist, the general run-off conditions of the river, and the general opportunities of an industrial market, 24-hour power is a most conservative basis on which to establish final figures.

As illustrative of this, the Pine Falls site may be briefly considered. The continuous 24-hour power available here is 63,100, and the annual cost per horse-power on this basis is \$7.08, or 0.216 cent per kilowatt hour on a 50 per cent load factor. The average load carried by the Pine Falls plant could, under a regulated river flow, be maintained at 63,000 horse-power and readily carry a peak load of 126,000 horse-power. The actual cost per kilowatt hour is therefore probably more truly represented by the figure 0.108 cent than by 0.216 cent.

Table 39.—Estimated Annual Cost of operation of the proposed power developments on the Winnipeg River in Manitoba. Power placed on the low-tension switchboard in the Power Stations.

Site.	ANNUAL OPERATING COST ON LOW-TENSION SWITCHBOARD IN POWER STATION										
	Total Annual Cost.		Per H. P. on basis of 75% efficiency 24-hour Power.		Per H. P. on basis of Installation.		Per K.W. hour 100% Load Factor		Per K.W. hour 50% Load Factor.		Cents
	12,000 Sec.-ft.	20,000 Sec.-ft.	12,000 Sec.-ft.	20,000 Sec.-ft.	12,000 Sec.-ft.	20,000 Sec.-ft.	12,000 Sec.-ft.	20,000 Sec.-ft.	12,000 Sec.-ft.	20,000 Sec.-ft.	
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.	11.	
	\$	\$	\$ cts.	\$ cts.	\$ cts.	\$ cts.	Cents	Cents	Cents	Cents	
Pine Falls .....	303,000	447,000	8 00	7 08	5 05	4 47	0-122	0 108	0 244	0 216	
1 Du Bonnet Falls .....	143,000	225,000	17 56	6 65	15 04	4 54	40-116	0 102	40 242	0 204	
2 Arthur Falls .....	199,000	322,000	10 82	8 86	7 24	6 40	0-166	0-136	0-332	0 272	
3 Lower Seven Sisters Falls .....	378,000	628,000	.....	8 63	5 47	5 47	.....	0-132	0-132	0 264	
4 Upper Seven Sisters Falls .....	128,000	208,000	10 40	9 05	7 11	5 58	.....	0-159	0-159	0 276	
Upper Pinawa .....	228,000	336,000	8 58	7 62	5 70	5 21	0-131	0-117	0 318	0 318	
Slave Falls .....	.....	.....	.....	.....	.....	.....	.....	.....	.....	.....	
Total .....	1,291,000	2,416,000	.....	.....	.....	.....	.....	.....	.....	.....	
Mean (based on power output) .....	.....	.....	8 47	7 71	5 48	4 21	0 140	0 114	0 260	0 246	

<sup>1</sup>Proportional annual cost of development of 12,000 second-feet at 56-foot head.

<sup>2</sup>Upper and Lower Seven Sisters sites are not feasible if development until the river flow is more systematically regulated

These remarks apply with equal force to the estimates of the other projects along the river.

While it is impossible in a work of this nature to go fully into the various conditions of load and market which may be experienced in the developments of the proposed concentrations, an endeavour has been made to supply sufficient data to permit an adjustment of the figures to meet individual requirements, and to enable the information and estimates herein being applied or compared, as may be desired.

#### COST OF DELIVERY OF POWER TO WINNIPEG.

No consideration has been given to the cost of transmitting the developed power to the present industrial market, the reason being the uncertainty as to the use to which the power developed at the various sites will be applied. Undoubtedly in some instances the power will be used industrially directly at the site, either for pulp grinding or in connection with one or more of the various electro-chemical processes which are now coming to the front. The foregoing estimates serve their general purpose, which is to indicate the relative commercial value of the sites as units.

An analysis of the power situation would, however, be incomplete unless some idea were given as to the cost of transmitting the power to the nearest industrial market, i. e., the city of Winnipeg. To this end, the following estimate of cost of transmission from the Pine falls site to the low-tension switchboard in the transformer house in Winnipeg is appended.

The estimates herewith are based on an initial and final development; the capital cost to the low-tension switchboard in the power station has been brought forward from the detailed estimates of the Pine falls development. The transmission distance is 60 miles.

The power station as designed does not include provision for step-up transformers, and hence a separate building has been provided at the site, together with a step-down station at Winnipeg. At the river station six 6,000 k.w., 6,600-66,000-volt transformers have been provided for the initial installation, and ten for the final installation at the station corresponding provision has been made after allowing for transmission line drop. The resulting costs place the power ready for distribution at Winnipeg.

## Department of the Interior.

(1) *Initial development.*—(Six 10,000 horse-power units.)(1) *Capital Cost of Installation*

Capital cost of installation to low-tension switchboard at falls, brought forward		\$3,057,000
Transformer house at falls	\$ 50,000	
Transformers, switches, wiring, etc.	216,000	
Transmission line	360,000	
Transformer house in Winnipeg	45,000	
Transformers, switches, etc.	194,000	
		865,000
Total initial cost		\$3,922,000

Twenty-four hour power available in Winnipeg, considering 10 per cent loss, 34,110 horse-power.  
 Capital cost per horse-power \$114.98

(2) *Annual Cost of Operation.*

Interest, sinking fund, and depreciation charges—		
Interest, 5½ per cent on \$3,922,000		\$ 216,000
Sinking fund, 4 per cent (40-year bonds)		41,000
Depreciation—		
1 per cent on permanent works	\$ 11,000	
4 per cent on machinery, etc.	87,000	
		98,000
Operation charges—		
Staff		\$ 36,000
Supplies	20,000	
		56,000
Total annual charge		\$ 411,000

Annual cost per horse-power year 24-hour power \$ 12.05  
 Annual cost per kilowatt hour 0.184 cent  
 Annual cost per kilowatt hour on basis of 50 per cent load factor 0.368 cent

(2) *Final development.*—(Ten 10,000 horse-power units.)(1) *Capital Cost of Installation.*

Capital cost of installation to low-tension switchboard at falls, brought forward		\$4,407,000
Transformer house at falls	\$ 80,000	
Transformers, switches, wiring, etc.	360,000	
Transmission line	420,000	
Transformer house in Winnipeg	70,000	
Transformers, switches, wiring, etc.	324,000	
		1,254,000
Total final cost		\$5,661,000

Twenty-four hour power available in Winnipeg, considering 10 per cent loss, 56,790 horse-power.  
 Capital cost per horse-power \$99.68

(2) *Annual Cost of Operation.*

Interest, sinking fund, and depreciation charges—		
Interest, 5½ per cent on \$5,661,000		\$ 311,000
Sinking fund, 4 per cent (40-year bonds)		60,000
Depreciation—		
1 per cent on permanent works	\$ 14,000	
4 per cent on machinery, etc.	134,000	
		148,000
Operation charges—		
Staff		\$ 45,000
Supplies	25,000	
		70,000
Total annual charge		\$ 589,000

Annual cost per horse-power year 24-hour power \$10.37  
 Annual cost per kilowatt hour 0.159 cent  
 Annual cost per kilowatt hour on basis of 50 per cent load factor 0.318 cent

As noted in connection with the operating costs at the power sites, 24-hour continuous power is a most conservative basis on which to base annual costs. The conditions under which the Pine Falls plant will operate are such that of the above two figures, 0.159 cent per kilowatt hour the more nearly represents the cost of power laid down in Winnipeg.

REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

CHAPTER VII.  
POWER FROM COAL, GAS, AND OIL.



## CHAPTER VII.

### POWER FROM COAL, GAS AND OIL.

In order to complement the cost data relative to hydro-electric power in Winnipeg, it is considered desirable to include in this report a discussion on the comparative cost of power from other feasible sources. Cost data relative to auxiliary or reserve fuel plants are also as a rule a matter of import in connection with hydro-electric installation.

The following discussion has therefore been prepared by Mr. H. E. M. Kensit, an engineer of the Dominion Water Power Branch

#### AUXILIARY OR RESERVE FUEL PLANT.

In the foregoing estimates of the cost of development and operation of undeveloped powers on the Winnipeg river the cost of a stand-by fuel plant has not been included for the reasons that the requirements in this direction, if any, will depend entirely upon the conditions under which the water-powers are developed and the use to which the power is to be put.

In the first place, a distinction should be made between the terms "auxiliary plant" and "reserve plant."

"*Auxiliary plant*" is considered to mean the provision of such additional independent plant, operated by fuel, as would be necessary to provide against diminished output during periods of low water.

The result of the exhaustive investigations and surveys made by the Dominion Water Power Branch over a series of years has shown that ample storage of water is available to give the regulated flow on which all the foregoing estimates have been based.

It is therefore not considered necessary to allow for the provision of any auxiliary plant for the purpose of precaution against low water.

"*Reserve plant*" is considered to mean additional independent plant, operated by fuel, that might be considered necessary to provide for such contingencies as:

- (1) Floods or troubles from ice
- (2) Damage to the transmission line from wind, sleet, lightning, electric surges or other cause.
- (3) Accident to the generating plant.

In regard to these contingencies it may be pointed out that:

(1) In respect to floods it is recognized that the natural regulation provided in the innumerable lakes, as above described, is an efficient safeguard against any such probability. In respect to troubles from ice it is believed that the natural and local conditions are such that with proper design and precautions the risk from this cause may be considered but slight.

(2) In respect to interruptions that may be caused by accidents to the transmission line, it is undoubtedly the fact that in the case of any transmission line such accidents are bound to occur sooner or later. If, however, either a double

circuit line, or preferably, two separate transmission lines are employed, each of capacity to carry the full output, then while accidents will still occur they should cause but momentary interruptions while the load is being switched from the damaged circuit to the spare circuit.

(3) In respect to accidents to the generating plant, all reasonable and usual precautions can be made by the provision of spare hydro-electric units.

*Summing up the foregoing:* Therefore, it is considered that separate fuel-operated plant will not be necessary for the purpose of providing against low water, but that it may possibly be advisable under some conditions as a reserve against accidents.

*Desirability of reserve plant:* It is generally conceded that in the case of a hydro-electric plant supplying light and power for general distribution in a city, an independently operated reserve plant should be provided and kept ready for immediate use at any time. This is especially the case if the power has to be transmitted any distance. The reason is that if a city is entirely dependent on the hydro-electric undertaking for light, power, and possibly for pumping the city water supply, no chances of interruption that can possibly be guarded against may be taken.

But it is not necessary or usual to provide steam or other reserve for a hydro-electric plant operated by a company for its own factory; or for supplying a limited number of individual factories.

In the case of the proposed developments that have been discussed in preceding chapters, it is doubtful if a company developing one or more of these powers for purposes other than general supply to a city, would consider steam reserve necessary, and especially would this be the case if the development was undertaken for the purpose of supplying power to industries locating near the power plant at the river, thus eliminating transmission risks.

A further possibility would be that of a company or group of interests acquiring two or more of the undeveloped powers for industrial purposes. In such case, a steam reserve plant, if considered necessary at all, might be considered to act as a reserve to more than one of the hydro-electric developments.

On account of the uncertainty caused by the above conditions, it was felt that any attempt to include the cost of stand-by plant would tend to obscure the estimates of the cost of the hydro-electric developments.

It is thought, however, that the inclusion of some separate estimates of cost of reserve plant operated by fuel may be of service to those interested, and who may not have cost data on hand.

#### ESTIMATES OF COST OF RESERVE PLANT.

As shown above, it is not considered that such plant would be required as an auxiliary in case of low water, but only as a reserve against possible accidents to the transmission line or power plant. In such case it is obvious that, with proper design and precaution in respect to the transmission line and hydro-electric plant, the reserve fuel-operated plant might be seldom required, possibly not for a year or more at a time.

It is therefore clear that the predominating factor in deciding on type of plant would be low capital cost rather than low operating costs.

The type of fuel plant that holds the field for low capital cost in large units is undoubtedly the steam turbine, and will therefore be the only one considered.

The undeveloped powers for which the possibility of steam reserve might arise are listed in table 35.

The size of reserve plant required would be a question for the individual judgment of the parties developing one or more of these powers, but it is obvious that the reserve plant would need to be large.

Whether required for use or not, it would be necessary to periodically run the engines under steam, and the generators on artificial load, in order to keep the plant in good condition and ready for service, and for this purpose it would be necessary to keep two men in continuous charge, with additional help when the plant was operated on artificial load to keep it in good condition.

In addition to interest and depreciation, repairs and maintenance would also be incurred, no matter how little the plant was used.

These and other charges may be figured as follows:

*Capital charges:* Interest, 6 per cent; depreciation, 4 per cent; total, 10 per cent.

*Repairs and maintenance:* 1.5 per cent.

*Insurance:* 1 per cent; taxes, 1 per cent; total, 2 per cent

*Labour:* Two men in constant service and additional help for periodic runs to keep the plant in proper order.

*Coal:* A supply must be kept in reserve whether the plant is used or not, and the cost must be added to capital expenditure, since it is capital lying idle. As to amount of fuel in reserve, allow say three days' supply at 75 per cent load factor at 5 pounds per kilowatt hour and \$6.25 per ton.

In addition, at least twice the above amount would be required for periodic runs to keep the plant in order, and this would be an annual charge.

*Oil and stores:* The same remarks apply as to coal.

*Heating and lighting* are not allowed for, but would be but a small percentage addition to the total.

On this basis, the capital and annual costs *without operation* would be approximately as shown in table 40.

No estimate of any service can be made of operating costs where the operation depends on accidents only.

It is assumed that the plant will not be kept under steam continuously.

Table 40.—Approximate Cost of Steam Turbine Plants complete with steel and concrete buildings.

SIZE OF PLANT.		Cost per K.W.	Coal and Supplies in Stock	Total Cost.	ANNUAL COST WITHOUT OPERATION					Per H.P. in stalled
Kilo-watts.	Horse Power.				Capital Charges 10%.	Maintenance and Repairs 1.5%.	Coal and Supplies Used.	Labor.	Total.	
		\$	\$	\$	\$	\$	\$	\$	\$	\$ cts.
5,000	6,700	80	4,500	405,000	40,450	14,160	9,000	2,500	66,110	9 90
10,000	13,400	75	9,000	759,000	75,900	20,600	18,000	3,000	124,500	9 20
20,000	26,800	70	18,000	1,418,000	141,800	49,500	36,000	3,500	230,800	8 60

NOTE.—These plants would have an overload capacity of 50 per cent to meet peak load. See text for details of charges given.

From the foregoing table it will be seen that the actual annual cost of keeping such a plant in reserve, without operation and without even keeping under steam continuously, would be from about \$9 to \$10 per horse-power year.

In the case of the Pine Falls site, the hydro-electric power per horse-power year is estimated to cost, delivered at Winnipeg and transformed down to 2,200 volts, \$12.05 from the initial and \$10.37 from the ultimate development.

The power generated by the steam plant during the periodic runs would be available to feed the circuits, but this would not really be a credit, for it would only replace hydro-electric power that would otherwise "run to waste." This power, on the basis above defined, would amount to about 540,000 horse-power hours, and at \$12 per horse-power year, would be equivalent to about \$2,700 per annum.

#### COST OF FUEL POWER IN WINNIPEG COMPARED WITH HYDRO-ELECTRIC POWER FROM PINE FALLS.

An account of the water-power possibilities of the Winnipeg river and of the cost of hydro-electric power delivered at or near Winnipeg would hardly be a complete review of the resources of that river without a comparison of the cost of that power with fuel power produced at factories in the same neighbourhood.

It is assumed that the hydro-electric power to be developed would be transmitted to a terminal station near Winnipeg, and sold in blocks to factories that would be induced, by the low price of the power, to locate near the said terminal station.

Two specific cases will therefore be assumed, i.e., a supply of 250 horse-power and a supply of 500 horse-power.

*Sources of fuel power* available in Winnipeg. These consist of coal for steam plants, producer gas, and fuel oil.

The city fire department has four 500 horse-power and two 250 horse-power engines operated by producer gas for fire pressure purposes, and this plant is also used to pump water to the Canadian Pacific railroad shops.

Fuel oil at the present price of 7 cents per gallon is an economical source of power.


Manufactured gas, though it has been available for some years, is not used for power on account of the high cost.

Natural gas is not available.

Steam, producer gas, and oil are therefore the only sources of fuel power to be considered.

*Basis of Estimates.*—The object herein is to make a fair comparison of the cost of fuel power in Winnipeg compared to low-priced hydro-electric power. Therefore, the estimates for fuel power have been put as *low* as could be reasonably done, both as to capital and operating costs.

The estimates represent the best conditions, and it is believed that few, if any, individual fuel-operated plants in the districts are obtaining or would obtain as good results in practice as those shown.



Department of the Interior Canada  
 Hon. CHARLES W. J. RICHELIEU, MINISTER  
 www.int.gov.ca  
 Hon. WALTER DUNDAS, MINISTER  
 Hon. WALTER DUNDAS, MINISTER  
 Hon. WALTER DUNDAS, MINISTER

**DOMESTIC COAL CONSUMPTION**  
**WESTERN CANADA**

Map showing coal consumption in the  
 provinces of Alberta, Saskatchewan, Manitoba, and Ontario,  
 1913, 1914, and 1915.

MAP SHEET NO.

WESTERN CANADA

Map showing coal consumption in the  
 provinces of Alberta, Saskatchewan, Manitoba, and Ontario,  
 1913, 1914, and 1915.

112 110 108 106 104 102 100 98 96 94 92 90 88 86

Hudson's Bay

ALBERTA  
 SASKATCHEWAN  
 MANITOBA  
 ONTARIO

Lake Superior

U N I T E D S T A T E S

u  
t  
l  
e  
n

p

All estimates include brick buildings, single units, and no reserve plant, except a spare boiler for the steam plant, and no electric equipment. Heating and lighting is not included for either the fuel or hydro-electric plants.

*Steam plants* are figured on compound non-condensing engines, steam-driven auxiliaries, and feed water heaters, using Pittsburg run-of-the-mine bituminous coal at \$6.25 per ton.

*Oil plant* is figured on Diesel engines. Fuel oil is now 7 cents per imperial gallon in Winnipeg, but is figured at 9 cents as an average price.

*Producer gas* is based on a pressure plant using run-of-the-mine Pittsburg bituminous coal at \$6.25 per ton.

*Cost of the Hydro-Electric Power.* Any calculation of the cost of fuel power must include interest, depreciation, and maintenance of the plant that produces it. Similarly, to obtain the actual cost of hydro-electric power to the user, interest, depreciation, and maintenance on the electric motors and equipment must be added to the price paid for power.

The cost of fuel power is generally given per brake horse-power applied to the shaft in useful work.

Similarly, in giving the cost of hydro-electric power, it must be considered whether this is charged on the input to or output of the motor. The loss in an electric motor is from 10 to 20 per cent, depending on size and the percentage of full load at which it is worked. To compare with fuel power the cost of hydro-electric power must be stated in terms of the useful power delivered by the motor.

Some additions to the cost of hydro-electric power at the terminal station must, therefore be made in order to put it on the same basis as the fuel power.

For the purpose of this comparison we will take the Pine falls site and the prices at which it has been shown that power can be delivered at or near the city limit of Winnipeg from that source.

For ready reference these figures may be repeated here. The Pine falls power site is 64 miles from the city of Winnipeg.

Table 41. - Pine Falls Power Site on Winnipeg river.

	24 HOUR POWER AT 75% EFFICIENCY.		COST AT WINNIPEG.	
	At the falls	At Winnipeg	Per H. P. year 24 hr power.	Per K. W. hr 50% load factor.
			\$ cts.	Cents.
Initial plant	37,000	34,100	12.05	0.468
Ultimate plant	63,100	56,790	10.37	0.348

The above prices are for power delivered at a terminal station near Winnipeg and include transforming down to 2,200 volts pressure.

To these prices have been added allowances to cover the costs above referred to, and the corrected prices are shown in Table 42 for comparison with fuel power.

Table 42.—Comparison of the Cost of Fuel Power in Winnipeg with power from Pine Falls. For details, see accompanying estimates.

	Capital Cost Installed Complete.	PER HORSE-POWER YEAR			PER KILOWATT HOUR.		
		Load Factor			Load Factor.		
		25%	50%	75%	25%	50%	75%
	\$	\$ cts.	\$ cts.	\$ cts.	Cents.	Cents.	Cents.
250 H. P.—							
Steam .....	22,500	60 00	100 00	114 00	1 64	3 06	2 71
Diesel Oil .....	30,000	17 00	58 00	78 00	2 28	1 77	1 59
Producer Gas .....	27,500	47 00	77 50	108 00	2 88	2 37	2 20
Hydro-Electric—							
Initial .....	6,000	15 00	15 35	15 70	0 66	0 57	0 54
Complete .....	6,000	13 30	13 70	14 10	0 60	0 51	0 48
500 H. P.—							
Steam .....	12,500	52 50	87 50	115 00	3 22	2 63	2 42
Diesel Oil .....	15,000	35 50	55 50	75 50	2 18	1 50	1 54
Producer Gas .....	50,000	42 50	70 00	97 00	2 60	2 13	1 97
Hydro-Electric—							
Initial .....	12,000	15 00	15 35	15 70	0 66	0 57	0 54
Complete .....	12,000	13 30	13 70	14 10	0 60	0 51	0 48

Commenting on this table, attention is drawn to the comparatively small expenditure required in connection with the use of hydro-electric power, this representing only electric motors and equipment, as against the cost of a complete fuel plant.

It will be noticed that Diesel oil plant will give power at a very reasonable rate with fuel oil at 9 cents per imperial gallon, but even then it is not comparable with the hydro-electric power.

The detailed estimates from which the table is constructed are attached hereto, and attention is again called to the remarks *re* "basis of estimates."

ESTIMATES OF COST OF STEAM, OIL, AND PRODUCER GAS POWER IN WINNIPEG.

250 B. H. P. Steam Plant.

Peak load, 250 horse-power Average load, 75 per cent.

Capital Cost complete at \$90 per b.h.p. .... \$ 22,500

Interest, 6 per cent. Depreciation, 4 per cent.

Labour: 25 per cent load factor, one shift; 50 per cent, two shifts; 75 per cent, three shifts.

Repairs and maintenance: one shift, 2 per cent, two shifts, 3 per cent; three shifts, 4 per cent.

Production Cost.

	LOAD FACTOR		
	25 per cent.	50 per cent.	75 per cent.
	\$ cts.	\$ cts.	\$ cts.
Interest and depreciation, 10 per cent .....	2,250 00	2,250 00	2,250 00
Repairs and maintenance, as above, .....	450 00	675 00	900 00
Labour: 1 engineman, \$90, 1 stoker, \$75 .....	1,980 00	3,960 00	5,940 00
Fuel: 1 shift, 5.5 lb.; 2 shifts, 5 lb.; 3 shifts, 4.5 lb. per b.h.p. hour at \$6 25 .....	9,400 00	17,100 00	23,000 00
Oil, waste, and supplies .....	350 00	600 00	900 00
Insurance, 1 per cent, taxes, 1 per cent .....	450 00	450 00	450 00
	14,880 00	25,035 00	33,440 00
25 per cent of 8,760 hours X 250 horse-power = 547,500 b.h.p. hours per annum, 408,000 k. w. hours per annum.			
Per b.h.p. installed per annum .....	\$ cts. 60 00	\$ cts. 100 00	\$ cts. 134 00
Per k. w. hour .....	Cents. 3 61	Cents. 3 06	Cents. 2 74

ESTIMATES OF COST OF STEAM, OIL, AND PRODUCER GAS POWER IN  
WINNIPEG—Continued.

500 B. H. P. Steam Plant.

Peak load, 500 horse-power Average load, 75 per cent

Capital Cost complete at \$85 per h.p.

\$ 42,500

Interest, 6 per cent. Depreciation, 4 per cent

Labour: 25 per cent load factor, one shift; 50 per cent, two shifts; 75 per cent, three shifts

Repairs and maintenance: one shift, 2 per cent; two shifts, 3 per cent; three shifts, 4 per cent

Production Cost.

	LOAD FACTOR		
	25 per cent	50 per cent	75 per cent
	\$ cts	\$ cts	\$ cts
Interest and depreciation, 10 per cent			
Repairs and maintenance, as above	4,250 00	4,250 00	4,250 00
Labour: 1 engineman, \$90; 2 atokers, \$75	850 00	1,275 00	1,700 00
Fuel: 1 shift, 5 lb.; 2 shifts, 4.5 lb.; 3 shifts, 4 lb. per h.p. hour at \$6.25	2,800 00	5,760 00	8,640 00
Oil, waste, and supplies	17,100 00	30,900 00	41,000 00
Insurance, 1 per cent. Taxes, 1 per cent	450 00	700 00	1,000 00
	850 00	850 00	850 00
	26,300 00	44,745 00	57,440 00
25 per cent of 8,760 hours × 500 horse-power 1,095,000 h.p. hours per annum. 817,000 k.w. hours per annum.			
Per h.p. installed per annum	\$ cts 52.50	\$ cts 87.50	\$ cts. 115.00
Per k. w. hour	Cents. 3.22	Cents. 2.68	Cents. 2.32

250 B. H. P. Diesel Oil Plant.

Peak load, 250 h.p. Average load, 75 per cent

Capital Cost complete at \$120 per horse-power

\$ 30,000

Interest, 6 per cent. Depreciation, 4 per cent.

Labour: 25 per cent load factor, one shift; 50 per cent, two shifts; 75 per cent, three shifts.

Repairs and maintenance: one shift, 2 per cent; two shifts, 3 per cent; three shifts, 4 per cent.

Production Cost.

	LOAD FACTOR		
	25 per cent	50 per cent	75 per cent
	\$ cts	\$ cts	\$ cts
Interest and depreciation at 10 per cent			
Repairs and maintenance, as above	3,000 00	3,000 00	3,000 00
Labour: 1 man at \$90; one-third time 1 man at \$60	600 00	900 00	1,200 00
Fuel Oil: 0.86 lb. per h.p. hour at 9c. imp. gal.	1,320 00	2,640 00	3,960 00
Lubricating oil	3,150 00	6,300 00	9,450 00
Waste, supplies, etc.	180 00	360 00	540 00
Circulating water make up	100 00	175 00	250 00
Insurance, 2 per cent. Taxes, 1 per cent	70 00	140 00	210 00
	900 00	900 00	900 00
	9,320 00	14,415 00	19,510 00
25 per cent of 8,760 hours × 250 horse-power 517,500 h.p. hours per annum. 408,000 k. w. hours per annum.			
Per h.p. installed per annum	\$ cts. 37 00	\$ cts. 58 00	\$ cts. 80 00
Per k. w. hour	Cents. 2.28	Cents. 1.77	Cents. 1.59



# MICROCOPY RESOLUTION TEST CHART

(ANSI and ISO TEST CHART No. 2)



1.50



1.63



1.8

1.9

2.0

2.25

2.5

2.8

3.15

3.6

4.0

4.5

5.0

5.6

6.3

7.1

8.0

9.0

10.0

11.2

12.5

14.0

16.0

18.0

20.0

22.5

25.0

28.0

31.5

36.0

40.0

45.0

50.0



APPLIED IMAGE Inc

1653 East Main Street  
Rochester, New York 14609 USA  
(716) 482 - 0300 - Phone  
(716) 288 - 5989 - Fax

ESTIMATES OF COST OF STEAM, OIL, AND PRODUCER GAS POWER IN WINNIPEG—Continued.

500 B.H.P. Diesel Oil Plant.

Peak load, 500 horse-power. Average load, 75 per cent.

Capital Cost complete at \$110 per horse-power..... \$ 55,000

Interest, 6 per cent. Depreciation, 4 per cent.  
 Labour: 25 per cent load factor, one shift; 50 per cent, two shifts; 75 per cent, three shifts.  
 Repairs and maintenance, one shift, 2 per cent; two shifts, 3 per cent; three shifts, 4 per cent.

Production Cost.

	LOAD FACTOR.		
	25 per cent.	50 per cent.	75 per cent.
	\$ cts.	\$ cts.	\$ cts.
Interest and depreciation, 10 per cent.....	5,500 00	5,500 00	5,500 00
Repairs and maintenance, as above.....	1,100 00	1,650 00	2,200 00
Labour: 1 man at \$90; 1 at \$70.....	1,920 00	3,840 00	5,760 00
Fuel Oil: 0.56 lb. per b.h.p. hour at 9c. imp. gal.....	6,950 00	13,900 00	20,850 00
Lubricating oil.....	360 00	720 00	1,080 00
Waste, supplies, etc.....	135 00	225 00	310 00
Circulating water make up.....	140 00	280 00	420 00
Insurance, 2 per cent. Taxes, 1 per cent.....	1,650 00	1,650 00	1,650 00
	17,755 00	27,765 00	37,770 00
25 per cent of 8,760 hours × 500 horse-power = 1,095,000 b.h.p. hours per annum, 817,000 k. w. hours per annum.			
Per b.h.p. installed per annum.....	\$ cts. 35 50	\$ cts. 55 50	\$ cts. 75 50
Per k. w. hour.....	Cents. 2.18	Cents. 1.70	Cents. 1.54

250 B.H.P. Producer Gas Plant.

Peak load, 250 horse-power. Average load, 75 per cent.

Capital Cost complete at \$110 per horse-power..... \$ 27,500

Interest, 6 per cent. Depreciation, 5 per cent.  
 Labour: 25 per cent load factor, one shift; 50 per cent, two shifts; 75 per cent, three shifts.  
 Repairs and maintenance: one shift, 3 per cent; two shifts, 4 per cent; three shifts, 5 per cent.

Production Cost.

	LOAD FACTOR.		
	25 per cent.	50 per cent.	75 per cent.
	\$ cts.	\$ cts.	\$ cts.
Interest and depreciation, 11 per cent.....	3,025 00	3,025 00	3,025 00
Repairs and maintenance as above.....	825 00	1,100 00	1,375 00
Labour: 2 men per shift.....	1,980 00	3,960 00	5,940 00
Fuel: 3 lb. per b.h.p. hour at \$6.25.....	5,150 00	10,300 00	15,450 00
Oil, waste and supplies.....	250 00	450 00	650 00
Insurance, 1 per cent. Taxes, 1 per cent.....	550 00	550 00	550 00
	11,780 00	19,385 00	26,990 00
25 per cent of 8,760 hours × 250 horse-power = 547,500 b.h.p. hours per annum, 408,000 k. w. hours per annum.			
Per b.h.p. installed per annum.....	\$ cts. 47 00	\$ cts. 77 50	\$ cts. 108 00
Per k. w. hour.....	Cents. 2.88	Cents. 2.37	Cents. 2.30

ESTIMATES OF COST OF STEAM, OIL, AND PRODUCER GAS POWER IN WINNIPEG—Continued.

500 B.H.P. Producer Gas Plant.

Peak load, 500 horse-power. Average load, 75 per cent.

Capital Cost complete at \$100 per horse-power . . . . .

\$ 50,000

Interest, 6 per cent. Depreciation, 5 per cent.

Labour: 25 per cent load factor, one shift; 50 per cent, two shifts; 75 per cent, three shifts.

Repairs and maintenance: one shift, 3 per cent; two shifts, 4 per cent; three shifts, 5 per cent

Production Cost.

	LOAD FACTOR.		
	25 per cent.	50 per cent.	75 per cent.
	\$ cts.	\$ cts.	\$ cts.
Interest and depreciation, 11 per cent . . . . .	5,500 00	5,500 00	5,500 00
Repairs and maintenance, as above . . . . .	1,500 00	2,000 00	2,500 00
Labour: 2½ men per shift . . . . .	2,500 00	5,000 00	7,500 00
Fuel: 3 lb. per b.h.p. hour at \$6 25 . . . . .	10,300 00	20,600 00	30,900 00
Oil, waste, and supplies . . . . .	450 00	750 00	1,050 00
Insurance, 1 per cent. Taxes, 1 per cent . . . . .	1,000 00	1,000 00	1,000 00
	21,250 00	34,850 00	48,450 00
25 per cent of 8,760 hours × 500 horse-power 1,095,000 b.h.p. hours per annum, 817,000 k. w. hours per annum.			
Per h.h.p. installed per annum . . . . .	\$ cts. 42 50	\$ cts. 70 00	\$ cts. 97 00
Per k. w. hour . . . . .	Cents. 2.60	Cents. 2.13	Cents. 1.97

COST OF HYDRO ELECTRIC POWER.

On account of the subdivision in applying the electric drive the connected horse-power is generally a good deal larger than the peak load taken.

For 250 horse-power load probably some 300 horse-power of motors would be installed ranging from 5 to 50 horse-power. These would cost, installed complete, about \$15 per horse-power.

Power would be available at the terminal station at the price quoted at 2,200 volts. While motors are now frequently used at that voltage it is more usual to transform down to 220 or 440 volts. Transformers for this purpose, with housing and switching equipment, would cost about \$8 per kilowatt or \$6 per horse-power.

If the charge for power was based on the rated horse-power of motors connected, the question of the loss in the motors would not come in.

If, however, the charge was based on the metered kilowatt hours, this would be measured on the high-tension side of the transformers and to compare the charge with that for fuel power, expressed per brake horse-power hour, it would be necessary to allow say 17½ per cent for loss in transformers and motors at varying loads.

## 250 B.H.P. Hydro-Electric Power.

Costs to be added to Cost of Power at Terminal Station.

Peak load, 250 b.h.p. Average load, 75 per cent.

## Capital cost—

300 b.h.p. of motors installed complete at \$15.....	\$ 4,500
250 h.p. of transformers and equipment at \$6.....	1,500
	\$ 6,000

Interest, 6 per cent. Depreciation, 4 per cent.

Repairs and maintenance: one shift, 1 per cent; two shifts, 2 per cent; three shifts, 3 per cent.

	LOAD FACTORS.		
	25 per cent.	50 per cent.	75 per cent.
	\$ cts.	\$ cts.	\$ cts.
Interest and depreciation, 10 per cent.....	600 00	600 00	600 00
Repairs and maintenance.....	60 00	120 00	180 00
Labour and oil.....	100 00	150 00	200 00
Insurance, 1 per cent. Taxes, 1 per cent.....	120 00	120 00	120 00
<b>Totals.....</b>	<b>880 00</b>	<b>990 00</b>	<b>1,100 00</b>
<i>Per Horse-Power Year.</i>			
If power is charged per rated horse-power of motors connected (300 horse-power) the extra cost per horse-power will therefore be.....	\$ cts.	\$ cts.	\$ cts.
The cost at the terminal station is:—	2 93	3 30	3 66
Initial plant, \$12.05			
Final 10.37.			
The total cost per horse-power year to the user will therefore be, under the—			
Initial development.....	14 98	15 35	15 73
Ultimate development.....	13 30	13 67	14 05
<i>Per Kilowatt Hour.</i>			
25 per cent of 8,760 hours × 250 horse-power = 547,500 b.h.p. hours on the shaft or tools.			
Loss in transformers and motors, average, say 17½ per cent			
$547,500 \times \frac{100}{82.5} = 663,500$			
$663,500 \times \frac{746}{10000} = 495,000$ k.w. hours			
to be paid for, on 25 per cent load factor.			
<i>Initial Development.</i>			
	\$ cts.	\$ cts.	\$ cts.
Metered k.w.h. at 0.368 cent.....	1,820 00	3,640 00	5,460 00
Additional costs as in preceding table.....	880 00	990 00	1,100 00
<b>Totals.....</b>	<b>2,700 00</b>	<b>4,630 00</b>	<b>6,560 00</b>
<i>Ultimate Development.</i>			
	\$ cts.	\$ cts.	\$ cts.
Metered k.w.h. at 0.318 cent.....	1,580 00	3,160 00	4,740 00
Additional costs.....	880 00	990 00	1,100 00
<b>Totals.....</b>	<b>2,460 00</b>	<b>4,150 00</b>	<b>5,840 00</b>
495,000 k.w.h. is the amount paid for.			
408,000 is the equivalent applied on shaft.			
<i>Cost per k.w. hour.</i>			
On latter basis as for fuel power—	Cents.	Cents.	Cents.
Under initial development.....	0.661	0.567	0.536
Under ultimate development.....	0.602	0.508	0.476

## 500 B.H.P. Hydro-Electric Power.

The rates would be increased in practically the same proportion in the case of 500 horse-power as for 250 horse-power, and may therefore be considered to be same as given for 250 horse-power.

REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

CHAPTER VIII.  
MARKET FOR POWER



## CHAPTER VIII.

### MARKET FOR POWER.

While it is not the intention in this report to go deeply into the power market situation in Manitoba, it is necessary, in order to secure a proper appreciation of the uses to which the power resources of the Winnipeg river may be applied, to briefly cover the main features. However excessive the latent power in the river may now appear, there is not the slightest doubt that profitable employment for the whole will be found, and that in the not distant future. In view of the almost unprecedented rapidity of the development of Western Canada, and of its undoubted continuance in the immediate future, the power resources of the Winnipeg possess added value, and the necessity for their conservation to meet this development is fully appreciated by water-power engineers of the department.

The advances which have been and are constantly being made in long-distance transmission have greatly extended the scope of power distribution. Markets which a few years ago were considered entirely beyond the reach of central hydro-electric stations are now within transmission distance and are being profitably developed. Transmission lines from 100 to 200 miles in length are now commonplace, while in California electric energy is being transmitted 240 miles. It is unlikely that the limit of long-distance transmission has been reached, but sufficient has been said to indicate the scope of the territory tributary to the Winnipeg river.

The constantly increasing industrial and domestic use of electrical energy, and the new uses which are constantly being discovered for its application, all tend to a future increase in the general power demand.

#### RATIO OF HORSE-POWER INSTALLED TO POPULATION.

No general rule can be laid down establishing a fixed ratio between power requirements and population. The ratio is largely dependent upon the general living conditions, the distribution of industrial life, and the natural opportunities for successful economic power production. At the same time, in definite areas, the general relation of power generated to population serves at least as an indication of the power demand which may be anticipated in similar districts and territories.

The relation which the general occupation of the population bears to the power developed is marked, but cannot be applied indiscriminately to all sections, since it is largely combined with, and dependent on, existing physical opportunities for successful development. Water-power in any section is of course entirely based upon the physical features relating to and controlling the run-off, though its successful development where the opportunity exists, depends on market opportunities, and on the degree of competition from other power sources. In other words, while a water-power undertaking in one section of the

country may prove an unsuccessful commercial venture, a similar and equally costly development may in different surroundings and under different conditions of competition prove entirely efficient and successful.

#### CANADA AS COMPARED WITH OTHER COUNTRIES.




A general review of the present status of hydro-electric power development in the leading countries of the world is of interest in this connection, and to this end table 43 and plate 75 have been compiled and are appended.

In compiling data of this nature, considerable research was required and dependence had necessarily to be placed on data from various sources. The results are not given, therefore, as depicting accurately the exact status of hydro-electric development in the various countries listed, but are given merely as an indication of the comparative degree of progress which has been made along these lines. The figures for the United States are taken from the evidence given in December, 1914, before the Senate Committee on the Ferris Water-Power Bill. For the Dominion of Canada, the paucity of definite information concerning the rivers in the northern portions of the country prevents any accurate statement of the available undeveloped power. One estimate of 17,820,000 horse-power has been made in this connection, which, while probably based on meagre information with regard to the northern rivers, is the best figure available. It should, however, be used with reserve. The developed power in Canada is placed at 1,711,000 horse-power, and represents the compilation to date by the engineers of the Dominion Water Power Branch. For the purposes of comparison, Canada has been considered both in terms of its whole area and of the populated area. This has been considered advisable in view of the vast expanse of at present practically uninhabited area in the north.

A reference to the table and plate shows the Dominion as comparing well with other countries in the status of water-power development. While the ratio of power developed per square mile does not compare with Switzerland, Norway, Italy, Sweden, and other countries smaller in area or more advanced in settlement, the ratio of power developed to population places Canada second in position only to Norway. The development per capita for the two countries is, respectively 0.210 and 0.487 or 210 horse-power and 487 horse-power per 1,000 population.


#### HYDRO-ELECTRIC DEVELOPMENT IN THE UNITED STATES.

In the United States the present total development of hydro-electric energy amounts to 7,000,000 horse-power, or at a ratio of 76 per 1,000 population. A report issued by the Commissioner of Corporations on water-power development in the United States dated March 4, 1912, lists data which are of general interest in viewing the growth of hydro-electric power in recent years. This report places the total prime moving stationary power installed in the United States in 1907 for manufacturing, mining, and quarrying, street and electric railways, and at central stations at practically 22,912,013 horse-power. This total is stated as being probably below the actual figure, as a considerable volume of





DEPARTMENT OF THE INTERIOR CANADA  
 DOMINION WATER POWER BRANCH

GRAPHICAL COMPARISON OF  
 AREA, POPULATION,  
 AVAILABLE AND DEVELOPED WATER-POWER  
 IN CANADA, THE UNITED STATES  
 AND CERTAIN EUROPEAN COUNTRIES



GENERAL NOTE  
 1. These data are taken from the following sources:  
 a. The U.S. Census Bureau, Statistical Abstract, 1914, U.S. Government Printing Office, Washington, D.C.  
 b. The U.S. Census Bureau, Statistical Abstract, 1914, U.S. Government Printing Office, Washington, D.C.  
 c. The U.S. Census Bureau, Statistical Abstract, 1914, U.S. Government Printing Office, Washington, D.C.  
 d. The U.S. Census Bureau, Statistical Abstract, 1914, U.S. Government Printing Office, Washington, D.C.



con  
cos  
of c

in t  
end

depo  
resu  
elec  
indi-  
thes  
in 1  
For  
river  
of th  
has  
infor  
shou  
place  
engi  
Can  
area.  
presc

with  
ratio  
Norv  
settle  
in pe  
coun  
per 1

I  
amou  
repor  
in the  
in vic  
places  
in 190  
and ;  
stated

Table 43.—Comparative Status of Available Water-Power and of Developed Water-Power in Canada and other countries.

Country.	Area (Square Miles).	Population (latest available figures.)	H.P. Available Estimated to end of 1914.	H.P. Developed Estimated to end of 1914.	Per-centage of Utiliza-tion.	PER SQUARE MILE OF AREA		H.P. PER CAPITA	
						1.	2.	3.	4.
Canada	3,729,700	18,013,500	17,820,000	1,710,843	9.6	4.74	0.46	2.2	0.210
" Area populated	927,800	8,000,000	8,004,000	1,700,000	21.0	8.74	1.83	1.01	0.210
United States	3,026,600	92,019,500	28,100,000	7,000,000	4.9	9.50	2.31	0.31	0.076
Austria-Hungary	241,340	49,418,600	6,460,000	566,000	8.8	26.80	3.14	0.13	0.019
France	297,100	39,601,500	5,587,000	650,000	11.6	17.00	5.02	2.39	0.487
Norway	124,140	2,402,700	5,500,000	440,000	20.4	44.30	7.27	0.27	0.024
Spain	194,700	18,018,100	5,000,000	500,000	15.6	26.00	4.08	0.81	0.127
Sweden	172,000	5,521,900	4,000,000	704,500	24.4	43.80	10.78	0.14	0.044
Italy	91,280	28,601,600	4,000,000	976,300	28.5	125.20	32.0	0.53	0.137
Switzerland	15,976	3,742,000	1,425,000	618,100	43.4	16.80	2.96	0.02	0.019
Germany	208,800	64,903,400	1,425,000	80,000	8.3	10.90	0.91	0.02	0.002
Great Britain	88,120	38,802,500	953,000	80,000	8.3	10.90	0.91	0.02	0.002

<sup>1</sup>Based on 12 per cent increase on official census of 1911.

<sup>2</sup>Does not include Alaska.

power in the aggregate was generated in small isolated plants, and was not covered in the tabulation. Also, the figures for the mines and quarries were complete only for 1902, and those of the manufactures were for 1905, while the balance were for 1907. Undoubtedly there was a marked addition during the omitted years, which would have considerably increased the total.

The three primary sources of the total power as listed were steam, water, and gas, supplying 18,858,000 horse-power, 3,423,000 horse-power, and 631,000 horse-power, or 82.3 per cent, 14.9 per cent, and 2.8 per cent, respectively. One of the most interesting features of the report is found in the data relative to the then recent development of central power installations distributing to more or less distant markets. The increase in the use of water-power in this connection during the period 1902 to 1907 was 208 per cent.

Returning to the listed total in table 43, the water-power now developed in the United States is 7,000,000 horse-power, or more than double the total for 1907. What proportion of this increase is due to the development of central stations for distribution to distant markets is not ascertainable from the data on hand. A review of the recent tendency in the construction of hydro-electric undertakings is sufficient, however, to indicate that the greater proportion has been so utilized. As covering the whole extent of the United States, the above is indicative of the rapid progress which has been made during recent years in the development of power projects distant from prospective markets, a progress that has been rendered possible by the advances in electrical transmission.

The results secured from a broad-based distribution of the above nature cannot, however, be applied indiscriminately to all sections of the country. A ratio of 76 horse-power per 1,000 population for the United States as a whole falls as low as 2 horse-power per 1,000 for Ohio, and rises to 650 horse-power per 1,000 in Montana.

It is apparent, therefore, that the distribution of water-power development is dependent not only on the natural facilities for cheap development, but also on the accessibility of a suitable market for the disposal of the energy. It is also evident that this market is not solely dependent on population.

#### HYDRO-ELECTRIC DEVELOPMENT IN CANADA.

Turning to the power situation in Canada, table 44 will be of interest. The developed power tabulated has been largely collected by engineers of the Dominion Water Power Branch, and is complete to the end of 1914. While the totals are not considered to be far astray, they cannot be taken as entirely accurate, since, due to lack of time, it has been necessary to place dependence on information from various unofficial sources. The population of the various provinces are based on a 12 per cent increase on the official census returns of 1911. The ratio of power developed to population as deduced from the above is a fair representation of the conditions maintaining in the Dominion to date.

The general ratio of water-power developed, taking the Dominion as a whole, is 214 horse-power per 1,000 population. A reference to the table will indicate that this distribution is by no means uniform throughout the provinces and the relation between the physical characteristics of the country, the occupa-

Table 41.—Ratio of Developed Power to Population in Canada.

Province.	Population.	ELECTRICAL ENERGY.		PULP AND PAPER.		OTHER INDUSTRIES.		GRAND TOTAL.	
		Total.	Per 1,000 Inhabitants.	Total.	Per 1,000 Inhabitants.	Total.	Per 1,000 Inhabitants.	For Province.	Per 1,000 Inhabitants.
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.
Ontario.....	2,825,000	632,083	223.8	83,375	29.5	73,008	26.2	789,466	279.5
Quebec.....	2,240,000	370,000	165.9	100,000	44.9	50,000	22.4	520,000	233.2
Nova Scotia.....	551,000	3,062	5.6	12,650	23.0	5,700	10.3	21,412	38.9
New Brunswick.....	394,000	5,890	15.0	3,050	7.7	4,450	11.3	13,390	34.0
Prince Edward Island.....	105,000	50	0.5	.....	.....	450	4.3	500	4.8
Manitoba.....	510,000	56,750	111.2	.....	.....	50	0.1	56,780	111.4
Saskatchewan.....	551,000	32,305	77.1	.....	.....	100	0.2	32,305	77.1
Alberta.....	419,000	216,345	493.0	49,000	111.3	4,275	9.7	269,620	614.0
British Columbia.....	439,000	12,000	126.4	.....	.....	.....	.....	12,000	126.4
Yukon.....	9,500	.....	.....	.....	.....	.....	.....	.....	.....
Total.....	8,033,500	1,328,465	165.5	218,075	30.9	139,033	17.3	1,715,573	213.7

NOTE.—The population of the provinces is based upon a 12 per cent increase over the official census for 1911.

tion of the local population, and the power developed, is at once apparent. Ontario, Quebec, Manitoba, and British Columbia are all well supplied with the natural facilities for successful water-power development, as is indicated by the ratios of 279, 233, 111, and 614 horse-power per 1,000 population respectively. In the Yukon, where the population is small and largely engaged in mining, the proportionate power developed is high. In the mountainous province of British Columbia, where high heads and an abundant run-off supply exceptional facilities for successful power development, and where the population is comparatively small, the proportionate power developed per head is exceptionally high. The industrial and urban life in Ontario and Quebec is making large demands on the respective water-power resources of the two provinces, and development keeps pace with a rapidly growing market.

Different conditions exist in the central prairie provinces. The population is largely rural, and the physical characteristics of the Middle West do not supply the conditions of uniform run-off and natural river fall essential to the cheap and immediate development of power from water. The rivers throughout this section are irregular in flow, with high floods and low winter discharges, and with fairly uniform but slow fall. Storage reservoirs for the relief of the extreme low-water winter conditions must form a necessary adjunct to the successful development of large undertakings throughout the central portion of the West. This has had the effect up to the present of restricting development, especially in the province of Saskatchewan, in spite of rapidly growing towns and cities which provide a ready and suitable power market. The province of Alberta, with the eastern slope of the Rocky mountains lying along its western border, provides better facilities for the development of hydro-electric undertakings.

At the time of writing there is upwards of 30,000 -horse-power turbine capacity installed on the Bow river at the Horseshoe and Kananaskis falls, the greater part of which is transmitted to Calgary and, together with a smaller development within the city limits, renders available about 20,000 horse-power for the supply of the city, the population of which is in the neighbourhood of 74,000. The ratio in this instance becomes about 270 horse-power per 1,000.

In the province of Manitoba, with which this report is mainly interested, the Winnipeg river was early recognized as a source of cheap power, to the end that a ratio of 111 developed horse-power per 1,000 inhabitants is shown in the above table. This is a high average for a population mainly engaged in agricultural pursuits. On looking into the distribution of the power consumers, however, the situation in the province emphasizes more strongly the influence of an urban population.

Of the total tabulated above for Manitoba, 50,000 horse-power is developed on the Winnipeg river, about 45,000 horse-power of which is available on the Winnipeg terminals for use in and around the municipality for purposes of street railway operation, lighting, heating, industrial and domestic use.

The general electrical power load in Winnipeg is at present carried by the two hydro-electric plants on the Winnipeg river, and by the auxiliary steam plant of the Electric Railway Company in the city. A combined peak load of

over 40,000 kilowatts or about 55,000 horse-power is frequently carried. On this basis, the general power requirements of the city are in the ratio of 260 horse-power per 1,000 population. In deducing the power requirements of the city of Winnipeg, this figure cannot be considered too high in view of the power which is in use throughout the city from other sources. It is probable that the ratio will rise rapidly in the future with the further development of industrial activity.

\* \* \* \* \*

A summary of the above data respecting the relation of water-power development to the number of population would serve to emphasize that, granting the existence of a supply of power capable of profitable development in competition with power from other sources, the ratio of development is not dependent so much upon the mere extent of the population as to the grouping of the same in industrial centres within easy and convenient transmission distance of the power sources.

This conclusion is illustrated definitely and concretely in the discussion and estimates on hydro-electric distribution in Manitoba, dealt with at a later stage.

#### THE WINNIPEG MARKET.

The market which first presents itself for the disposal of the Winnipeg river power is that of the city of Winnipeg. The growth of this city has been one of the remarkable features of the general development of the Canadian West.

#### HISTORY AND GROWTH OF THE CITY.

As a trading post of the Hudson's Bay Company, Winnipeg had a long and varied history, with, however, little growth in population or industry. In the year 1812, Lord Selkirk established his colonists in the Red River valley, but lack of trade outlet prevented any real progress. With Confederation, the securing of the Hudson Bay territory from the Hudson's Bay Company, and the suppression of the Riel rebellion by Colonel, afterwards Lord Wolseley, a new order came into being, and the development of the western territory commenced, with Winnipeg as the portal to the new Empire.

In 1870, Winnipeg, then a Hudson's Bay trading post, had a population of 215. In 1874 a population of 1,869 had assembled, and Winnipeg was incorporated as a city. In 1878 the first steam railway reached the city, coming in from the United States to the south. This was followed in 1886 by the advent of the Canadian Pacific from Eastern Canada, and the era of rapid development had arrived. Railway extension proceeded with unexampled rapidity until to-day the city is the hub of five railroad systems, with a total of fifteen radiating lines. The tabulated increase in yearly population, realty values, etc., based on the assessment records, and appended herewith, illustrates concisely the growth of the city.

Table 45.—Increase in Population, Realty Values, Building Permits, and Factory Output of the City of Winnipeg.

Year.	POPULATION.		Realty Value.	Building Permits.	Factory Output.
	City of Winnipeg.	Greater Winnipeg.			
1.	2.	3.	4.	5.	6.
			\$	\$	\$
1870	215				
1874	1,869				
1885	19,574				
1898	39,384				
1900	42,500	50,500			8,606,248
1902	48,411		30,496,920	2,408,125	
1903	56,741		38,596,680	5,689,400	
1904	67,262		50,595,900	9,651,750	
1905	79,975	97,401	65,662,240	10,840,150	18,983,248
1906	101,057	119,837	84,752,580	12,625,950	
1907	111,729	136,953	112,413,900	6,309,950	
1908	118,252	139,869	124,523,160	5,513,700	
1909	122,390	157,383	131,402,840	9,226,325	
1910	132,720	172,865	185,870,140	15,116,450	39,400,608
1911	151,958	204,145	200,888,600	17,550,400	
1912	166,553	227,339	247,601,580	20,563,750	
1913	184,730	260,436	299,698,980	18,357,150	
1914	210,000	276,177			145,000,000

<sup>1</sup>Estimated by Winnipeg Industrial Bureau.

Column 2, from city assessment records.

Column 3, from Henderson's Directories, Limited.

Twenty years from the date at which the population was only 215, the city had over 40,000 people. In the five years following 1902 the population was doubled. In 1914 the population is estimated, from assessment records, at 210,000. Including the surrounding municipalities which are comprised in the Greater Winnipeg Water district, i.e., St. Boniface, Transcona, Assiniboia, Fort Garry, St. Vital, and Kildonan, the total population is 237,000.<sup>(1)</sup>

In this connection, plate 76 is of interest. The curves thereon were compiled by the Board of Consulting Engineers, reporting to the Winnipeg Water Supply Commission in 1907, on the question of an adequate source of water supply for the future needs of the city. The curves show the relative rate of increase of the various cities of Canada and the United States after attaining a population of 100,000. According to the deduced curve of growth for Winnipeg, the population in 1914 should have been about 220,000. Reference to table 45 and to the population of the Greater Winnipeg Water District shows how closely the estimates of the engineers have been fulfilled.

The assumption that the rate of growth shown by the curve will continue in the future, will give to Winnipeg a population of 800,000 in the year 1948. Considering the past progress of the city and its unequalled situation and opportunities as the gateway of the West, and the abundant supply of cheap power within easy transmission distance this estimate does not seem unreasonable.

As was noted above, the present consumption of power in Winnipeg rises during peak loads to 260 horse-power per 1,000 population. The equivalent continuous power actually used is on the basis of 140 horse-power per 1,000.

<sup>1</sup>Henderson's directory for Winnipeg for the year 1915 gives the population of Greater Winnipeg as 273,047.

**DOMINION WATER POWER BRANCH**  
 J. B. CHALLIES, Superintendent


**CITY OF WINNIPEG**

**DIAGRAM SHOWING ESTIMATED FUTURE POPULATION**  
 NOTE: COMPILED FROM A DIAGRAM PREPARED IN 1907 BY  
 THE CONSULTING ENGINEER FOR THE CITY OF WINNIPEG  
 IN CONNECTION WITH THE CITY WATER SUPPLY.

James H. Fuertes  
 R. S. Lea  
 J. E. Schwitzer  
 George C. Whipple

**LEGEND**

City	Population, 100,000, in
Chicago	1869
St. Louis	1891
St. Paul and Minneapolis	1891
Cleveland	1870
Philadelphia	1867
Montreal	1864
San Francisco	1864
Milwaukee	1877
Boston	1877
Newark, N. J.	1876
Toronto	1882
Providence, R. I.	1879
St. Louis, Mo.	1882
Kansas City, Mo.	1886
Denver, Colo.	1882
WINNIPEG	1906



A population of 800,000 in 1948 would, on this basis, require some 200,000 horse-power available for peak-load distribution. This would, conservatively speaking, mean a development of 225,000 peak load on the river, or say 140,000 continuous horse-power.

According to the totals compiled elsewhere in this report, 418,000 twenty-four hour horse-power can be developed on the regulated river. The above calculation indicates that, after reserving sufficient power *at the present rate of consumption* to supply the city's requirements till 1948, there would still be an ample balance of available power on the river to use for other purposes. However, reference to the proportionate power growth curve on plate 78 shows a rapidly increasing use of electrical energy per head of population, and assuming that this rate of increase continues, indicates that practically the entire output from the river would be required by the city in about forty years.

The curve on plate 77 indicates the growth of power consumption in the city. This curve represents in terms of kilowatt hours per month and in continuous horse-power, the total load used in and around Winnipeg, from the Winnipeg Electric Railway Company's hydro-electric and steam plants and from the municipal plant at Point du Bois. The load carried by the steam plant prior to the construction of the Pinawa station in 1906 is not plotted. From this date the curve shows a growth from zero to 15,000,000 kilowatt hours per month, or to some 28,000 continuous horse-power.

In this connection, table 46 is of interest as showing the growth of the ratio of power used to the population.

The curve on plate 78 is based on table 46. It is to be noted that the ratio of power consumption to the population has been growing continuously and regularly since hydro-electric power was first transmitted to the city. The regularity of this proportionate increase is remarkable. With the abundance of power seeking market, and the industrial growth of the city at present in its vigorous infancy, there is every reason to anticipate that this proportionate use of power will continue to increase.

Plates 79 and 80 are also of interest in this connection as showing the general conditions of daily load maintaining in the city under typical summer and early winter conditions.

#### INDUSTRIAL DEVELOPMENT.

In recent years an active campaign has been inaugurated looking to the establishment of Winnipeg as an industrial centre. The opportunities in this direction can be readily realized when the location of the city is noted, lying as it does at the threshold of the agricultural West, and in close touch with an abundance of cheap power to the east. The enormous influx of people to the new lands has created a heavy and constantly growing demand for manufactured goods which offers possibilities to the city in the manufacturing line that the municipal authorities have not been slow to realize.


It is difficult to determine the exact quantity of manufactured goods brought annually into the West, but the railroad receipts at Winnipeg, covering some of the heaviest lines of imports, give a fairly accurate idea of how great is the flow of industrial products through this city into Western Canada.

**DOMINION WATER POWER BRANCH**  
 J. B. CHALLER, Superintendent

**GROWTH OF POWER CONSUMPTION**  
 IN THE  
**CITY OF WINNIPEG**

FROM THE PLACING IN OPERATION OF THE  
 PHAMA PLANT TO DATE  
 To accompany a report on POWER AND STORAGE  
 INVESTIGATIONS by J. V. JOHNSTON S.A.E.  
 March 31st, 1916.

**NOTE** Power consumption includes total loads of  
 Winnipeg Electric Railway Company's Steam Plant in Winnipeg  
 Winnipeg Electric Railway Company's Hydro Electric Plant at  
 Prairie Channel  
 City of Winnipeg Municipal Plant at Point du Bois



Total Monthly Load in Millions of Kilowatt Hours

Equivalent Horse Power at 100% Load Factor  
 Equivalent Horse Power at 50% Load Factor

1906 1907 1908 1909 1910 1911 1912 1913 1914 1915

29

A  
h  
s  
p  
c

f  
c  
c  
a  
H  
a  
t  
f

c  
t  
V  
t  
p  
t  
n

c

c  
r  
c  
v  
t

c  
v

v

v

v

**DOMINION WATER POWER BRANCH**  
 J. B. CHALLIES, Superintendent

**CURVE OF  
 PROPORTIONATE  
 GROWTH OF POWER CONSUMPTION  
 TO POPULATION**

in the  
**CITY OF WINNIPEG,**  
 FROM THE PLACING IN OPERATION OF THE  
 PIKAWA PLANT TO DATE  
 To accompany a report on POWER AND STORAGE  
 INVESTIGATIONS by J. T. JOHNSON, S.A.S.C.  
 March 6th 1916

**NOTE** Power consumption includes that  
 of:  
 Winnipeg Electric Railway Company, a Steam  
 Plant in Winnipeg  
 Winnipeg Electric Railway Company, a Hydro  
 Electric Plant on Pimasse Channel  
 City of Winnipeg Municipal Plant at Point  
 St. Bon







Table 46.—Ratio of the Growth of the Total Electrical energy used in Winnipeg to the Growth in Population. Power supplied by the Winnipeg Electric Railway company's steam and hydro-electrical plants and by the city municipal hydro-electrical plant.

Year.	Population.	LOAD IN KILOWATT HOURS.		LOAD IN HORSE-POWER HOURS.		MONTHLY POWER USED PER 1,000 POPULATION.		
		Total.	Monthly Average.	Total <sup>1</sup>	Monthly Average.	Kilowatt Hours.	Horse-power Hours.	Continuous Horse-power.
1906.....	101,057	8,500,000	1,417,000	11,300,000	1,898,780	14,030	18,400	25.8
1907.....	111,729	30,784,000	2,565,000	41,280,560	3,437,100	22,060	40,750	42.1
1908.....	118,252	40,734,000	3,395,000	54,383,360	5,437,100	28,700	38,450	52.6
1909.....	122,390	47,845,000	3,957,000	64,044,000	6,746,580	37,870	43,650	59.8
1910.....	132,720	66,441,000	5,031,000	97,974,000	8,746,580	47,870	50,900	69.7
1911.....	151,958	73,735,000	6,114,000	111,740,460	8,164,630	40,090	53,700	73.6
1912.....	166,553	105,709,000	8,814,000	141,578,460	11,816,760	52,800	70,900	97.1
1913.....	184,730	135,709,000	11,240,000	180,578,400	15,048,200	60,800	81,320	111.5
<sup>1</sup> 1914.....	210,000	135,979,000	13,598,000	182,211,860	18,221,186	64,780	86,400	119.0

<sup>1</sup>1906 for six months only.  
<sup>2</sup>1914 for ten months only.

DOMINION WATER POWER BRANCH  
J. B. CHALLIES, Superintendent  
CURVES OF  
TYPICAL DAILY POWER LOAD  
in the  
CITY OF WINNIPEG  
AUGUST 26, 1914


To accompany a report on POWER AND STORAGE  
INVESTIGATIONS by J. T. JOHNSTON B.Sc.  
March 8th, 1915



DOMINION WATER POWER BRANCH  
 J. B. CHALLIES Superintendent

**CURVES OF  
 TYPICAL DAILY POWER LOAD**  
 in the  
**CITY OF WINNIPEG**  
 NOVEMBER 19, 1914

To accompany a report on POWER AND STORAGE  
 INVESTIGATIONS by J. T. JOHNSTON B.A.S.  
 March 21st, 1915



Records show that 25,000 carloads of manufactured goods were received in 1910 with bills of lading reading Winnipeg, 75 per cent of which, it is estimated, could have been made in the country. A classification of the above total shows the following: 6,535 carloads of iron and the products of steel and iron, including structural steel, wire nails, hardware, machinery, iron pipe, stoves, furnaces, and tinware; 4,748 carloads of agricultural implements, automobiles, furniture, carriages, barrels, wagons, paints, organs and pianos. Paper, sugar, brick, sewer pipe, glass products, crockery, paints, canned goods all figure largely and range in quantities from 250 to 700 cars each.

The demand for manufactured goods is the normal sequel to the rapid development of the agricultural territory of the prairies. This development is proceeding continuously and rapidly, and is concurrently developing an increasing market for industrial products.

That Winnipeg is well able and ideally located to supply a large proportion of this demand for manufactured goods is well recognized, and that rapid progress in this direction is being made is evidenced by the fact that there are at present established in the city over 400 factories, employing in the neighbourhood of 20,000 hands, with an output in 1914 valued at \$45,000,000. The percentage of increase in the manufactures in the past ten years was 351, and in twenty years was 608. While these figures are indicative of rapid and substantial development, it may be said without exaggeration that the possibilities in this direction are at present little more than broached upon, and that the future holds much greater opportunities than have been grasped to date. The outstanding advantages upon which the city may confidently rely as ensuring its future industrial development are: an abundant supply of cheap power, unexcelled distribution facilities in the shape of railway connections, and a practically unlimited market for manufactured products.

#### THE GENERAL MANITOBA MARKET.

Turning to the province as a whole, the question of market conditions becomes somewhat more complex. This is mainly due to the fact that the industry of the province as a whole largely pertains to agriculture, with a consequent dispersed population.

The mineral and timber resources of the Prairie Provinces are to a great extent undeveloped, and undoubtedly offer a very profitable field for investment. Among such resources, to the development of which the Winnipeg river will undoubtedly be in part applied, might be listed limestone with clay and shale for Portland cement, calcareous shales suitable for natural cement, gypsum, friable sandstone for glass, clay for brick and tile, timber for building and manufacturing, and wood-pulp for paper manufacture.

#### GENERAL HYDRO-ELECTRIC DISTRIBUTION IN MANITOBA.

While on the question of power market in Manitoba, it will be well to look into the prospects of a general scheme of hydro-electric distribution throughout the province. In this connection we are fortunate in having to hand recent and reliable data, the Provincial Government having, with the co-operation of the

Dominion Water Power Branch, recently completed a very thorough study of the problem.

The development of the hydro-electric system of the province of Ontario under the Hydro-Electric Power Commission has widely advertised public ownership of transmission systems for the distribution of electrical energy, as well as the opportunities for successful public ownership and operation of hydro-electric generating stations. For some time there existed throughout the province of Manitoba a feeling that with the great water-powers of the Winnipeg so readily available, a duplication of the Ontario hydro-electric system in Manitoba was not only feasible but was bound to prove a successful undertaking. The outstanding difference between the conditions existing in the two provinces, i.e., that Ontario was thickly dotted with manufacturing towns and cities offering a large existing and rapidly growing market for power, while Manitoba was essentially an agricultural province with more scattered and in general less populous municipalities, was to a large extent overlooked.

In order to test the feasibility of an hydro-electric system for Manitoba the Provincial Government determined to thoroughly investigate the whole question. To this end a resolution was passed in the legislature providing for an investigation into the question of the development of publicly-owned hydro-electric power within the province, with a view to securing for all sections of the province, rural as well as urban, the benefits and conveniences enjoyed by the citizens of Winnipeg as the result of the expenditure of public money for power development and distribution. Mr. H. A. Robson, K.C., Public Utilities Commissioner of the province, was placed in charge of the investigation.

The general results of this investigation are of great interest, not only from the standpoint of a state-owned hydro-electric system, but also from the standpoint of private ownership and operation of a similar project. The commissioner based his report upon very thorough personal research, backed by reliable engineering data and expert engineering opinion as to the power available, the market offering, and the cost of constructing and operating a suitable system. Full and definite information was supplied by the Dominion Water Power Branch as to the water-power available for supplying such a system as was under consideration. An exhaustive analysis of the capital and annual cost of distributing the power throughout the province was made by Mr. W. E. Skinner, C.E., of Winnipeg, based upon the market to be anticipated, this being determined after a careful canvass of the municipalities and rural districts to be served.

The definite project investigated involved a generating station at Pine falls, distant 64 miles from Winnipeg, 367 miles of 110,000-volt, 61 miles of 60,000-volt, and 525 miles of 30,000-volt transmission line, as well as local 6,600 volt transmission. The 110,000-volt line was projected from Pine falls direct to Winnipeg, thence westerly to Brandon, thence directly south some 33 miles, thence east to the vicinity of Morris, and thence northeasterly to Winnipeg. The 60,000 volt transmission involved two lines radiating from Brandon, one southwesterly to Hartney, and the other southeasterly to Wawanesa. The 30,000-volt transmission involved lines radiating from Winnipeg, Portage-la-Prairie, Brandon, Rapid City, Hartney, Pipestone, Wawanesa, Glenboro,

Roland, and Plum Coulee. The 6,600-volt distribution was considered in a more general manner.

Mr. Skinner's estimates are based on first-class construction and standard equipment of permanent character, steel towers being considered for all 110,000-volt, 60,000-volt, and 30,000-volt lines. The proposed Pine falls—Winnipeg transmission comprised a single line of steel towers with two complete three-phase circuits. The balance of the high-tension line is estimated for one three-phase circuit, and provides for the stringing of a second. The distribution circuits are not included in the main estimates, as it was the intention of the report to cover only the outlay necessary to place the energy within reach of the different sections of the province.

The report assumes the development and placing on the low-tension switchboard of the Pine falls power plant 38,000 horse-power, i.e., the present minimum flow capacity of the river at that site. The transmission system is planned to deliver not less than 10,000 kilowatts over either branch of the loop.

The estimated capital cost of developing the necessary power at Pine falls was supplied by the Dominion Water Power Branch.

*Summary of Capital Cost (excluding distribution).*

Power-house, generating equipment, step-up transformers, etc.....	\$ 3,117,400
110,000-volt transmission.....	2,545,123
60,000-volt transmission.....	310,906
30,000-volt transmission.....	2,575,125
110,000-volt substations.....	600,511
60,000-volt substations.....	123,714
30,000-volt substations.....	569,330
<b>Total.....</b>	<b>\$ 9,902,109</b>
<i>Operation Costs (supplying towns and villages only).</i>	
Depreciation (on above capital cost).....	\$ 283,919
Interest, 5 per cent.....	495,105
Operation.....	177,580
<b>Total Annual Cost.....</b>	<b>\$ 956,604</b>

With the information at hand, Mr. Skinner estimated that an hydro-electric system in the section of the province indicated would result in the use of energy totalling 8,308,320 kilowatt hours per annum, 2,400,000 kilowatt hours of this total being for lighting and power purposes in farming communities, leaving 5,908,320 kilowatt hours for the towns and villages. Upon the above basis the unit cost to the towns and villages would average at the rate of 16.2 cents per kilowatt hour.

Upon taking into consideration the cost of a comprehensive system of rural distribution, the capital cost rises to \$18,633,909, with an annual charge of \$1,926,669. Taking this on a basis of 10,000,000 kilowatt hours' output (considerably above the estimated market) it raises the average rate to 19.26 cents per kilowatt hour.

These figures are greatly in excess of the price for which power is now being developed and sold by local plants throughout the district.

It is clear, therefore, that the present industrial status of the province does not warrant the inauguration of an hydro-electric system of the nature described. The enormous overhead charges which must be borne render such a scheme entirely impractical, until such time as the local market conditions throughout the province will guarantee at least a fair return from the investment at rates

reasonable to the consumer. That such a time will come, and that in the not distant future, can be confidently anticipated, if the present prosperity and rate of growth of the cities and towns of the province is continued.

While a comprehensive hydro-electric system of provincial scope for rural as well as urban supply is apparently out of the question at the present date, there is little doubt that the linking up of the major municipalities, especially those in the vicinity of Winnipeg, will offer attractive features and fair returns to the investor at rates reasonable to the consumer. An ample supply of cheap power to such centres will result in greatly accelerating their industrial development, enabling them to more fully grapple with the problem of supplying the West with manufactured products. Further investigation in this direction will probably show attractive features from a commercial standpoint.

Reference to plate 81, whereon are shown the municipalities of population over 100, located within a 400-mile radius of the power centre of the Winnipeg river in Manitoba, indicates the future promise of the district as well as the extent of the territory available for market. The Winnipeg river forms the only source of cheap hydro-electric power available in bulk for distribution in southern Manitoba. It will also be available for distribution in eastern Saskatchewan as soon as the market warrants its transmission.

#### PRESENT STATUS OF THE POWER SUPPLY.

The present status of the power supply available in the city of Winnipeg has already been referred to, but can be briefly re-stated.

The Winnipeg Electric Railway Company's hydro-electric plant on the Pinawa channel (see chapter V) has an installed turbine capacity of 34,000 horse-power which allowing for transmission, is fully utilized for lighting, industrial, and traction purposes in Winnipeg. This plant is augmented by steam turbine plants in the city with an installed capacity of 22,000 horse-power.

The city of Winnipeg has constructed at Point du Bois on the Winnipeg river (see chapter V), a modern hydro-electric plant with a present turbine installation of 47,000 horse-power. This power is for use in the city, 77 miles distant, for lighting and industrial purposes. Future enlargement of this plant, combined with a system of regulation on the river, will permit of an ultimate development of 76,800 continuous 24-hour power.

The Winnipeg River Power Company has at present under construction at the Du Bonnet falls (see chapter VI and Appendix II) a plant capable of an ultimate development with a regulated river, of 95,500 twenty-four hour horse-power, destined for the Winnipeg market and vicinity.

A summary of the above shows that a total of 81,000 horse-power turbine capacity is now installed on the river, and that the new development now under construction, together with the possible expansion of the municipal plant, guarantees an additional supply of about 130,000 continuous horse-power (after allowing for line losses) which is rapidly being provided to meet the market demands.

This leaves a total of some 220,000 continuous horse-power suitable for commercial use still latent in the river in Manitoba.

#### OTHER USES FOR WINNIPEG RIVER POWER.

It is clear from a study of the market conditions that if the Winnipeg river is to be used solely to supply power for lighting, traction, and general industrial undertakings, a large reserve of power will be left unutilized for many years to come. The present hydro-electric plants on the river, with their reserve of power, together with the new undertaking now under construction, will supply ample power for the above purposes for many years, not only to the city of Winnipeg and vicinity but also to such hydro-electric distribution systems as are likely to be profitably established, even allowing for the anticipated industrial expansion. It is advisable, therefore, to look into the prospects offering for the immediate profitable utilization of the unused power, since available water-power unused is a definite although not generally appreciated waste of natural resources.

The power at present running to waste on the Winnipeg river in Manitoba is equivalent to an annual consumption of 3,500,000 tons of coal or, at \$5 per ton, equivalent to an annual value of \$17,500,000. In so far as this power is not put to profitable use in connection with industrial enterprise, it is a definite and distinct loss to the economic and commercial life of the province.

#### PULP AND PAPER MANUFACTURE.


The Pine falls site possesses certain attributes which appear to offer exceptional opportunities for its use as a pulp and paper manufacturing site. The entire river basin above is available as a source for pulpwood supplies. Water connection with lake Winnipeg assures the widening of this source to include pulpwood areas adjacent to lake Winnipeg and its tributaries. Rail connection with Winnipeg by way of the Canadian Northern is probably assured within a few years. At present there is direct water transportation to the city.


On the whole, it would seem that a study of the site with a view to its utilization in connection with pulp and paper manufacture would well repay investigation. Information with respect to the site itself, and to its development, is now complete. Definite data with respect to the sources from which pulpwood could be secured are a necessary complement.

#### ELECTRO-CHEMICAL, ETC., INDUSTRIES.

A further field for the profitable utilization of the Winnipeg river powers is to be found in the various electro-chemical processes which during recent years have come increasingly to the front. Mr. J. R. Freeman in his report to the department on the Winnipeg river powers touched on this phase. The following is a selection from his report.—

“While water-power opportunities on the Winnipeg river may have a very few years ago appeared so far beyond possible use that ordinary economies were unnecessary, it is, I believe, plain to-day beyond serious question that all of the remaining opportunities for power should be





4

c

is  
u  
cc  
p  
at  
W  
lil  
ex  
in  
un

is  
toi  
is 1  
ano

exc  
The  
Wa  
incl  
con  
witl

utili  
inve  
is ne  
coul

is to  
have  
depa  
is a s

carefully conserved and only developed under such conditions as will not necessitate any great waste or the impairment of remaining opportunities.

"Sundry remarkable electro-chemical processes have been very recently invented, which promise to be of great future benefit to agriculture and other arts. Fertilizer for farmers' use is now being successfully made by electricity from the nitrogen of the air, and great water-powers in Norway are now being developed for these purposes in addition to those already in use, and recent developments have also been made of similar processes not far from the southern boundary of Canada.

"The great uses of hydro-electric power at Niagara falls and at the Sault, for making aluminum, carbide for gas lighting, bleaching powders, and caustic soda and sundry other important products were unknown only a few years ago. Indeed it may be said that every one of the electro-chemical processes now located at Niagara falls has been invented since the first of the large hydro-electric power stations was built at that point. It is idle to say that the era of important electro-chemical invention is yet more than begun and, with the many able investigators now earnestly working on these lines in many parts of the world, great additional discoveries and commercial developments in the application of cheap electric power are almost sure to come, particularly in metallurgy or the reduction of ores.

"*The Winnipeg market now fully supplied.*—The city of Winnipeg will soon have all the power that it needs for public service corporations and for any conceivable manufacturing purposes likely to locate in or near that city for perhaps a score of years to come.

"*A possible field for use.*—The best use that I can foresee for the vast water-powers now remaining untouched upon the Winnipeg river is as the basis for founding three or four new industrial cities based upon electro-chemical industry, very much as water power was the basis for creating years ago the cities of Lowell, Lawrence, Manchester, Holyoke, Bellows falls, and as in recent years it has brought together hundreds of new homes at Niagara falls, Shawenegan falls, and at the Sault.

"We cannot to-day say what the line of manufacture may be, for the electro-chemical arts are still in a state of ferment and creation. It has already been demonstrated that by electric smelting, steel for the manufacture of tools can be made having a quality and value difficult to obtain otherwise. Fertilizer in the form of artificial saltpetre is being produced commercially in large quantities under German processes, while carbide, carborundum, aluminum, and numerous other useful products are being made by electro-chemical means in great quantity at Niagara and elsewhere, and sooner or later the time will come when fertilizer will not be scorned by the farmers of the Canadian Northwest. There is prospect of new metallurgical processes for which cheap electricity is a necessity, and the price per pound of several of these products is such that they could stand a considerable cost of freighting to their markets, and such that a power capable of being developed in so vast

quantity at one point and at so low a cost per horse-power as appears practicable at three of the sites along the Winnipeg river, will surely be very attractive.

*"These new industries must locate close to the water fall.* These electro-chemical processes when carried on in the large commercial way demand that the work be done close to the point where the power is generated, for two reasons: first, because although the air-salt-petre process used alternating current, most electro-chemical processes require the direct current at low voltage which cannot be transmitted to great distances with anything like the facility of alternating current; and second, because in order to attract these processes it is necessary that the cost per horse-power be the very lowest and not overloaded by the cost of long transmission lines or the percentage of power necessarily lost in such transmission.

"Wherever a new industrial centre with some hundred of homes can be established in the wilderness within a hundred miles of Winnipeg, it will add to Winnipeg's prosperity in a degree but little less than if located within its borders, and will add to the prosperity of the province by the new opportunities that it brings for employment, the diversity that it adds to its business interests and by the money that it will put into circulation."

With respect to the present status of electro-chemical, electro-metallurgical, and electro-siderurgical industries, and as showing the room for further progress in the development of the same in Canada, Mr. Arthur Surveyer, M. Can. Soc. C.E., in a recent paper on the subject contributed to the Proceedings of the Canadian Society of Civil Engineers, has compiled some very interesting data.

In the provinces of Ontario and Quebec only 7.8 and 14.1 per cent, respectively, of the developed water-power is used in electro-chemical and electro-metallurgical processes, the remainder being used for motive power, traction, and lighting. In Manitoba, Alberta, and Saskatchewan the entire developed output is utilized for the latter purposes. On the other hand, in France, Norway, and Sweden, the proportion of power used in these processes is, respectively, 49.1, 50.6, and 32.4 per cent of the whole.

This comparative disproportion between the European countries named and Canada in respect to the use of power for these purposes is due to the natural efforts of a young and rapidly developing country to first meet the most urgent requirements of growth. A stage has now been reached in the country's development where it is advisable to give more aggressive attention to the expansion of the present electro-chemical and similar undertakings, and to the inception of further development along these lines. There will undoubtedly be in the future a vast market for the use of fertilizers in the western provinces, and the application of the Winnipeg powers in this direction should receive close investigation.

Further development in this direction will add largely to the general prosperity of the Dominion as a whole. It is therefore of prime importance that the Government should co-operate with prospective investors, and endeavour to interest capital in the possibilities of our undeveloped rivers. One

form of such assistance lies in placing before men of capital, such definite and exact information about our undeveloped water-powers as will enable them to accurately gauge the power procurable and the cost of developing the same. It is the object of this report to fully supply this information along the Winnipeg river.

— — —

In reviewing the general present market situation in Manitoba, with the prospects of future enlargement and of new industrial opportunity, the resources of the Winnipeg river do not appear greater than is necessary to ensure the continued progress of the province. Market for the whole power output of the river is assured when it can be produced as reasonably as is shown in the estimates in chapter VI.

It is therefore of the highest importance that the resources of the river be conserved to the utmost by careful oversight and by energetic control, based on definite knowledge of the situation. Such control, based on the extensive investigations which have been summarized herein, can now be exercised through the Dominion Water Power Branch.



REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

CHAPTER IX.  
INTERNATIONAL WATERWAYS REFERENCES



## CHAPTER IX.

### INTERNATIONAL WATERWAYS REFERENCES.

A considerable portion of the Winnipeg river watershed lies within the borders of the United States. The international boundary intersects the south-easterly limits of the basin, and has been established along a series of lesser lakes and connecting rivers and continued through lake Namakan, Kettle river, Rainy lake, Rainy river, and across Lake of the Woods to the western extremity of the Northwest arm, from whence it runs directly south to the intersection of the 49° parallel of latitude. In consequence of this international character, questions as to the handling of the water for power, storage, navigation, etc., are bound to arise and in many cases, to conflict with existing interests on both sides of the border.

Questions of this nature have arisen in the past and have been and are still being considered by international commissions appointed for this purpose.

In 1903, following correspondence between the representatives of Great Britain and the United States, the International Waterways Commission was provided for. Three commissioners from Canada and a similar number from the United States made up the commission and, among other questions, dealt with the Birch Lake diversion, a question of particular interest to the storage possibilities of the basin.

The International Waterways Commission, while continuing with a view to completing its investigations into international questions brought to its consideration, was superseded by the International Joint Commission. This commission was created by virtue of the provisions of the treaty between His Britannic Majesty and the United States, dated January 11, 1909. As in the case of the International Waterways Commission, the new Joint Commission consists of three commissioners from Canada and three from the United States. The three commissioners were appointed in 1911, and two questions of particular moment to the Winnipeg river situation have been under consideration, i.e., the diversion of water from Shoal lake for the Greater Winnipeg Water District and the Lake of the Woods reference. These two questions, together with the Birch Lake diversion, are reviewed hereunder.

#### BIRCH LAKE DIVERSION.

The Minnesota Canal and Power Company, a corporation organized under the laws of Minnesota, applied to the International Waterways Commission for permission to construct reservoirs in the Birch Lake basin in the southern portion of the Lake of the Woods drainage, in which water was to be stored and, as needed, conducted by artificial and natural channels southward to Duluth, there to be employed in generating power. This meant the withdrawal and diversion southward of the Birch Lake drainage from its natural outflow through the Winnipeg River system.

The physical conditions in the locality are as follows: The Birch Lake drainage basin is situated in the counties of St. Louis and Lake, in the state of Minnesota, the border of the basin being only about 14 miles from lake Superior. The drainage basin contains a chain of small lakes, the largest of these known as Birch lake lying near the western border of the basin. A portion of the drainage of this basin flows westerly through the North Kawishiwi river and Farm lake to Garden lake, with a fall of about 56 feet in the distance of 9 miles; another portion flows southwesterly through the South Kawishiwi into Birch lake and thence northerly through the Birch river and White Iron lake to Garden lake, the distance traversed by the waters along this route being about 24 miles. Passing Kawishiwi falls, the waters, continually increasing in volume, flow through Fall lake over the Pipestone falls to Basswood lake, lying on the international boundary between Canada and the United States. The waters thence flow in a general northwesterly direction through Crooked and Iron lakes, Lac la Croix, Namakan river and lake to Rainy lake, and thence through Rainy river to the Lake of the Woods, and thence to the Winnipeg river.

Within 2 miles of the western end of Birch lake, and separated from it by a low divide, rises the Embarrass river, its waters flowing southwesterly through Sabin, Embarrass, and Esquagaman lakes into the St. Louis river, and thence into St. Louis bay and Lake Superior.

The general works proposed to carry out this diversion project involved a dam at the mouth of the Gabbro lake to impound the water in the lakes tributary thereto and form what was to be known as the Isabelle reservoir; a dam in the North Kawishiwi river to impound the waters in the lakes and streams tributary to Birch lake, naturally flowing westerly into White Iron and Garden lakes; a dam in the South Kawishiwi river, which, in connection with the dam in the North Kawishiwi river, would form the Kawishiwi reservoir; and a dam in the Birch river at the outlet of Birch lake to impound its waters and form the Birch Lake reservoir. The reservoirs proposed were sufficient to store eight billion nineteen million cubic feet of water, and the claim was made that this capacity might be doubled by the extension of the works.

To convey the waters from the reservoirs to the site of development, the company proposed to cut a canal from the west end of Birch lake, a distance of about 6 miles, across the divide to the headwaters of the Embarrass river, and to erect controlling works at the entrance to this canal. From a point in the St. Louis river above Cloquet it was proposed to dig another canal about  $24\frac{1}{2}$  miles long, to a point in the city of Duluth where the bluff is about 600 feet above the level of lake Superior, and to lay pipes from the easterly end of the St. Louis river canal to the power house of the company to be erected on the shores of the St. Louis bay.

The minimum discharge from the Birch Lake drainage basin has been estimated by the engineers of the company to be about 220 cubic feet per second, and the average discharge 975 cubic feet per second. The reservoir system was considered ample to permit of storing sufficient water through the flood period to maintain a minimum discharge of 600 cubic feet per second available for power purposes. It was proposed to withdraw at least 600 second-feet from

the Birch Lake drainage basin and to utilize the same for the development of about 30,000 electrical horse-power in Duluth.

Many interests, both in the United States and Canada, were affected by this proposed withdrawal of the water from its natural channels. These interests were varied in character, the more important having to do with navigation, power, and lumbering. Several commercial corporations in both countries protested vigorously against the scheme. The Dominion Water Power Branch is particularly interested in the power and storage side of the question and the general effects of the diversion on the same. A short statement of these effects is appended.

After reaching the international boundary and Namakan lake, the water from the Birch Lake drainage basin, in its natural course, drops through 410 feet before reaching Lake Winnipeg, 348 feet of which are capable of successful commercial development. Of this total, 144 feet are already harnessed in hydro-electric and general commercial undertakings at Fort Frances, Kenora, Point du Bois, and in the Pinawa channel, while a further head of 56 feet is at present being harnessed at the Du Bonnet falls. The balance, 148 feet, can be successfully utilized as soon as the market demands. Of the full 348 feet of dependable drop, 30 feet are in international waters at the outlet of Rainy lake, 318 feet are wholly within Canadian territory, and 248 feet wholly within the provincial boundary of Manitoba. It will be readily understood, therefore, that the power interests affected by the withdrawal of 600 second-feet continuous flow from its natural channel of discharge are of very great magnitude. The argument might be carried a step further and the drop from Lake Winnipeg to Hudson bay by way of the Nelson river considered. This amounts to 710 feet in all, the greater part of which can be readily concentrated.

Considering the Winnipeg river system alone, 600 cubic feet per second with a concentrated drop of 348 feet means a permanent withdrawal of 19,000 horse-power.

It has been claimed that only the minimum or low-water discharge of the Birch Lake drainage should be considered in connection with the powers farther down the river, since during the balance of the year there is a great surplus of water in the remainder of the basin which would more than supply the amount withdrawn. With this viewpoint, considering the 220 feet minimum flow claimed by the company's engineers, the 348-foot head means a permanent loss of 7,000 horse-power to the Winnipeg river system.

The fallacy of this reasoning is evident when it is considered that unless storage or auxiliary power is secured, the low-flow period of the year is the measure of a power plant's capacity. When, as is the case of the plants of the Ontario and Minnesota Power Company at Fort Frances and International falls, the full minimum flow development has long been passed, and provision for extensive storage works to equalize the run-off is necessary, it becomes a matter of immediate concern, should any portion of the natural low-water run-off be by any means shut off or diverted. Even if it were practically feasible in the operation of the project after construction to discharge the natural low-flow run-off from the Birch Lake drainage down its natural channel, diverting the surplus only, a suggested solution, the general aspect of the question would

remain as before. It would be, to say the least, a peculiar application of the principles of conservation, to create storage dams in one section of a drainage basin for the purpose of storing and diverting a portion of the run-off to an entirely different watershed, while, at the same time, other dams are being constructed and other reservoirs being created in the same watershed for the purpose of augmenting the low-flow run-off of the basin itself in the interests of undertakings already established and in urgent need of water. Any storage which is created in the Birch Lake district is required for, and should be applied to, the equalization of the Rainy Lake drainage.

A reference to the discussion on storage in Chapter IV of this report will emphasize the necessity of conserving to the fullest extent the natural run-off of the Rainy Lake basin. In whatever way the diversion question is faced the broad fact remains that the proposed diversion would result in the withdrawal from the run-off resources of the Winnipeg watershed of the equivalent of a uniform discharge of 600 cubic feet per second, all of which is required in the development of its water-power resources as contemplated.

As a result of the vigorous protests of the parties and municipalities interested in the question, among which might be mentioned the North Eastern Minnesota Power Company, the St. Croix Lumber Company, the Enterprise Iron and Land Company, the town of Fort Frances, the Rainy River Improvement Company, the Ontario and Minnesota Power Company, the Rainy River Navigation Company, and the City of Winnipeg, the proposed diversion was carefully inquired into by the International Waterways Commission which, on November 15, 1906, rendered a report to the two Governments recommending, among other things, that the permit for diversion applied for be not granted without the concurrence of the Canadian Government.

The above recommendation was apparently successful in preventing steps being taken towards the actual construction of the project. It is, however, understood that the scheme has not been wholly abandoned and that it is still active in the Minnesota courts. It will probably be raised again before the International Joint Commission, and the interests adversely affected should be constantly alive to the importance of the question.

#### WATER SUPPLY FOR GREATER WINNIPEG WATER DISTRICT.

The city of Winnipeg has, during recent years, made careful investigation into the question of a suitable source of water supply. In July, 1906, a "Water Supply Commission," under chairmanship of Mr. J. P. Ashdown, was appointed under authority of a special Act passed by the Manitoba Legislature, for the purpose of investigating and reporting on the best available sources of supply. In order to secure the expert opinion necessary to a proper solution of the engineering and technical questions inseparable from an undertaking of this nature, a "Board of Engineers" was appointed consisting of J. H. Fuertes, C.E., of New York; G. C. Whipple, C.E., of the firm of Hazen and Whipple, Consulting Engineers, New York; R. S. Lea, C.E., of Montreal; and J. E. Schwitzer, C.E., Assistant Chief Engineer, Canadian Pacific Railway.

Several sources of supply were considered, among the more important of which were: a continuation of the present artesian well system; Shoal lake,

tributary to the lake of the Woods; the Winnipeg river, and the Red river. After a careful study of the different proposals and full consideration of all aspects, and more particularly of the then financial position of the city in relation to both the water supply undertaking and to the municipal power proposals then taking form, the board reported in favour of the Winnipeg river as the most suitable source of supply, the water to be taken from a point just above the Seven Sisters rapids.

The recommendations of the board were not acted upon at the time, the city being fully occupied in the municipal hydro-electric undertaking at Point du Bois, and the matter lay dormant until the year 1913, when the Greater Winnipeg Water District composed of the cities of Winnipeg, St. Boniface, Transcona, Assiniboia, Fort Garry, St. Vital, and Kildonan was constituted a corporation, and the question was again brought under consideration. A new board of consulting engineers, consisting of J. H. Fuertes, C.E.; R. Hering, C.E., of New York; and F. P. Stearns, C.E., of Boston, had charge of the investigation. This board, in view of the satisfactory completion of the municipal power plant, and the consequent improved financial position of the city in respect to a large expenditure such as would be involved in securing a suitable water supply, made a more detailed study of the Shoal Lake proposition.

As a result of, and based on, the fuller data secured in this investigation, Shoal lake was recommended as offering the most satisfactory source of supply for the city, and active steps were taken towards getting the project under way.

Since Shoal lake is practically an arm of the lake of the Woods, receiving water from and discharging water into that lake as the surface level varies, it was considered a boundary water and, consequently, came under the jurisdiction of the International Joint Commission, in so far as any interference with its natural discharge conditions might be contemplated. It was necessary, therefore, that the city should secure the formal assent of the Joint Commission prior to commencing active construction work, in order that the project might be inaugurated on a strictly legal basis.

A formal petition was accordingly made requesting that the commission confirm the petitioners' right to take the water of Shoal lake and the lake of the Woods for the purpose of a domestic supply.

The aqueduct proposed provided for a capacity of 85,000,000 imperial gallons per day, which, on a basis of 100 gallons per inhabitant, allowed for a population of 850,000 people.

The Dominion Water Power Branch was interested in the application of the city in two respects: first, in the quantity of water withdrawn from the Shoal lake, and consequently from the powers of the Winnipeg river in Manitoba; and second, in the effect of the same on the levels of the lake of the Woods.

In so far as the quantity of water withdrawn was concerned, little objection could be raised, since domestic water supply must, at all times, receive first consideration in the disposal and utilization of river run-off. Again, the quantity of water (equivalent to 157 cubic feet per second) was not excessive. The effect of the withdrawal upon the surface level of the lake was, however, of more importance to the power interests under the jurisdiction of the Dominion Water Power Branch. One hundred and fifty-seven cubic feet per second for one year is

equivalent to a depth of 1.42 inch on the lake of the Woods. This is stated more as illustrative of the comparatively small effect of the water supply withdrawal upon the storage question, than as being of any immediate concern to the question of regulation on the lake. Up to the present, there has been at all times a very great wastage of water at the lake outlets amounting to many times the quantity required for the city's water supply.

The hearing in the matter took place in Washington on January 13 and 14, 1914. The various interests affected were represented and the various arguments for and against were considered.

The question of the regulation of the lake was already before the commission in what was known as "the Lake of the Woods Reference," covered at length hereunder.

In view of the importance to the city of an immediate granting of the application in order that construction could be commenced at once, and of the consequent inadvisability of waiting for the definite settlement of the Lake of the Woods Reference, authority was secured from the municipal authorities by the city representatives at the hearing, to press for an immediate settlement of the question and risk a possible future adverse fixing of the low limit of lake regulation for power purposes.

As a result of the various representations made, the commission approved the application of the Water District in the following words: -

"That the use and diversion of the waters of Shoal lake and of the lake of the Woods for domestic and sanitary purposes by the inhabitants of the Greater Winnipeg Water District, prayed for in the said application, be permitted, subject to the conditions contained in the statutes and orders in council herein above recited. And provided, further, that the water so to be diverted from Shoal lake and from the lake of the Woods be not used for other than domestic and sanitary purposes, that the present approval and permission shall in no way interfere with or prejudice the rights, if any, of any person, corporation, or municipality to damages or compensation for any injuries due in whole or in part to the diversion permitted and approved of, and that the quantity of water so taken and diverted shall never at any time exceed one hundred million gallons per day. And provided, further, that the present permission and order shall not be invoked or relied upon in any manner against the recommendations or report to be made by the commission on the reference to it respecting the levels of the lake of the Woods, and shall in no way interfere with the action of the commission in that regard.

"Dated at Washington the fourteenth day of January, one thousand nine hundred and fourteen.

It will be noted that it is specifically provided in the above permission and order that the future fixing of lake levels is not prejudiced thereby. Other considerations as well will serve to prevent conflict between the question of water supply on one hand and lake regulation on the other.

The city of Winnipeg, through its municipally owned and operated plant at Point du Bois, is interested equally with other power interests on the lower

river in the question of power regulation in the lake of the Woods, and must therefore give a sympathetic consideration to the fixing of the lower regulation limit at such an elevation as will ensure maximum utilization of the full power available at Point du Bois. Should this low limit interfere with the discharge of 85,000,000 gallons per day through the water supply intake during times of low water on the lake, it must be remembered that such periods will only be of very rare occurrence, possibly once every two or three years, and then for only a month or so at a time. To meet such a contingency, a pumping plant to raise the water the one or two feet necessary could be cheaply provided.

#### LEVELS OF THE LAKE OF THE WOODS.

By far the most important reference placed before the International Joint Commission to date, in so far as the power situation on the Winnipeg river is affected, is that having to do with the levels of the lake of the Woods. The reference was jointly submitted to the commission by the Governments of Canada and the United States, for examination and report, with such conclusions and recommendations as might seem appropriate. It consists of the following questions: -

(1) In order to secure the most advantageous use of the waters of the lake of the Woods and of the waters flowing into and from that lake on each side of the boundary for domestic and sanitary purposes, for navigation and transportation purposes, and for fishing purposes, and for power and irrigation purposes, and also in order to secure the most advantageous use of the shores and harbours of the lake and of the waters flowing into and from the lake, is it practicable and desirable to maintain the surface of the lake during the different seasons of the year at a certain stated level; and if so, at what level?

(2) If a certain stated level is recommended in answer to question No. 1, and if such level is higher than the normal or natural level of the lake, to what extent, if at all, would the lake, when maintained at such level, overflow the lowlands upon its southern border, or elsewhere on its border, and what is the value of the lands which would be submerged?

(3) In what way or manner, including the construction and operations of dams or other works at the outlets and inlets of the lake or in the waters which are directly or indirectly tributary to the lake, or otherwise, is it possible and advisable to regulate the volume, use, and outflow of the waters of the lake so as to maintain the level recommended in answer to question No. 1, and by what means or arrangement can the proper construction and operation of regulating works, or a system or method of regulation, be best secured and maintained in order to ensure the adequate protection and development of all the interests involved on both sides of the boundary, with the least possible damage to all rights and interests, both public and private, which may be affected by maintaining the proposed level?

This reference is still before the commission, and considerable progress has been made to date. Hearings have been held at International Falls and Warroad, in Minnesota, and at Kenora, in Ontario, and were attended by

representatives of the Dominion of Canada, the state of Minnesota, the provinces of Ontario and Manitoba, the cities or towns of Fort Frances, International Falls, Warroad, Kenora, and Winnipeg, local boards of trade, and various navigation, lumbering, power, fishing, agricultural, and other interests. The principal interests concerned in the questions at issue were those connected with power and manufacturing, navigation, agriculture, and fishing. The reference has a vital bearing on the successful carrying out of a policy of power conservation in the watershed.

The Dominion Water Power Branch has taken a very active interest in the entire question of the lake of the Woods regulation. The power resources of the Winnipeg river in Manitoba, which come under the jurisdiction of the Dominion Water Power Branch, are of great magnitude; the investigation into these resources has been most extensive and complete, while the method of administration which is being adopted is far-reaching and involves the principles of fullest conservation of the power resources. It was an essential sequel to the power studies that the unexcelled storage possibilities of the lake of the Woods should receive careful consideration.

At the commencement of the Winnipeg river power and storage surveys, the storage opportunities of the lake of the Woods were recognized as an outstanding feature of the watershed, and as one of the exceptional advantages which it possessed in the interests of a comprehensive power system such as was contemplated. Steps were at once taken to gather all possible data relative to the past surface levels of the lake, to the discharges from the lake through the various outlets, to the history and general utilization of the outlets, to the artificial structures in the way of dams, bridges, mills, and power stations which have been built at the outlets and, in short, to secure all existing information which might have influenced the lake levels in the past and have a bearing on the future systematic regulation. In addition to the securing of past records, active steps were at once taken to establish metering stations at the outlets and to secure an accurate record of the daily discharge, as well as to maintain careful gauge readings of the lake surface level and of all vital head- and tailwater elevations.

The securing of the above data became increasingly necessary as a result of the conflict of interests which has arisen over the question of surface regulation, and while the full compilation of the material is not yet completed, nor a final study possible, sufficient has been gathered to fully establish the necessity for a measure of regulation on the lake if the full power resources of the river below are to be realized.

The discussion on storage has already pointed out the necessity of a very substantial regulation in the lake for the proper control of the run-off of the basin. It is advisable at this stage to summarize the more important results which will arise from adequate regulation and non-regulation respectively.

## LAKE LEVELS.

Before examining into the question of regulation for power purposes in the Lake of the Woods, it is of interest to look again into the past surface-level records, since the conditions shown by them have a particular bearing on the question of future systematic control.

Table 20 lists the mean monthly levels of the lake of the Woods as based on the gauge records of the Ontario Department of Public Works, taken at the Keewatin traffic bridge, to which corrections have been applied as a result of a study and comparison of the surface-level records available around the lake.

The figures in table 20 are not published as definitely and finally setting out the lake levels over the period in question. A numerous and complicated series of gauge readings have been kept at different points around the lake by various parties interested. The collation and study of these records is now being carried on by Mr. S. S. Scovil of the Lake of the Woods Technical Board, and will result in an authoritative statement as to the lake levels prevailing in the past. The levels listed herein can, however, be taken as representing with very fair accuracy the surface conditions over the period covered. It should be pointed out that these figures represent average monthly elevations, and that daily records show much more extreme conditions.

The levels are given to Dominion Water Power Survey datum.<sup>(1)</sup>

The maximum mean monthly elevation recorded in the cycle is 1060.8 for the month of July, 1899, and for the month of October, 1907. A rise above elevation 1060 is of common occurrence, as is instanced by the twenty-one listed months showing higher records. The lowest average monthly surface level in the period is 1055.4, occurring in January, 1912, and making a maximum range between monthly averages of 5.4 feet for the period tabulated. The actual range between extremes of daily records was considerably higher.

## RUN-OFF.

Reference to chapter III will give in detail the run-off data which have been secured to date in the Winnipeg drainage basin.

For a study of the storage and run-off conditions in the watershed, there are available continuous discharge records from 1907 to date, at three important points on the river system, i.e., at Slave falls on the power reach in Manitoba, at the outlets of the lake of the Woods, and at the outlet of Rainy lake. Upon these records have been based the statements herein as to the influence of the Lake of the Woods on the run-off of the Winnipeg river.

Since water-power is wholly and entirely dependent on run-off, the influence of the lake of the Woods on the power question is as direct and as complete as is its influence on the river flow.

<sup>1</sup>Elevation 959.8 Water Power Survey = zero of the present gauge of the Ontario Department of Public Works at Keewatin.

Elevation 1053.3 Water Power Survey datum = zero of the present gauge at Warroad.

Zero of the Water Power Survey datum = 1.3 on the United States Coast and Geodetic Survey datum.

## INFLUENCE OF THE LAKE OF THE WOODS ON THE RUN-OFF OF THE WINNIPEG RIVER BASIN.

The influence of the lake of the Woods on the run-off of the Winnipeg River basin is treated under three headings: first, the results arising from the incomplete measure of regulation now in operation on the lake; second, the results arising from the maintenance of the lake at one uniform level throughout the year, and from year to year; and third, the results arising from a properly and systematically operated system of power regulation and control on the lake.

## (A) CONDITIONS RESULTING FROM PRESENT SYSTEM OF REGULATION.

The regulation of the surface level of the lake of the Woods is at present in control of the Keewatin Power Company, subject to supervision on the part of the Minister of Public Works of the province of Ontario for the protection of navigation interests. The regulation of the lake has not in the past been based upon a study of the general run-off conditions of the watershed, such records not being available for this purpose. It has consequently been of a somewhat irregular character, more with the object of meeting sudden and pressing local exigencies than with the idea of a permanent and systematic control meeting all requirements.

Even under such a measure of control as has been realized in the past, the benefits to the power reach below have been most marked. The plants of the Winnipeg Electric Railway Company and of the city of Winnipeg were not in operation prior to the inauguration of the present measure of control on the lake of the Woods, and consequently have not experienced the natural low run off conditions which would have maintained without the present balancing effect of the lake. It is probable, therefore, that the beneficial effect of the present measure of regulation is not fully appreciated by these hydro-electric undertakings.

During the period since 1907 over which discharge records are available, the lowest daily flow recorded at Slave falls on the Lower Winnipeg was 11,700 cubic feet per second. This discharge occurred on March 27, 1911. Discharges in the neighbourhood of 12,000 cubic feet per second have been frequently recorded. For the purpose of convenient use, 12,000 cubic feet per second has been taken throughout this report as the minimum flow to be anticipated in the power reach under present conditions of regulation.

The maximum mean monthly record over the period in question is 52,820 cubic feet per second for the month of May, 1910, while the maximum daily flow recorded is 53,440 cubic feet per second on May 7 of the same year.

Over the same period the minimum mean monthly discharge from the lake of the Woods was 4,870 cubic feet per second, occurring in the month of July, 1912, and the minimum daily flow was 4,425 on July 21 of the same year. Mean monthly discharges below 5,500 cubic feet per second are of frequent occurrence. For the purpose of the present discussion, 5,500 cubic feet per second is therefore considered a *conservative* figure at which to place the minimum outflow from the lake under the present system of regulation.

The maximum mean monthly record from the lake over the period in question is 24,690 cubic feet per second occurring in May, 1910, while the maximum daily flow recorded is 25,238 cubic feet per second occurring in May 4 of the same year.

It might be pointed out here that the inflow from the English river below the outlets from the lake and above the Manitoba power reach necessitates the consideration in the following of two limiting flows along the respective reaches.

#### (II) CONDITIONS RESULTING FROM NO POWER REGULATION ON THE LAKE.

Should the lake of the Woods reference be decided in the affirmative, that is to say, in favour of maintaining the lake surface at a fixed uniform level throughout the year, and from year to year, the effect on the run-off would be essentially the same as *the complete removal of the lake from the watershed* in so far as the question of its influencing or controlling the flow of the Winnipeg river is concerned.

The immediate result of maintaining a uniform flow would be the increasing of the present flood discharges, and the decreasing of the present minimum discharges. Furthermore, the effect would be to raise the flood discharges and to lower the low water discharges above and below what they would respectively have been under natural conditions of run-off in the basin. In other words, lower winter flows and higher spring and summer floods than have at any time been experienced in the past, would be experienced, due to the elimination of the natural balancing effect of the lake.

It is the low winter flow with which the power interests are most concerned.

From the run-off data which have been collated and secured in the field by the departmental engineers, it has been calculated that, with the influence of the lake of the Woods removed from the watershed, as it would be under conditions of a continuous and unchanging surface level, a minimum outflow of 3,600 cubic feet per second is to be anticipated from the lake, while a minimum flow of 7,000 is to be anticipated on the power reach of the Winnipeg river in Manitoba.

#### (III) CONDITIONS RESULTING FROM COMPREHENSIVE AND SYSTEMATICALLY CONTROLLED REGULATION ON THE LAKE.

A far-sighted properly controlled system of regulation for power purposes on the lake between definite fixed limits, and based on the definite run-off and storage data now in possession of the engineers of the department, will vastly improve the present surface level conditions on the lake of the Woods, the outflow from the lake, and the run-off available on the power reach in Manitoba.

The calculations which are now possible as a result of the field investigations and studies of the engineers of the Dominion Water Power Branch, show that with suitable regulation on the lake of the Woods and under the present condition of power development at the lake outlets, it will be a comparatively easy matter to ensure a minimum flow of 20,000 cubic feet per second on the power reach in Manitoba, and that a minimum flow of 12,000 cubic feet per second from the lake may be possible.

<sup>1</sup>In dealing with the question of one level, minimum flows only have been considered. An investigation of flood discharges would also be necessary.

On the other hand, a study of the lake distribution over the balance of the watershed, and assuming storage possible on the majority of these lakes, shows, from a review of the general run-off records, that if no regulation for power purposes is permissible on the lake of the Woods, the present discharge conditions can be but slightly bettered, even with complete regulation on these lakes. Also, such regulation, even if practicable, could only be secured by a very heavy expenditure for the construction of numerous storage dams, and for their maintenance and operation.

In considering regulation for power purposes on the lake of the Woods, it is important to note that an actual variation of some 6 feet has taken place in the past fifteen years; furthermore, that past control has been most irregular the low surface levels at times occurring during the summer season when navigation interests have been most adversely affected. At the same time, the result of this past regulation has not ensured from the lake a greater minimum outflow than 4,870 cubic feet per second, or than 11,700 cubic feet per second on the power reach in Manitoba.

Systematic regulation between fixed upper and lower limits can be so operated that past conditions of lake level will be greatly improved, at the same time maintaining high minimum flows. Reference is here made to plate 24, discussed at length in chapter V. This plate shows a mass curve study of the general run-off and the lake level conditions which might have been maintained from January 1, 1907 onwards, had a properly controlled system of power regulation been enforced at the lake outlets. The lower surface-level curve on this plate shows the actual conditions of lake level for the years 1907 to 1914, inclusive, over which run-off records are available. The upper curve shows a possible series of controlled levels for the same period. The *actual* conditions represented by the first curve ensured only 12,000 cubic feet per second in the Manitoba power reach, while those *assumed* for the second ensure 20,000 cubic feet per second, and at the same time supply more than sufficient water to properly operate the present power plants and mills at the lake outlets. The latter curve shows the result of systematic and intelligent power regulation. In this curve the greatest variation in lake level in the seven-year period is 3.1 feet, that is to say, although some 6 feet variation has taken place in the past seven years, only 3.1 feet would have been required to maintain the desired 20,000 cubic feet per second. While this measure of regulation would, under the conditions assumed, have ensured the 20,000 cubic feet per second desired, a somewhat larger measure of regulation is necessary to ensure this flow at all seasons under the fuller degree of development at the lake outlets which is to be anticipated, and under the more extreme run-off conditions which may occur in the future. It is well to note here that the eight-year cycle which has been studied in plate 24 includes a period of exceptionally low run-off.

Drawing the lake down to its lowest limit would in any event be a matter of very rare occurrence, and only necessary at long intervals of years. Again, the lowest stage on the lake would in the natural course of events occur about the end of March or the middle of April. In a normal year the lake would rise 0.7 foot in April, 0.9 foot in May, 0.8 foot in June, 0.5 foot in July, 0.5 foot in

August, 0.6 foot in September, 0.5 foot in October, and 0.4 foot in November, or practically 5 feet in the eight months named, and at the same time possible an abundant supply of water for the present power users at the lake outlet.

(D) SUMMARY OF THE INFLUENCE OF THE LAKE OF THE WOODS ON THE RUN-OFF OF THE WINNIPEG RIVER.

In brief the influence of the Lake of the Woods on the run-off of the Winnipeg river basin is as follows:

*Present system of regulation* results in a minimum flow of considerably less than 5,500 cubic feet per second for the reach below the lake to the junction with the English river, and of somewhat less than 12,000 cubic feet per second for the power reach in Manitoba.

*No power regulation permissible on the lake* would result in a minimum flow of about 3,600 cubic feet per second for the reach below the lake to the junction with the English river, and of 7,000 cubic feet per second for the power reach in Manitoba.

*Systematically controlled regulation on the lake for power purposes* would render possible a minimum flow of 12,000 cubic feet per second for the reach below the lake to the junction with the English river, and ensure 20,000 cubic feet per second for the power reach in Manitoba.

INFLUENCE OF THE LAKE OF THE WOODS ON THE POWER AVAILABLE IN THE WINNIPEG RIVER.

The lake of the Woods influences the power possibilities of the Winnipeg river in direct proportion to its influence on the run-off. This influence is discussed in detail hereunder, covering the entire series of power plants and possible sites of power development along the river from the lake of the Woods to lake Winnipeg. All development capacities are in terms of 24-hour horse-power at 75 per cent efficiency.

(A) *Outlets of the Lake of the Woods.* Three developments are at present in operation at the outlets from the lake of the Woods.

The Kenora municipal plant, constructed in 1906 and succeeding a prior plant constructed in 1892, has a present turbine installation of four units of 900 horse-power each (manufacturers' rating), or 3,600 horse-power in all. Two bays are still in reserve for the installation of two additional units. The power is used for lighting and municipal distribution in Kenora and Keewatin.

The Lake of the Woods Milling Company's mill "C," replacing a former smaller development, was placed in operation in 1907. The turbine capacity installed at present consists of two runners of 900 horse-power operating the mill, and one runner of 600 horse-power direct connected to a generator for lighting and hoisting purposes. The total turbine capacity (manufacturers' rating) is 2,400 horse-power.

The Lake of the Woods Milling Company's mill "A" was placed in operation about the year 1887. The present turbine installation consists of two horizontal turbines on one shaft rated at 2,400 horse-power, one wheel of 95 horse-power, two generator turbines of 360 horse-power each, and one fire pump turbine of

180 horse-power. The total turbine capacity installed (manufacturers' rating) is 3,395 horse-power. The power is used in running the milling machinery and in supplying light and power to the hoists, elevators, etc.

The total turbine capacity installed at the outlets from the lake is at present 9,395 horse-power. In view of the working conditions and of the use of certain runners as auxiliaries, only 60 per cent or 5,637 horse-power of this capacity is considered herein as continuously in use.

Plate 82 graphically illustrates the present conditions of the power situation at the lake outlets (fig. 2) and the comparative conditions which will result from no regulation (fig. 1), and systematically controlled regulation (fig. 3), respectively.

*Present regulation* means a total development capacity of 9,390 horse-power, i.e., 3,753 horse-power in reserve over and above the present continuously employed power, or practically the same as the turbine capacity now installed.

*No power regulation* on the lake means a development capacity of 6,140 horse-power or 503 horse-power in reserve over the present continuously employed power.

*Systematically controlled regulation* on the lake means a development capacity of 20,500 horse-power or 14,863 horse-power in reserve over the present continuously employed power.

A comparison of the above figures will concisely illustrate how greatly the industrial future of the communities at the outlets of the lake depends on the question of power regulation in the lake. No regulation means no further expansion without steam auxiliary, while complete regulation means 14,863 additional horse-power available for industrial expansion, or more than two and one-half times the present power capacity.

(B)—*White Dog falls.*—The Dominion Water Power Branch has made no detail field investigations with a view to ascertaining the concentration possibilities along the river from Kenora to the junction with the English river. Private investigations and reconnaissance observations, would indicate that a 45-foot head can be economically developed in this reach.

*Present regulation* on the lake of the Woods means a development capacity of 21,100 horse-power along this reach.

*No power regulation* on the lake of the Woods means a development capacity of 13,800 horse-power.

*Systematically controlled regulation* on the lake of the Woods means a development capacity of 46,100 horse-power.

(C)—*City of Winnipeg Municipal Plant at Point du Bois.*—The city of Winnipeg completed the initial installation of the municipal plant in 1911. This installation consisted of five 5,200 horse-power turbines. Three additional units have been installed during the past year of 7,000 horse-power capacity per unit, making a total present turbine installation of 47,000 horse-power. In addition to this, the city has constructed the headworks of eight additional bays, in order to duplicate the existing power station as soon as the market demands.

Plate 83 graphically illustrates the influence of the lake of the Woods regulation on the municipal undertaking.

*Present regulation* on the lake of the Woods means a development capacity of 46,100 horse-power at the city station.

*No power regulation* on the lake of the Woods means a development capacity of 26,900 horse-power at the city station.

*Systematically controlled regulation* on the lake of the Woods means a development capacity of 76,800 horse-power at the city station.

The above indicates that with no regulation on the lake there would not be sufficient water to operate the present installation during times of low water, and the construction of a steam auxiliary in the city would be necessary in the immediate future. Even under the present condition of regulation on the lake, the minimum flow will be practically entirely utilized by the machinery now installed, leaving no power available for the second half of the power station yet to be completed.

To ensure not only the profitable completion of the duplicate section, but even the dependable use of the present section of the power station requires, therefore, that power regulation must be assured on the lake of the Woods.

(D)—*Slave Falls site.*—The Winnipeg River Power Investigations show that a head of 26 feet can be profitably developed at Slave falls.

*Present regulation* on the lake of the Woods means a development capacity at this site of 26,600 horse-power.

*No power regulation* on the lake of the Woods means a development capacity of 15,520 horse-power.

*Systematically controlled regulation* on the lake of the Woods means a development capacity of 44,400 horse-power.

(E)—*Upper Seven Sisters site.*—The power investigations covered herein show that a head of 29 feet can be profitably developed at the Upper Seven Sisters concentration. At this site, a portion only of the river flow is available, since the plant of the Winnipeg Electric Railway Company on the Pinawa channel requires an average flow of 8,000 cubic feet per second. The net result of this is that the Upper Seven Sisters site will be entirely unfavourable for development until such time as a fairly complete system of regulation is instituted.

*Present regulation* on the lake of the Woods means a development capacity of 9,900 horse-power at this site, after allowing 8,000 second-feet down the Pinawa channel.

*No power regulation* on the lake of the Woods means no development capacity at this site.

*Systematically controlled regulation* on the lake of the Woods means a development capacity of 29,600 horse-power at this site.

(F)—*Lower Seven Sisters site.*—A head of 37 feet can be profitably developed at the Lower Seven Sisters site. As is the case of the Upper Seven Sisters site, a portion only of the river flow is available, an average of 8,000 cubic feet per second being diverted down the Pinawa channel.

*Present regulation* on the lake of the Woods means a development capacity of 12,600 horse-power at this site after providing for the Pinawa Channel flow.

*No power regulation* on the lake of the Woods will completely cut off the flow from this reach during ordinary winter seasons, and render it entirely unfeasible of development.

*Systematically controlled regulation* on the lake of the Woods means a development capacity of 37,900 horse-power at this site.

It might be noted here that neither the Upper nor the Lower Seven Sisters site is capable of profitable development until a minimum flow in the neighbourhood of 20,000 cubic feet per second is assured in the power reach in Manitoba.

(G)—*Winnipeg Electric Railway Company's Plant on the Pinawa channel.*—The hydro-electric plant of the Winnipeg Electric Railway Company is located on the Pinawa channel of the Winnipeg river. The water supply necessary to properly operate the plant varies with the different conditions of load, but has been placed at an average of 8,000 cubic feet per second for purposes of convenient reference and as representing average conditions. The water is diverted into the channel by diversion weirs spanning the main river-bed. A normal head of 39 feet is developed at the plant.

The present installation of the power stations consists of four settings of four runners each, at 2,595 horse-power per setting, or 10,380 horse-power for the group; also five settings of four runners each, at 4,788 horse-power per setting, or 23,940 horse-power for the group. The above figures represent the manufacturers' rating at a 39-foot head and total to 34,320 horse-power for the entire plant.

The question of regulation on the lake of the Woods affects the Winnipeg Electric Railway Company's plant as directly but not in the same manner as it does the plants on the main river channel. Plate 84 illustrates graphically the influence of the lake of the Woods regulation on this plant.

*Present regulation* on the lake of the Woods results in difficulty in operating the company's plant during ordinary winter flow. This is instanced by the steps which have been successfully taken during the past two seasons by the company, through the Dominion Water Power Branch, to secure the removal of the logs from the Norman dam at the outlet of the lake, and to thereby augment run-off from lake of the Woods storage at such times as the flow in the Manitoba reach falls below 15,000 cubic feet per second. It is evident, therefore, that the present measure of regulation on the lake does not meet the actual present requirements of the Winnipeg Electric Railway Company.


*No power regulation* on the lake of the Woods would reduce the minimum flow to 7,000 cubic feet per second. This is less than is frequently required at the plant for handling the heavy loads which the market demands, even if it were all diverted into the Pinawa channel. Such a diversion would leave the main river channel from the diversion dams to Whitemouth falls 8 miles down stream, entirely dry during the low-water season. Such conditions could not be permitted by the department.

The present diversion weirs of the company are not, however, at such an elevation as will divert the entire 7,000 second-feet into the Pinawa channel. At such times as 7,000 cubic feet per second forms the entire river flow, the weirs will divert approximately 5,000 cubic feet per second into the Pinawa, and discharge the remaining 2,000 down the Seven Sisters reach. To secure the full 7,000 cubic feet per second down the Pinawa, leaving the main channel dry, would, even if permitted by the department, necessitate expensive crest-raising alterations to the present diversion weirs.


**DOMINION WATER POWER BRANCH**

**PLATE NO. 62**


J. B. CHALLIES, Superintendent



**PRESENT REGULATION ON THE LAKE**  
5500 Cu.ft. per sec  
low discharge.




**NO REGULATION ON THE LAKE**  
3600 Cu.ft. per sec low discharge.



**SYSTEMATICALLY CONTROLLED REGULATION ON THE LAKE**  
12000 Cu.ft. per sec low discharge

Comparisons of the **TOTAL POWER** available under above conditions of runoff.



**LEGEND:**

Power developed to date (60% installed turbine capacity)

Additional Power available under conditions stated in terms of 24 hour H.P. at 75% efficiency

**DIAGRAM**

SHOWING THE

**INFLUENCE OF THE LAKE OF THE WOODS**

ON THE


**POWER SITUATIONS AT THE OUTLETS OF THE LAKE.**

To accompany a report on **POWER AND STORAGE INVESTIGATIONS**  
by J. T. JOHNSTON, B.A.Sc.

February 1, 1915



J. B. CHALLIES, SUPERINTENDENT.




**LEGEND**

Developed Power to date

- ① Power available with **NO** regulation permitted on Lake of the Woods
- ② Power available under **PRESENT INCOMPLETE** regulation on the Lake of the Woods
- ③ Additional power available under **SYSTEMATICALLY CONTROLLED** regulation on the Lake of the Woods

Comparison of **TOTAL** power available under the above conditions of regulation on the Lake of the Woods.



NOTE - Power given in terms of 24 hour H.P. of 75% efficiency

**DIAGRAM**

SHOWING THE

**INFLUENCE OF THE LAKE OF THE WOODS**

ON THE

**WINNIPEG CITY PLANT AT POINT DU BOIS**

ON THE


**WINNIPEG RIVER**

To accompany **REPORT on POWER & STORAGE INVESTIGATIONS**  
by J. T. JOHNSTON B. A. Sc.

Mar. 31 1915

Vertical text along the left edge of the page, likely bleed-through from the reverse side. The text is mostly illegible but appears to contain a list or index of items.





**LEGEND**

- Power available with **NO** regulation permitted on the Lake ..... 
- Power available under **PRESENT** regulation on the Lake ..... 

Comparison of **TOTAL POWER** available under the above conditions of regulation



**NOTE**- Power given in terms of 24 hour H.P. at 75% efficiency

**DIAGRAM**  
SHOWING THE  
**INFLUENCE OF THE LAKE OF THE WOODS**  
ON THE  
**WINNIPEG ELECTRIC RAILWAY COMPANY'S PLANT**  
ON THE  
**PINAWA CHANNEL**

To accompany **REPORT** on **POWER & STORAGE INVESTIGATIONS**  
by **J. T. JOHNSTON B. A. Sc.**

Feb. 1 1915



With no storage in the lake of the Woods, the present capacity of the Electric Railway Company's plant would be reduced under minimum flow conditions, to 16,600 horse-power.

*Systematically controlled regulation* on the lake of the Woods will permit the automatic diversion at all seasons of the full flow necessary to properly operate the company's plant, and with no possible complications, and will in addition render available for profitable development, 67,500 horse-power on the Seven Sisters reach.

(H)—*Upper Pinawa site.*—The Upper Pinawa site will operate under exactly the same conditions of flow as the plant of the Winnipeg Electric Railway Company; that is to say, under the present regulation, difficulty will be experienced in securing sufficient water during the season of low discharge on the river, while with no regulation permissible on the lake, about 5,000 cubic feet per second will be available for utilization.

*Present regulation* on the lake of the Woods means a development capacity of some 12,300 horse-power at this site.

*No power regulation* on the lake of the Woods means a development capacity of some 7,700 horse-power at this site.

*Systematically controlled regulation* on the lake of the Woods will not increase the output possible under present conditions, but will render it dependable at all seasons.

(I)—*McArthur site.*—The power investigations show that a head of 18 feet can be profitably developed at McArthur falls.

*Present regulation* on the lake of the Woods means a development capacity of 18,400 horse-power at this site.

*No power regulation* on the lake of the Woods means a development capacity of 10,760 horse-power at this site.

*Systematically controlled regulation* on the lake of the Woods means a development capacity of 30,700 horse-power.

(J)—*Du Bonnet site.*—Of the entire series of power sites investigated by the engineers of the Dominion Water Power Branch in connection with the power study of the Winnipeg river, the Du Bonnet site offered the best opportunities for commercial exploitation. The Winnipeg River Power Company has secured rights to the development of this site, based upon and in line with the departmental investigations and conclusions, and is at present actively engaged in construction operations. The head available here is 56 feet. The question as to the effect of regulation or non-regulation of the lake of the Woods is therefore of pressing importance to the power possibilities of the site. Reference to plate 85 will illustrate the situation.

*Present regulation* on the lake of the Woods means a development capacity of 57,300 horse-power at this site.

*No power regulation* on the lake of the Woods means a development capacity of 33,450 horse-power.

*Systematically controlled regulation* means a development capacity of 95,500 horse-power.

(K)—*Pine falls site.*—The proposed power concentration at Pine falls offers exceptional opportunities for successful development. A head of 37 feet is available.

*Present regulation* on the lake of the Woods means a development capacity of 37,900 horse-power at this site.

*No power regulation* on the lake of the Woods means a development capacity of 22,100 horse-power.

*Systematically controlled regulation* on the lake of the Woods means a development capacity of 63,100 horse-power.

#### SUMMARY OF THE INFLUENCE OF THE LAKE OF THE WOODS ON THE POWER AVAILABLE IN THE WINNIPEG RIVER.

The above detail of the influence of the lake of the Woods on the available power of the Winnipeg river is graphically shown on plate 86, and is concisely stated in table 47.

Table 47.—*Effect of No Regulation and Systematic Regulation on the lake of the Woods, on the power possibilities and hydro-electric plants from the lake of the Woods to lake Winnipeg.*

Site.	POWER AVAILABLE IN 24-HOUR H.P. AT 75% EFFICIENCY.		
	No Regulation.	Present Regulation.	Systematic Regulation.
Pine Falls .....	22,100	37,900	63,100
Du Bonnet .....	33,450	57,300	95,500
McArthur .....	10,760	18,400	30,700
Lower Seven Sisters .....	00	12,600	37,900
Upper Seven Sisters .....	00	9,900	29,600
Upper Pinawa .....	7,700	12,300	12,300
Slave Falls .....	15,520	26,600	44,400
City Plant .....	26,900	46,100	76,800
White Dog Falls .....	13,800	21,100	46,100
Outlets of Lake of the Woods .....	6,130	9,390	20,500
Winnipeg Electric Railway Company .....	16,600	26,600	26,600
Total .....	152,970	278,190	483,500

Reference to table 47 indicates that the dependable power available on the entire reach of the Winnipeg river from Kenora to lake Winnipeg, under present conditions of regulation on the lake, is 278,190 horse-power. Under a system of uniform surface control on the lake, or, in other words, under conditions of no power regulation, this dependable power would be reduced to 152,970 horse-power, or by 45 per cent. Under a systematically and properly operated regulation of the lake, the dependable power would be increased to 483,500 horse-power or 74 per cent above the present power capacity and 215 per cent above that resulting from a system of no power regulation.

#### SUMMARY OF THE RELATION OF THE LAKE OF THE WOODS TO THE POWER RESOURCES OF THE WINNIPEG RIVER.

Hereunder are summarized briefly the outstanding features governing and governed by the relation of the lake of the Woods to the question of power

development on the Winnipeg river below the lake. Certain of these features have already been enlarged upon in the foregoing, and are supplemented by the equally important considerations appended.

#### RELATION OF THE LAKE OF THE WOODS TO THE WATERSHED.

- (1) The lake of the Woods has a surface area of 1,500 square miles.
- (2) The total area of the Winnipeg river watershed is 53,200 square miles.
- (3) The watershed above and tributary to the lake of the Woods has an area of 26,400 square miles, or practically one-half the total river watershed.
- (4) Of the total area of the Winnipeg watershed, some 7,400 square miles possesses no suitable storage reservoirs, and the run-off from the same cannot be controlled.

Of the watershed area tributary to the lake of the Woods, 10,400 square miles has no lake area suitable for storage reservoir purposes other than the lake of the Woods.

Hence, if no storage privileges are permissible on the lake of the Woods, there will be a total of 17,800 square miles, or practically one-third of the basin from which there will be no opportunity to control or regulate the run-off.

- (5) Permitting storage privileges on the lake of the Woods will increase the controllable area 45,800 square miles, or practically five-sixths of the watershed.
- (6) The lake of the Woods dominates a drop of 347 feet in the Winnipeg river, capable of profitably developing under a regulated flow some 483,500 24-hour dependable horse-power.

#### EFFECT OF NON-STORAGE REGULATION ON THE LAKE OF THE WOODS.

The answering of the Lake of the Woods Reference in the affirmative, or, in other words, the maintenance of the lake surface at *one uniform level*, thereby destroying the lake's regulating capacity for river control and power purposes, would result in the following:—

- (1) The present minimum outflow from the lake would be reduced from 5,500 cubic feet per second to 3,600 cubic feet per second.
- (2) The present minimum flow in the Manitoba power reach would be reduced from 12,000 cubic feet per second to 7,000 cubic feet per second.
- (3) The maximum practical control of the balance of the watershed would not greatly better the present run-off conditions maintaining below the lake.
- (4) The dependable power capacity of the river below the lake would be reduced from the present 278,190 horse-power to 152,970 horse-power, of which 53,000 horse-power is already developed.

(5) Practically no additional development above the present operated capacity could be carried out at the outlets from the Lake of the Woods without the addition of steam auxiliary.

(6) The present installation in the city of Winnipeg municipal plant at Point du Bois could not be operated during the low-water season.

(7) The present dependable output of the Winnipeg Electric Railway Company's plant on the Pinawa channel would be cut down by 10,000 horse-power.

#### EFFECT OF SYSTEMATIC REGULATION ON THE LAKE OF THE WOODS.

Systematic and comprehensive regulation for power purposes on the Lake of the Woods, based upon the detailed and reliable data now in the possession of the engineers of the Dominion Water Power Branch as a result of the power and storage investigations carried on in this basin, will result in the following:—

(1) The present minimum outflow from the lake may be increased to 12,000 cubic feet per second.

(2) A minimum flow of 20,000 cubic feet per second will be ensured in the power reach in Manitoba.

(3) The dependable power capacity of the river below the lake will be increased from the present 278,190 horse-power to 483,500 horse-power.

(4) The flow from the outlets of the lake will permit the development of 14,360 dependable horse-power in addition to the power now in use there.

(5) The Winnipeg municipal plant at Point du Bois can be developed to the maximum capacity of its designed installation.

(6) The Winnipeg Electric Railway Company's plant on the Pinawa channel will have at all seasons ample water to fully operate its entire installation.

#### OUTSTANDING FEATURES RELATIVE TO REGULATION ON THE LAKE OF THE WOODS.

In addition to the foregoing, the following general features are particularly pertinent to the question of regulation for power purposes:—

(1) The Lake of the Woods is the *obvious and most natural reservoir* for the control and regulation of the river below. With simple repairs and improvements to the present outlet structures, the lake forms a perfect and ready-made reservoir, in shape for instant and complete regulation purposes.

(2) The lake has been subject to artificial regulation since the construction of the Norman dam in 1895, and partial regulation since 1887.

(3) Maintaining a uniform level on the lake would have the effect of *entirely removing it from the watershed* in so far as its effect on and relation to the run-off and power of the river is concerned, and would greatly accentuate the flood flows which have been experienced in the past both before and since the institution of the present regulation on the lake, in other words the *natural* regulating influence of the lake would be destroyed.

(4) The *natural* regulating influence of the lake will not be destroyed by systematic regulation, but, on the contrary, will be artificially perfected, and that at a less range in lake level than has occurred under natural conditions of run-off.

(5) The lake levels, if systematically controlled, will not be subject to the extremes and irregularities which have been experienced in the past. Extreme low water will be necessary only at intervals of several years.

(6) Experiences in the operation of *existing* hydro-electric developments below the lake show that a more systematic regulation of the lake than is now in practice is necessary to the proper operation of *present installations*.


(7) The use of the Lake of the Woods is *essential* to the ultimate storage and control policy which must be instituted for the proper conservation of the river resources as contemplated by the Dominion Water Power Branch, and covered in this report.

A review of the foregoing emphasizes how essential to present and future power development and to dependent industrial development in this district, is the question of an adequate regulation of the surface levels of the Lake of the Woods. The lake is, from its strategic location and its exceptional surface area, the controlling and essential reservoir for any conservation scheme of storage or run-off control which may be instituted in the watershed.

A careful study of past runoff records from the basin proves that a storage range of *at least five feet* on the lake is necessary to ensure an adequate regulation of its outflow in the interests of all powers on the Winnipeg river. Other interests concerned would require that such range should preferably be as near the upper limits of lake level as possible.

It is, therefore, from the power viewpoint, entirely impossible to agree to the suggestion that the lake of the Woods be maintained continuously at one uniform surface level. Regulation on the lake between fixed limits is essential to the conservation of the power resources of the watershed.





LEGEND

- ① Power available with **NO** regulation permitted on Lake of the Woods [Hatched Box]
- ② Power available under **PRESENT INCOMPLETE** regulation on the Lake of the Woods. [White Box]
- ③ Additional power available under a **PROPERLY CONTROLLED** system of regulation on the Lake of the Woods [Unshaded Box]

Comparison of **TOTAL POWER** available under the above conditions of regulation on the Lake of the Woods



NOTE - Power given in terms of 24 hour H.P. of 75% efficiency

DIAGRAM


SHOWING THE  
INFLUENCE OF THE LAKE OF THE WOODS  
ON THE  
DU BONNET FALLS POWER SITE  
ON THE  
WINNIPEG RIVER

To accompany REPORT on POWER & STORAGE INVESTIGATIONS  
by J. T. JOHNSTON B. A. Sc.

Feb. 1 1918




DOMINION WATER POWER BRANCH  
J. B. CHALLIES, SUPERINTENDENT



LEGEND

- ① Power available with NO regulation on the Lake
- ② Power available under PRESENT INCOMPLETE reg on the Lake
- ③ Additional power available under a SYSTEMATICALLY CONTROLLED regulation on the Lake
- Power already developed

Comparison of TOTAL POWER under the above conditions of regulation on the Lake




NOTE: Power given in terms of 24 hour H.P. at 75% efficiency

DIAGRAM

SHOWING THE  
INFLUENCE OF THE LAKE OF THE WOODS  
ON EACH OF THE  
AVAILABLE POWER SITES ON THE WINNIPEG RIVER  
BELOW THE LAKE


To accompany REPORT on POWER & STORAGE INVESTIGATIONS  
by J. T. JOHNSTON B. A. Sc.

Feb. 1 1913



REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

APPENDIX I.  
REPORT OF CONSULTING ENGINEER  
J. B. McRAE, C.E.



## APPENDIX I.

### REPORT OF J. B. McRAE, C.E., CONSULTING ENGINEER

BOOTH BUILDING, OTTAWA, September 27, 1915.

J. B. CHALLIES, Esq., C.E.,  
Superintendent of Water Powers,  
Dominion Water Power Branch,  
Ottawa.

DEAR SIR,—In the summer of 1911 the Dominion Water Power Branch began a systematic investigation of the power possibilities of the Winnipeg river in Manitoba. This work is now complete in as far as has been necessary to map out a comprehensive scheme of water-power development and enunciate a general policy for the proper control of the same, with due regard to future storage and regulation of the run-off. The history of the investigation, together with results and recommendations, may be found in the accompanying report of Mr. J. T. Johnston, hydraulic engineer of the Water Power Branch.

The value of such work cannot be overestimated. For proof of this, many cases of failure can be pointed to when works have been undertaken without sufficient data to warrant the large expenditures made. On the other hand, there are cases, though not so numerous, where power possibilities have been underestimated and future extensions thereby made more expensive than they otherwise would have been. Apart from the above, it is of interest to note that both during the progress of the work and since its completion, your department has been able to dictate conditions and give sound engineering advice, both of which have been cheerfully accepted, to applicants for power privileges. The Winnipeg river, situated as it is, is a heritage which should be safeguarded against irresponsible and unguided private enterprise. Plate No. 1 illustrates the relation of this great source of power to the city of Winnipeg and surrounding country. A study of table 1 shows the power available and estimated costs of same. These costs have been worked out separately for each development. The basis on which the estimates are made is treated on pages 182 and 183.

Attention is also directed to the "recommendations," pages 10, and 11. "Recommendation 10" is of particular importance, and it is to be hoped that the department will be allowed to keep up the good work and extend same along the lines recommended here.

These investigations were the first of their kind to be taken up by the Dominion Government, and it is fortunate that they fell into such competent hands as your assistant, Mr. Johnston, to whom credit is due in large measure for the excellent results obtained.

These results have made it possible to work out the comprehensive scheme of water-power development, already referred to, to the maximum extent of the unusual natural power possibilities of this river. Your department is now, and has been for sometime, in a position to dictate requirements for power developments which will conform to this scheme and ensure the complete development of the river to the best possible advantage.

The navigation features have been worked out entirely by Mr. Johnston, and are satisfactory, not only from a navigation standpoint, but also from the power point of view. It is very satisfactory to record that the engineers of the Dominion Department of Public Works have approved of the scheme in so far as navigation is concerned throughout the entire power reach.

Before closing, the writer wishes to endorse the report and recommendations without qualification; he also wishes to express his thanks to yourself for the many courtesies extended during the time he has acted as consultant to your department.

Yours faithfully,

J. B. McRAE.

M. Can. Soc. C.E.

M. Am. Soc. C.E.

REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

---

APPENDIX II.  
PROPOSED DEVELOPMENT OF THE WINNIPEG  
RIVER POWER COMPANY



## APPENDIX II.

### THE GREAT FALLS DEVELOPMENT.

(DU BONNET POWER SITE).

The Winnipeg River Power Company<sup>1</sup> has at present under way the development of the Du Bonnet site. This is the first power undertaking to acquire rights and commence construction operations on the river since the organization of the power survey, and it serves as an excellent illustration of the manner in which the interest of the investor and of the public are served by a careful and thorough investigation of a river's power resources, and by a pre-determined scheme of power development conserving fully all economically developable head.

In the case of the undertaking under discussion, the surveys of the department enabled the Winnipeg River Power Company to take immediate action towards the construction of the project, as soon as the authority for the same was secured from the department, without the necessity of carrying on long and expensive preliminary surveys.

The interests of the public were served by the preservation of a profitable power site at the McArthur falls, which, under the first proposals of the company, would have been rendered uneconomical of development.

The company has accepted the essential features of the departmental concentration at Du Bonnet falls as set out herein, i.e., the head- and tailwater levels, the Whitemud falls addition, the discharging capacity, and the general requirements as to stability of dam and contingent structures. Detail soundings and examination on the part of the company of the river channel at island No. 2, 3,000 feet below the Little du Bonnet falls, disclosed a distinct submerged rock ridge, presenting such favourable features as to warrant the location of the layout at this point. The principal consideration in adopting this location in preference to the site at the falls is the freedom which will be secured from ice troubles in the tail-race. This will become more evident when the Whitemud cut is made and a 10-foot lowering of the tail-race takes place.

The development of the Du Bonnet power site under the name of the Great Falls development, forms a component link in the complete scheme of hydro-electric development which has been laid down as a result of the departmental power investigations, and by which it is intended that the entire power resources of the Winnipeg river in Manitoba will be fully conserved.

#### LAYOUT.<sup>(2)</sup>

The general layout (Plate 87) proposed consists of a power station spanning the channel to the left of island No. 2, tied in to the left river bank by a non-overflow concrete dam, 900 feet in length and with top elevation at 816. The power

<sup>1</sup>The Winnipeg River Power Company is controlled by the same interests as control the Winnipeg Electric Railway Company.

<sup>2</sup>The greater portion of the data relative to the layout and equipment have been secured from the plans and reports filed in the department by the Winnipeg River Power Company.



WINNIPEG RIVER POWER COMPANY  
GREAT FALLS DEVELOPMENT

Winnipeg River Power Company, Proposed Great Falls Development.

station is joined to the right river bank by a gravity section concrete dam of the combined sluiceway and free spillway type, 2,100 feet in total length. A corewall embankment connects the free spillway with contour 816 on the right bank. A fishway is provided at the left abutment, and a log slide on the island adjacent to the sluices.

Provision for the future inclusion of lockage facilities, should such become necessary, is made on the right river bank.

*The dam.* The dam proposed is of solid concrete construction throughout the portion spanning the river channel and crossing island No. 2. The spillway section of the dam, 1,570 feet in length, with crest at elevation 808, provides exceptional facilities for the automatic control of flood flows. Twenty 20-foot sluices, with sills at elevation 794, are located on the island adjacent to the power station. Stoplog control is contemplated, and double gates are provided. The corewall embankment connecting the spillway section of the dam with the high ground on the right river bank has a 16-foot top with 2:1 slopes, the corewall being bonded to the bedrock. The dam is continued as a solid non-overflow section, 900 feet in length with top at elevation 816, joining the power station with the left bank. The foundation conditions throughout, so far as they have been definitely investigated, show a firm granite bedrock.

*Power station.*—The plans of the power station as at present submitted to the department may be revised both as to layout and installation, prior to the commencement of construction operations. The station as now designed provides for the ultimate utilization of the entire regulated river flow, and will install eight 21,000-horsepower turbines, each running at a speed of 163.3 revolutions per minute, and requiring 4,100 cubic feet of water per second when operating under a head of 56 feet. These turbines will be of the four-runner horizontal shaft type, and will be placed in pits formed in the concrete substructure.

Adjacent to the turbine pits, in the downstream direction, is the generating room, in which are located the electric generators, exciters, and turbine governors. All apparatus requiring attendance and adjustment are thus placed close together, and hence will require the minimum operating staff. The generating room, being on the downstream side, will have ample light and ventilation.

Located on the level above the turbine pits and the generating room, are the low- and high-tension switch rooms and the transformer banks. The low- and high-tension switching apparatus has been so arranged as to permit all switching operations to be carried out in the most direct manner and in the shortest possible time, and also to provide the most direct system of connections from generators to transmission lines. On the same level are also located a storage battery room, and locker and rest rooms for the operating staff.

On the generating room level, at the shore end of the station, is the machine shop. On the control room level, directly above the machine shop and railroad track in the generating room, a large room for stores is provided.

<sup>1</sup>More recent studies made by the company engineers contemplate single runner vertical turbines. If these are adopted, the design of the power station will differ from that described herein.

On the roof levels are located the lightning arrestors, horn gaps, choke coils, air brake switches, and terminal towers for the transmission lines.

A railroad track will run to the generating room floor and extends to the rear wall of the house, with hatchways above in the floors of the storeroom and screen room for effectively handling apparatus.

Provision is made for steam-heating plant capable of maintaining proper temperature in the screen room, generating room, switch rooms, offices, control room, etc.

Plates 87 and 88 show the layout and section of the power-house.

*Head Gates.*—Each unit will be provided with two vertical operating steel headgates, arranged with rollers to minimize friction. Each gate will be 19 feet wide by 26 feet high, and when fully open will pass a flow of 4,100 cubic feet of water per second, at a velocity of approximately 4.5 feet per second.

Provision will be made for stoplogs, outside the screens and gates, affording ready access for inspection and repairs.

*Screens.*—Screens consisting of heavy steel bars supported on a steel framework attached to the substructure will be provided for preventing débris from entering the wheel pits.

Provision is made for cleaning the screens by reversing the direction of flow of the water and discharging the débris through drains to the tail-water.

*Water Wheels or Turbines.*—Each unit will consist of two double-runner horizontal turbines in tandem, and direct connected to the electric generator. Hydraulic governors located in the generating room will control the speed of the machines.

*Electric Generators.*—Eight electric generators are provided, each to be of 11,000-kilowatt capacity, normal rating at 30° Centigrade, with continuous overload capacity of 50 per cent. These machines will generate three-phase, 60-cycle alternating current at 12,000 volts. Individual exciters will be provided for each machine, direct connected to the shafts, and, in addition, an auxiliary motor-driven exciter will be provided and so connected that it may be substituted for any of the direct-connected exciters in case of breakdown.

*Transformers.*—Five banks of transformers, each consisting of three single-phase transformers, will be provided. Each transformer will be of 6,000-kilowatt normal rating capacity, and so designed as to safely withstand a continuous overload of 50 per cent. The low-tension voltage will be 12,000 volts, and the high-tension voltage will be 110 000 volts.

*Switching and Protective Equipment.*—The low-tension oil break switches, and all disconnecting switches will be motor operated. All disconnecting switches, instrument transformers and busses on the low-tension circuits will be placed in concrete structures. The bus reactances will be placed in enclosed pockets with doors opening into the low-tension switch room.

The high-tension switches will be of the oil break solenoid type, enclosed in iron tanks and placed directly on the floor of the high-tension switch room.

The lightning arresters will be of the electrolytic type, enclosed in iron tanks and located on the floor of the lightning arrester house.

The system of electrical connections provides means of connecting any generator to any transformer bank and line.

oke

the  
and

pper  
trol

steel  
feet  
et of

ling

me-  
rom

n of  
ter.  
nner  
ator.  
peed


be of  
uous  
hase,  
ided  
liary  
sub-

ngle-  
watt  
uous  
l the

ches,  
cting  
y will  
losed

losed  
oom.  
iron

any













## PROPOSED INITIAL GENERATING INSTALLATION.

The initial development will consist of four complete units, viz., turbines, generators, transformers, and switching equipment. The hydraulic development will include dams, sluices, building, gates, etc., for the eight units, all sufficiently completed so that any of the four remaining generating units provided for may be installed without further construction work, except on the installation of the units themselves, which may be done at a minimum expense, and in the least time.

## AVAILABLE POWER OUTPUT.

Without regulation at the Lake of the Woods, the maximum discharge of the Winnipeg river in abnormal years has reached 90,000 cubic feet per second, and the minimum discharge 12,000 cubic feet per second for three or four weeks in the year. The average run-off, from government records, is 45,000 cubic feet per second for high-water and 16,000 cubic feet per second for the low-water period.

The reservoir created by the dam at island No. 2 will have an area of 1,935 acres at elevation 808, the crest of the dam, and 1,600 acres at elevation 806 (two feet below the crest of the dam), thus furnishing a reserve supply of water of approximately 145,000,000 cubic feet, equivalent to 13,000 cubic feet per second for three hours. This reserve will produce 50,000 horse-power for three hours every day, in addition to the river's supply, taken at the rate of 16,000 cubic feet per second. At 46-foot fall, this rate of flow will produce 66,000 horse-power constant, and for three hours the output may be increased to 110,000 horse-power. The same water operating under 56 feet head, involving the excavation of the Whitemud falls canal, will produce a constant 82,000 horse-power, and for three hours an additional 63,000 horse-power, a total for three hours of 145,000 horse-power.

A regulated flow of at least 20,000 cubic feet per second minimum can readily be secured by proper control of the upper watershed, while a higher flow is also feasible.

Upon the basis of 25,000 cubic feet per second, there will be available under 46 feet head, Whitemud falls canal not excavated, a constant 90,000 horse-power, and 50,000 horse-power additional for three hours, or a total peak load capacity of 140,000 horse-power.

By utilizing Whitemud falls canal, the head is increased to 56 feet, and the power available will become constant 110,000 horse-power, and 63,000 horse-power additional for three hours, or a total peak load capacity of 173,000 horse-power.

The load factor at Winnipeg is between 60 per cent and 62 per cent, and under these conditions the peak load period could be extended to four hours without shortage of water.

## TRANSMISSION LINES.

A double circuit transmission line will connect the plant direct with the step-down substation at Winnipeg, about 80 miles distant.

The lines will be three phase and supported on structural steel towers, 54 feet high. The insulator will be of porcelain and designed for ultimate operation of the lines at 110,000 volts.

Towers of special design will be provided at railway and river crossings, and other locations where necessary.

A second double circuit line will connect the power-house with the present plant at Pinawa, thence over the existing lines to Winnipeg. The company will thus have the advantages of a double loop connection between its sources of power and the consumers, assuring continuity of service.

#### ESTIMATES OF COST.

The cost estimates have been prepared for three steps in development; the first, including four units and utilizing 46 feet head; the second including eight units and utilizing 46 feet head; and the third including eight units, and utilizing Whitemud falls, giving 56 feet head.<sup>1</sup> The total capital cost of construction at the site, and not including transmission, is estimated by the company's engineers at \$5,450,000, \$5,902,000, and \$6,767,000 for the three respective steps.

The preliminary engineering investigations carried out by the Winnipeg River Power Company were made by the J. G. White Engineering Corporation of New York, based upon field plans, and engineering data furnished by the Dominion Water Power Branch, and augmented by further detail work in the field on the part of the Company. The final analysis and design preparatory to commencing actual construction operations is being developed by the Pearson Engineering Corporation, Limited, of New York and Toronto; Mr. L. J. Hirt, C.E., Vice-President, with Mr. H. Hartwell, engineer in charge of design and construction at Winnipeg.

<sup>1</sup>These estimates furnish an excellent check on the estimates of the Du Bonnet site, 3,000 feet upstream, and hence on the estimates submitted herein covering the other proposed power concentrations on the river. The Du Bonnet site involves the same head and tailwater elevations as the Island No. 2 site. The total cost of the ultimate development is \$6,767,000, according to the figures of the company's engineers, and as opposed to the departmental estimate of \$6,551,600 for the Du Bonnet site.

REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

APPENDIX III.  
REPORT ON GEOLOGY OF WINNIPEG RIVER  
WATERSHED BY CHARLES CAMSELL,  
B.Sc., Ph.D.



### APPENDIX III.

#### GEOLOGY OF THE WINNIPEG RIVER BASIN.

By CHARLES CAMSELT, B.Sc., Ph.D.

##### INTRODUCTION.

The following report on the geology of the Winnipeg River basin is compiled from the reports of officers of the Geological Survey who have at different times during the last thirty years reported on various portions of the basin.

For more detailed descriptions of certain portions of the district, the following reports should be consulted:

*Lawson, A. C.*—On the Lake of the Woods region, with special reference to the Keewatin Belt of the Archean rocks. Annual Report, Geol. Surv. of Can. vol. I, 1885, part CC.

*Lawson, A. C.*—Report on the Geology of the Rainy Lake region. Annual Report, Geol. Surv. of Can. vol. iii, 1887-88, part F.

*McInnes, W.*—Report on the Geology of the area covered by the Seine River and Shebandowan Map Sheets, comprising portions of Rainy River and Thunder Bay districts. Annual Report, Geol. Surv. of Can., vol. x, 1897, part H.

*McInnes, W.*—District east of Manitou, Ont., Summary Report Geol. Surv. of Can., 1898, p. 87.

*McInnes, W.*—Rainy River District, Summary Report, Geol. Surv. of Can., 1899, p. 115.

*McInnes, W.*—Region southeast of Lac Seul, Summary Report, Geol. Surv. of Can., 1901, p. 89.

*Tyrrell, J. B.*—Report on the East Shore of Lake Winnipeg and adjacent parts of Manitoba and Keewatin. Annual Report Geol. Surv. of Can., vol. xi, 1898, part G.

*Collins, W. H.*—Report on a Geological Reconnaissance of the region traversed by the National Transcontinental Railway between Lake Nipigon and Clay lake, Ontario Geol. Surv., Can., No. 1059, 1909.


##### GENERAL PHYSICAL FEATURES.

The basin of the Winnipeg river lies on the southwestern border of the greatest of the main physiographic provinces into which Canada is naturally divisible, namely, the Laurentian Highland, or as it has sometimes been called the Canadian Shield. This province embraces the Labrador peninsula, northern



# MICROCOPY RESOLUTION TEST CHART

(ANSI and ISO TEST CHART No. 2)



APPLIED IMAGE Inc

1653 East Main Street  
Rochester, New York 14609 USA  
(716) 482-0300 - Phone  
(716) 288-5989 - Fax

Quebec, northern Ontario, and extends thence northwestward through northern Manitoba and Saskatchewan up to the Arctic ocean, completely encircling the great inland sea of Hudson bay...

In the far distant past of geologic time this province formed the original land area of North America, and to a large extent the continent was built out to the south and west by the materials eroded from that land area. It has probably remained a land area from pre-Cambrian times, and has consequently been continuously exposed to the eroding agencies of water and the atmosphere since that period. Its present topographic features are the result of that history and of the glaciation which completed its history. Probably hundreds of feet of its surface have been, in the course of ages, worn down and carried away and its surface has in that time been reduced from a mountainous character to one of subdued and rounded outline.

The whole basin has been heavily glaciated by a great ice-sheet which was accumulated in the region to the northeast and flowed over it to the southwest. This ice-sheet removed the decomposed surface of the rocks of the region and transported the materials so removed across the boundary line into the United States. On the retreat of the ice-sheet the region was left much as it is to-day, with its surface glaciated down to the undecomposed rock. Over this surface there is generally a marked absence of alluvium or drift, and only here and there patches of clay, sand, and gravel of glacial origin.

When viewed broadly, the topography of the basin of Winnipeg river is that of a broad plain sloping gradually to the west with elevations ranging from about 1,500 feet above the sea in the east to 710 feet at lake Winnipeg. In detail, however, it is exceedingly irregular and broken, with an uneven, hummocky, or mammillated surface. It is a country of numerous rockbound lakes and muskegs which occupy all the lower levels. The intervening areas are rocky, sparsely timbered hills which rarely rise more than 200 feet above the lakes.

Here and there areas of clay of greater or less extent cover the surface and obliterate the irregularities of the bedrock beneath. The most important of these clay areas occur in the vicinity of Dryden on the Canadian Pacific railway, at Lac Seul, and in the region towards the mouth of Rainy river and the southern end of lake of the Woods. The clay deposits are sediments that were laid down in lake basins formed at the front of the continental ice-sheet as it was retreating northward in the closing stages of the Glacial period.

The drainage system of the Winnipeg River basin is not well developed, and its streams flow, as a rule, in ill-defined valleys that are often merely chains of lakes connected with each other by short stretches of rapid, broken river. Except where they flow through areas of drift they carry little sediment, and this they soon deposit in the lakes which are perfect sedimentation basins.

Neither the Winnipeg river itself nor its tributaries are well graded in profile because they are young streams and have had neither time nor power since their beginning at the close of the Glacial period to cut deep or well-defined valleys. They are, as a rule, merely connecting links between the lakes, and their courses are dependent on chance irregularities of the rock floor. Owing to their youth and feeble cutting power, falls and rapids in them are numerous.

The region also is essentially a lake country, a feature which is due to the lack of any pronounced general slope to the region, and the mammillated or hummocky nature of the surface. These lakes serve to regulate the flow of the streams and act as conservation basins, so that there is no great difference between the extremes of high and low water. These characteristics make the whole Winnipeg River system excellent for power development.

The lakes of the basin are as a rule shallow rock basins whose positions and shapes have been determined mainly by the character and disposition of the rocks in which they have been excavated. Lakes have been formed more readily in rocks of schistose or gneissic character, because such rocks are more susceptible to the action of decomposing and eroding agencies, than in the more massive granitoid rocks. The shapes of the lakes, too, are dependent very largely on the strike of the strata and the direction of foliation, for after decomposition had affected the surface of the region to depths varying with the character and structure of the rocks, glacial ice removed the decomposed portion down to the unaltered rock, giving the surface the irregular hummocky character that it now has. The more deeply eroded portions were later filled with water to form the lakes.

#### GEOLOGY.

The entire region of the Winnipeg River basin (plate 89), with the exception of a narrow strip along the valley of Whitemouth river, is underlain by very ancient rocks of pre-Cambrian age. For the purposes of this description these rocks can be divided naturally according to age and composition into three distinct series, namely, Keweenawan, Laurentian, and Huronian-Keewatin. The first of these is of little consequence, and consists of a few dykes. The second is the most important rock series, since it covers the widest area, and consists of crystalline igneous rocks of granitoid or gneissic character. The Huronian-Keewatin series includes, as well, certain rocks that are considered to be older, but the whole series consists mainly of schists and sediments that occur in detached elongated bands either on or intruded by the granites and gneisses.

Younger Paleozoic rocks of sedimentary origin overlap the pre-Cambrian rocks on the extreme western border of the Winnipeg River basin, but really they are of little consequence in this region.

Stratified deposits of clay and sand, and unstratified deposits of gravel of glacial origin are spread here and there over the surface of the older rocks.

The geological sequence, therefore, for the Winnipeg River basin may be summarized in the following table in which the formations are arranged in order of age:—

Pleistocene and Recent.....	Unconsolidated deposits of clay, sand, and gravel, mainly of glacial origin.
Ordovician.....	Limestone.
Keweenawan.....	Diabase dykes.
Laurentian.....	Granites and gneisses.
Huronian-Keewatin.....	Schists, limestones, slates, quartzites.

*Huronian-Keewatin.*—Rocks of this group have a fairly wide distribution throughout the basin of Winnipeg river. They occur in irregular patches, usually elongated in an east-northeast direction, parallel to the strike of the strata of which they are made up.

This group of rocks consists of mica, hornblende, and chlorite schists, limestone, slate, quartzite, conglomerate and various altered forms of these rocks. The beds usually stand in vertical positions or dip at high angles, and they strike in general in an east-northeast direction. Though relatively hard rocks they are much more susceptible to eroding and decomposing influences than the granites, and consequently they often occupy lake basins. They are rocks that have been subjected to considerable compression and disturbance, and have thereby had planes of cleavage, shearing or schistosity developed in them, causing them to become less resistant to disintegration than they might otherwise have been.

The prevailing colours of these rocks are dark grey or green, and in texture they are usually fine grained.

The boundaries of this series of rocks are, as a rule, not clearly defined for the reason that they have been intruded by the granites and gneisses, and a wide contact zone of highly altered rock has been formed as a result. Tongues of the granite also project into these rocks and tend to obscure the sharpness of the contact line. The patches of Huronian-Keewatin rocks that are now found here and there are mere remnants of once more extensive sheets that probably extended over the whole region, but destruction and absorption by the granite batholiths and erosion have reduced these rocks to their present areal dimensions.

*Laurentian.*—For convenience in description in this report it has been deemed advisable to classify all the granites and gneisses and other massive crystalline igneous rocks under this head, although it is certain that many of the granite bodies are of later age and are intrusive into the true Laurentian. These rocks cover a greater area in the Winnipeg River basin than those of any other age or formation. They might be said to form the basement on which all the other geological formations of the region rest, or in which they have been sunk.

These rocks are all of igneous origin, and have crystallized out from fusion, some in massive form and others in which a gneissic or foliated structure has been induced. The commonest variety of the massive form is a true granite containing quartz, feldspar, and mica. In texture they are crystalline and of medium to coarse grain. Some phases have a pronounced porphyritic habit, with individual crystals, sometimes several inches long. In other varieties the mica is replaced by hornblende, either wholly or only in part. Basic dark-coloured phases of the massive varieties also occur, but they do not cover wide areas.

The gneissic varieties of the Laurentian are of the same mineral composition as the massive, and are differentiated only by their foliated character. They frequently mark the border of the massive bodies into which they grade insensibly without change of mineral constituents. Their gneissic characters have probably been induced by movement in the igneous mass during solidifica-

tion, or else they represent portions of the Keweenaw rocks that have been torn off by the igneous rock in the course of its intrusion, and recrystallized by it.

The granites are probably the most important building stones within the area of the Winnipeg River basin, but they are not all equally good. In strength, mineral composition, and durability they are generally suitable for all construction purposes, but dynamic forces of compression have often ruined their structure for such purposes by developing lines of cleavage and fracture at inconvenient angles. The younger granites are, as a rule, more suitable for quarrying and building than the older granites, since they have suffered less from dynamic forces, and have retained their massive, unfractured, and unfoliated form. These granites, however, are not as widespread as the older granites and gneisses.

*Keweenawan.*—In the region bordering the Winnipeg River basin on the east, namely, about lake Nipigon, a large area is covered by a thick sheet of Keweenawan sediments and diabase. This sheet at one time extended westward into the basin of Winnipeg river, but on account of its erosion it is now only represented in the eastern portion of the basin by isolated patches of diabase which rest on the older rocks. The diabase lies in a horizontal attitude, and is usually found in the deeper valleys and along the shores of lakes.

Farther west the Keweenawan is represented by dykes of diabase which are found on lake of the Woods, Shoal lake, and in the Rainy Lake region. These dykes have a general northwest and southeast trend and are remarkable for their width and persistence.

*Ordovician.*—On the western edge of the basin of Winnipeg river the pre-Cambrian rocks pass out of sight underneath a cover of Ordovician rocks, whose eastern boundary follows a line drawn from the mouth of Winnipeg river to the southwest end of the lake of the Woods. These rocks are limestone and sandstone which, on account of a covering of glacial drift, are rarely exposed at the surface. The limestone quarries at Tyndall and Garson are in the Ordovician. The beds lie flat and the rock has a light grey, mottled colour. It makes a useful building stone.

*Pleistocene and Recent.*—The formations classed under this head are the loose unconsolidated materials of Glacial and post-Glacial origin which cover the surface of the older rocks more or less throughout the whole region. They are beds of stratified clays and sands laid down presumably in ancient lake basins, and irregular deposits of gravel of both Glacial and recent stream origin. The most extensive gravel deposits are of glacial origin and have been formed by streams flowing under or on the glacial ice-sheet, or they represent the beaches of now extinct glacial lakes.

The present rivers have not, as a rule, a great extent of beach gravels.

#### DETAILED GEOLOGY OF SOME OF THE POWER SITES.

Since the Dominion Water Power Branch is concerned only with the development of Winnipeg River power sites that lie inside the province of Manitoba it is unnecessary to present details of the geology of the various sites in the province of Ontario. At the same time, no geological investigations have ever been carried out in the Winnipeg River basin that had for their

main purpose the study of the rocks relative to power development, consequently the references in the various reports to the geology at the proposed sites are of a very general and cursory character.

In a report on the East Shore of lake Winnipeg, J. B. Tyrrell describes the geology of Winnipeg river as far up as the mouth of Whitemouth river. At Pine falls, he says, "similar red granite and hornblende granite are exposed, and little foliation is seen in the granite at the short portages above. No boulders are noticed along this stretch of the river, the country being all covered by a thick bed of alluvial blue clay. . . . From these portages to Silver falls . . .

the rock is seen, the banks being of alluvial clay, sloping up gradually to woods of aspen. At the falls the rock is a red hornblende granite." Above Silver falls the banks are composed of blue alluvial clay without pebbles or boulders, through which only two or three bosses of granite project.

At Whitemud falls the river breaks over a mass of red granite containing a few inclusions of dark grey gneiss, and cut by many veins of red pegmatite.


The rock at Little du Bonnet falls is a hornblende granite of light to dark grey colour. Above this to the Grand du Bonnet falls the river has low rocky banks, with clay generally filling the depressions, while at the falls knobs of granite protrude here and there through the surface clay.

The two falls between the Grand du Bonnet falls and Lac du Bonnet are known as McArthur falls, at each of which red granite containing inclusions of gneiss project in several places through the thin covering of alluvial material.

The shores of Lac du Bonnet are composed almost entirely of a coarse red micaceous granite which is massive and free from inclusions or pegmatite veins. About the mouth of Oiseau river, however, is a belt of red and green schists and gneisses which strikes up the valley of Oiseau river. These schists are of Huronian or Keewatin age and are the only rocks of this age on the Winnipeg river in Manitoba.

At the Seven Sisters falls the rock is said to be similar in character and composition to that at the previously mentioned falls.





WATER POWER BRANCH  
 J. B. CHALLINOR, Superintendent.

**GEOLOGICAL MAP**  
 - of the -  
**WINNIPEG RIVER**  
**BASIN.**

To accompany a report by CHARLES CAMSELL, B.Sc., Ph.D., on the GEOLOGY OF THE WINNIPEG RIVER BASIN, prepared at the request of the Superintendent of Water Power

**LEGEND**

- |   |   |   |
|---|---|---|
| <br><b>ORDOVICIAN</b><br>(limestone) | <br><b>HURONIAN-KEEWATIN</b><br>(mainly schists, limestone, slate, and quartzite.) | <br><b>LAURENTIAN</b><br>(mainly granites and gneisses.) |
|---|---|---|

March, 1915.





REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

APPENDIX IV.  
WATER POWER REGULATIONS



## APPENDIX IV.

### WATER POWER REGULATIONS

UNDER THE DOMINION LANDS ACT AND THE DOMINION FOREST RESERVES AND PARKS ACT.

*Regulations made by His Excellency the Governor General in Council in virtue of the provisions of subsection 2 of section 35 of the Dominion Lands Act, 7-8 Edward VII, chapter 20, and by His Royal Highness the Governor General in Council in virtue of the provisions of subsection (b) of section 17 of the Dominion Forest Reserves and Parks Act, 1-2 George V, chapter 10, to govern the granting and administration of water-power rights in the provinces of Manitoba, Saskatchewan, Alberta, and in the Northwest Territories, and in Dominion Parks within the Railway Belt of British Columbia.*

SECTION 35—DOMINION LANDS ACT—7-8 EDWARD VII, CHAPTER 20, AS AMENDED BY SECTION 6, CHAPTER 27 OF 1-2 GEORGE V.

35. Lands which are necessary for the protection of any water supply or lands upon which there is any water-power, or which border upon or being close to a water-power will be required or useful for the development and working of such water-power, shall not be open to entry for homestead, for purchased homestead, or pre-emption, or be sold or conveyed in fee by the Crown, but may only be leased under regulations made by the Governor in Council.

2. Subject to rights which exist or may be created under the Irrigation Act, the Governor in Council may make regulations: (a) for the diversion, taking or use of water for power purposes, and the granting of the rights to divert, take or use water for such purposes, provided that it shall be a condition of the diversion or taking of water that it shall be returned to the channel through which it would have flowed if there had been no such diversion or taking, in such manner as not to lessen the volume of water in the said channel; (b) for the construction on or through Dominion or other lands of sluices, races, dams or other works necessary in connection with such diversion, taking or use of water; (c) for the transmission, distribution, sale and use of power and energy generated therefrom; (d) for the damming of and diversion of any stream, watercourse, lake or other body of water for the purpose of storing water to augment or increase the flow of water for power purposes during dry season; (e) for fixing the fees, charges, rents, royalties or dues to be paid for the use of water for power purposes, and the rates to be charged for power or energy derived therefrom.

3. Any person who under such regulations is authorized to divert, take or use water for power purposes, or to construct works in connection with the diversion, taking or use of water for such purposes, shall for the purposes of his

<sup>1</sup>NOTE.—These regulations were made to apply to all forest reserves and parks by order of His Excellency the Governor General in Council, dated June 6, 1911, and by order of His Royal Highness, the Governor General in Council dated August 2, 1913, in virtue of the provisions of subsection (b) of section 17 of the Dominion Forest Reserves and Parks Act.

<sup>2</sup>NOTE.—These regulations were made to apply to all school lands by order of His Royal Highness, the Governor General in Council, dated the 9th of February, 1915.

<sup>3</sup>NOTE.—By virtue of the provisions of the Railway Belt Water Act, 2 George V, chapter 47, and the Railway Belt Water Act, 1913, 3-4 George V, chapter 45, all water within the Railway Belt of British Columbia is administered under and in accordance with the provisions of the Water Act, 1909, and amendments thereto, by the province of British Columbia, except only the territory included within Dominion Parks.

undertaking have the powers conferred by the Railway Act upon railway companies, including those for the acquisition and taking of the requisite lands, so far as such powers are applicable to the undertaking and are not inconsistent with the provisions of this Act or the regulations thereunder, or with the authority given to such persons under such regulations—the provisions of the said Railway Act giving such powers being taken for the purposes of this section to refer to the undertaking of such person where in that Act they refer to the railway of the railway company concerned.

4. All maps, plans and books of reference showing lands other than Crown land necessary to be acquired by any such person for right of way or other purposes in connection with his undertaking shall be signed and certified correct by a duly qualified Dominion Land Surveyor.

5. Such maps, plans and books of reference shall be prepared in duplicate, and one copy thereof shall be filed in the office of the Minister at Ottawa, and the other shall be registered in the land titles office for the registration district which within the lands affected are situated.

6. The Minister, or such officer as he designates, shall in case of dispute, be the sole and final judge as to the area of land which may be taken by any person without the consent of the owner for any purpose in connection with any water-power undertaking.

REGULATIONS GOVERNING THE GRANTING OF WATER-POWER RIGHTS IN THE PROVINCES OF MANITOBA, SASKATCHEWAN AND ALBERTA, AND IN THE NORTHWEST TERRITORIES, INCLUDING ALL DOMINION FOREST RESERVES AND PARKS, AND IN DOMINION PARKS WITHIN THE RAILWAY BELT OF BRITISH COLUMBIA.

Established and approved by orders of His Excellency the Governor General in Council dated June 2, 1909, June 8, 1909, April 20, 1910, January 24, 1911, August 12, 1911, and by orders of His Royal Highness, the Governor General in Council, dated August 2, 1913, and February 9, 1915, in virtue of the provisions of subsection 2 of section 35 of the Dominion Lands Act, 7-8 Edward VII, chapter 20.

DEFINITION OF WORKS.

1. Under these regulations the word "works" shall be held to mean and include all sluices, races, dams, weirs, tunnels, pits, slides, flumes, machine fixed to the soil, buildings and other structures for taking, diverting and storing water for power purposes, or for developing water-power and rendering the same available for use.

MODE OF APPLICATION.

2. Every applicant for a license to take and use water for power purposes shall file with the Minister of the Interior a statement in duplicate setting forth:—

- (a) The name, address and occupation of the applicant.
- (b) The financial standing of the applicant so far as it relates to his ability to carry out the proposed works.
- (c) The character of the proposed works.
- (d) The name, or if unnamed, a sufficient description of the river, lake or other source from which water is proposed to be taken or diverted.
- (e) The point of diversion.
- (f) The height of the fall or rapid of such river, lake or other source of water at high, medium and low stages, with corresponding discharges of water per second, reckoned approximately in cubic feet.

(g) A reasonably accurate description, and the area, of the lands required in connection with the proposed works, such lands, if in surveyed territory, to be described by section, township and range, or river or other lot, as the case may be, and a statement whether such lands are or are not Dominion lands.

(h) If such lands be not Dominion lands, then the applicant shall give the name of the registered owner in fee, and of any registered mortgagee or lessee thereof, and of any claimant in actual possession other than a registered owner, mortgagee or lessee.

(i) The minimum and maximum amount of water-power which the applicant proposes to develop, and the maximum amount of water which he desires for such purpose.

(j) Sketch plan showing approximate locations of the proposed works.

(k) Elevations of headwater and tailwater of the nearest existing works, if any, below and above the proposed works.

(l) Particulars as to any water to be taken, diverted or stored to the detriment of the operation of existing works, if any.

(m) Particulars as to any irrigation ditches or reservoirs, or other works for irrigation within the meaning of *The Irrigation Act*, in use or in course of construction within the vicinity of the proposed works, and which might affect or be affected by the operation of the proposed works.

#### APPLICATION BY A COMPANY.

**3.** If the applicant be an incorporated company, the statement shall, in addition to the foregoing information, set forth:—

(a) The name of the company.

(b) The names of the directors and officers of the company and their places of residence.

(c) The head office of the company in Canada.

(d) The amount of subscribed and paid-up capital, and the proposed method of raising further funds, if required, for the construction and operation of the proposed works.

(e) Copy of such parts of the charter or memorandum of association as authorize the application and proposed works.

#### APPLICATION BY A MUNICIPALITY.

**4.** If the applicant be a municipality, then, excluding the special information to be given by a company, the following information shall be given:—

(a) The location, area and boundaries of the municipality.

(b) The approximate number of its inhabitants.

(c) The present estimated value of the property owned by such municipality, and the value of the property subject to taxation by such municipality.

#### MINISTER MAY REQUEST FURTHER INFORMATION.

**5.** The Minister of the Interior shall have the power to call for such other plans and descriptions, together with such measurements, specifications, levels, profiles, elevations and other information as he may deem necessary, and the same shall be furnished by and at the expense of the applicant.

The Agreement for,—(a) A license for the diversion and use of water.  
(b) A lease of the necessary lands.

6. Upon receipt and consideration of the application, and information accompanying same, the Minister of the Interior may, if he approves of the proposed works, enter into an agreement with the applicant, which agreement, in addition to usual conditions and covenants, shall contain clauses to provide as follows:—

- (a) For a time within which the proposed works shall be begun.
- (b) For a stated minimum amount of expenditure to be made in connection with the works annually during the term of the agreement.
- (c) For a stated amount of water-power to be developed from the water applied for within a fixed period not exceeding five years.
- (d) For summary cancellation of the agreement by the Minister if any of the above conditions have not been complied with.
- (e) For defining and allotting the areas of Dominion lands within which the applicant may construct and operate the proposed works; and if there be no Dominion lands available for such purpose then for defining and allotting the lands in regard to which the applicant may exercise the powers given under section 35, subsection 3 of the *Dominion Lands Act*.
- (f) For granting a license to the applicant, upon fulfilment of the said agreement, to take, divert and use for power purposes a stated maximum amount of water, in accordance with the application, and plans and specifications as approved by the Minister; the term of such license to be twenty-one years at a fixed fee payable annually, and such license to be renewable as provided for in these regulations.
- (g) For granting a lease to the applicant of such Dominion lands as may be allotted under paragraph (e) of this section, and approved of by the Minister, such lease to be at a fixed rental, for a term of twenty-one years running concurrently with the said license, and renewable in like manner, and as near as may be subject to all the terms and conditions thereof. When there are no Dominion lands available for such purpose, or when other lands are considered by the Minister to be more suitable for such purpose, then the Minister shall define such lands in regard to which the applicant may exercise the powers given under section 35, subsection 3, of the *Dominion Lands Act*.

#### INSPECTION OF CONSTRUCTION WORK.

7. During the construction of any works for the development of water-power the Minister of the Interior, or any engineer appointed by him for that purpose, shall have free access to all parts of such works for the purpose of inspecting same, and ascertaining if the construction thereof is in accordance with the plans and specifications approved of by the Minister, and whether the terms of the agreement, as provided for in the preceding section, are being fulfilled.

#### THE LICENSE FOR THE DIVERSION AND USE OF WATER.

Upon fulfilment by the applicant of the conditions of the said agreement, the Minister of the Interior shall grant to the applicant a license as agreed upon, and such license shall contain clauses to provide as follows:—

- (a) The term of the license shall be twenty-one years, renewable for three further consecutive terms of twenty-one years each, at a fixed fee payable annually and to be readjusted at the beginning of each term, as hereunder provided.

(b) At the expiry of each term of twenty-one years the Governor in Council, may, on the recommendation of the Minister, order and direct that the license and any lease granted in connection therewith be cancelled. Provided that the Minister shall have given at least one year's notice to the licensee of intention so to cancel.

(c) If the licensee shall refuse to pay the license fee as readjusted by the Governor in Council, or as fixed by arbitrators chosen as provided in paragraph (e) hereunder, then in such case the Minister may renew the license at the former fee, or the Governor in Council may, on the recommendation of the Minister, order and direct that the license and any lease issued in connection therewith be cancelled.

(d) In either of the above cases compensation shall be paid to the licensee as provided for in paragraph (e) hereunder.

(e) On termination of the third renewal of such license, except in case of default on the part of the licensee in observance of any of the conditions thereof, or of any lease granted in connection therewith, compensation shall be paid for the works to the amount fixed by arbitration, one arbitrator to be appointed by the Governor in Council, the second by the licensee, and the third by the two so appointed. If the licensee fails to appoint an arbitrator within ten days after being notified by the Minister to make such appointment, or if the two arbitrators appointed by the Governor in Council and the licensee fail to agree upon a third arbitrator within ten days after their appointment or within such further period as may be fixed by the Minister in either such cases such arbitrator, or third arbitrator, as the case may be, shall be appointed by the Judge of the Exchequer Court of Canada. In fixing the amount of compensation only the value of the actual and tangible works and of any lands held in fee in connection therewith shall be considered, and not the value of the rights and privileges granted, or the revenues, profits or dividends, being, or likely to be derived therefrom.

(f) The license shall state the maximum amount of water which the licensee may divert, store and use for power purposes, and shall provide for the return to the stream, or other source of water, of the full amount so diverted.

(g) The licensee shall develop such power as, in the opinion of the Minister, there shall be a public demand for, up to the full extent possible from the amount of water granted by the license.

(h) Upon a report being made by the Minister of the Interior to the Governor in Council that the licensee has not developed the amount of power for which there is a public demand, and which could be developed from the amount of water granted by the license, the Governor in Council may order to be developed and rendered available for public use the additional amount of power for which there is, in the opinion of the Minister, a public demand, up to the full extent possible from the amount of water granted by the license, and within a period to be fixed by the Minister, which period shall not be less than two years after the licensee or person in charge of the existing works shall have been notified of such order, and in default of compliance with such order the Governor in Council may direct that the license, together with any lease issued under these regulations shall be cancelled, and the works shall thereupon vest and become the property of the Crown without any compensation to the licensee.

(i) Upon a report being made by the Minister of the Interior to the Governor in Council that a greater amount of water-power could be developed advantageously to the public interests from the same stream

or other source of water from which the existing works derive power and (1st) that the existing works could be enlarged or added to for such purpose, then the Governor in Council may authorize the Minister to offer the licensee the privilege of constructing and operating such enlarged or additional works at or in the vicinity of the existing works, and to grant such supplementary license as he may consider proper for such purpose, and if the licensee fail within six months thereafter to accept such offer, and in good faith to begin and carry on to completion such enlarged and additional works, and to complete same in accordance with plans and specifications approved of by the Minister, and within a fixed period not to exceed five years, and upon like conditions as the existing works were begun and completed; or (2nd) if the Minister shall report to the Governor in Council that the existing works, owing to their location or construction, cannot advantageously be enlarged or added in order to develop further power sufficient to meet the probable demand, or would be a hindrance to other works contemplated for such purpose; or (3rd) that the existing works cannot, or will not, be any longer advantageously operated owing to the exercise of rights existing or created under the *Irrigation Act*; then in every such case, the Governor in Council may order and direct that the license, and any lease in connection therewith, and all rights thereunder, shall be cancelled, and the existing works shall thereupon vest in and become the property of the Crown: Provided always that in every such case compensation shall be paid to the licensee as provided for in paragraph (e) of section 8 of these regulations, together with a bonus apportioned as follows:—

(1) If the works have been in operation less than five years, a thirty per cent bonus upon the value of the works.

(2) If in operation more than five years, and less than ten years, a twenty-five per cent bonus.

(3) If in operation more than ten, and less than fifteen years, a twenty per cent bonus.

(4) If in operation more than fifteen, and less than twenty years, a fifteen per cent bonus.

(5) If in operation twenty years or more, a ten per cent bonus.

(j) That the license shall not be transferable without the written consent of the Minister, and that if the licensee fail to keep and observe all or any of the conditions of the license, or any renewal thereof, or of any lease to be issued in connection therewith, then the license, together with such lease, shall in every such case be subject to cancellation by the Exchequer Court on the application of the Crown.

(k) That a schedule of rates and prices to be charged to the public for the use of power shall first be submitted by the licensee to the Board of Railway Commissioners of Canada for adjustment and approval before being put into effect, and that no rates or prices for power shall be legal or enforceable until such schedule has been so adjusted and approved nor if they shall exceed the amount fixed by such schedule; and that such schedule shall be readjusted and approved by the Board every seven years during the term of the lease and license, and all renewals thereof.

(l) That for the purpose of ascertaining the quantity of power actually developed, or capable of being developed, from the amount of water granted by such license, the Minister, or any engineer appointed by him for that purpose, shall have free access to all parts of the works, and to all books, plans or records in connection therewith, bearing on the quantity of power developed, and may make measurements, take

observations and do such other things as he may consider necessary or expedient for such purpose, and the findings of the Minister, or such engineer, thereon shall be conclusive and binding upon the licensee.

(m) For the proper provision, as required by law, for the passage of logs and timber down the stream or other waterway affected by the works.

(n) For the erection and maintenance by the licensee of a durable and efficient fishway in the stream or other waterway affected by the works when so required by the proper officer or authority in that behalf.

(o) That the licensee shall have no right to any water beyond the amount stated in the license.

(p) For the indemnifying of the Crown against all actions, claims or demands against it by reason of anything done by the licensee in the exercise, or purported exercise, of the rights and privileges granted under the lease or license.

#### FORM OF AGREEMENTS AND LICENSES.

9. The agreements and licenses to be issued hereunder shall, subject always to the provisions of these regulations, be in such form and contain such provisions as the Minister may from time to time determine.

#### STORAGE OF WATER.

10. If at any time it is proposed by the applicant or the licensee to divert water from any lake or body of water for storage purposes, or to dam same in order to augment the flow of water in any stream from which water power is to be developed, the applicant or licensee shall, in addition to other information required under these regulations, file plans as follows:—

(a) A general plan in duplicate, on tracing linen, showing the location of such lake or other body of water, and the lands to be submerged or otherwise affected, and contour lines showing the water level at high and low stages, and the level to which it is proposed to raise such water for storage, and the estimated storage capacity of such lake or other body of water.

(b) A plan in duplicate, from actual survey, by a Dominion Land Surveyor, and certified to by him, showing the lands to be submerged or otherwise affected by the proposed storage; the name of the registered owner in fee of such lands, and of any registered mortgagee or lessee thereof, and of any claimant in actual possession other than a registered owner, mortgagee or lessee.

(c) A detail plan in duplicate on tracing linen, showing all dams and other works proposed to be constructed in connection with such storage.

#### FORM OF AUTHORITY OF STORAGE OF WATER.

11. When the plans of such storage of water have been approved of by the Minister of the Interior, provision for same shall be made in the agreement for a license, or in the license itself, or in a supplementary license to be issued for such purpose, upon such terms and conditions as may appear to the Minister reasonable or expedient in the circumstances of each case, and subject to these regulations.

## SMALL WATER-POWERS OF LESS CAPACITY THAN 200 HORSE-POWER.

**12.** If upon receipt and consideration of the information set out in sections 2, 3, 4 and 5, the water-power to be developed is found to have no greater capacity than 200 horse-power at the average low stage of water, the Minister may issue a lease and a license as may be required, authorizing the development of the proposed power; the lease and license to be for a period of ten years, subject to such special terms and conditions as may be considered advisable in each particular case and renewable if in the opinion of the Minister the power has been continuously and beneficially used.

REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

---

APPENDIX V.  
LIST OF BENCH MARKS



## APPENDIX V.

### LIST OF BENCH MARKS.

BENCH MARKS ESTABLISHED ALONG THE WINNIPEG RIVER IN CONNECTION WITH THE POWER SURVEY.

No.	Elevation.	Description.	Location.
"A"	1,045.88	Copper bolt in concrete	In sill of side door, northwest corner of Kenora municipal power-house.
"B"	1,064.09	Copper bolt in concrete	In centre concrete base of tower of transmission line, 80 feet from Kenora municipal power house.
223	1,043.70	Chiselled and painted on rock	400 feet northeast of Kenora municipal power-house, on outcrop of rock on right bank, below power house.
220	1,046.73	Chiselled and painted on rock	About 450 feet above the head of Dalles rapids, on the left bank.
219	1,044.67	Chiselled and painted on rock	About 1,100 feet below island at foot of Dalles rapids, on left bank 400 feet below meter section.
218	1,036.16	Chiselled and painted on rock	At crest of First fall, south channel, Whitelog rapids, on right bank.
217	1,038.70	Chiselled and painted on rock	About 150 feet above crest of Second fall, south channel Whitelog rapids, on right bank.
216	1,017.92	Chiselled and painted on rock	About 100 feet above crest of Fourth fall, south channel, Whitelog rapids, on right bank.
215	1,002.59	Chiselled and painted on rock	On left bank at Fifth fall, South channel, Whitelog rapids.
214	997.49	Chiselled and painted on rock	East end of island some 1 mile above First falls, close to left bank and near the mouth of the English river, on steep rocky bank.
213	991.16	Chiselled and painted on rock	On left bank around bend from First falls, and some 100 yards from it, close to water's edge, on the top of a sheer rock several feet high.
212	989.51	Chiselled and painted on rock	On right bank on point across a wide expanse of the river below First falls, conspicuous from upstream.
211	989.67	Chiselled and painted on rock	On right bank some 100 feet west of E. bdy., sec. 22, tp. 15, r. 17, E.P.M., sheer rocky bank, conspicuous from swift water past interprovincial boundary.
210	991.06	Chiselled and painted on rock	On left bank some 100 ft. east of Wit. I.P.M.-XVII, XVI, XVII E. and VIII N. close to shore, on a sloping bank conspicuous from downstream looking south.
209	989.64	18-inch jack pine	Sec. 20 16 17 E.P.M., on left bank SW. of small island near bank.
208	988.85	18-inch poplar	On right bank on point opposite East end of a long narrow island and in sec. 19, tp. 16, r. 17 E.P.M., some 100 ft. upstream from E. bdy., sec. 24-16-16 E.P.M.
207	986.14	5-inch poplar	On right bank, on high point opposite west end of large island ("D" on township plan), in sec. 24 16 16, E.P.M., and close to E. bdy., sec. 23.
206	989.48	15-inch spruce	On southeastern side of island ("C" on township plan) near right bank in sec. 23 16 16 E.P.M.
205	987.16	8-inch poplar	On outbend of right bank opposite channel between islands ("A" and "B" on township plan), in sec. 22 16 16 E.P.M.
204	986.28	6-inch poplar	On right bank where the river bank bends to the north and the river widens to over half a mile at west end of island "A" and in sec. 22 16 16 E.P.M.
203	986.29	10-inch poplar	On right bank on point N. 38° W. from NW. point of island "A" and in SE. 1/4 sec. 28 16 16 E.P.M.
202	984.51	10-inch poplar	On right bank on broad point above narrows, N. 56° W. from NW. point of island "A" and in SW. 1/4 sec. 28-16-16 E.P.M.
201	985.85	20-inch spruce	On left bank on small rock point on west side of a broad point in SW. 1/4 sec. 29 16 16 E.P.M., at edge of trees.
200	984.87	8-inch poplar	On left bank on small point in SE. 1/4 sec. 29 16 16 E.P.M.
199	985.68	14-inch poplar	On left bank in SE. 1/4 sec. 25 16 15 E.P.M., above swift water at Lamprey falls and opposite a small island.
198	983.34	9-inch poplar	On south end of island in rapids above Lamprey falls.
197	984.22	15-inch spruce.	On left bank on point 700 ft. above Lamprey falls and opposite a small island.
196	984.27	12-inch spruce.	On left bank on point at head of Lamprey falls.
195	989.79	Jack pine stump 5 inches by 5 inches by 3 inches.	500 feet NW. of intake of Point du Bois power plant.
194	987.96	Painted on concrete and marked 218.88 (city datum).	Pillar of verandah of staff house, Point du Bois, first pillar south of steps.
193	938.73	5-inch jack pine	On right bank on first rocky point below rapids which are situated some 200 yards downstream from transmission line on Point du Bois power plant, and in NW. 1/4 sec. 25 15-14 E.P.M.

## BENCH-MARKS ESTABLISHED ALONG THE WINNIPEG RIVER, ETC. (Continued)

No.	Elevation	Description.	Location
193A	939.87	Chiselled and painted on rock	On right bank, south end of bay, below rapids situated some 200 yds. downstream from transmission line of Point du Bois power plant, on top of rock shore and in NW $\frac{1}{4}$ sec. 25-15-14 E.P.M.
192	940.47	12-inch spruce	On right bank above Eight Foot falls, 375 feet west of rock cut and close to log shack S. 45° W. from $\frac{1}{4}$ W.P. on E. bdy., sec. 25-15-14 E.P.M.
192A	940.37	Chiselled and painted on rock	On right bank above Eight Foot falls, 320 feet west of rock cut, 64 ft. N.E. of shack and S. 44° W. from $\frac{1}{4}$ W.P. on E. bdy., sec. 25-15-14 E.P.M.
191	941.38	10-inch jack pine	Right bank below Eight Foot falls, 160 ft. SW. of lower end of rock cut and N. 31° W. from Wit. I.P. Stone M. 4 S. on E. bdy., sec. 25-15-14 E.P.M.
191A	940.02	Chiselled and painted on rock	Right bank below Eight Foot falls, 450 ft. SW. of rock cut and 8 ft. east of B.M. No. 171.
190	929.21	10-inch poplar	Right bank on point 1 mile south of Eight Foot falls and 220 feet S. 66° E. from $\frac{1}{4}$ W.P. on E. bdy., sec. 24-15-14 E.P.M.
190A	928.21	Chiselled and painted on rock	Right bank on point 1 mile south of Eight Foot falls and 205 feet S. 82° E. from $\frac{1}{4}$ W.P. on E. bdy., sec. 24-15-14 E.P.M.
190B	930.75	Chiselled and painted on rock	On left bank on E. bdy. of sec. 24-15-14 E.P.M., some 200 ft. west of trail to Hunt Club, on top of steep rock bank.
189	929.60	6-inch poplar	Above Slave falls on right bank, 170 ft. N. 62° W. from "A" frame of cable meter station and 150 ft. east of log shack, SW. $\frac{1}{4}$ sec. 12-15-14 E.P.M.
189A	929.91	Chiselled and painted on rock	Above Slave falls on right bank 40 ft. S. 6° W. of "A" frame of cable meter station.
	952.62	6-inch poplar stump	Above Slave falls on right bank on E. bdy., sec. 11-15-14 E.P.M., some 125 ft. south on the line from the bank.
	939.33	16-inch poplar stump	Below Slave falls on right bank, on E. bdy., sec. 11-15-14 E.P.M. and 165 ft. north of Wit. I.P. & M.
188	916.03	Jack pine stump	Below Slave falls on right bank, in sec. 2-15-14 E.P.M., 530 ft. S. 22° W. from Wit. I.P. sec. 11 and N. 60° E. from rock at mouth of Portage bay.
188A	912.33	Chiselled and painted on rock	Below Slave falls on right bank in sec. 2-15-14 E.P.M., 580 ft. S. 22° W. of Wit. I.P.M. on E. bdy., sec. 11, and 53 ft. S. 33° W. of B.M. No. 188.
	939.72	Jack pine stump	Above Slave falls on left bank, 125 ft. SE. of support for cable of meter station, in SW. $\frac{1}{4}$ sec. 12-15-14 E.P.M.
	967.41	Jack pine stump	Below Slave falls on left bank, due east of Wit. I.P.M. on E. bdy., sec. 11, and 540 feet from shore.
187	910.38	8-inch spruce	Three-quarter mile below Slave falls on right bank at narrows between island and mainland, first swift water below Slave falls, sec. 2-15-14 E.P.M.
187A	917.32	Chiselled and painted on rock	On right bank at narrows between island and mainland, first swift water below Slave falls, 25 ft. SW. of B.M. No. 187, sec. 2-15-14 E.P.M.
186	908.63	5-inch jack pine	On right bank on short point in the middle of Scott's channel, 700 ft. downstream from I.P. of metering station of city of Winnipeg and S. 50° W. from hub on right on meter station, sec. 21-14-14 E.P.M.
186A	907.65	Chiselled and painted on rock	On right bank Scott's channel N. 30° E. from point on right bank at lower end of channel, above bay adjacent to point at lower end, sec. 21-14-14 E.P.M.
Sta. 79	903.15	Chiselled and painted on rock	On right bank at crest of Sturgeon falls. Referenced to 9-inch oak, 16 ft. NW., and 5-inch poplar 34 ft. E. sec. 8-14-14 E.P.M.
Sta. 79A	905.58	Chiselled and painted on rock	On middle of southern part of island at Sturgeon falls. Referenced to three jack pine trees 37.5 feet, 35 feet, and 14 feet in sec. 8-14-14 E.P.M.
185	912.27	5-inch oak	On left bank above Sturgeon falls at head of portage in sec. 8-14-14 E.P.M.
185A	907.45	Chiselled and painted on rock	On left bank above Sturgeon falls, close to head of portage in sec. 8-14-14 E.P.M.
184	902.32	7-inch poplar	On left bank in sec. 13-14-13 E.P.M., on lower side of the neck of the "Barrier".
184A	903.73	Chiselled and painted on rock	On left bank in sec. 13-14-13 E.P.M., on lower side of the neck of the "Barrier" on low rock.
183	899.05	10-inch dry jack pine	On right bank at water's edge, 70 ft. above small diversion weir, 130 ft. downstream from E. bdy., sec. 2-14-12 E.P.M.
183A	901.18	Chiselled and painted on rock	On right bank on sloping bank 80 ft. above small diversion weir, 125 ft. downstream from E. bdy., sec. 2-14-12 E.P.M., N. 85° W. from Rock island forming part of weir.
182	895.58	7-inch poplar	Sec. 2-14-12 E.P.M., on right bank near water's edge, 150 ft. above Twin falls, 30 ft. above head of portage and N. 25° E. from northerly point of large island at head of falls.
182A	897.96	Chiselled and painted on rock	Sec. 2-14-12 E.P.M. on right bank near water's edge, on top of steep rock 90 ft. above Twin falls and N. 45° W. from northerly point of large island at head of falls.
181	894.00	10-inch poplar	At mouth of Loon river, on right bank and upstream some 650 feet from Wit. I.P.M., on E. bdy., sec. 3-14-12 E.P.M.
181A	893.25	Chiselled and painted on rock	At mouth of Loon river, on right bank, on flat rock 25 feet from water's edge and some 700 feet upstream from Wit. I.P.M. on E. bdy., sec. 3-14-12 E.P.M.
180	893.80	12-inch poplar	Sec. 3-14-12 E.P.M. on right bank opposite a small island midstream between the bank and a large island called Porcupine Island.

BENCH-MARKS ESTABLISHED ALONG THE WINNIPEG RIVER, Etc.—Continued

No.	Elevation.	Description.	Location.
180A	894.99	Chiselled and painted on rock	Sec. 4-14-12 E.P.M., on right bank, on an out-bend of the bank conspicuous from the river, on steep rocky bank opposite a small island midstream between the bank and Porcupine island.
179	894.42	12-inch poplar	Sec. 4-14-12 E.P.M., on right bank, some 350 feet downstream from E. bdy., sec. 4, close to shore and opposite a group of bare rock islands, situated 1/4 mile above first swift below Twin falls.
179A	891.35	Chiselled and painted on rock	Sec. 4-14-12 E.P.M., on right bank, on about wide point which is situated some 100 yards above first swift below Twin falls located on top of rock bank and conspicuous from upstream.
178	894.80	15-inch poplar	Sec. 4-14-12 E.P.M., on right bank, on east side of point at foot of first swift below Twin falls and some 25 feet from shore.
178A	892.98	Chiselled and painted on rock	Sec. 4-14-12 E.P.M., on right bank, on point at foot of swift on vertical rock at water's edge and conspicuous from the up and down stream.
177	891.34	18-inch poplar	Sec. 4-14-12 E.P.M., on right bank N. 60° E. from West 1 on N. bdy., sec. 12-13-12 E.P.M., and some 800 feet upstream from E. bdy., sec. 5.
177A	891.72	Chiselled and painted on rock	Sec. 4-14-12 E.P.M., on right bank, N. 50° E. from north point of rocky island, on E. bdy., sec. 5, and some 400 feet upstream from E. bdy., sec. 5; on vertical rock at water's edge, conspicuous from the river, up and down stream.
176	892.54	8-inch oak	Sec. 5-14-12 E.P.M., on right bank, on first rocky point of Seven Sisters falls some 1,000 feet downstream from E. bdy., sec. 5, and on W. side of point.
176A	891.38	Chiselled and painted on rock	Sec. 5-14-12 E.P.M., on right bank, on first rocky point of Seven Sisters falls, some 1,000 feet downstream from E. bdy., sec. 5, on top of bank, close to water's edge and conspicuous from up and down stream on the river.
175	894.40	12-inch poplar	Sec. 5-14-12 E.P.M., on right bank, N. 45° W. from low rock bend to south of left bank and some 200 yds. downstream from a small creek close to shore.
174	891.06	5-inch poplar	Sec. 11-12-12 E.P.M. on right bank, N. 72° W. from intersection of south shore and E. bdy., sec. 31, above Seven Sisters where the right bank bends to northeast and the stream widens, located close to shore.
173	890.37	9-inch mountain ash	Sec. 11-12-12 E.P.M., on right bank, on point at head of swift water above Seven Sisters, at edge of vegetation.
173A	890.44	Chiselled and painted on rock	Sec. 11-13-12 E.P.M., on right bank, on point at head of swift water above Seven Sisters, on shelving rocky shore.
173B	890.86	Chiselled and painted on rock	Sec. 11-13-12 E.P.M., on top of small island near left bank at crest of First fall of Seven Sisters, conspicuous from river.
172	892.46	10-inch jack pine	Sec. 36-13-11 E.P.M., on right bank, on point east of deep bay above Second fall of Seven Sisters at edge of vegetation.
172A	882.28	Chiselled and painted on rock	Sec. 36-11-11 E.P.M., some 350 feet downstream from E. bdy., sec. 36, on right bank, on point East side of the bay above Second fall of Seven Sisters, on shelving rocky shore.
171	872.49	8-inch poplar	Sec. 36-13-11 E.P.M., on right bank, on west side at low point below Second fall of Seven Sisters.
171A	871.15	Chiselled and painted on rock	Sec. 36-13-11 E.P.M., on right bank, on low point below Second fall of Seven Sisters, conspicuous from the river from above Third falls on north side.
170	867.09	7-inch mountain ash	Sec. 36-11-11 E.P.M., on right bank, in bay to east of high point below Third falls, close to edge of vegetation.
170A	869.77	Chiselled and painted on rock	Sec. 36-13-11 E.P.M., on right bank, on high point, first below Third fall of Seven Sisters.
170B	869.67	Painted on rock	Sec. 36-13-11 E.P.M. on left bank, at foot of Third fall of Seven Sisters.
	898.90	4-inch balsam stump	On left bank south of river, at Third falls, on a traverse line which crosses the portage some 400 feet from its lower end and situated some 400 ft. north of portage.
169	864.71	8-inch poplar*	Sec. 35-11-11 E.P.M., some 500 ft. downstream from E. bdy., sec. 35, on right bank on an out-bend of the bank N. 60° W. from first high point below Third fall of Seven Sisters.
169A	864.87	Chiselled and painted on rock	Sec. 35-11-11 E.P.M., approx. 1/4 mile down-stream from E. bdy., sec. 35, on right bank NW. of large rocky island mid-stream, N. 63° E. small island and N. 80° W. from first high point below fall.
168	864.40	8-inch poplar	Sec. 35-13-11 E.P.M., on right bank, some 400 feet above Fourth fall.
168A	864.19	5-inch birch	Sec. 35-13-11 E.P.M., and downstream from E. bdy., sec. 26, some 300 yds., on left bank below Third fall, S. 34° W. of high point on right bank below falls, S. 15° E. of large rocky island midstream.
168B	863.88	Chiselled and painted on rock	Sec. 35-13-11 E.P.M., on right bank, in small bay close to head of Fourth fall, on steep rocky bank, conspicuous from upstream.
168C	866.58	Painted on rock	Sec. 35-13-11 E.P.M., on left bank, on sloping rock point at Fourth falls of Seven Sisters, facing upstream.
167	857.52	7-inch spruce	Sec. 35-13-11 E.P.M., on right bank on east side of bay, below first high point downstream from Fourth falls, at edge of vegetation.

BENCHMARKS ESTABLISHED ALONG THE WINNIPEG RIVER, Etc. - *Continued*

No.	Elevation	Description	Location
167A	859.02	Chiselled and painted on rock	Sec. 35 11-11 E.P.M., on right bank, on first high point downstream from Fourth falls, on steep rock close to water's edge.
166	858.46	8-inch poplar	Sec. 34 13 11 E.P.M., and on an out-bend of right bank N. 80° W. from where the left bank is intersected by E. bdy. sec. 31
166A	857.62	Chiselled and painted on rock	Sec. 34 13 11 E.P.M., and downstream from E. bdy. sec. 31 some 100 yards, on an out-bend of right bank, N. 70° W. from where the left bank is intersected by E. bdy. sec. 31, and S. 45° W. from first high point below falls.
165	857.07	7-inch poplar	Sec. 34 13 11 E.P.M., on right bank, at head of lower portage of Seven Sisters, close to water's edge.
165A	856.55	Chiselled and painted on rock	Sec. 34 13 11 E.P.M., on right bank, at head of lower portage on rocky shore.
164	852.40	16 inch balsam of Gilead	On right bank below Seven Sisters falls, at lower end of portage, on high bank at edge of trees.
164A	844.80	Chiselled and painted on rock	Sec. 33 13 11 E.P.M., on right bank, below Seven Sisters falls, in small deep bay at foot of falls, on top of sheer rocky shore.
	843.61	9-inch balsam	On E. bdy. 28 13 11 E.P.M., 580 feet south of witness post on left bank and 15 feet south of base line.
	845.42	11 inch balsam	Sec. 28 13 11 E.P.M., on right bank of Whitemouth river, across from house of Louis Brent.
	854.84	Chiselled and painted on rock	Sec. 28 13 11 E.P.M., on rocky shore of right bank of Whitemouth river, opposite small point above Whitemouth falls.
	845.94	Stump	Sec. 33 13 11 E.P.M., close to shore of left bank, Winnipeg river, below Seven Sisters, some 200 yards downstream from low rocky point at mouth of Whitemouth river and opposite large rocky island at foot of falls.
163	851.68	7-inch oak	Sec. 33 13 11 E.P.M., on right bank, on point 1/4 mile below Seven Sisters, and across from a clearing and close to edge of trees.
163A	840.96	Chiselled and painted on rock	Sec. 33 13 11 E.P.M., on rocky shore of right bank, on point 1/4 mile below Seven Sisters and across from clearing, conspicuous from the river.
162	845.44	6-inch poplar	Sec. 4 14 11 E.P.M., on right bank above first "swift", below Seven Sisters, across from small island adjacent to left bank.
	841.74	Stump	Sec. 4-14 11 E.P.M., on left bank above low rocky point near head of first "swift" below Seven Sisters, close to shore.
161	850.00	16-inch oak	Sec. 4-14 11 E.P.M., on right bank, on south side of point, at bend in river about middle of first "swift" below Seven Sisters.
161A	840.75	Chiselled and painted on rock	Between secs. 4 and 5 14 11 E.P.M., on rocky shore of right bank, at bend in river about middle of first "swift" below Seven Sisters.
160	841.80	12-inch poplar	Sec. 8 14 11 E.P.M., on right bank, above a narrow strip of hay land and watercourse, N. 45° E. from creek on left bank, river bends to NW. downstream.
160A	844.26	Chiselled and painted on rock	Sec. 8 14 11 E.P.M., on right bank, below a low small rounded point and opposite a small creek on low rock outcrop.
159	841.40	16-inch poplar	Sec. 8 14 11 E.P.M., on an out-bend of right bank, some 400 feet south of N. bdy. sec. 8 and ch. to shore.
158A	840.16	Chiselled and painted on rock	On right bank near head of rapids in sec. 17 14 11 E.P.M., and S. 60° W. from house of Charles Gustafson, on low rock outcrop.
157	848.90	22-inch poplar	On right bank in SW. 1/4 sec. 20 14-11 E.P.M., 150 feet west from log house of P. A. Larson, at edge of trees.
156	849.81	5-inch poplar	Sec. 29 14 11 E.P.M., close to shore, on right bank 670 feet north of N. bdy. sec. 26.
156A	829.78	Chiselled and painted on rock	Sec. 29 14 11 E.P.M., on right bank.
155	844.26	16-inch poplar	On right bank, near shore, in NW. 1/4 sec. 29 14 11 E.P.M., and N. 70° E. of house of Olaf Dohlgren on left bank.
154	844.68	8-inch spruce	On left bank, in sec. 32-11 11 E.P.M., downstream at edge of trees, some 1/4 mile from house of John Lonade.
152	826.50	8-inch poplar	Sec. 8 15 11 E.P.M., on right bank, close to shore and to summer cottages on first point upstream from island owned by Lac du Bonnet Mining & Development Co., on which is located a telephone pole.
152A	826.57	Chiselled and painted on rock	Sec. 8 15 11 E.P.M., on right bank, on low rocky shore, close to summer cottages on first point upstream from island owned by Lac du Bonnet Mining & Development Co.
151	828.18	10-inch poplar	Sec. 27 15 14 E.P.M., on left bank, a lone tree on first rocky point upstream from city bridge and downstream from N. bdy. sec. 22, some 750 feet, at edge of vegetation.
150	828.30	10-inch poplar	Sec. 27 15 14 E.P.M., on left bank, some 500 feet upstream from city bridge, close to edge of vegetation.
	826.30	Chiselled on rock (marked 826-11)	Sec. 27 15 11 E.P.M., on left bank, some 100 feet upstream from bridge on top of highest rock and close to shore.
149	828.81	Blazed tree	Sec. 27-15 11 E.P.M., on left bank, close to edge of trees, some 500 feet downstream from fish company's vice house at city bridge.
149A	828.66	Chiselled and painted on rock	Sec. 27-15 11 E.P.M., on left bank, on rock point some 400 feet upstream from shack and S. 55° W. from fish company's storehouse which is on south side of point, located some 1/2 mile from city bridge.

## BENCHMARKS ESTABLISHED ALONG THE WINNIPEG RIVER Etc. (Continued)

No.	Elevation	Description	Location
118	826.36	Blazed tree	Sec. 14-15-11 E.P.M. on left bank, some 100 feet upstream from E. bdy. sec. 31 on south side of point at first swift current below city bridge, close to shore.
118A	827.31	Chiselled and painted on rock	Sec. 31-15-11 E.P.M. some 250 feet upstream from E. bdy. sec. 31 on left bank on south side of point at first swift water below city bridge, on steep rocky bank, conspicuous from upstream.
117A	825.75	Chiselled and painted on rock	Sec. 31-15-11 E.P.M. on left bank, some 350 feet downstream from E. bdy. sec. 31 on north side of point at first swift water below city bridge, on steep rocky bank, conspicuous from downstream.
117	826.98	Blazed tree	Sec. 34-15-11 E.P.M. on left bank, some 200 yards from E. bdy. sec. 31 on north side of point at first swift water below city bridge, close to shore.
116	826.00	Poplar tree	Sec. 27-16-11 E.P.M. on island at head of west channel, on south side of point, at edge of trees.
116A	827.84	Chiselled and painted on rock	Sec. 27-16-11 E.P.M. on left bank, at head of first swift water on west channel, on steep rocky bank, conspicuous from south.
115	826.65	3-inch rock pine	Close to E. bdy. sec. 27-16-11 E.P.M. on left bank, on top of point at First McArthur Falls.
115A	827.05	Chiselled and painted on rock	Close to E. bdy. sec. 27-16-11 E.P.M. on left bank, on top of point at First McArthur Falls.
111	825.37	8-inch oak tree	Sec. 27-16-11 E.P.M. on left bank, at top of bank 15 feet north of section line.
113	816.22	6-inch poplar	Sec. 35-16-11 E.P.M. on left bank, 100 yards above Second McArthur Falls, on clay bank.
113A	819.47	Chiselled and painted on rock	Sec. 35-16-11 E.P.M. on left bank, 200 feet above Second McArthur Falls, on rocky shore.
112	819.35	8-inch spruce	Sec. 35-16-11 E.P.M. on left bank, lower end of portage, at Second McArthur Falls.
112A	819.61	Chiselled and painted on rock	Sec. 35-16-11 E.P.M. on left bank, on steep rocky bank, to east of lower end of portage, at Second McArthur Falls.
111	813.33	10-inch oak tree	West channel, Second McArthur Falls, south side of point on island at end of rapids below falls, at edge of trees.
111A	812.99	Chiselled and painted on rock	On point out from B.M. No. 141.
140	811.00	9-inch poplar	North side of point at B.M. No. 141.
110A	811.16	Chiselled and painted on rock	West channel, Second McArthur Falls, east point on island, south side on steep rock at water's edge, conspicuous going downstream.
	820.75	Stump	Northeast corner, 31-16-11 E.P.M., island at Second McArthur Falls.
	841.70	Stump	On north boundary 35-16-11 E.P.M., 575 feet east of northeast corner 31-16-11 E.P.M., island at Second McArthur Falls.
139	813.12	10-inch oak tree	SE. point, island below Second McArthur Falls, on E. bdy. sec. 3-17-11 E.P.M.
14	812.46	Chiselled and painted on rock	South side island below Second McArthur Falls, on E. bdy. sec. 3-17-11 E.P.M., on steep rocky bank.
	818.78	Stump	Sta. 78 + 70 on left bank traverse on sec. 3-17-11 E.P.M.
	819.59	Stump	Left bank sec. 10-17-11 E.P.M., at sta. 29 + 61 on traverse from north boundary sec. 10.
148	813.63	18-inch poplar tree	Right bank, head of first narrows above Grand du Bonnet, at edge of trees.
138A	811.71	Chiselled and painted on rock	Head of first narrows above Grand du Bonnet, right bank, on shelving rocky point.
138B	812.86	Chiselled and painted on rock	Middle of first narrows above Grand du Bonnet, left bank, on steep rocky bank.
	831.81	Stump	Left bank traverse, first narrows above Grand du Bonnet, Station 27 + 19.
	819.40	Stump	North boundary 10-17-11 E.P.M., station 26 + 27 from northeast corner sec. 10.
	814.19	Stump	Right bank, lower end narrows, above Grand du Bonnet.
	810.13	Chiselled and painted on rock	Left bank, Initial Point of metering station, narrows above Grand du Bonnet, lower end of steep rocky bank.
137B	813.79	Chiselled and painted on rock	Left bank, head of Grand du Bonnet falls, on top of steep rocky shore.
	812.84	Stump, rock pine	South side island at head of Grand du Bonnet, traverse across.
	817.92	Stump, tamarac	Northeast corner, 14-17-11 E.P.M.
	813.27	Stump, poplar	Left bank, point above Grand du Bonnet, upper side.
137	813.58	8-inch poplar tree	Right bank, 200 feet downstream from head of Grand du Bonnet portage, close to edge of trees.
137A	810.77	Chiselled and painted on rock	Right bank, on large boulder at shore, some 100 yards above head of Grand du Bonnet falls.
136	804.55	6-inch poplar tree	80 feet down right bank from brink of falls, near edge of trees.
136A	808.45	Chiselled and painted on rock	40 feet north of B.M. No. 136, at Grand du Bonnet.
135	801.53	7-inch oak tree	First point below first pitch, right bank, Grand du Bonnet falls.

## BENCH-MARKS ESTABLISHED ALONG THE WINNIPEG RIVER, ETC.—Continued.

No.	Elevation.	Description.	Location.
135A	805-55	Chiselled and painted on rock	First point below first pitch, right bank, Grand du Bonnet falls on shelving rocky shore.
134	805-99	8-inch poplar	Right bank, 300 feet above second pitch, Grand du Bonnet falls near edge of trees.
134A	805-81	Chiselled and painted on rock	Right bank 50 feet above second pitch, Grand du Bonnet falls on top of rocky shore in small bay, at end of traverse line.
133	800-93	12-inch jack pine	Point on right bank 600 feet below second pitch, Grand du Bonnet, at top of bank.
133A	799-18	Chiselled and painted on rock	Point on right bank 600 feet below second pitch, Grand du Bonnet falls on top of rock bank on north side of point.
132	795-02	5-inch poplar	Right bank at shore on east side of bay above third pitch, 60 feet north of traverse line.
132A	796-73	Chiselled and painted on rock	Right bank at shore on east side of bay above third pitch 10 feet south of traverse line on low rock outcrop.
131	781-27	8-inch poplar	Right bank at foot of bank some 15 yards south of E. and W. traverse line, midway between third and fourth pitches of Grand du Bonnet.
131A	782-75	Chiselled and painted on rock	500 feet below third pitch, right bank, on rocky shore 70 feet south of E. and W. traverse line, midway between third and fourth pitches.
130	776-66	6-inch poplar	50 feet south of line at fourth pitch, on right bank, at foot of bank.
130A	779-26	Chiselled and painted on rock	10 feet north of line at fourth pitch, at brink of falls, right bank.
129	778-48	6-inch oak	Right bank, 50 feet north of lower end of Long Portage.
129A	779-59	Chiselled and painted on rock	Right bank, 85 feet north of lower end of Long Portage, at top of rock bank and facing out to river.
128	779-91	6-inch oak	South side of first point below Long Portage, right bank.
128A	778-87	Chiselled and painted on rock	Right bank, south side of first point below Long Portage, conspicuous from end of portage.
127	777-74	8-inch poplar	First point above Little du Bonnet, right bank 25 feet upstream from traverse line at foot of bank.
127A	776-27	Chiselled and painted on rock	Right bank on first point above Little du Bonnet, 100 feet upstream from traverse line on rocky shore.
126	775-53	4-inch poplar	350 feet above brink of Little du Bonnet, right bank, at edge of trees.
126A	777-16	Chiselled and painted on rock	Right bank, some 150 yards above Little du Bonnet and 330 yards downstream from N. bdy., sec. 22-17-11 E.P.M., of rocky shore.
126B	775-70	Chiselled and painted on rock	8 feet south of station 20 + 21 on north boundary 22-17-11 E.P.M., left bank, where line crosses small bay above falls.
125	775-35	Tree	600 feet below Little du Bonnet, right bank, 40 feet south of line, near edge of trees.
125A	769-04	Chiselled and painted on rock	Right bank at top of sheer rock 600 feet below Little du Bonnet and 40 feet south of line, conspicuous from river.
124	766-81	6-inch poplar	First point below Little du Bonnet falls, right bank, at edge of trees.
124A	768-57	Chiselled and painted on rock	Right bank, first point below Little du Bonnet at shore.
	811-41	Stump, poplar	East boundary 21-17-11 E.P.M. sta. 78 + 40 from north east corner, sec. 9.
	782-23	Stump, spruce	22-17-11 E.P.M., 20 feet north of sta. 12 + 46 on offset east from station 75 + 00 on east boundary, 22-17-11 E.P.M.
	782-16	Stump, spruce	Station 11 + 96 on offset east from station 85 + 00 on east boundary 21-17-11 E.P.M.
	781-82	Stump, oak	Station 20 + 77 on offset E. from station 95 + 00 on east boundary 21-17-11 E.P.M.
	806-62	Stump, poplar	Station 24 + 67 on north boundary 15-17-11 E.P.M. from northeast corner sec. 16.
	824-85	Stump, poplar	Station 26 + 73 left bank traverse in sec. 15 at point at foot of first pitch.
	814-49	Stump, poplar	Station 25 + 39 east boundary 16-17-11 E.P.M., from north-east corner sec. 9.
	833-48	Stump, poplar	Station 29 + 75 east boundary, 22-17-11 E.P.M. from north-east corner sec. 22.
	815-88	Stump, poplar	Station 20 + 06 east boundary, 22-17-11 E.P.M. from north-east corner sec. 22.
	811-61	Stump, poplar	Station 10 + 60 east boundary, 22-17-11 E.P.M. from north-east corner sec. 22.
	811-31	Stump, poplar	At northeast corner, sec. 22 = 0 + 00 of survey.
	816-16	Stump, poplar	Station 40 + 25 on traverse through section 23 northeast from east boundary sec. 22.
	815-87	Stump, tamarack	Station 26 + 23 on east boundary 23 from northeast corner sec. 23.
	833-85	Stump, poplar	Station 8 + 19 on line east through sec. 23 from east boundary 22.
	817-35	Stump, poplar	Station 12 + 62 on north boundary 23-17-11 E.P.M. from northeast corner sec. 22.
	824-56	Stump, jack pine	Station 41 + 36 on north boundary 23-17-11 E.P.M., from northeast corner sec. 22.
	835-70	Stump, jack pine	Station 19 + 79 on east boundary 27-17-11 E.P.M. from northeast corner sec. 22.
	800-82	Stump, poplar	Station 30 + 35 on east boundary 27-17-11 E.P.M. from northeast corner sec. 22.

BENCH-MARKS ESTABLISHED ALONG THE WINNIPEG RIVER, ETC.—*continued.*

No.	Elevation.	Description.	Location.
123	767-32	8-inch poplar	South end of island No. 2, 1/2 mile below Little du Bonnet
122	770-70	8-inch oak	Right bank, upper end of portage at Whitmud falls.
122A	768-48	Chiselled and painted on rock	Right bank, on shore downstream from upper end of portage some 50 feet on large boulder.
121	757-46	Gnarled oak	Right bank, 50 feet upstream from lower end of Whitmud portage.
121A	758-39	Chiselled and painted on rock	Right bank, on rocky shore at foot of Whitmud falls, lower end of small channel.
Sta. 34	775-22	Oak stump	Top right bank, to north of upper end of portage on traverse line.
Sta. 35	784-85	Birch stump	Left bank base line, head of falls, top of bank.
Sta. 36	783-49	Birch stump	Left bank base line, foot of falls, top of bank
120	755-15	20-inch oak	Sec. 1-18-10 E.P.M., on point of left bank, opposite home- stead of E. Sandberg.
120A	755-30	12-inch birch	Sec. 1-18-10 E.P.M., in bay on right bank, close to shore on north side of road leading up to home-steads of E. Sandberg and C. Carlson.
119	752-90	6-inch poplar	Sec. 1-18-10 E.P.M., on left bank, at foot of bank some 150 feet N. 75° W. from W.P. on E. bdy. lot 1-18-10 E.P.M.
118	754-16	12-inch oak	Sec. 1-18-10 E.P.M., on left bank, on side of bank north of portage and close to head of Silver falls.
117	748-36	7-inch poplar	Sec. 1-18-10 E.P.M., on left bank, near foot of bank, at lower end of upper portage.
116	739-48	8-inch oak	Sec. 1-18-10 E.P.M., on left bank, near lower end of lower portage and some 50 yards to the east of it on top of open rocky ridge.
115	737-75	20-inch spruce	On left bank beyond small deer bay below Silver falls, at edge of trees, conspicuous from the river.
115A	734-56	Old stump	Lot 7-18-10 E.P.M., on left bank, 30 feet west of landing of I. Vincent, at foot of bank.
114	731-62	12-inch oak	N. bdy. lot 10-18-10 E.P.M., on left bank, on point at foot of bank, first narrows below Silver falls.
113	732-60	12-inch oak	On point of left bank, at foot of bank down from church
112	734-10	8-inch oak	Near NE. corner lot 14-18-10 E.P.M., close to foot of left bank at south end of point above Maskwa rapids.
111	740-06	5-inch mountain ash	Lot 16-18-10 E.P.M., on left bank, in bay above Maskwa rapids, near foot of bank, down from house.
110	731-81	12-inch poplar	Lot 18-18-10 E.P.M., on point of left bank, at second Maskwa rapids, near foot of bank, at upper side of point.
109	726-69	12-inch poplar	On left bank, some 650 feet upstream from E. bdy. lot 19-18- 10 E.P.M. near foot of bank and S. 45° E. from island above Pine falls.
	728-51	Top of iron staple with ring	Lot 19-18-10 E.P.M., on left bank, at top of steep rock shore, 100 yards above head of canal.
108	728-21	5-inch oak	Lot 19-18-10 E.P.M., on island formed by canal, on rock to east of lower end of portage.
108A	721-53	Chiselled and painted on rock	E. bdy., lot 20-18-10 E.P.M., on left bank, on top of rocky shore, visible from downstream.
107	719-74	30-inch oak	On right bank, on east side of first point below Maniton rapids, near foot of bank, near by Butcher's house.
106	722-01	12-inch spruce, marked 722-03	On upstream side of point of left bank at J. Arkinson's house, across and down-stream from old mill.
105	740-68	24-inch poplar, marked 740-70	On left bank, south of road, at corner between Wm. Skeet and Sam Kinnard and 600 feet above English Mission.
104	725-09	9-inch poplar, marked 725-11	On left bank, 400 feet upstream from H. B. Cox's dock, at edge of trees.



REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

---

APPENDIX VI.  
TEMPERATURE, PRECIPITATION AND  
EVAPORATION TABLES



## APPENDIX VI.

### TEMPERATURE, PRECIPITATION AND EVAPORATION TABLES.

*Table 48.—Daily Records of Temperature at Winnipeg.*

1912.

JANUARY.					FEBRUARY.				
Day of Month.	TEMPERATURE.			Mean Daily Temp.	Day of Month.	TEMPERATURE.			Mean Daily Temp.
	Max.	Min.	Daily Range.			Max.	Min.	Daily Range.	
1	-17.6	-22.3	4.7	-20.4	1	15.9	-14.6	30.5	0.7
2	-13.1	-30.0	16.9	-21.5	2	-8.2	-20.6	12.4	-14.4
3	-12.2	-24.8	12.6	-18.5	3	-0.9	-18.5	17.6	-9.7
4	-16.6	-31.3	14.7	-24.0	4	11.8	-3.2	15.0	4.3
5	-22.1	-34.9	12.8	-28.5	5	15.2	8.0	7.2	11.6
6	-22.8	-34.0	11.2	-28.1	6	9.8	-5.5	15.3	2.1
7	-3.1	-29.4	26.3	-16.1	7	0.1	-14.6	14.7	-7.2
8	-8.8	-23.8	15.0	-16.3	8	-0.9	-17.4	16.5	-9.2
9	-19.7	-32.7	13.0	-28.2	9	6.0	-25.6	31.6	-9.8
10	-27.5	-37.9	10.4	-32.7	10	12.9	2.1	10.8	7.5
11	-24.8	-41.3	16.5	-33.1	11	13.4	2.6	10.8	8.0
12	-10.8	-32.7	21.0	-21.8	12	17.9	-8.5	26.4	4.7
13	-0.9	-10.8	9.9	-1.9	13	24.8	16.6	8.2	20.7
14	-8.8	-24.4	15.6	-16.6	14	33.0	15.2	17.8	24.1
15	-2.8	-32.7	29.9	-19.1	15	33.5	13.2	20.3	23.3
16	10.0	-2.8	12.8	3.6	16	35.9	17.7	18.2	26.8
17	6.7	-11.8	21.5	-1.0	17	38.4	24.1	14.3	31.3
18	-11.8	-24.9	13.1	-18.3	18	34.8	6.0	28.8	20.4
19	-1.1	-26.5	19.4	-10.8	19	12.1	4.6	7.5	8.4
20	5.1	-13.7	18.8	-4.3	20	12.9	-0.9	13.8	6.0
21	3.2	-15.5	18.7	-6.1	21	8.6	0.0	8.6	4.3
22	10.9	-2.5	13.4	3.2	22	18.9	-2.0	20.9	8.4
23	4.6	-11.5	16.1	-3.4	23	30.2	10.5	19.7	20.3
24	4.9	-7.8	1.4	1.4	24	25.4	-0.6	26.0	12.4
25	3.9	-6.1	1.1	1.1	25	1.9	-21.0	22.9	-9.5
26	-0.3	-21.7	21.4	11.0	26	8.8	-18.9	27.7	-5.1
27	-0.8	-25.3	24.5	13.0	27	15.7	-1.4	17.1	7.1
28	15.2	-12.8	28.0	1.2	28	10.9	-11.3	22.2	-0.2
29	15.4	-1.1	19.5	5.7	29	5.5	-14.2	19.7	-4.3
30	19.0	-8.4	27.4	5.3					
31	21.8	12.2	12.6	18.5					
Means	-3.2	-20.0	16.8	-11.6	Means	15.3	-2.7	18.0	6.3

MARCH.					APRIL.				
Day of Month.	TEMPERATURE.			Mean Daily Temp.	Day of Month.	TEMPERATURE.			Mean Daily Temp.
	Max.	Min.	Daily Range.			Max.	Min.	Daily Range.	
1	6.4	-17.6	24.0	-5.6	1	39.6	32.0	7.6	35.8
2	13.9	-17.2	31.1	-1.7	2	52.0	17.6	34.4	31.8
3	21.6	-6.3	21.9	10.6	3	64.9	32.0	32.9	48.4
4	24.5	0.7	23.8	12.6	4	75.1	36.8	38.3	56.0
5	26.6	-0.4	27.0	13.1	5	64.3	39.9	24.4	52.1
6	23.2	0.8	22.4	12.0	6	41.6	30.4	11.2	36.0
7	16.7	2.1	14.6	9.4	7	39.1	21.7	17.1	30.4
8	24.9	-5.7	30.6	9.6	8	55.3	36.8	18.5	46.0
9	31.8	1.5	30.3	16.7	9	50.0	26.0	24.0	38.0
10	34.8	5.9	28.9	20.3	10	62.2	32.6	29.6	47.4
11	32.1	3.1	29.0	17.6	11	57.9	30.3	27.6	44.1
12	31.2	-2.8	31.0	14.2	12	52.2	28.3	23.9	40.3
13	22.8	-3.0	25.8	9.9	13	43.4	33.1	10.3	38.2
14	18.6	-6.0	21.6	6.3	14	38.8	32.8	6.0	35.8
15	26.3	1.9	21.4	14.1	15	34.6	28.7	5.9	31.7
16	22.8	0.5	22.3	11.7	16	42.0	22.0	20.0	32.0
17	30.5	0.7	29.8	15.6	17	52.5	24.9	27.6	38.7
18	33.7	10.1	23.6	21.9	18	54.8	29.2	25.6	42.0
19	25.4	-8.3	33.7	8.5	19	60.2	30.5	29.7	45.3
20	19.9	-10.9	30.8	4.5	20	53.9	33.0	20.9	43.5
21	19.8	-2.3	22.1	8.8	21	45.6	25.3	20.3	35.1
22	29.7	9.9	19.8	19.8	22	55.6	26.0	29.6	40.8
23	31.1	7.4	26.7	20.7	23	52.2	38.5	13.7	45.3
24	41.5	10.1	31.4	25.8	24	62.3	31.7	30.6	47.0
25	38.7	21.6	17.1	30.1	25	71.2	42.1	29.1	56.6
26	37.1	11.2	26.2	24.3	26	59.3	41.8	27.5	45.6
27	38.4	29.0	9.4	33.7	27	36.6	18.1	18.5	27.1
28	37.6	20.3	17.3	29.0	28	47.8	34.4	14.4	40.6
29	28.4	12.9	15.5	20.6	29	55.9	25.1	30.8	40.5
30	28.0	12.3	15.7	20.1	30	49.8	38.8	11.0	44.3
31	38.1	-0.9	39.0	18.6					
Means	27.7	2.8	24.9	15.2	Means	52.3	30.4	22.0	41.3

Table 48.—Daily Records of Temperature at Winnipeg—Continued.  
1912.

MAY.					JUNE.				
Day of Month.	TEMPERATURE.			Mean Daily Temp.	Day of Month.	TEMPERATURE.			Mean Daily Temp.
	Max.	Min.	Daily Range.			Max.	Min.	Daily Range.	
1	49.9	40.8	9.1	45.3	1	78.8	46.9	31.9	62.8
2	54.1	40.0	14.1	47.1	2	70.9	46.5	24.4	58.7
3	74.0	42.8	31.2	58.4	3	64.2	47.0	17.2	56.6
4	66.3	48.1	18.2	57.2	4	62.1	45.2	16.9	53.7
5	58.2	43.2	15.0	50.7	5	63.5	39.0	24.5	51.2
6	53.0	42.1	11.8	48.0	6	67.1	33.3	33.8	50.2
7	52.5	41.8	20.7	42.1	7	72.3	44.1	28.2	58.2
8	61.5	40.2	21.3	50.8	8	72.1	44.9	27.2	58.5
9	71.8	48.0	23.8	59.9	9	76.7	51.5	25.2	64.1
10	59.7	42.0	17.7	50.8	10	74.1	57.8	15.3	65.4
11	64.5	42.1	22.4	48.3	11	75.5	47.2	28.3	61.4
12	55.9	42.3	23.6	44.1	12	78.5	43.9	33.9	61.6
13	55.9	25.8	30.1	40.9	13	77.3	48.3	29.0	62.8
14	57.1	41.7	15.4	49.4	14	77.0	56.1	20.9	66.5
15	55.4	34.5	20.9	44.9	15	68.3	48.2	20.1	58.3
16	68.9	37.6	31.3	53.3	16	56.9	41.4	15.5	49.2
17	66.4	38.9	27.5	52.6	17	64.5	44.3	20.2	54.4
18	54.0	35.0	19.0	44.5	18	78.4	40.8	37.6	59.6
19	60.1	38.7	21.4	49.4	19	74.1	52.6	21.5	63.3
20	64.0	42.0	22.0	53.0	20	77.5	43.0	34.5	60.2
21	66.3	34.5	31.8	50.4	21	84.0	47.0	37.0	65.5
22	59.1	46.9	12.2	53.0	22	89.1	58.2	30.9	73.6
23	66.5	45.0	21.5	55.7	23	94.8	61.2	33.6	78.0
24	73.9	42.9	31.0	58.4	24	98.2	63.4	34.8	80.8
25	82.1	51.1	31.0	66.6	25	88.2	58.8	29.4	73.5
26	84.9	52.1	32.8	68.5	26	83.4	47.5	35.9	65.5
27	77.2	57.3	19.9	67.3	27	91.6	64.1	27.5	77.8
28	64.0	49.2	15.7	57.0	28	96.8	67.0	29.8	81.9
29	71.0	46.1	24.9	58.5	29	97.9	75.6	22.3	86.8
30	79.5	56.0	23.5	67.8	30	94.3	62.3	32.0	78.3
31	76.4	53.8	22.6	65.1					
Means	64.7	42.3	22.4	53.5	Means	78.3	50.9	27.3	64.6
JULY.					AUGUST.				
1	89.3	65.5	23.8	77.4	1	65.3	46.1	19.2	55.7
2	85.7	68.4	17.3	77.1	2	64.7	45.4	19.3	55.0
3	76.9	63.8	13.1	70.3	3	68.5	39.0	29.5	53.8
4	71.6	51.0	20.6	61.3	4	73.4	44.4	29.0	58.9
5	80.7	58.9	21.8	69.8	5	69.9	52.5	17.4	61.2
6	80.0	57.9	22.1	67.0	6	67.5	57.7	9.8	62.6
7	79.1	60.9	18.2	70.0	7	74.1	54.8	19.3	64.4
8	80.3	55.5	24.8	67.9	8	72.8	56.9	15.9	64.9
9	69.8	56.9	12.9	63.3	9	78.2	49.2	29.0	63.7
10	75.2	46.0	29.2	60.6	10	77.5	49.4	28.1	63.4
11	78.3	58.4	19.9	68.4	11	81.9	52.0	29.9	67.0
12	70.8	57.0	13.8	63.9	12	78.6	63.9	14.7	71.2
13	80.0	51.7	28.3	65.8	13	69.9	56.2	13.7	63.1
14	75.4	50.2	25.2	62.8	14	64.0	45.1	18.9	54.5
15	68.8	42.0	26.8	55.4	15	70.1	43.9	26.2	57.0
16	69.3	55.9	13.4	62.6	16	77.9	45.2	32.7	61.5
17	63.8	49.2	14.6	56.5	17	71.0	58.4	12.6	64.7
18	70.0	43.6	26.4	56.8	18	76.5	51.1	25.4	63.8
19	76.2	52.3	23.9	64.3	19	73.5	54.3	19.2	63.9
20	68.9	54.4	14.5	61.6	20	73.3	58.3	15.0	65.8
21	68.2	49.5	18.7	58.9	21	71.4	55.4	16.0	63.4
22	75.1	49.0	26.1	62.0	22	63.9	50.5	13.4	57.2
23	80.6	62.0	18.6	71.3	23	56.8	44.4	12.4	50.6
24	77.0	60.3	16.7	68.7	24	61.9	47.6	14.3	54.8
25	68.0	51.4	13.6	61.2	25	61.7	49.5	12.2	55.6
26	80.1	53.0	26.2	67.0	26	65.5	42.1	23.4	53.8
27	76.9	63.1	13.8	70.0	27	60.1	48.0	12.1	54.0
28	77.4	56.2	21.2	66.8	28	70.3	52.2	18.1	61.3
29	78.5	58.4	20.1	68.2	29	71.4	49.0	22.4	60.2
30	77.9	53.8	24.1	65.9	30	66.3	56.9	9.4	61.6
31	69.4	48.5	20.9	58.9	31	72.1	45.0	27.1	58.5
Means	75.5	55.1	20.3	65.3	Means	70.0	50.5	19.5	60.2

Table 48.—Daily Records of Temperature at Winnipeg Continued.  
1912.

Mean Daily Temp.	SEPTEMBER.					OCTOBER.				
	Day of Month.	TEMPERATURE.			Mean Daily Temp.	Day of Month.	TEMPERATURE.			Mean Daily Temp.
		Max.	Min.	Daily Range.			Max.	Min.	Daily Range.	
62.8	1	70.9	56.6	14.3	63.7	1	70.2	47.5	22.7	53.8
58.7	2	72.8	44.3	28.5	58.6	2	70.1	40.8	29.3	55.5
56.6	3	73.5	55.7	18.8	65.1	3	67.8	43.5	24.3	55.6
53.7	4	78.0	60.3	17.7	69.1	4	74.9	42.2	32.7	58.6
51.2	5	85.9	64.3	21.6	75.1	5	62.6	44.4	18.2	53.5
50.2	6	74.7	51.8	21.9	62.8	6	45.4	37.9	7.5	41.6
58.2	7	70.9	46.2	24.7	58.5	7	58.8	35.7	23.1	47.3
58.5	8	72.1	50.1	22.0	61.1	8	57.5	41.7	15.8	49.6
64.1	9	73.1	56.0	17.1	64.5	9	48.0	33.9	14.1	41.0
65.4	10	64.1	50.9	13.2	57.5	10	41.6	32.5	9.1	37.0
61.4	11	78.5	47.1	31.4	62.8	11	50.3	32.7	17.6	41.5
61.6	12	75.3	52.0	23.3	63.7	12	53.8	34.3	19.5	44.1
62.8	13	66.1	54.0	12.1	60.1	13	63.5	32.6	30.9	48.0
66.5	14	56.1	49.9	6.2	48.0	14	58.2	35.8	22.4	47.0
58.3	15	51.7	36.6	15.1	34.1	15	60.1	32.0	28.1	46.0
49.2	16	57.4	46.2	11.2	51.8	16	72.9	41.0	31.9	57.0
54.4	17	62.2	47.1	15.1	54.7	17	62.8	38.9	23.9	50.9
59.6	18	70.5	43.3	27.2	56.9	18	57.9	38.9	19.0	48.4
63.3	19	61.9	46.8	15.1	54.4	19	46.3	34.1	12.2	40.2
60.2	20	56.0	49.9	6.1	52.9	20	51.5	38.1	13.4	44.8
65.5	21	52.2	44.8	7.4	48.5	21	42.8	26.4	16.4	34.6
73.6	22	51.9	38.0	12.9	44.5	22	4.4	20.7	23.7	32.6
78.0	23	50.3	40.4	9.9	45.3	23	4.9	31.6	23.3	43.2
80.8	24	43.9	35.2	9.7	39.6	24	5.1	39.6	16.5	47.9
73.5	25	43.3	33.3	10.0	38.3	25	10.1	30.4	25.7	43.2
65.5	26	46.8	31.1	15.7	38.9	26	46.6	33.6	3.0	45.1
77.8	27	49.6	30.7	18.9	40.2	27	53.1	25.6	27.5	39.4
81.9	28	46.0	32.5	13.5	39.2	28	45.4	30.1	15.3	37.7
86.8	29	51.8	26.2	25.6	39.0	29	33.1	24.0	9.1	28.6
78.3	30	61.2	31.7	29.5	46.5	30	34.0	17.1	16.9	25.5
	31					31	32.9	23.5	9.4	28.2
64.6	Means	62.3	44.8	17.5	53.5	Means	54.0	34.2	19.8	44.1

Mean Daily Temp.	NOVEMBER.					DECEMBER.				
	Day of Month.	TEMPERATURE.			Mean Daily Temp.	Day of Month.	TEMPERATURE.			Mean Daily Temp.
		Max.	Min.	Daily Range.			Max.	Min.	Daily Range.	
55.7	1	20.2	20.9	7.3	24.5	1	25.8	7.9	17.9	16.9
55.0	2	28.1	13.8	14.3	21.0	2	17.0	-2.5	19.5	7.2
53.8	3	37.0	18.8	18.2	27.9	3	21.5	10.6	10.9	16.1
58.9	4	35.0	24.9	10.1	29.9	4	22.0	15.2	6.8	18.6
61.2	5	35.1	25.6	9.5	30.4	5	-1.1	-7.9	6.8	-4.5
62.6	6	38.6	25.8	12.8	32.2	6	18.6	-11.5	30.1	3.6
64.4	7	41.0	25.2	15.8	33.1	7	11.9	-5.0	16.9	3.4
64.9	8	35.3	29.6	5.7	32.4	8	25.2	-15.5	40.7	4.9
63.7	9	39.9	28.1	11.8	34.0	9	34.9	12.3	22.6	23.6
63.4	10	34.7	28.6	6.1	31.7	10	7.2	-4.7	11.9	1.2
67.0	11	29.4	25.4	4.0	27.4	11	-0.2	-15.2	15.4	-7.7
71.2	12	28.5	23.8	4.7	26.1	12	-19.8	-19.9	23.7	2.0
63.1	13	33.1	27.0	6.1	30.1	13	21.4	1.7	19.7	11.6
54.5	14	31.3	28.5	2.8	29.9	14	26.1	13.4	12.7	19.7
57.0	15	32.0	26.4	5.6	29.2	15	19.1	13.1	6.0	16.1
61.5	16	33.2	21.2	12.0	27.2	16	22.1	17.6	4.5	19.9
64.7	17	38.3	21.3	17.0	29.8	17	22.2	19.9	2.3	21.0
63.8	18	49.3	28.6	20.7	38.9	18	19.3	16.4	-2.9	17.9
63.9	19	41.0	27.2	13.8	31.1	19	18.4	13.7	4.7	16.0
65.8	20	43.7	29.4	14.3	36.6	20	5.5	1.4	4.1	3.5
63.4	21	35.1	28.8	6.3	31.9	21	5.5	-3.7	9.2	0.9
57.2	22	34.7	26.3	8.4	30.5	22	28.5	-2.2	30.7	13.2
50.6	23	24.9	19.2	5.7	22.0	23	20.9	12.9	8.0	16.9
54.8	24	26.9	20.5	6.4	23.7	24	24.7	11.0	13.7	17.8
55.6	25	35.4	19.5	15.9	27.4	25	21.8	4.9	16.9	14.3
53.8	26	29.8	20.7	9.1	25.2	26	16.2	5.1	11.1	10.7
54.0	27	24.4	16.4	8.0	20.4	27	39.1	3.9	35.2	21.5
61.3	28	38.4	21.9	16.5	29.2	28	35.8	18.4	17.4	27.1
60.2	29	24.1	20.4	3.7	23.2	29	24.1	17.1	7.0	20.6
61.6	30	31.0	18.2	13.7	25.1	30	28.9	10.9	18.0	19.9
58.5						31	19.9	9.1	10.8	14.5
60.2	Means	33.9	23.7	10.2	28.8	Means	19.9	5.1	14.8	12.5

Table 48.—Daily Records of Temperature at Winnipeg—Continued.  
1913.

JANUARY.					FEBRUARY.				
Day of Month.	TEMPERATURE.			Mean Daily Temp.	Day of Month.	TEMPERATURE.			Mean Daily Temp.
	Max.	Min.	Daily Range.			Max.	Min.	Daily Range.	
1	28.9	17.7	11.2	23.3	1	5.2	-21.4	26.6	-8.1
2	-0.6	-9.9	9.3	-5.2	2	2.6	-12.1	14.7	-4.7
3	-0.9	-13.5	12.6	-7.2	3	-9.3	-23.5	14.2	-16.4
4	2.7	-12.2	14.9	-4.8	4	-11.8	-25.5	13.7	-18.7
5	-16.1	-20.7	4.6	-18.4	5	-4.8	-22.6	17.8	-13.7
6	-16.8	-31.2	14.4	-24.0	6	3.5	-12.3	15.8	-4.4
7	-0.2	-24.4	24.2	-12.3	7	21.9	-2.7	24.6	9.6
8	17.2	-7.9	25.1	4.6	8	5.9	-9.9	15.8	-2.0
9	15.2	-4.7	19.9	5.2	9	-1.8	-20.0	18.2	-10.9
10	-9.9	-18.4	8.5	-14.1	10	11.9	-4.9	16.8	3.5
11	-20.2	-26.0	5.8	-23.1	11	-9.7	-16.8	7.1	-13.3
12	-10.9	-29.4	18.5	-20.2	12	13.8	-24.3	38.1	-5.3
13	6.1	-21.0	27.1	-7.4	13	23.3	3.1	20.2	13.2
14	8.0	-9.1	17.1	-0.6	14	26.7	-3.1	29.8	11.8
15	9.7	-5.1	14.8	2.3	15	10.8	-10.2	21.0	0.3
16	8.2	1.8	6.4	5.0	16	13.6	2.9	10.7	8.2
17	-9.8	-14.5	4.7	-12.1	17	24.8	10.0	14.8	17.4
18	2.5	-23.0	25.5	-10.3	18	28.3	21.5	6.8	24.9
19	-2.4	-14.5	12.1	-8.4	19	13.2	5.4	7.8	9.3
20	-17.2	-28.3	11.1	-22.8	20	10.9	-4.4	15.3	3.2
21	-7.9	-25.7	17.8	-16.7	21	11.4	-18.3	29.7	-3.4
22	6.1	-8.0	14.1	-0.9	22	3.3	-16.8	20.1	-6.8
23	-5.8	-21.1	15.3	-13.5	23	12.8	-17.0	29.8	-2.1
24	-2.7	-21.2	18.5	-11.9	24	18.9	0.7	18.2	9.8
25	14.9	-2.7	17.6	6.1	25	14.3	-31.1	45.4	-8.4
26	5.6	-12.9	18.5	-3.6	26	-3.1	-27.8	24.7	-5.4
27	4.2	-6.2	10.4	-1.0	27	2.8	-23.2	26.0	-10.2
28	16.5	-5.1	21.6	5.7	28	3.3	-12.0	15.3	-4.3
29	17.2	12.6	4.6	14.9					
30	9.2	-7.9	17.1	0.7					
31	-9.7	-25.5	15.8	-17.6					
Means	1.3	-13.5	14.8	-6.1	Means	8.6	-11.3	19.9	-1.3
MARCH.					APRIL.				
1	-15.1	-24.5	9.4	-19.8	1	49.9	28.5	21.4	39.2
2	8.7	-25.7	34.4	-8.5	2	44.8	34.4	10.4	39.6
3	0.3	-22.1	22.4	-10.9	3	42.8	33.1	9.7	38.0
4	26.8	-10.0	36.8	8.4	4	42.7	26.9	15.8	34.8
5	0.9	-9.8	10.7	-4.5	5	48.3	28.4	19.9	38.4
6	8.0	-20.7	28.7	-6.4	6	47.9	30.2	17.7	39.0
7	29.0	-18.7	48.6	5.6	7	43.2	33.3	9.9	38.1
8	24.3	15.2	9.1	19.7	8	38.7	32.2	6.5	35.4
9	37.0	5.0	32.9	21.5	9	41.2	31.9	9.3	36.6
10	34.6	16.8	17.8	25.7	10	51.8	29.9	21.9	40.9
11	16.0	5.2	10.8	10.6	11	57.3	27.9	29.6	45.7
12	31.5	-5.7	37.2	12.9	12	67.9	38.0	29.9	53.0
13	22.1	10.4	11.7	16.2	13	64.4	33.9	30.5	49.1
14	12.6	-3.1	15.7	4.8	14	77.0	40.2	36.8	58.6
15	12.9	-12.8	25.7	0.0	15	75.3	39.9	35.4	57.6
16	13.6	-7.9	21.5	2.9	16	74.4	47.8	26.6	61.1
17	18.9	0.0	18.9	9.5	17	65.7	46.8	18.9	56.3
18	10.9	0.5	10.4	5.7	18	61.5	31.9	29.6	46.7
19	8.2	-0.7	8.9	3.7	19	61.1	29.5	31.6	45.2
20	10.2	-14.9	25.1	-2.3	20	65.8	36.8	29.0	51.3
21	11.1	-11.1	22.2	0.0	21	77.8	45.0	32.8	61.4
22	21.8	-3.3	25.1	9.2	22	73.8	53.9	19.9	63.9
23	18.9	-1.3	20.2	8.8	23	62.7	44.5	18.2	53.6
24	11.4	-4.1	15.5	3.6	24	52.2	34.1	18.1	43.1
25	16.1	-8.1	24.2	4.0	25	42.8	29.4	13.4	36.1
26	17.8	-8.3	26.1	4.8	26	38.5	19.4	19.1	26.9
27	24.7	-7.3	32.0	8.7	27	54.3	24.0	30.3	39.2
28	38.7	10.3	19.4	29.0	28	68.1	37.0	31.1	52.5
29	41.8	31.9	9.9	36.9	29	75.4	40.3	35.1	57.9
30	40.0	26.9	13.1	33.4	30	58.5	36.8	21.7	47.6
31	46.4	25.0	21.4	35.7					
Means	19.4	-2.1	21.5	8.7	Means	57.5	34.8	22.7	46.2



Table 48. Daily Records of Temperature at Winnipeg. - Concluded.  
1911.

SEPTEMBER.					OCTOBER.				
Day of Month.	TEMPERATURE.			Mean Daily Temp.	Day of Month.	TEMPERATURE.			Mean Daily Temp.
	Max.	Min.	Daily Range.			Max.	Min.	Daily Range.	
1	77.0	63.8	13.2	70.4	1	67.0	47.7	19.3	57.3
2	74.2	45.4	28.8	58.8	2	74.4	10.1	64.3	56.8
3	68.1	52.4	15.7	60.2	3	61.9	41.0	20.9	54.5
4	75.8	58.8	17.0	67.3	4	52.9	34.2	18.7	43.5
5	77.5	61.7	15.8	69.6	5	18.9	11.5	7.4	16.2
6	83.1	62.4	20.7	72.9	6	49.8	29.8	20.0	44.8
7	69.8	49.1	20.7	59.6	7	50.7	34.1	16.6	42.4
8	69.9	40.8	29.1	55.3	8	43.0	28.8	14.2	35.9
9	79.8	53.7	26.1	66.8	9	52.8	25.1	27.7	38.9
10	71.4	56.1	15.3	63.9	10	43.2	35.6	7.6	38.9
11	64.8	43.2	21.6	54.0	11	46.7	42.4	4.3	49.5
12	64.9	42.3	22.6	53.6	12	50.9	28.5	22.4	49.7
13	64.3	44.2	20.1	48.8	13	69.9	47.1	22.8	53.5
14	74.9	44.4	30.5	59.6	14	51.0	39.1	11.9	45.0
15	68.3	46.2	22.1	57.3	15	44.9	21.3	23.6	34.7
16	70.0	40.9	29.1	55.0	16	51.2	23.3	27.9	37.6
17	73.2	43.0	30.2	58.1	17	51.8	15.9	35.9	42.8
18	75.9	50.3	25.6	63.1	18	43.9	22.0	21.9	33.0
19	53.2	41.3	11.9	47.7	19	42.0	24.0	18.0	28.0
20	50.2	36.7	13.5	43.5	20	22.0	18.0	4.0	20.0
21	43.7	31.9	11.8	37.8	21	27.8	14.2	13.6	21.0
22	51.4	22.8	28.6	36.9	22	40.4	23.0	17.4	31.5
23	47.1	26.7	20.4	36.9	23	48.3	26.4	21.9	36.4
24	50.1	36.3	13.8	43.3	24	54.7	32.2	22.5	43.1
25	53.9	40.0	13.9	47.0	25	43.3	29.5	13.8	36.4
26	62.1	45.8	16.3	48.9	26	49.9	23.2	26.7	41.5
27	76.9	43.1	33.8	60.0	27	48.1	29.2	18.9	34.7
28	73.1	44.6	28.5	58.8	28	22.3	9.8	12.5	16.2
29	73.9	47.5	26.4	55.7	29	23.8	8.0	15.8	14.4
30	74.9	46.1	28.8	60.5	30	40.3	14.4	25.9	22.4
					31	41.3	15.1	26.2	28.2
Means	67.0	44.4	22.6	55.7	Means	45.5	27.9	17.6	36.7
NOVEMBER.					DECEMBER.				
1	48.8	26.2	22.6	37.5	1	44.5	27.8	6.7	41.1
2	47.2	29.3	17.9	38.2	2	44.7	26.0	7.7	29.9
3	44.5	24.9	19.6	29.7	3	48.9	22.7	26.2	40.8
4	54.9	20.3	34.6	37.6	4	48.2	28.3	19.9	38.4
5	55.2	35.1	20.1	45.5	5	49.7	22.8	26.9	31.2
6	52.6	40.6	12.0	41.6	6	40.6	13.9	26.7	22.3
7	36.1	31.0	5.1	33.6	7	21.5	3.0	18.5	13.7
8	33.9	21.0	12.9	27.4	8	46.8	10.8	36.0	23.8
9	19.2	14.0	5.2	16.6	9	40.1	26.2	13.9	33.2
10	25.2	6.7	18.5	16.0	10	37.9	18.4	19.5	28.1
11	44.4	19.2	25.2	26.7	11	48.8	25.1	23.7	37.0
12	37.5	28.4	9.1	33.0	12	37.7	17.8	19.9	27.7
13	26.9	15.5	11.4	21.2	13	42.2	15.1	27.1	28.7
14	30.9	8.3	22.6	19.6	14	26.5	9.8	16.7	18.1
15	37.6	24.3	13.3	30.9	15	37.7	20.0	17.7	28.9
16	49.6	49.9	18.7	40.3	16	41.3	26.5	14.8	34.9
17	51.2	33.7	17.5	42.4	17	27.5	17.8	9.7	22.6
18	32.7	22.3	10.3	27.6	18	33.6	8.7	24.9	21.2
19	43.6	22.1	21.5	28.3	19	43.7	5.1	38.6	24.4
20	43.0	19.7	23.3	31.9	20	20.1	- 3.0	23.1	8.5
21	33.5	24.9	8.6	29.2	21	8.4	- 7.1	15.5	0.7
22	29.7	21.6	8.1	25.6	22	22.5	1.1	21.4	11.8
23	37.6	21.0	16.6	29.3	23	15.9	1.4	14.5	8.6
24	43.4	19.7	23.7	31.6	24	- 0.8	- 7.2	6.4	- 4.0
25	29.9	21.7	8.2	25.8	25	4.8	- 14.4	19.2	- 4.8
26	35.7	22.1	13.6	28.9	26	13.4	- 4.0	17.4	4.7
27	38.4	32.0	6.4	35.1	27	12.2	1.8	10.4	7.0
28	41.3	35.9	5.4	37.6	28	24.3	- 5.2	29.5	9.6
29	46.3	33.2	13.1	34.8	29	24.8	13.7	11.1	19.2
30	32.1	28.0	4.1	30.0	30	19.7	5.3	14.4	12.5
					31	26.2	- 3.0	29.2	11.6
Means	48.2	24.0	14.1	31.1	Means	27.9	10.5	17.4	19.2

Table 49. - Monthly Records of Temperatures at Winnipeg and Kenora, 1906-1911.

1906

Mean Daily Temp.	Month	WINNIPEG						KENORA					
		RANGE OF TEMPERATURE DEGREES FAH.			MEAN TEMPERATURES DEGREES FAH.			RANGE OF TEMPERATURE DEGREES FAH.			MEAN TEMPERATURES DEGREES FAH.		
		Max	Min	Mean	Max	Min	Daily	Max	Min	Mean	Max	Min	Daily
57.4	January	48.1	-32.5	25.1	15.0	-10.4	2.3						
56.8	February	53.1	-19.5	23.4	22.5	1.1	15.8						
54.5	March	80.8	17.5	26.8	60.4	33.6	17.0						
46.2	April	84.0	17.8	25.1	61.4	46.2	48.8						
44.8	May	81.8	42.2	23.4	74.8	52.5	63.5						
42.4	June	89.0	46.5	21.1	77.7	56.6	66.2						
45.9	July	92.8	41.8	24.0	77.1	53.1	65.1						
48.9	August	99.0	51.0	27.7	71.6	46.9	60.7						
49.5	September	72.9	5.8	21.9	52.6	40.7	41.6						
49.7	October	47	-10.0	13.8	32.7	18.0	25.8						
54.5	November	40	51.9	20.8	13.0	7.8	2.6						
45.0	December												
44.2	Yearly	99.0	42.5	22.4	51.5	28.6	10.0						

Note. - Average of 11 months.

1907

37.6	January	0	-48.6	26.4	-1.1	21.6	-11.4	22.0	-38.0	16.2	0.7	-17.0	-8.9
42.8	February	47.5	-38.0	22.1	15.8	-6.5	4.6	42.0	-37.0	18.1	13.9	-4.1	4.9
33.0	March	47.0	-11.6	20.9	28.0	7.1	17.5	50.0	-10.0	18.4	28.5	10.1	219.4
28.0	April	53.8	5.2	16.3	36.4	20.4	28.4	52.0	5.0	15.7	33.5	17.8	25.7
20.0	May	74.3	10.9	25.0	52.8	27.7	40.2	68.0	16.0	13.7	42.2	28.5	45.4
21.0	June	90.2	42.1	21.1	73.8	49.6	61.7	80.0	69.0	20.2	71.9	51.7	61.8
31.5	July	87.5	40.0	24.3	78.9	54.5	66.7	85.0	45.0	2.4	77.8	56.4	67.1
36.4	August	85.2	48.2	20.4	71.5	51.1	64.4	83.0	41.0	19.8	69.1	39.4	50.2
43.4	September	77.4	21.8	20.8	61.4	40.7	51.1	78.0	28.0	37.1	58.1	49.8	49.4
41.5	October	69.0	13.6	23.5	50.9	27.4	39.2	61.0	19.0	16.4	45.4	29.0	34.1
33.7	November	54.1	-12.0	18.2	34.5	16.2	25.4	40.0	3.0	7.7	28.8	21.2	25.0
28.2	December	40.8	-19.5	18.1	23.0	5.1	14.2	41.0	-20.0	14.1	24.6	10.2	17.4
22.4	Yearly	90.2	-48.6	21.2	43.9	22.7	33.2	89.0	-38.0	15.0	41.1	24.5	42.8

Note. - <sup>1</sup>Records Oct. 2-8 (incl.) missing. <sup>2</sup>Records Mar. 14-15 (incl.) missing. <sup>3</sup>Records Oct. 5-12 (incl.) missing.

1908

31.4	January	12.2	-46.0	20.4	17.5	-2.6	7.6	40.0	-39.0	13.8	15.1	1.4	8.2
29.9	February	38.0	-25.0	18.7	18.1	-0.6	8.7	48.0	-40.0	14.1	18.4	4.2	11.4
40.8	March	11.0	-22.0	23.7	21.4	-2.5	9.4	32.0	-26.0	21.1	16.9	-4.2	16.4
31.2	April	73.6	2.2	22.8	51.4	28.5	49.0	60.0	-4.0	47.6	41.8	21.2	33.0
22.4	May	77.5	24.9	24.1	64.0	39.9	51.9						
13.7	June	88.0	32.4	22.0	73.1	51.0	62.0						
23.8	July	94.0	37.0	24.8	78.9	54.1	66.5						
34.2	August	91.0	34.2	24.8	74.4	49.5	61.9						
28.1	September	90.8	27.0	23.3	70.0	46.6	58.4						
37.0	October	69.3	23.2	16.6	54.3	35.1	43.4						
27.7	November	50.6	-5.5	14.2	35.1	21.2	28.3	48.0	-6.0	12.7	36.6	23.9	30.2
28.7	December	31.5	-22.3	15.0	17.9	4.0	9.9						
18.1	Yearly	94.0	-46.0	20.9	47.8	26.8	37.3		-39.0				

Note. - <sup>1</sup>First 20 days only. <sup>2</sup>Last 15 days only.

1909

34.9	January	39.1	-45.4	20.0	7.5	-12.5	-2.5	48.0	-44.0	16.2	7.0	-9.2	1.1
22.6	February	29.1	-43.8	19.9	10.2	-9.7	0.2	29.0	-47.0	19.1	12.2	-6.9	2.6
21.2	March	47.9	-18.5	20.1	27.2	7.4	17.1	43.0	-14.0	18.6	27.5	8.9	18.2
9.4	April	50.3	8.8	17.0	48.4	24.4	29.9	58.0	4.0	16.7	33.7	17.0	35.4
8.5	May	82.8	20.0	24.4	63.6	39.2	51.4	66.0	16.0	21.8	46.0	24.2	35.1
0.7	June	90.0	33.7	27.2	77.1	49.9	63.5						
11.8	July	87.3	44.0	23.8	80.0	56.1	68.0						
8.6	August	92.6	35.0	23.2	78.5	55.4	66.9						
-1.0	September	84.9	29.8	25.8	70.9	45.1	58.0						
-4.8	October	82.0	10.7	19.7	52.4	32.7	42.5	78.0	14.0	10.8	41.1	33.0	48.7
4.7	November	59.4	-6.0	18.1	34.0	15.0	23.9	52.0	-2.0	19.3	39.4	19.0	24.1
7.0	December	35.8	-34.4	14.5	9.7	-1.8	2.5	35.0	-28.0	11.0	11.0	0.8	6.4
9.6	Yearly	92.6	-45.1	21.1	45.8	24.6	35.2		-44.0				

Note. - <sup>1</sup>May 1-5 (incl.) only.

Table 49. - Monthly Records of Temperatures at Winnipeg and Kenora 1906-1914 - Continued.

1910.

Month.	WINNIPEG.						KENORA.					
	RANGE OF TEMPERATURE DEGREES FAH.			MEAN TEMPERATURES DEGREES FAH.			RANGE OF TEMPERATURE DEGREES FAH.			MEAN TEMPERATURES DEGREES FAH.		
	Max	Min	Mean	Max	Min	Daily	Max	Min	Mean	Max	Min	Daily
January	41.9	-36.2	17.1	13.9	-4.2	5.4	23.0	-02.0	12.7	11.1	1.6	4.8
February	35.0	-31.2	21.7	9.5	-12.1	-1.4	31.0	-33.0	18.5	8.0	-10.6	-1.3
March	74.0	-6.2	23.6	11.9	23.2	31.0	70.6	0.0	14.6	35.9	21.3	28.6
April	74.9	15.3	25.2	55.1	39.2	42.8	70.6	8.0	18.6	46.6	28.0	37.4
May	75.8	19.3	27.3	62.4	35.1	48.8	71.0	20.0	13.7	47.3	33.6	40.4
June	99.2	31.4	27.2	82.1	53.8	68.0	98.5	61.0	24.1	77.9	53.8	65.9
July	95.8	47.3	26.4	81.8	55.6	68.7	92.0	50.1	30.4	82.3	62.0	72.2
August	93.1	30.1	26.4	75.4	48.9	62.2	89.4	38.6	19.9	76.6	56.1	66.0
September	78.1	28.8	21.8	65.1	43.4	51.2	69.6	29.0	17.7	58.1	40.4	49.2
October	78.2	18.8	21.2	57.6	34.0	46.6	70.4	20.9	13.6	31.9	32.3	40.6
November	37.6	-3.7	12.0	25.8	33.8	39.8	50.4	0.0	8.8	21.1	12.4	16.7
December	33.9	-42.4	20.0	15.9	4.1	5.9	21.0	-37.6	32.0	11.8	-0.3	5.7
Yearly	99.2	-42.4	22.3	49.1	26.8	48.9	98.5	-37.6	16.4	43.7	27.5	35.5

NOTE. -<sup>1</sup>No records for 18th or 31st. <sup>2</sup>No records for 11th.

1911.

January	20.4	-36.9	18.6	-0.5	-18.9	-9.5	25.0	-37.0	17.4	-0.8	-18.2	-9.5
February	35.5	-34.6	23.7	16.8	-3.0	6.1	36.0	-26.0	15.0	17.0	2.0	19.5
March	52.5	-11.4	19.8	33.4	13.6	23.5	45.0	-11.0	14.5	23.2	8.6	15.9
April	79.9	4.9	23.0	52.8	22.8	41.3	70.0	-3.0	3.1	42.6	28.2	35.1
May	85.9	19.3	25.4	67.8	42.4	55.1	74.0	21.0	19.8	57.9	38.0	47.9
June	89.2	31.4	19.6	75.9	55.6	65.1	90.0	40.0	22.8	74.2	51.4	62.8
July	84.8	43.3	22.1	75.2	53.1	64.1	83.0	38.0	23.2	77.3	51.1	65.7
August	88.5	49.8	22.8	71.3	51.6	63.1	89.0	37.0	27.3	71.7	47.4	61.1
September	76.1	29.1	21.5	64.1	41.6	52.3	69.0	31.0	13.3	53.9	40.4	47.1
October	69.5	13.3	16.3	51.2	31.9	43.1	61.0	8.0	11.0	47.3	32.1	39.6
November	50.8	-11.9	18.1	25.9	8.7	17.8	45.0	-15.0	10.2	20.4	10.2	15.3
December	38.4	-31.4	13.1	18.8	5.7	12.3	32.0	-31.0	30.0	16.8	6.8	11.8
Yearly	89.2	-36.9	20.1	49.3	26.2	36.2	94.0	-37.0	15.9	42.0	25.1	33.5

NOTE. -<sup>1</sup>No records 11-30 (incl.).

1912.

January	24.8	-41.3	16.8	-3.2	-23.0	-11.6	18.0	-35.0	15.6	-7.8	-23.0	-15.1
February	38.4	-25.6	18.6	15.3	-2.7	6.3	29.0	-32.0	16.6	9.1	-7.5	0.8
March	41.5	-17.6	24.9	27.7	2.8	15.2	34.0	-23.0	20.2	20.3	0.2	10.3
April	75.1	37.6	22.0	52.3	31.3	43.3	61.0	15.0	17.8	45.1	27.3	36.2
May	81.9	25.8	22.4	63.7	32.3	53.5	82.0	24.0	17.9	56.3	38.8	47.8
June	98.2	33.3	27.3	78.3	50.9	63.6	96.6	33.0	21.8	75.0	53.2	61.1
July	89.3	32.0	23.3	75.5	55.1	65.3	83.0	32.0	13.6	67.3	47.7	57.5
August	81.9	39.6	19.5	70.1	51.5	69.2	80.0	31.0	21.6	67.0	45.6	56.3
September	85.9	26.2	17.5	62.3	41.8	53.5	74.0	23.0	15.5	57.1	41.6	49.4
October	73.4	17.1	19.8	53.0	31.2	43.1	65.0	26.0	15.7	45.9	30.2	38.1
November	49.3	14.8	10.3	33.9	23.7	28.8	45.0	15.0	9.8	33.1	23.3	28.2
December	39.1	15.5	11.8	19.9	5.1	12.5	31.6	-21.0	11.8	15.3	3.6	9.5
Yearly	98.2	-31.3	19.5	45.3	26.4	36.1	96.0	-35.0	17.0	40.4	23.4	31.9

NOTE. -<sup>1</sup>No records 19th-21st incl. <sup>2</sup>No records 7th-12th incl. <sup>3</sup>No records 2nd-9th and 9th-11th incl. <sup>4</sup>No records 30th.

1913.

January	28.9	-31.2	33.8	1.3	-13.5	-6.1	25.4	-37.0	14.7	1.0	-13.7	-6.4
February	28.3	-31.3	19.9	8.0	-14.3	-1.3	28.6	-33.0	35.5	3.6	-12.0	-3.2
March	46.1	-25.7	24.5	19.4	-2.1	8.7	49.0	-41.1	21.6	23.1	0.2	11.1
April	77.8	49.3	22.7	57.5	34.8	45.2	68.0	18.0	17.0	48.2	39.9	39.6
May	88.2	22.1	23.5	61.7	38.2	50.0	84.0	23.0	23.4	56.6	32.7	44.3
June	91.2	33.8	24.2	77.0	52.8	61.9	93.0	33.0	24.2	76.5	52.3	64.1
July	88.0	46.4	21.8	75.3	53.8	64.4	81.6	43.0	28.1	73.5	48.0	60.8
August	90.8	44.3	21.9	76.1	54.2	65.2	87.0	26.9	26.9	73.8	46.9	60.4
September	83.1	22.8	22.0	67.4	41.5	55.7	74.0	20.0	25.1	61.6	36.5	49.0
October	73.4	5.0	17.6	45.5	27.0	36.7	61.0	6.0	13.4	40.5	27.1	33.8
November	55.9	6.7	14.4	38.2	24.0	31.1	48.0	-4.0	16.0	34.5	21.5	29.5
December	43.3	-14.3	17.4	27.9	13.5	19.3	41.6	17.0	19.8	22.2	11.4	16.8
Yearly	91.2	-31.2	20.2	46.3	26.1	36.2	93.0	-37.0	19.3	42.8	23.7	33.3

NOTE. -<sup>1</sup>No records 3rd-5th and 15th-31st incl. <sup>2</sup>No records 1st-5th incl. <sup>3</sup>No records 8th and 9th.

Table 49.—Monthly Records of Temperatures at Winnipeg and Kenora 1906-1914—Concluded.

1914

Month.	WINNIPEG.						KENORA.					
	RANGE OF TEMPERATURE DEGREES FAH.			MEAN TEMPERATURES DEGREES FAH.			RANGE OF TEMPERATURE DEGREES FAH.			MEAN TEMPERATURES DEGREES FAH.		
	Max.	Min.	Mean.	Max.	Min.	Daily	Max.	Min.	Mean.	Max.	Min.	Daily
January	33.6	-23.5	18.0	16.7	-1.3	7.7	44.0	-00.0	15.0	13.4	-1.6	5.9
February	38.8	-49.5	20.4	7.0	-18.8	-8.7	11.0	-40.0	20.4	1.5	-18.8	-8.6
March	46.2	-16.4	18.0	29.4	13.4	20.1						19.5
April	66.0	9.0	18.4	43.0	26.9	36.1						42.1
May	82.1	22.1	25.7	68.1	42.4	55.2						50.7
June	88.8	35.0	24.4	73.4	51.6	64.2						60.4
July	93.4	47.0	23.0	80.9	60.7	72.4						68.2
August	94.6	48.5	24.1	74.0	51.3	62.8						
September	82.0	31.8	21.6	67.8	-16.2	57.0						
October												
November												
December												
Yearly												

AN  
ATURES  
S FAH.  
n. Daily  
1.6 4.8  
9.6 -1.1  
1.0 28.6  
8.0 37.4  
4.6 40.4  
4.8 65.9  
0.0 72.2  
0.4 79.2  
6.1 66.0  
0.4 79.2  
2.1 40.6  
2.4 16.7  
0.4 5.7  
7.5 33.5

3.0 -15.4  
7.5 9.8  
0.2 10.4  
7.3 36.2  
8.8 147.8  
3.2 264.1  
7.7 357.5  
5.6 56.3  
1.6 49.4  
0.2 38.4  
3.3 928.2  
4.6 9.5  
4.4 31.9

11th, incl.

3.7 -6.4  
2.0 -4.2  
0.2 11.1  
19.9 39.6  
2.7 44.4  
2.3 64.4  
8.0 160.8  
16.9 260.4  
16.5 49.0  
17.1 33.8  
24.5 329.5  
11.4 16.8  
23.7 33.3

19th.

## PRECIPITATION TABLES.

Table 50. Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin.

Year 1874-1875.

Month.	PRECIPITATION IN INCHES.		
	Winnipeg.	Kenora.	Sawawano (Pt. Assin.).
October	0.63		
November	1.09		
December	0.33		
January	0.79		
February	0.66		
March	0.24		
April	0.67		
May	3.34		
June	3.15		
July	1.76		
August	1.88		
September	0.86		
Total	18.61		

Year 1875-76.

October	1.38		
November	1.01		
December	0.98		
January	1.02		
February	1.11		
March	1.24		
April	0.46		
May	3.05		
June	1.50		
July	3.31		
August	9.42		
September	1.36		
Total	29.14		

Year 1876-77.

October	0.66		
November	2.55		
December	0.72		
January	0.42		
February	0.11		
March	1.08		
April	1.28		
May	5.39		
June	5.69		
July	3.24		
August	0.83		
September	3.02		
Total	21.99		

Year 1877-78.

October	0.78		2.28
November	0.70		1.80
December	2.23		1.10
January	0.30		0.35
February	1.20		0.85
March	2.49		1.15
April	3.98		4.82
May	3.76		3.49
June	3.09		2.37
July	5.17		0.81
August	1.53		2.00
September	1.80		4.97
Total	28.23		26.29

Table 50. Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin - Continued.

Year 1878-79.

Month.	PRECIPITATION IN INCHES			
	Winnipeg.	Kenora	Savanne	Pt. Arthur
October	3.18			3.05
November	0.22			0.53
December	1.10			0.09
January	1.67			0.78
February	0.65			0.22
March	0.64			2.81
April	2.21			2.82
May	2.78			1.50
June	6.98			2.09
July	5.22			2.66
August	1.82			1.37
September	0.72			4.16
Total	27.52			25.08

Year 1879-80.

October	1.48			2.20
November	0.12			1.12
December	2.12			2.39
January	1.01			0.21
February	1.86			0.84
March	0.18			0.20
April	0.15			1.01
May	5.88			3.23
June	3.52			1.73
July	2.71			2.71
August	1.06			2.97
September	4.13			7.08
Total	28.48			26.33

Year 1880-81.

October	1.72			2.36
November	0.24			3.01
December	1.23			0.51
January	0.15			1.16
February	3.93			2.77
March	0.63			1.04
April	0.76			2.07
May	2.07			3.58
June	2.66			1.14
July	0.87			2.91
August	4.82			2.27
September	2.60			4.47
Total	18.68			30.62

Year 1881-82.

October	1.50			2.80
November	2.79			1.66
December	0.35			0.32
January	1.26			1.44
February	1.77			2.33
March	2.58			1.54
April	0.17			1.07
May	1.58			1.41
June	1.45			2.17
July	7.40			3.06
August	1.51			1.46
September	1.01			1.35
Total	23.37			20.70

Table 50.—Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin—Continued.

Year 1882-83.

Month.	PRECIPITATION IN INCHES.			
	Winnipeg.	Kenora.	Savanne.	Pt. Arthur.
October	3.79			3.88
November	1.06			0.92
December	2.00			0.72
January	0.65			1.08
February	0.68			0.60
March	0.29			1.41
April	1.02			0.11
May	1.35			0.90
June	3.48			4.14
July	1.77			3.24
August	2.96			1.88
September	1.96			1.54
Total	21.01			20.42

Year 1883-84.

October	3.68			1.89
November	1.25			4.15
December	0.92			1.81
January	0.61			0.89
February	1.37			1.08
March	1.20			1.90
April	2.69			1.42
May	0.87			2.47
June	2.97			1.07
July	1.32			1.92
August	6.91			4.23
September	3.75			4.41
Total	27.54			27.24

Year 1884-85.

October	1.52			4.35
November	0.83			0.73
December	1.11			1.29
January	0.23			0.23
February	0.44			0.54
March	1.12			1.12
April	1.82			2.55
May	1.94			1.43
June	3.05			3.28
July	2.65			4.25
August	1.99			1.44
September	0.74			1.66
Total	17.44			22.87

Year 1885-86.

October	0.59			0.37
November	0.84			1.55
December	1.22			0.42
January	0.61			1.09
February	0.50			1.76
March	0.38			0.62
April	1.73			1.92
May	1.19			0.73
June	1.20			1.91
July	0.67			1.63
August	1.17			1.25
September	4.75			7.54
Total	14.85			20.79

Table 50.—Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin—Continued.

Year 1886-87.

Month.	PRECIPITATION IN INCHES.			
	Winnipeg.	Kenora.	Savanne.	Pt. Arthur.
October	1.22		3.59	3.06
November	0.57		1.30	1.23
December	0.39		0.90	0.54
January	0.71		0.90	0.94
February	1.07		1.80	0.89
March	0.94		0.40	0.52
April	1.14		1.80	1.68
May	3.01		1.40	1.68
June	2.94		4.4"	9.21
July	2.02		2.5	1.02
August	1.49		3.8.	2.49
September	1.77			
Total	17.26		23.32	24.74

Year 1887-88.

October	0.45		2.07	2.51
November	1.04		2.30	1.66
December	1.37		0.90	1.44
January	0.79		1.83	1.46
February	0.31		1.90	0.58
March	1.09		1.10	2.76
April	1.29		0.90	2.90
May	0.18		2.18	2.66
June	3.10		4.50	4.94
July	3.88		2.06	1.64
August	1.14		3.51	3.63
September	1.49		1.36	2.43
Total	16.11		21.58	28.61

Year 1888-89.

October	2.70		3.02	2.22
November	0.50		2.91	1.12
December	1.48		0.26	0.02
January	1.57		4.45	1.34
February	1.03		1.70	0.32
March	0.29		2.10	1.04
April	0.85		1.67	3.04
May	1.79		2.65	2.40
June	0.45		1.50	0.50
July	2.38		2.73	3.82
August	0.95		1.41	3.69
September	2.67		2.78	3.86
Total	15.66		27.18	23.37

Year 1889-90.

October	0.86		1.45	1.64
November	0.73		0.70	0.94
December	1.38		3.40	1.91
January	0.51		3.40	0.85
February	0.82		1.49	1.05
March	1.54		1.20	0.54
April	1.20		0.22	0.89
May	2.10		1.55	2.09
June	2.46		1.35	2.66
July	5.61		2.37	5.20
August	3.05		1.53	2.29
September	3.06		2.11	2.58
Total	23.32		20.68	22.64

Table 50.—Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin—Continued.

Year 1890-91

Month.	PRECIPITATION IN INCHES.			
	Winnipeg.	Kenora.	Savanne.	Pt. Arthur.
October	3.67		1.60	1.26
November	0.43		1.10	0.59
December	0.46		1.60	0.26
January	0.78		1.15	0.59
February	0.88		2.15	0.36
March	0.38		2.40	1.01
April	1.13		1.95	0.83
May	0.92		3.73	0.62
June	4.72		2.43	0.93
July	1.94		4.45	3.16
August	3.90		3.53	3.16
September	2.20		4.90	3.24
Total	21.41		30.99	16.72

Year 1891-92.

October	1.05		1.90	2.39
November	1.18		0.60	0.75
December	1.01		1.40	2.68
January	0.53		0.80	0.23
February	0.60		0.90	0.32
March	1.60		0.60	0.69
April	2.55		2.26	2.90
May	1.85		2.05	1.84
June	1.40		3.06	1.19
July	3.57		3.40	2.14
August	3.73		8.37	4.02
September	0.86		2.10	3.08
Total	19.93		27.44	22.23

Year 1892-93.

October	0.84		1.75	1.13
November	2.26		1.00	1.10
December	0.10		0.40	0.30
January	1.88		1.50	1.36
February	1.52		2.00	2.02
March	0.22		1.20	0.92
April	2.30		1.60	3.09
May	2.23		0.95	0.79
June	3.87		4.36	3.98
July	5.42		3.53	1.39
August	1.52		2.62	2.02
September	0.66		0.86	3.39
Total	22.82		21.77	21.19

Year 1893-94.

October	1.35		1.07	2.60
November	2.34		0.70	0.4
December	0.62		1.80	1.08
January	1.16		0.00	0.93
February	1.00		0.70	0.04
March	1.63		0.70	1.53
April	3.56		3.76	2.26
May	0.58		2.58	2.73
June	2.40		3.40	1.16
July	0.63		2.01	3.74
August	0.77		1.42	1.17
September	2.18		3.8	1.77
Total	18.22		23.02	19.02

Table 50. Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin - Continued.

Year 1891-93.

Month.	PRECIPITATION IN INCHES.			
	Winnipeg.	Kenora.	Sylvan.	Pt. Arthur.
October	1.79		5.15	5.27
November	1.87		1.70	1.26
December	0.57		0.90	1.16
January	1.54		1.00	0.71
February	1.18		0.70	0.75
March	0.55		0.60	0.96
April	0.62		2.58	2.60
May	3.71		3.37	2.58
June	2.31		4.40	2.89
July	3.30		3.31	3.01
August	1.01		3.01	1.96
September	1.14		3.80	4.27
Total	19.62		30.55	27.42

Year 1895-96.

October	0.34		2.01	1.20
November	0.95		1.90	0.58
December	0.22		2.20	1.96
January	1.34		0.50	0.55
February	0.42		0.40	0.21
March	1.85		0.60	0.76
April	5.64		1.50	3.00
May	5.32		3.45	4.10
June	3.96		3.07	2.04
July	2.01		4.79	1.75
August	1.51		4.65	1.73
September	1.96		4.25	1.41
Total	25.20		32	19.29

Year 1896-97.

October	1.01		1.80	3.15
November	1.31		1.90	2.62
December	0.27		0.50	0.16
January	0.89		0.50	0.73
February	0.89		2.10	0.86
March	1.58		1.00	0.92
April	1.01		0.30	1.45
May	1.59		1.60	2.06
June	2.31		1.75	3.39
July	5.38		6.05	6.53
August	1.00		5.40	4.65
September	0.34		1.30	1.12
Total	17.58		24.20	27.64

Year 1897-98.

October	1.32		1.20	1.44
November	0.72		1.40	1.06
December	0.55		1.20	0.46
January	0.89		0.80	0.51
February	1.07		1.40	0.46
March	2.56		1.40	0.87
April	0.98		0.00	0.07
May	0.89		1.30	3.06
June	6.10		8.05	6.94
July	1.77		6.85	1.58
August	2.15		2.40	2.42
September	2.50		6.60	5.40
Total	21.51		32.60	27.27

Table 50.—Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin—Continued.

Year 1898-99.

Month.	PRECIPITATION IN INCHES.			
	Winnipeg.	Kenora.	Savanne.	Pt. Arthur.
October	5.67		2.70	2.78
November	2.00		2.00	0.77
December	0.61		0.60	0.28
January	1.77		1.50	0.50
February	0.84		1.80	0.57
March	0.36		1.00	0.34
April	2.17		0.75	2.57
May	2.20		0.13	3.40
June	3.68		1.50	3.84
July	1.96		2.26	3.52
August	3.42		3.20	3.76
September	0.91		3.70	3.65
Total	25.59		22.14	25.98

Year 1899-1900.

October	1.85	1.82	2.00	1.79
November	0.55	0.58	0.30	1.34
December	0.11	0.56	0.30	1.25
January	1.05	1.70	1.30	0.85
February	0.20	0.62	0.00	0.20
March	0.68	0.40	0.60	0.29
April	0.30	0.57	0.20	0.50
May	0.11	0.31	0.60	0.36
June	1.85	1.84	2.60	2.48
July	4.06	4.58	3.11	3.33
August	3.66	7.33	5.91	6.77
September	4.22	5.09	5.12	6.14
Total	18.64	25.00	22.04	25.30

Year 1900-01.

October	0.94	3.46	22.25	5.20
November	0.84	1.25	21.46	0.67
December	0.67	1.20	21.09	0.30
January	0.81	2.25	11.38	0.84
February	0.90	0.55	21.28	0.06
March	0.26	0.75	11.12	0.66
April	1.93	0.04	11.27	1.57
May	0.36	1.47	12.05	0.95
June	10.07	3.88	4.10	3.76
July	3.12	2.93	4.65	6.24
August	1.70	2.53	3.95	2.92
September	3.80	1.70	2.35	1.98
Total	25.40	22.01	26.95	25.15

NOTE.—<sup>1</sup>Average of 20 years. <sup>2</sup>Average of 19 years.

Year 1901-02.

October	0.46	0.82	2.00	2.47
November	0.06	0.60	2.10	0.71
December	0.43	1.10	0.90	0.35
January	0.12	0.13	1.40	0.50
February	0.54	0.48	0.00	0.26
March	2.88	1.22	1.05	0.40
April	1.33	1.05	2.10	0.55
May	3.87	0.84	3.30	1.89
June	3.46	5.76	2.85	5.18
July	1.55	3.60	2.10	3.03
August	0.93	2.04	4.35	3.01
September	2.01	2.06	2.90	1.99
Total	17.42	19.10	25.05	20.34

Table 50. Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin—Continued.

Year 1902-03.

Month.	PRECIPITATION IN INCHES.			
	Winnipeg	Kemora	Savanne	Pt. Arthur
October	1.23	1.40	2.80	2.78
November	1.02	0.79	1.85	1.77
December	1.50	1.38	1.90	0.46
January	0.28	1.10	1.70	0.23
February	0.10	0.55	1.00	0.29
March	1.08	1.30	0.30	0.95
April	0.51	1.05	1.10	1.81
May	3.10	3.64	0.70	3.17
June	0.19	1.58	1.20	1.60
July	3.05	2.37	5.65	3.29
August	2.00	3.09	1.50	1.97
September	2.77	1.56	3.10	5.56
Total	17.46	24.09	23.10	23.88

Year 1903-04.

October	0.69	1.47	3.85	2.71
November	1.50	1.00	1.35	0.35
December	1.02	1.28	0.80	0.18
January	0.17	0.15	1.31	0.23
February	0.85	0.83	0.90	0.18
March	3.00	2.30	1.50	1.11
April	0.16	0.81	0.30	0.36
May	1.77	1.78	4.25	2.31
June	4.22	2.50	2.80	3.36
July	5.55	5.33	4.75	2.91
August	1.62	1.67	3.40	2.65
September	1.88	3.27	3.95	3.41
Total	22.43	26.85	29.15	19.82

Year 1904-05.

October	1.51	0.81	1.00	3.62
November	0.32	0.63	0.90	0.58
December	1.65	2.12	0.60	1.43
January	0.20	0.15	0.00	0.22
February	0.27	0.62	1.20	0.29
March	1.78	1.25	4.60	1.43
April	0.25	0.04	1.11	1.32
May	3.35	2.24	1.45	2.14
June	4.62	5.55	3.25	2.86
July	4.35	3.51	5.11	7.43
August	1.41	4.18	1.20	1.30
September	1.56	3.69	4.50	4.58
Total	21.27	24.79	25.55	26.60

Year 1905-06.

October	1.03	2.45	1.80	2.31
November	1.13	1.41	1.50	2.70
December	0.41	0.15	0.20	0.10
January	1.33	1.40	0.50	0.15
February	0.21	0.75	3.28	0.52
March	0.54	0.10	0.80	0.55
April	1.64	0.20	1.10	0.53
May	2.97	3.90	3.35	2.97
June	6.30	4.84	3.50	5.88
July	3.37	1.12	2.55	3.60
August	1.33	6.65	13.27	2.34
September	1.51	0.90	3.45	1.45
Total	21.77	23.87	23.58	23.13

NOTE.—<sup>1</sup>Average of 20 years. <sup>2</sup>Average of 19 years.

Table 50.—Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin—Continued.

Year 1906-07.

Month	PRECIPITATION IN INCHES.			
	Winnipeg.	Kenora.	Savanne.	Pt. Arthur.
October	0.21	0.20	.....	2.18
November	1.87	1.35	.....	4.29
December	1.26	1.50	.....	0.55
January	2.12	2.50	.....	1.03
February	0.27	0.55	.....	0.80
March	1.12	1.38	.....	1.63
April	0.99	1.10	.....	1.01
May	0.97	0.40	.....	0.88
June	1.54	2.78	.....	0.74
July	3.98	5.40	.....	5.94
August	3.90	6.45	.....	5.06
September	0.69	3.25	.....	3.26
Total	18.92	26.56	.....	27.37

NOTE.—<sup>1</sup>Approximate.

Year 1907-08.

October	0.40	0.65	.....	2.47
November	0.72	0.90	.....	1.05
December	0.18	0.25	.....	0.02
January	3.41	0.30	.....	0.47
February	1.80	1.20	.....	1.67
March	1.83	0.60	.....	0.57
April	1.75	1.05	.....	2.82
May	3.01	12.50	.....	2.85
June	3.11	13.30	.....	3.70
July	1.76	14.04	.....	1.96
August	2.14	14.93	.....	3.71
September	1.89	13.13	.....	1.08
Total	19.43	22.15	.....	22.47

NOTE.—<sup>1</sup>Average of 13 years.

Year 1908-09.

October	2.21	72.03	.....	1.00
November	0.55	40.20	.....	1.99
December	0.68	0.50	.....	2.73
January	0.73	40.60	.....	1.20
February	0.76	0.40	.....	0.56
March	2.67	0.85	.....	0.66
April	1.58	.35	.....	0.64
May	1.25	.00	.....	1.20
June	1.54	3.80	.....	0.57
July	3.84	34.04	.....	5.17
August	1.75	33.93	.....	3.05
September	0.60	33.43	.....	2.61
Total	21.13	22.03	.....	21.38

NOTE.—<sup>1</sup>Approximate. <sup>2</sup>Average of 15 years. <sup>3</sup>Average of 13 years.

Year 1909-10.

October	0.52	2.00	.....	1.49
November	0.89	11.60	.....	2.63
December	3.99	3.82	.....	1.20
January	0.25	0.10	.....	0.71
February	1.56	40.30	.....	0.79
March	1.65	3.30	.....	0.23
April	1.49	3.30	.....	1.62
May	1.65	1.30	.....	0.76
June	2.38	0.26	.....	0.54
July	0.80	0.50	.....	2.85
August	2.14	1.25	.....	1.47
September	2.75	3.80	.....	3.42
Total	20.07	21.53	.....	17.71

NOTE.—<sup>1</sup>Approximate.

Table 50.—Monthly Precipitation Records in the vicinity of the Winnipeg River and Basin—Concluded.

Year 1910-11

Month.	PRECIPITATION IN INCHES.			
	Winnipeg	Kemora.	Savanna.	Pt. Arthur.
October				
November	1.08	2.60		2.46
December	1.27	2.05		1.29
January	1.87	0.90		0.41
February	0.13	0.90		0.56
March	0.71	0.65		1.28
April	0.28	0.10		0.75
May	2.57	2.10		0.67
June	6.38	3.90		2.36
July	2.77	2.60		6.24
August	2.96	7.81		3.01
September	2.43	4.80		2.96
September	2.13	3.70		2.91
Total	24.58	41.84		24.87

Note.—Average of 14 years.

Year 1911-12.

October	1.81	2.30		1.65
November	0.59	0.10		1.52
December	0.59	1.59		1.05
January	0.40	0.15		0.26
February	0.18	0.40		0.33
March	0.40	0.90		0.36
April	2.25	3.20		2.50
May	3.59	9.60		3.03
June	0.91	4.80		1.75
July	6.11	8.80		1.97
August	1.61	4.50		2.54
September	5.49	7.50		4.97
Total	23.79	41.35		21.93

Year 1912-13.

October	1.15	4.20		1.20
November	0.11	0.90		0.42
December	0.78	0.20		0.78
January	0.75	0.80		0.54
February	0.61	0.90		0.56
March	0.46	0.65		1.22
April	0.41	0.60		0.75
May	0.53	11.29		3.43
June	3.27	2.09		2.11
July	2.09	3.84		6.26
August	4.71	4.27		2.87
September	1.27	1.02		3.85
Total	16.04	19.86		21.29

Note.—This and all subsequent records at Kemora obtained by Dominion Water Power Branch.

Year 1913-14.

October	0.77	3.21		3.73
November	0.75	1.35		1.27
December	0.26	0.05		0.08
January	0.79	1.30		0.97
February	0.83	0.42		0.39
March	0.59	0.36		0.94
April	0.75	1.79		1.17
May	0.53	1.87		3.43
June	1.46	4.67		1.30
July	7.14	3.80		2.30
August	2.05	2.12		4.48
September	2.28	4.07		2.70
Total	18.20	25.01		22.96

Table 51. Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods.

MAY 1914

Day	TEMPERATURE IN DEGREES FAHRENHEIT				Velocity Wind.  Miles per hour.	Direc- tion Wind.	Baro- meter.  Inches.	Evapo- ration.  Inches.	Rain.  Inches.	Humid- ity.  Per cent.
	Lake.	Tank	Air	Mean Day.						
1										
2										
3							Set tank			
4			47		3.46		0.00	0.015		
5			47		0.54		0.01	0.195		
6					0.54					
7					3.77		Set tank			
8					5.70					
9			44		5.70		0.11			
10			50		6.98		0.11			
11			50		3.48		0.21			
12					5.82					
13			44		5.82		0.07	0.150		
14			32		6.32		0.00	0.160		
15			37		4.15		0.05			
16			38		3.88		0.00	0.030		
17					3.88		0.01	0.160		
18			40		3.22		0.00	0.065		
19	44		44		6.97		0.06	0.020		
20	42		44		6.97		0.00	0.005		
21	43		48		2.50		0.07			
22	46		50		5.48		0.10	0.030		
23	47		50		5.18		0.05			
24	46	47	50		1.80		0.05			
25	46	47	50		3.25		0.005	0.285		
26	48	50	51		4.11		0.09			
27	47	48	58				0.16			
28	49	52	63				0.05			
29	50	54	75				0.04	0.020		
30	51	53	65				0.04	0.010		
31	51	56	66				0.00	0.040		
	55	56	57				0.02			
	51	53	60				0.06	0.100		
Total							1.36	1.285		
Average							0.051	0.041		

Table 51. Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods - Continued.

JUNE, 1910

Day.	TEMPERATURE IN DEGREES FAHRENHEIT				Velocity Wind	Dir- tion Wind	Bar- ometer.	Evapo- ration	Rain	Humi- dity
	Lake	Fork	Air	Mean Day						
1	52.0	54.0	66.0	55.5	8.00			0.01		
2	51.0	59.0	56.0	54.0	2.83			0.09	0.20	
3	50.0	51.0	56.0	49.0	1.93			0.01		
4	52.0	53.0	60.0	51.5	6.15			0.11		
5	52.0	53.0	58.0	53.0	3.00				0.34	
6	51.0	52.0	50.0	43.0	3.39			0.07		
7	52.0	54.0	58.0	46.5	3.81			0.13		
8	54.0	55.0	65.0	51.0	2.11	W		0.10		
9	56.0	57.0	60.0	59.0	3.19	W	29.81	0.10		48.0
10	54.0	55.0	61.0	58.0	1.93	W	29.81			54.0
11	55.0	57.0	68.0	61.0	6.07	W	29.11	0.10		68.0
12	56.0	58.0	75.0	67.0	3.88	W	29.11			53.0
13	60.0	61.5	69.0	70.0	3.81	W	29.26	0.01		61.0
14	63.0	64.0	72.0	66.0	3.27	W	29.24			77.0
15	66.0	68.0	80.0	68.5	5.59	W	29.16	0.02	0.38	81.0
16	61.0	61.5	68.0	61.0	8.76	W	29.06	0.03		74.0
17	60.0	60.5	63.0	51.5	2.33	W	28.96	0.03		81.0
18	62.5	62.5	71.5	59.0	4.06	W	29.21	0.08	0.01	47.0
19	63.0	63.5	78.5	65.0	4.36	W	29.36	0.11		71.0
20	61.5	62.0	80.0	61.5	3.41	W	29.16	0.11		60.0
21	65.0	64.5	72.5	60.5	1.31	W	29.16	0.13		64.0
22	68.0	69.0	90.0	63.0	1.90	W	29.16	0.06		75.0
23	66.0	67.5	72.5	67.5	4.51	W	29.11	0.06		63.0
24	65.5	66.0	81.0	72.5	1.15	W	29.42	0.09		61.0
25	66.0	67.0	75.0	70.0	5.93	W	29.40	0.06		65.0
26	65.5	66.0	76.0	61.0	5.65	W	20.45	0.06		76.0
27	65.0	64.5	58.0	53.5	5.85	W	29.11	0.06		65.0
28	67.0	67.0	71.0	67.5	4.57	W	29.11	0.06	0.28	56.0
29	70.0	70.0	94.0	69.0	4.58	W	29.42	0.09		61.0
30	68.5	69.0	73.0	64.5	8.26	W	29.40	0.13		61.0
						W	29.36	0.13		84.0
						W	29.31	0.05		37.0
						W	29.01			53.0
						W	29.09			90.0
						W	29.01			42.5
						W	28.80	0.13		63.0
						W	28.76			63.0
						W	28.86	0.08	0.27	66.0
						W	29.11			42.0
						W	29.26	0.18		38.0
						W	29.10			
						W	29.26	0.04	0.55	
						W	29.15			85.0
						W	29.16	0.06	0.28	78.0
						W	29.11	0.02		99.0
						W	28.90			62.0
						W	28.96	0.16	0.06	54.0
Total								2.25	2.09	
Average	59.9	60.8		59.9				0.080	0.070	

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods.—Continued.

JULY, 1914.

Day.	TEMPERATURE, IN DEGREES FAHRENHEIT.				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Eva-po- ration.	Rain.	Humid- ity.
	Lake	Tank.	Air.	Mean Day.						
1	66.0	66.0	59.0		6.17	N.	29.20	0.08		
	69.0	69.0	74.0	57.0	6.14	N.	29.41	0.05		58.0
2	67.0	67.0	68.0		0.52	SW.	29.40	0.06		55.0
	68.0	67.0	67.0	56.5	1.79	SE.	29.06	0.07		76.0
3	67.0	67.0	75.0		5.09	SW.	28.99	0.06		48.0
	66.0	66.0	60.0	7.5	2.72	SE.	29.16	0.08	0.01	100.0
4	66.0	65.0	58.0		2.72	N.	29.41	0.06		89.0
	66.0	66.0	59.0	56.5	11.11	SW.	29.22	0.07		
5	65.0	65.0	61.0		6.36	N.	29.06	0.01	0.73	94.0
	66.0	66.0	52.0	53.0	7.07	N.	29.26	0.01	0.08	81.0
6					3.07	SW.				29.0
	70.0	71.0	80.0	60.5	2.19	SW.	29.51	0.08	0.01	
7	69.0	68.0	78.0		1.50	W.	29.28	0.07		60.0
	67.0	68.0	66.0	61.0	3.14	SW.	29.16	0.07		40.0
8	66.0	66.0	76.0		5.95	W.	29.01	0.01		45.0
	65.0	65.0	62.5	65.0	21.00	W.	28.94	0.17	0.01	79.0
9	65.0	63.8	56.0		5.23	NW.	29.26	0.10		65.0
	65.5	66.0	63.0	58.0	5.72	NW.	29.47	0.14		56.0
10	65.8	65.0	62.5		1.71	S.	29.41			65.0
	66.0	66.5	68.5	56.5	5.68	E.	29.15	0.06		57.0
11	65.6	61.8	63.0		8.56	S.	28.86	0.05	0.99	90.0
	65.5	64.5	60.0	54.7	8.42	S.	28.76	0.02	0.22	89.0
12	65.0	63.6	58.5		8.41	SE.	28.65	0.05	0.62	89.0
	61.6	63.5	56.0	49.0	10.31	SE.	28.80	0.04	0.23	88.0
13	65.6	66.0	63.0		1.51	NW.	29.17	0.01		58.0
	68.0	68.5	67.0	58.5	3.19	SW.	29.21	0.08		77.0
14	64.5	63.5	58.0		3.19	SE.	29.41	0.05	0.02	16.0
	68.5	69.5	73.0	58.5	2.91	SE.	29.45	0.05		68.0
15	66.0	66.0	63.0		4.40	N.	29.14	0.09		72.0
	67.0	67.5	69.5	63.0	3.74	S.	29.41	0.04		79.0
16	66.0	66.0	65.0		2.75	SE.	29.15	0.04	0.18	80.0
	69.0	70.0	72.0	66.5	1.31	S.	29.10	0.04	0.01	86.0
17	66.0	65.5	61.8		2.45	S.	29.45	0.02		75.0
	67.9	69.0	75.0	61.5	5.89	NW.	29.42	0.08		44.0
18	65.8	65.6	69.7		4.40	SW.	29.40	0.02		75.0
	66.0	66.5	65.5	66.0	9.18	NW.	29.47	0.08		62.0
19	66.9	65.0	62.0		6.40	NW.	29.39	0.04		79.0
	66.5	66.0	58.0	63.0	6.99	N.	29.44	0.05	0.09	61.0
20					1.99	N.				0.0
	6.0	68.5	68.0	62.0	2.96	SW.	29.52	0.00	0.01	65.5
21	67.5	67.0	64.5		4.97	NW.	29.22	0.13		82.0
	67.1	68.5	71.5	67.0	7.03	NW.	29.20	0.05	0.13	54.5
22	67.0	66.2	65.5		4.98	NW.	29.15	0.04		64.0
	67.5	67.5	60.5	60.2	10.80	NE.	29.15	0.06	0.11	78.5
23	66.0	65.0	57.0		5.18	N.	29.30	0.05		74.0
	66.0	66.0	56.5	59.5	4.33	N.	29.36	0.10		66.0
24	66.5	65.5	59.0		6.77	W.	29.38	0.03		75.0
	67.0	67.0	67.0	59.0	5.00	N.	29.30	0.08		50.0
25	66.5	66.0	66.0		3.52	SW.	29.20	0.01		66.0
	68.0	69.2	77.0	67.0	5.23	SW.	29.15	0.08		52.0
26	66.0	65.0	64.5		3.73	S.	29.00	0.04		82.0
	66.5	67.0	71.0	67.0	3.63	SW.	29.00	0.06		73.0
27	67.0	67.0	62.0		8.74	NW.	29.20	0.06		57.0
	67.0	66.5	63.0	61.0	10.58	NW.	29.30	0.06	0.06	62.5
28	66.0	68.0	62.5		2.41	W.	29.36	0.04		72.0
	67.0	67.0	68.5	59.0	5.99	SW.	29.44	0.01		59.0
29	66.0	66.0	69.0		3.30	S.	29.24	0.06		72.0
	70.0	71.0	79.0	75.0	3.75	SW.	29.20	0.05		57.0
30	67.0	68.0	72.0		3.66	SE.	29.10	0.01		82.0
	70.5	71.5	78.0	74.5	5.35	W.	29.16	0.00		57.0
31	65.5	65.5	62.0		8.93	W.	29.18	0.07		60.0
	67.0	67.0	72.0	63.0	11.11	W.	29.25	0.12		46.0
Total								3.49	3.84	
Average	66.0	66.0		61.5				0.055	0.174	

Table 51. Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods. (Continued).

AUGUST 1913

Day	TEMPERATURE IN DEGREES FAHRENHEIT				Average Wind	Dir. Wind	Humidity	Evaporation	Rain	Humidity
	Lake	Lake	Air	Wet Bulb Day						
1	69.0	69.5	72.0		6.08	W	29.08	0.08		61.0
	68.0	69.7	78.0	68.0	4.14	NW	29.31	0.07		49.0
2	67.0	67.0	77.0		6.46	W	29.33	0.08		57.0
	68.0	70.0	81.0	71.0	7.86	NW	29.37	0.03		99.0
3	68.5	69.0	68.0		7.44	NW	29.48	0.08		4.0
	70.5	72.0	76.0	66.0	6.88	W	29.48	0.06		6.0
4	67.5	67.0	64.0		0.89	W	29.44	0.08		65.0
	68.5	68.5	70.0	61.0	7.86	W	29.38	0.08		60.0
5	67.5	67.0	65.0		7.08	W	29.27	0.05		70.0
	68.0	69.0	70.0	65.5	4.08	W	29.40	0.10		48.0
6	67.0	66.0	59.0		1.70	W	29.48	0.04		78.0
	70.0	70.0	69.0	62.0	2.06	W	29.45	0.09		55.0
7	67.5	66.0	61.5		1.22	W	29.40	0.09		68.0
	66.0	67.0	63.0	63.5	6.88	W	28.90	0.04	0.69	90.0
8	66.0	65.0	58.0		1.41	W	28.87	0.01	0.84	77.0
	67.0	66.0	64.5	60.0	7.89	W	28.97	0.03	0.21	83.0
9	67.0	66.0	64.0		1.93	W	29.15	0.08		79.0
	67.0	65.5	54.0	52.5	5.09	W	29.45	0.08	0.01	74.0
10	66.0	65.5	59.0		7.77	SE	29.51	0.08	0.01	53.0
	65.0	64.8	59.0	52.0	7.75	SE	29.48	0.10		73.0
11	65.0	64.0	54.5		7.05	SE	29.48	0.01	0.74	91.0
	65.8	66.8	64.2	56.0	1.43	W	29.57	0.01	0.01	81.5
12	65.6	65.8	68.0		1.56	SW	29.34	0.01		88.0
	68.8	71.4	67.0	69.0	0.07	W	29.01	0.04		67.0
13	66.7	68.0	77.0		0.64	W	29.26	0.02		89.0
	71.0	72.6	75.0	74.0	4.18	W	29.30	0.02		82.0
14	70.0	70.0	71.0		1.67	W	29.06	0.02		86.0
	71.0	76.0	81.0	74.0	3.93	W	29.00	0.05		86.0
15	70.0	69.0	69.0		6.00	W	29.20	0.00		61.0
	71.0	70.0	78.0	67.5	2.08	W	29.50	0.03	1.78	86.0
16	68.0	69.0	64.0		2.86	W	29.35	0.04		78.0
	71.0	71.0	64.0	64.5	2.42	W	29.38	0.02		79.0
17	71.0	74.0	64.0		0.40	W	29.40	0.07		61.0
	74.0	72.0	64.0	51.0	1.44	NW	29.52	0.16		55.0
18	68.0	67.0	66.0		4.44	E	29.51	0.09		71.0
	70.8	70.0	71.8	64.0	5.88	SE	29.58	0.01		65.0
19	68.0	68.0	66.0		7.47	SE	29.50	0.075		76.0
	69.2	70.0	68.2	68.0	4.62	SW	29.45	0.01	0.045	85.0
20	69.0	69.0	71.0		2.48	W	29.45	0.05		86.0
	74.3	74.0	68.5	72.0	3.46	W	29.36	0.05		62.0
21	69.0	68.0	63.0		7.22	W	29.25	0.05	0.20	74.0
	66.0	67.0	61.0	61.5	11.93	SE	29.40	0.12	0.41	79.0
22	66.0	66.0	60.0		5.44	NE	29.49	0.01		89.0
	71.0	70.0	68.0	61.0	1.57	NW	29.40	0.05		66.0
23	68.0	68.0	66.8		6.08	W	29.35	0.07		71.0
	68.0	68.0	66.5	59.0	6.42	N	29.40	0.09		55.5
24	69.0	69.0	65.0		3.46	SW	29.38	0.09		62.0
	68.0	68.0	65.0	55.0	6.00	NW	29.20	0.04		78.0
25	68.0	66.0	66.0		6.00	NW	29.05	0.075	0.015	76.0
	69.0	71.0	72.5	58.0	17.17	NW	29.21	0.08		46.0
26	66.0	66.0	62.0		9.48	W	29.25	0.09		69.0
	67.0	67.0	60.0	60.5	6.40	SE	29.36	0.06		94.0
27	67.0	66.0	62.0		1.91	SE	29.35	0.04		84.0
	67.0	67.0	63.0	58.5	5.88	SE	29.30	0.03	0.08	90.0
28	66.0	65.0	58.0		1.73	SE	29.36	0.05	0.40	83.0
	67.0	67.0	59.0	58.0	15.60	NW	29.48	0.08	0.09	79.0
29	66.0	64.0	58.0		8.08	NW	29.22	0.01		83.0
	66.0	66.0	60.0	60.5	6.72	NW	29.17	0.07		84.0
30	65.0	65.0	63.0		2.46	SW	29.10	0.02		79.0
	68.0	70.0	72.0	61.5	2.49	SW	29.13	0.04		65.0
31	67.0	68.0	65.0		34.00	SE				
				54.5	4.40	SE	29.26	0.08		57.0
Total								4.42	4.58	
Average	68.2	68.2	62.3					0.057	0.118	

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods Continued.

SEPTEMBER 1913.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Evapo- ration.	Rain.	Humi- dity.
	Lake.	Tank.	Air.	Mean Day.						
1	67.0	68.0	71.0		6.60	SE.	29.00	0.13		69
	67.0	68.0	70.0	68.5	5.14	S.	29.05	0.06	0.03	81
2	64.0	63.0	60.0		7.46	NW.	29.39	0.04		78
	66.5	68.0	60.0	60.0	6.67	NW.	29.50	0.06		71
3	66.0	64.0	58.0		2.48	SE.	29.57	0.05		72
	66.0	66.0	62.0	56.5	6.88	SE.	29.46	0.06		79
4	66.0	64.0	58.0		7.91	SE.	29.34	0.13		80
	66.0	66.0	64.0	59.5	6.74	SE.	29.35	0.04		90
5	66.0	65.0	64.5		4.36	SE.	29.31	0.04		87
	68.0	70.5	74.0	67.0	3.28	SE.	29.29	0.02		80
6	66.0	67.0	9		2.05	SE.	29.25	0.01		90
	72.0	76.0	79.0	74.5	1.76	SE.	29.25	0.10	0.02	88
7	66.0	64.0	58.0		5.84	NW.	29.41	0.01		89
	66.0	66.0	60.0	62.5	10.76	NW.	29.60	0.07	0.23	68
8	66.0	64.0	60.0		2.52	S.	29.70	0.07		68
	66.0	65.0	61.0	54.5	2.76	S.	29.60	0.08		68
9	65.0	64.0	58.0		6.86	SE.	29.15	0.08		67
	66.0	68.0	69.0	62.0	9.48	SE.	29.24	0.10		68
10	65.0	64.0	61.0		5.22	NW.	29.36	0.13		89
	66.0	68.0	66.0	63.0	2.45	NW.	29.40	0.07	0.47	66
11	63.0	62.0	50.0		4.02	NW.	29.45	0.07		81
	64.0	63.0	56.0	55.0	1.32	NW.	29.50	0.15		55
12	64.0	60.0	50.0		7.24	N.	29.51	0.09		77
	63.0	65.0	59.0	50.0	2.98	N.	29.52	0.09		53
13	62.0	58.0	41.0		3.37	E.	29.46	0.06		92
	64.0	64.0	55.0	61.5	4.98	E.	29.40	0.11		60
14					7.38	SE.				
	63.0	61.0	56.0	59.0	7.51	S.	29.17	0.10		77
15	64.0	63.0	58.0		5.21	NW.	29.34	0.155	0.175	83
	64.0	64.0	58.0	55.5	3.41	SW.	29.45	0.07		83
16	63.0	61.0	54.0		0.39	SW.	29.47	0.025		94
	65.0	63.0	60.0	57.0	0.84	SW.	29.50	0.06	0.005	68
17	63.0	61.0	54.0		0.64	SW.	29.45	0.01		88
	64.0	64.0	62.0	61.0	2.17	SW.	29.46	0.05		79
18	63.0	63.0	62.0		0.51	SW.	29.20	0.01		69
	64.0	64.0	66.0	61.0	7.06	S.	29.00	0.08		71
19	64.0	61.0	60.0		7.39	W.	29.32	0.01		92
	63.0	60.0	60.0	47.5	7.56	W.	28.80	0.13	0.06	84
20	61.0	57.0	40.0		14.30	NW.	29.12	0.15		84
	60.0	57.0	38.0	41.5	21.96	NW.	29.21	0.12		67
21					27.50	N.	29.26		0.015	62
22	60.0	59.0	42.0	39.5	13.50	NE.		0.12		
	59.0	57.0	38.0		1.98	NE.	29.25	0.10		91
	59.0	57.0	43.0	35.0	3.29	SW.	29.25	0.08		49
23	59.0	54.0	43.0		4.52	SE.	29.35	0.08		78
	59.0	54.0	43.0	38.0	3.41	SE.	29.35	0.08		78
24	58.0	54.0	43.0		3.31	NE.	29.30	0.07	0.01	85
	58.0	54.0	41.5	41.5	2.34	NE.	29.30	0.04		84
25	57.0	53.0	41.0		0.62	SW.	29.25	0.01		85
	57.0	56.0	50.0	43.0	4.37	W.	29.20	0.04		62
26	56.0	52.0	41.0		2.99	NW.	29.15	0.06		84
	58.0	60.0	61.0	49.0	21.37	NW.	29.32	0.98		50
27	58.0	55.0	52.0		4.06	SW.	29.25	0.05		75
	58.0	56.0	72.0	57.0	9.13	SW.	29.22	0.09		42
28	58.0	58.0	59.0		4.48	W.	29.10	0.05		68
				59.5	2.02	NE.				
29	56.0	54.0	48.0			SE.	29.18	0.08		87
	59.0	61.0	62.0		3.18	SE.	29.25	0.04		60
30	56.0	58.0	54.0			SE.	29.19	0.03		88
	60.0	63.0	74.0		2.87	SW.	29.20	0.01		47
Total								4.68	1.01	
Average	62.6	61.6		51.9				0.072	0.034	

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.

OCTOBER 1913.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Eva-pora- tion.	Ram.	Humi- dity.
	Lake.	Tank.	Air.	Mean Day.						
1.	57	57	56			NW.	0.02			
2.	57	57	62	55	10.3	SW.	0.06		85	
3.	58	59	60	53	5.5	SW.	0.06	0.015		
4.	57	56	50		4.4	SW.	0.05		63	
5.	57	57	56	55	4.4	SW.				
6.	56	55	46		2.9	NE.	28.62	0.07	80	
7.	57	54	49	45	2.5	NE.	28.87	0.05	79	
8.	55	51	42		2.8	NE.	28.77	0.03	0.64	
9.	55	54	42	40	6.6	NE.	0.04	0.32	84	
10.	54	53	40		4.4	NE.	0.04	0.01		
11.	54	53	43	48	9.4	NE.	28.73	0.03	80	
12.	51	52	41		2.7	SW.	0.03			
13.	51	52	11	43	11.8	SW.	28.80		0.73	
14.	55	57	53		3.8	NE.	0.03			
15.	55	56	55	12	2.0	NE.	28.90	0.02	70	
16.	55	55	59	47	2.7	NE.	0.02	0.08	85	
17.	55	56	59		1.4	S.	0.92			
18.	55	54	45	46	4.1	SE.	28.41	0.03	0.98	
19.	51	53	48		1.7	SW.	0.06			
20.	51	52	50	40	1.0	NW.	28.55	0.08		
21.	52	50	48		8	SW.	28.85	0.11		
22.	52	53	48	40	1.6	SW.	28.95	0.02	0.02	
23.	52	51	52		5.9	SE.	28.80	0.03		
24.	54	57	62	52	11.0	SE.	28.73	0.01	83	
25.	54	52	55		6.4	SW.	28.65	0.11		
26.	52	52	46	49	7.9	NW.	28.82	0.06	74	
27.	52	50	39		0.4	NW.	29.15	0.08		
28.	52	52	45	37	4.6	NW.	29.19	0.05	62	
29.	52	49	39		2.8	NE.	29.25			
30.	51	51	42	37	2.5	NE.	29.25	0.07	64	
31.	50	48	41		0.8	S.	29.47	0.04		
32.	50	50	41	42	8.4	SE.	29.06	0.08	74	
33.	50	49	40		5.8	NW.	28.94	0.05		
34.	50	50	38	38	5.6	NW.	28.90	0.06	72	
35.	49	47	27		5.6	NW.	28.96	0.04		
36.	48	45	28	30	8.6	NW.	28.99	0.05	70	
37.	48	44	26		5.6	NW.	28.70	0.01		
38.	47	43	20	30	4.6	NW.	28.72	0.06	73	
39.	46	43	20		2.6	NW.	28.70	0.03		
40.	46	44	22	19	3.3	NW.	28.67	0.03	71	
41.	46	44	30		3.0	SE.	28.67	0.06		
42.	46	45	35	27	3.9	S.	28.67	0.01	100	
43.	46	45	36		3.4	S.	28.50	0.02		
44.	46	45	38	33	5.9	S.	28.49	0.02	0.16	
45.	46	45	38		3.7	NW.	28.73	0.07	95	
46.	46	46	41	37	5.5	NW.	28.80	0.03	0.02	
47.	46	45	37		3.9	NW.	28.84	0.04	0.03	
48.	46	45	37	40	1.4	NW.	28.92	0.01	0.06	
49.	45	43	32		1.9	NW.	29.00	0.04		
50.	45	43	32	34	1.9	NW.	28.95	0.01	100	
51.	44	43	34		5.5	NW.	28.72	0.02		
52.	44	43	35	30	1.2	NW.	28.70	0.01	77	
53.	43	40	31		5.4	NW.	29.08			
54.	43	41	21	20	7.2	NW.	29.13		0.14	
55.	43	40	17		2.2	NE.	29.10		88	
56.	44	40	21	19	2.2	NE.	29.13		97	
57.	42	40	24			SW.	29.10			
58.	42	40	27	24	4.7	SW.	29.16		87	
59.	41	40	26		4.0	SW.	29.20			
60.	41	42	35	31	10.2	SW.	29.16		63	
Total								2.15	3.34	
Average	50.2	49.1		37.8				0.045	0.108	

Table 51.— Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.

NOVEMBER, 1913.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind.	Direction Wind.	Baro- meter.	Evapo- ration.	Rain.	Humi- dity.
	Lake.	Tank.	Air.	Mean Day.						
					Miles per hour.		Inches.	Inches.	Inches.	Per cent.
1.	41	39	33		3.6	S.W.	28.97	0.03		
	41	41	41	37	6.7	S.W.	29.27	0.05		74
2.	41	43	38		1.5	S.	28.79	0.02		
	42	44	43	41	18.3	Calm	29.09	0.05		76
3.	41	40	34		2.2	N.W.	28.96			
	41	39	28	30	7.8	N.W.	29.26	0.06		79
4.	41	40	37		4.0	S.W.	29.02	0.05		
	41	42	49	28	8.7	S.W.	29.32	0.09		67
5.	41	41	42			S.W.	28.70	0.03		
	41	42	44			S.W.	29.00	0.04		63
6.	41	40	41			S.E.	28.49	0.03		
	41	44	45		4	S.E.	28.79	0.02		88
7.	41	40	33		9	N.W.	28.73	0.02		
	41	40	20		12.9	N.W.	29.03	Ice.	0.75	95
8.			20		1.7	N.W.	29.03			
			29	26	5.6	N.W.	29.33			87
9.			22		1.7	N.W.	29.10			
			14	27	6.2	N.W.	29.40			72
10.			10		2.4	N.W.	29.08			
			18	11	2.5	N.W.	29.38			
11.			26		2.5	S.	28.70			
			33	24	5.0	S.	29.00		0.05	84
12.			30		4.3	S.W.	28.66			
			35	33	5.0	S.	28.96			95
13.			25		5.2	W.	28.85			
			24	27	9.1	N.W.	29.15			87
14.			14		5.5	S.	29.13			
			25	21	3.0	S.W.	29.43			96
15.			32		2.6	W.	28.95			
			35	28	9.2	W.	29.25			100
16.			36		3.9	S.W.	28.64			
				55	6.1	S.	28.94			91
17.			41		2.5	S.	28.60			
			46	40	3.8	S.W.	28.90			80
18.			25		6.5	N.W.	28.85			
			28	30	6.1	W.	29.15			88
19.			36		2.7	S.W.	28.55			
			28	29	10.1	W.	28.85			85
20.			35		3.0	S.W.	28.58			
			39	34	7.3	S.W.	28.88			79
21.			38		1.3	Calm	28.48	0.03		
			33	35	7.2	N.W.	28.78	0.01	0.02	95
22.			27		11.4	N.W.	28.82			
			28	27	13.5	N.W.	29.12			89
23.			30		1.2	N.W.	28.92			
			35	32	3.3	N.	29.22		0.05	69
24.			34		9.4	S.E.	28.92			
			35	32	3.7	W.	29.22			72
25.			30		2.8	N.W.	28.82			
			30	24	7.5	N.W.	29.12			73
26.			24		3.4	N.W.	29.05			
			29	30	5.8	S.E.	29.35			76
27.			32		5.9	S.E.	29.02			
			37	35	4.2	S.E.	29.32			86
28.			36		2.3	S.E.	29.00			
			39	38	2.6	S.W.	29.30			96
29.			39		4.3	S.W.	28.94			
			36	35	4.9	S.W.	29.24		0.46	100
30.			33		4.2	N.W.	29.03			
			32	33	1.4	S.E.	29.33		0.02	95
Total.									1.35	
Average.				31.6					0.045	

Winnipeg River Power and Storage Investigations.

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.

DECEMBER, 1913.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Evapo- ration.	Rain.	Humi- dity.
	Lake.	Tank.	Air.	Mean Day.						
					Miles per hour.		Inches.	Inches.	Inches.	Per cent.
1			32		2.2	S.E.				
			32	32	1.3	N.W.	29.10			95
2			32		1.5	N.W.				
			32	33	2.7	W.	29.28			90
3			29		3.9	S.W.				
			35	31	3.9	S.W.	29.27			95
4			32		7.4	S.W.				
			41	37	5.0	S.W.	29.09			86
5			28		3.1	N.W.				
			35	34	1.5	N.W.	28.95			85
6			28		4.5	N.W.				
			20	24	17.0	N.W.	28.96			68
7						N.W.				
			12	12	5.3	N.W.	29.11			
8			22		4.1	S.W.				
			27	25	7.1	S.W.	28.95			94
9			29		2.9	S.W.				
			32	29	10.1	N.W.	28.81			89
10			23		6.0	N.W.				
			31	27	2.4	S.	28.92			88
11			27		2.8	S.W.				
			34	31	2.6	W.	28.75			89
12			22		2.5	S.E.				
			29	26	1.0	Calm	28.83			88
13			22		0.7	S.W.				
				26	4.5		28.88			86
14										
				19			29.05			
15			27			S.				
			28	27	4.2	S.E.	28.82			88
16			25		2.1	S.W.				
			35	30	10.0	S.W.	28.71			78
17			27		10.2	N.				
			25	25	7.4	N.	28.89			75
18			14		0.9	N.				
			25	19	4.7	N.E.	28.90			
19			12		3.3	N.				
			12	13	5.8	N.W.	28.81			
20			0		6.4	N.W.				
			12	8			28.73			
21			-1		6.3	N.W.				
			5	5	2.5	N.W.	28.82			
22			9		1.7	S.E.				
			17	12	2.2	S.E.	28.86			
23			18		3.2	S.E.				
			20	16	1.6	S.E.	28.78			
24			10		6.0	N.W.				
			3	5			28.92			
25			-9		4.0	S.E.				
				-2			29.01			
26			13		3.1	S.E.				
			11	10	2.2	E.	28.90			
27			10		1.5	N.E.				
			13	9	1.4	N.W.	28.97			
28			10		1.4	N.W.				
			19	10	7.2	S.	28.85			
29			16		10.0	N.W.				
			17	18	4.4	S.W.	28.82			
30			22		4.0	N.W.				
			17	20	2.9	N.	28.87			
31			9		3.1	S.				
			21	16	5.1	S.	28.75			
Total										
Average				20.2						

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keeewatin on the Lake of the Woods—Continued.

JANUARY, 1914.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Evapo- ration.	Rain.	Humi- dity.
	Lake.	Tank.	Air.	Mean Day.						
					Miles per hour.		Inches.	Inches.	Inches.	Per cent.
1	32		25	24	6.3	SW.				
2	32		23	21	2.8	S.				
3	32		13	14	1.2	N.				
4	32		8	9	2.7	N.				
5	32		18		3.3	N.				
6	32		27		1.0	SE.				
7	32		30		2.0	SE.				
8	32		23		3.2	S.				
9	32		7		1.7	SW.				
10	32		3		14.1	W.				
11	32		-8		8.2	W.				
12	32		-13		6.1	SE.				
13	32		9		2.3	SE.			0.42	
14	32		19		4.1	NW.				
15	32		18		2.6	N.				
16	32		17		3.1	N.				
17	32		18	15	4.0	N.				
18	32		30	22	3.7	SW.				
19	32		30	26	1.4	SW.				
20	32		4	5	1.8	SW.				
21	32		-8	-7	0.97	W.				
22	32		-7	-4	1.1	SE.				
23	32		4	-2	3.9	SE.				
24	32		-17	-16	1.1	SE.				
25	32		-9	-10	3.9	SE.				
26	32		2	-3	1.9	N.				
27	32		-2	-3	5.2	NE.				
28	32		20	5	6.0	NW.				
29	32		-9	-5	4.8	W.				
30	32		-9	2	3.7	S.				
31	32		2	-6	5.6	SE.				
Total					2.0	SE.			0.105	
Average	32				3.3	SW.			0.104	
					3.2	N.				
					1.4	SE.				
					3.2	N.				
					3.2	E.				
					8.8	SE.				
					5.0	W.				
					20.0	SE.				
					5.9	E.				
					2.4	W.				
					7.2	NW.				
					14.7	NW.			0.26	
									1.34	
									0.043	

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Kewatin on the Lake of the Woods. Continued.

FEBRUARY 1914.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Evapo- ration.	Ram.	Humi- dity.
	Lake.	Tank.	Air.	Mean Day.						
					Miles per hour.		Inches.	Inches.	Inches.	Per cent.
1.....			-10							
2.....			-10	5	1.4	NE.	28.75			
3.....			-14	10	6.6	NE.	28.75		0.11	
4.....			-4	-1	4.3	SW.	28.95			
5.....			-5	-4	2.5	SW.	29.05			
6.....			-2	-4	1.6	SW.	29.10			
7.....			-29	-20	1.7	W.	29.00			
8.....			-10	-20	0.8	W.	28.80			
9.....			-32	-20	7.0	W.	28.70			
10.....			-6	-20	1.5	SW.	28.75			
11.....			-7	-29	1.0	SW.	29.15			
12.....			-3	-29	0.9	SW.	29.40			
13.....			-20	-15	0.5	SE.	29.35			
14.....			-10	-15	5.4	W.	29.00			
15.....			-31	-22	5.5	W.	29.10			
16.....			-16	-22	6.3	W.	29.15			
17.....			-36	-23	7.0	W.	29.40			
18.....			-16	-20	1.9	SW.	29.35			
19.....			-14	-15	1.3	SW.	29.00			
20.....			-36	-15	3.5	SW.	29.10			
21.....			-6	-8	0.9	SE.	28.75			
22.....			-3	-8	3.3	E.	28.80		0.09	
23.....			2	-2	5.0	E.	28.85			
24.....			-17	-4	8.2	NE.	28.85			
25.....			-4	-5	6.7	NE.	29.00			
26.....			-1	-8	2.7	W.	28.85			
27.....			-18	-6	3.5	W.	28.75			
28.....			-4	-6	6.4	E.	28.80			
29.....			-22	-2	0.7	E.	28.85			
30.....			-8	-2	1.5	NE.	28.85			
31.....			-2	-4	1.3	W.	28.85			
1.....			1	-4	4.0	SW.	29.00			
2.....			-26	-12	14.7	SW.	28.85			
3.....			-3	-12	5.2	W.	28.75			
4.....			-20	-12	1.7	E.	28.20			
5.....			-20	-10	1.6	SE.	28.25			
6.....			11	0	2.7	W.	28.95			
7.....			-6	-10	1.8	W.	28.75			
8.....			-9	-10	3.0	SW.	28.20			
9.....			-26	-20	3.9	SW.	28.25			
10.....			-4	-20	2.7	W.	28.25			
11.....			-22	-6	1.8	SE.	28.95			
12.....			8	-6	3.0	SE.	28.75			
13.....			8	11	5.0	W.	28.90			
14.....			18	11	6.6	SE.	28.45			
15.....			20	20	3.1	SE.	28.70		0.22	
16.....			31	20	3.0	SE.	28.75			
17.....			22	24	3.4	SE.	28.90			
18.....			36	24	2.9	SE.	28.45			
19.....			31	32	5.4	SE.	28.70			
20.....			40	32	14.2	W.	28.70			
21.....			-1	2	14.0	W.	28.70			
Total.....									0.42	
Average.....				-1.6					0.015	

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.

MARCH, 1914.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind.	Direction Wind.	Baro- meter.	Evapo- ration.	Rain.	Humi- dity.
	Lake.	Tank.	Air.	Mean Day.						
1			-20		11.4	S.	28.72			
2			8	4	20.1	SE.	28.31			
3			20	21	6.9	SE.	28.42			
4			22	24	3.9	W.	28.04		0.09	
5			34	21	9.2	W.	28.21			
6			22	30	3.4	SE.	28.51		0.26	
7			35	28	5.9	E.	28.70			
8			30	20	4.0	NE.	29.05			
9			26	12	2.2	NE.	28.92			
10			0	10	2.2	NE.	29.27			
11			20	15	2.8	NE.	28.65			
12			25	12	2.0	NE.	28.52			
13			4	24	4.8	SE.	28.14			
14			25	32	6.4	SW.	28.28			
15			13	31	4.7	W.	27.82		0.01	
16			34	36	5.7	NW.	28.26			
17			26	16	3.5	NW.	28.63			
18			42	10	3.7	NW.	28.80			
19			20	7	4.1	S.	28.82			
20			40	12	2.8	S.	28.70			65
21			38	7	8.5	W.	28.89			
22			13	17	16.3	NW.	28.65			
23			20	22	18.8	NW.	28.26			70
24			8	23	4.2	NW.	28.28			
25			22	13	19.3	NW.	28.15			
26			2	14	3.4	N.	28.38			
27			18	14	3.0	N.	28.68			76
28			1	30	1.7	E.	28.48			89
29			18	32	1.7	SE.	29.15			91
30			9	32	1.7	SE.	28.76			77
31			27	33	1.4	NW.	28.34			73
Total			29		4.3	SE.			0.36	79
Average			35	19.6	2.8	N.			0.012	76

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.

APRIL, 1914.

Day.	TEMPERATURE, IN DEGREES FAHRENHEIT.				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Eva- poration.	Ran.	Humi- dity.
	Lake.	Tank.	Air.	Mean Day.						
					Miles per hour.		Inches.	Inches.	Inches.	Per cent.
1.....			36		1.4	N.				83
2.....	31		39	31	1.9	N.W.	28.64		0.23	84
3.....	31		28		5.5	N.W.				77
4.....	34		26	26	6.9	N.W.	28.70		0.08	88
5.....	34		20		5.9	N.W.				
6.....	34		29	22	7.8	N.W.	28.85			89
7.....	34		20		6.2	N.W.				
8.....	34		29	22	11.1	N.W.	28.80			85
9.....	34		32		5.0	N.W.				71
10.....	34		32	24	5.0	S.W.	28.65			79
11.....	34		32		3.7	W.				90
12.....	34		28	26	1.2	W.	28.57			77
13.....	34		10		4.9	N.W.				
14.....	34		26	14	6.8	N.W.	28.95		0.23	75
15.....	31		34		1.6	N.W.				
16.....	31		26	22	4.3	N.W.	28.90			84
17.....	35		41		4.2	N.W.				88
18.....	35		34	21	8.1	N.W.	28.40			81
19.....	34		34		5.2	N.W.				90
20.....	34		27	27	1.3	W.	27.97			65
21.....	32		20		8.1	N.W.				
22.....	32		49	26	1.1	N.W.	28.37			77
23.....	33		45		3.2	N.W.				
24.....	33		29	20	2.2	N.W.	28.70			
25.....	33		50	40	2.8	N.E.				89
26.....	35		35		2.7	N.W.				71
27.....	35		49	39	1.8	N.W.				82
28.....	35		43		2.0	N.W.	28.58			67
29.....	35		57	44	4.5	N.W.				78
30.....	35		42		4.1	N.W.	28.47			77
31.....	36		43		4.6	N.W.				
32.....	36		17	43	3.6	E.	28.62			85
33.....	36		49	45	2.6	N.W.				80
34.....	36		37		2.3	N.W.	28.60		0.05	80
35.....	36		30	34	5.6	N.W.				94
36.....	36		30		9.1	N.W.	28.17		0.29	
37.....	36		32	24	12.3	N.E.				
38.....	31		28		1.4	N.W.	28.65		0.87	90
39.....	31		38	31	10.3	N.W.				
40.....	35		36		1.8	N.W.	28.35	0.13		83
41.....	35		40	34	15.0	N.W.				56
42.....	35		32		3.1	N.W.	28.65	0.06	0.01	81
43.....	35		51	34	2.7	N.W.				96
44.....	36		39		4.4	N.W.	28.99	0.01		75
45.....	36		47	40	7.0	N.W.		0.01		92
46.....	36		45		4.4	N.W.	28.70	0.03		86
47.....	36		49	42	4.1	N.W.				89
48.....	36		41		1.4	N.W.	28.60	0.01	0.02	71
49.....	36		49	43	2.0	N.W.		0.02	0.01	85
50.....	36		53		2.0	N.W.	28.37	0.02	0.01	87
51.....	36		56	48		N.W.				75
52.....	37		36		5.1	N.W.	28.47	0.05		82
53.....	37		36	32	6.7	N.E.				73
54.....	35		30		10.0	N.E.	28.75	0.01		65
55.....	35		38	30	13.2	N.E.				89
56.....	35		36		7.5	N.W.	28.80			84
57.....	35		54	37	3.6	N.E.				91
58.....	35		44		4.2	N.E.	28.95	0.18		48
59.....	36		45	35	3.4	N.W.				69
60.....	36		45			N.W.	28.95	0.01		79
Total.....								0.54	1.79	
Average.....	34.7			32.1				0.054	0.060	

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.

MAY 1914.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind.	Direction Wind.	Baro- meter.	Evapo- ration.	Rain.	Humidi- ty.					
	Lake.	Tank.	Air.	Mean Day							Miles per hour.	Inches.	Inches.	Inches.	Per cent.
1			43		4.0			0.01	0.02	88.0					
			63	50	4.4	W.W.	28.65	0.02		51.0					
2			54		4.2	W.W.				76.0					
			64	52	2.6	W.W.	28.44			77.0					
3			51		3.0	W.W.									
			51	48	4.8	W.W.	28.35			94.0					
4			52		2.1	N.E.				94.0					
			67	56	1.8	N.E.	28.40			67.0					
5			58		3.8	W.W.									
			70	54	5.4	W.W.	28.40			77.0					
6			43		3.2	W.W.				92.0					
			42	40	6.5	N.E.	28.45			88.0					
7			46		3.8	W.W.				93.0					
			61	44	4.4	W.W.	28.70			57.0					
8					2.1	W.W.									
			60	44	7.0	W.W.	28.65			63.0					
9			56		4.5	W.W.									
			48	45	2.8	W.W.	28.40	0.02		77.0					
10															
			44	40	5.1	W.W.	28.75			79.0					
11					2.2	N.E.				78.5					
			44		4.0	N.E.	28.95								
12		38			2.2	N.E.				85.0					
			44	48	7.2	W.W.	29.00								
13			53		5.0	N.E.		0.08		75.0					
			55	44	5.3	N.E.	28.95	0.01		49.0					
14		40			2.6	N.E.		0.08		87.0					
			48	43	4.7	W.W.	29.00	0.01		62.0					
15		42			2.2	W.W.		0.02		63.0					
			52	44	2.2	W.W.	28.90	0.00		52.0					
16		42			3.6	N.W.		0.06		67.0					
			60	44	2.8	N.W.	28.80	0.00		15.0					
17		42								60.0					
			72	52	5.4	W.W.	28.75			60.0					
18		44			8.4	W.W.				73.0					
			63	58	5.7	W.W.	28.75		0.04	76.0					
19		42			6.2	W.W.			0.29	74.0					
			60	56	1.8	W.W.	28.70		0.25	72.0					
20		46			3.0	W.W.				83.0					
			46	54	2.4	W.W.	28.70			72.0					
21		48			2.0	W.W.			0.01	87.0					
			72	55	4.0	W.W.	28.70			77.0					
22		41			1.8	W.W.	28.75		0.04	87.0					
			46	49	1.8	W.W.				50.0					
23		43			9.5	W.W.	28.80	0.03	0.02	50.0					
			52	45	4.3	W.W.		0.06		49.0					
24		46			3.5	W.W.	28.72	0.02		67.0					
			50	45	3.6	N.E.		0.05		74.0					
25		48			4.8	W.W.	28.45			89.0					
			67	55	1.4	W.W.			0.38	53.0					
26		47			19.1	W.W.	28.20			84.0					
			77	60	15.0	W.W.				63.0					
27		47			12.2	W.W.	28.47	0.02		70.0					
			63	60	5.0	W.W.				54.0					
28		48			3.6	W.W.	28.78	0.02		73.0					
			74	58	2.5	W.W.				89.0					
29		50			6.8	W.W.	28.60	0.03	0.43	88.0					
			50	56	34.2	W.W.			0.72	52.0					
30		49			24.4	W.W.	28.57			58.0					
			52	55	4.8	W.W.		0.05		44.0					
31		49			4.8	W.W.	28.73	0.03							
			60	57	9.0	S.									
34		51													
			53	57			28.80								
Total								0.62	1.87						
Average		43.1		59.7				0.041	0.060						

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.

JUNE 1914

Day.	TEMPERATURE, IN DEGREES FAHRENHEIT.				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Eva- poration.	Rain.	Humi- dity.
	Lake.	Tank.	Air.	Mean Day.						
1	52	52	57.5		6.7					91
2	57	58	70.5	60	2.2		28.80	0.18		86
3	54	54	64.6	60	2.7					87
4	57	58	74.0	60	4.0		28.64	0.04		78
5	54	54	61.0	62	4.4				1.72	90
6	54	54	65.0	62	8.0		28.50	0.05		80
7	52	52	58.0	55	13.2			0.04		88
8	52	52	68.0	55	13.4	E.	28.65	0.03		67
9	55	56	53.0	56	13.3	E.		0.06		88
10	54	54	68.0	56	11.2	SE.	28.65	0.06		71
11			70.0	60	13.3					82
12		60	74.0	70	8.3	E.	28.45			81
13			77.0	70	6.2	SE.				74
14	64	62	67.0	76	4.7	SW.	28.42			63
15	64	64	79.0	76	3.6	SE.	28.87		0.42	75
16	58	59	63.0	76	6.6	SW.			1.25	79
17			76.0	64	7.7	SW.			1.12	84
18	57	57	66.0	64	10.4		28.54			59
19	60	61	72.0	63	14.0	W.		0.04		90
20	56	56	58.0	63	3.9	NW.	28.45	0.03		86
21			64.0	55	7.7	W.		0.04		88
22	57	57	61.0	55	4.7	W.	28.70	0.04	0.02	70
23	60	60	74.0	55	10.4	NW.		0.01		88
24	58	58	60.0	55	4.5	SE.	28.73	0.05		74
25	59	60	70.0	58	12.2	SW.		0.05		83
26	60	60	78.0	60	27.2	SW.	28.90	0.06		48
27	60	60	66.0	60	10.6	S.	28.94	0.02		46
28	59	58	63.0	60	3.3	S.		0.05		44
29	61	61	76.0	60	4.4	SW.	29.00	0.05		64
30	60	60	68.0	60	5.3	SW.		0.05		82
31	60	60	76.0	60	11.2	SW.	29.13	0.05		85
32	66	68	73.0	65	7.9	SW.		0.04		66
33	58	58	48.0	65	5.9	NE.	28.65			90
34	60	60	64.0	56	11.1	NE.		0.05		85
35	58	57	54.0	56	10.9	NE.	28.65	0.08		86
36			62.0	50	4.4	SW.		0.06		65
37	61		61.0	50			28.70			76
38	63	63	79.0	72	6.8	W.				63
39	66	66	71.0	72	8.7	NE.	28.70	0.05		90
40	64	64	73.0	62				0.08		57
41	62	62	61.0	62			28.85	0.03		61
42	63	63	70.0	60	5.0	S.		0.03	0.09	57
43	62	62	70.0	60	5.2	SW.	28.60	0.03	0.09	89
44			65.0	62	9.3	SW.		0.05		81
45	62	62	68.0	62			28.55			86
46	64	64	69.0	60	6.9	W.		0.12		85
47	61	61	62.0	60	12.3	NW.	28.85	0.08		85
48	63	63	65.0	54	6.4	S.		0.06		95
49	64	60	62.0	54	4.5	S.	28.85			79
50	64	63	74.0	56	2.4	SE.		0.06		55
51	61	61	61.0	56	10.3	SE.	28.76	0.26		74
52	62	62	66.0	62	12.8	E.		0.03		44
53	64	64	68.0	62	14.2	E.	28.65	0.09		89
54	63	63	66.0	58	3.3	S.		0.09		64
55	63	62	67.0	58			28.76	0.03		62
56	63	63	71.0	60	1.7	S.		0.05		64
57			65.0	60	3.7	NW.	28.85	0.09		71
58				58	2.7	SW.		0.03		64
59				58	1.7	SW.	28.75			
Total				58						
Average	59.9	59.9		60.3				2.46	4.67	
								0.061	0.456	

Table 51. — Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods — Continued.

JULY 1911.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Evapo- ration.	Rain.	Humid- ity.
	Lake.	Tank.	Air.	Mean Day.						
1.....	65	65	75	65	2.3	N.	28.53	0.16	0.02	78
2.....	66	66	68	64	5.5	N.W.	28.55	0.05		70
3.....	64	64	69	68	5.0	S.W.	28.45	0.02		85
4.....	68	70	73	68	2.9	W.	28.59	0.06	0.07	73
5.....	66	66	72	62	1.2	S.	28.52	0.00	0.01	77
6.....	73	73	78	70	2.9	S.S.	28.52	0.04		60
7.....	68	68	74	70	2.8	S.S.	28.52	0.04		78
8.....	73	70	78	70	6.1	S.S.	28.52	0.01		75
9.....	70	70	72	65	7.3	W.	28.35	0.00	0.01	86
10.....	67	67	67	68	12.7	W.W.	28.35	0.02		78
11.....	66	66	61	68	11.5	N.	28.75			70
12.....	68	68	66	64	5.1	N.N.	28.75			
13.....	69	69	71	76	2.8	S.	28.59	0.18		73
14.....	69	69	71	76	6.3	S.E.	28.59			
15.....	69	69	71	76	5.2	E.	28.53		0.33	86
16.....	69	69	70	68	5.7	S.W.	28.53	0.00		
17.....	69	70	73	68	4.8	S.W.	28.53	0.02	0.01	83
18.....	70	70	70	65	1.0	S.W.	28.53	0.06	0.03	81
19.....	70	70	69	65	6.8	E.	28.48	0.02		95
20.....	70	70	69	66	8.0	N.	28.48			
21.....	70	71	74	66	1.7	N.	28.41		1.05	95
22.....	73	74	80	70	10.6	N.	28.41	0.04	0.01	86
23.....	73	73	77	70	7.5	S.W.	28.52	0.05		79
24.....	75	76	79	70	4.7	S.W.	28.52	0.03		87
25.....	72	72	71	71	21.0	S.	28.43			
26.....	73	73	70	71	22.9	S.W.	28.43	0.10	0.46	100
27.....	69	69	61	58	8.7	W.	28.60	0.05		95
28.....	70	70	66	58	11.8	W.	28.60	0.00		94
29.....	68	68	49	55	11.5	N.	28.83	0.07	0.07	90
30.....	70	70	66	63	9.6	S.W.	28.15	0.01	0.19	100
31.....	68	58	63	63	3.5	S.W.	28.15	0.13	0.01	80
32.....	70	71	70	63	7.0	S.W.	28.57	0.09	0.00	79
33.....	70	70	65	64	4.7	S.W.	28.57	0.05	0.01	72
34.....	70	71	70	64	1.9		28.69	0.08		90
35.....	68	69	72	73	4.7	E.	28.69	0.01		75
36.....	76	77	84	73	1.9		28.60	0.02		84
37.....	71	71	75	76	3.9	S.	28.66	0.05		74
38.....	73	73	77	76	8.6	W.	28.66			79
39.....	69	69	65	66	5.2	W.	28.66	0.08	1.00	80
40.....	71	71	73	66	3.8		28.47	0.03		65
41.....	69	69	65	67	4.6	S.W.	28.47	0.03		85
42.....	68	69	65	67	3.3	S.W.	28.50			85
43.....	70	70	69	67	4.6	S.W.	28.50	0.09		81
44.....	73	73	74	71	2.3	S.W.	28.52	0.09	0.02	74
45.....	74	74	78	72	10.7	S.W.	28.52	0.06	0.02	87
46.....	73	73	79	72	13.9	S.W.	28.44	0.01	0.02	68
47.....	75	76	82	77	14.6	S.W.	28.44			87
48.....	74	74	82	77	7.5	S.S.	28.60	0.12	0.12	76
49.....	73	73	74	75	6.3	S.S.	28.60	0.01		80
50.....	76	76	83	75	9.5	S.	28.58	0.03	0.01	86
51.....	74	74	72	73	7.7	S.	28.58	0.09		49
52.....	73	73	77	73	7.7	S.W.	28.72	0.01		82
53.....	73	73	77	73	7.7	S.W.	28.72	0.02		74
54.....	73	73	65	64	6.4	S.	28.68	0.10		85
55.....	73	74	72	71	4.6	S.	28.68	0.04		86
56.....	72	72	68	72	3.2	S.W.	28.68	0.06	0.22	95
57.....	75	75	77	72	1.5	S.W.	28.56	0.01		96
58.....	71	71	62	72	6.0	W.	28.56	0.04		94
59.....	75	75	75	72	4.6	W.	28.65			100
Total.....								2.46	3.80	
Average.....	70.6	70.8		68.2				0.052	0.125	

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.

AUGUST 1914

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind  Miles per hour	Dire- tion Wind	Baro- meter.	Ex-pa- n-sion	Rain.	Humi- dity.
	Lake	Lank	Air	Mean Day						
1	74	73	71							
2	75	75	76		0.8	W	28.45	0.04	60	
3	76	76	76		4.1	NE		0.04	70	
4	71	74	70				28.64	0.06	48	
5	72	72	66		3.4	W		0.15	68	
6	75	75	82		10.4	NW	28.47	0.02	90	
7	77	77	83		1.9	SE			61	
8	72	72	67		4.5	NW	28.50	0.04		
9	72	72	72		9.3	NW		0.01	80	
10	71	71	62		12.0	NW	28.29	0.18	95	
11	72	72	68		6.1	NW		0.16	77	
12	69	69	62		1.2	SE	28.48	0.12	84	
13	73	73	78		1.3	SE		0.12	58	
14	71	71	68		6.1	SE	28.43	0.16	74	
15	71	71	70		5.8	W		0.08	60	
16	70	70	66		2.8	W	28.15	0.06	81	
17	71	71	66						71	
18	71	70	62		1.0	N	28.30	0.12	66	
19	71	71	64					0.08	90	
20	68	68	61		5.3	NW	28.51	0.12	74	
21	70	70	67		3.1	NW		0.05	79	
22	69	69	62		3.1	NW	28.68	0.06	75	
23	68	68	62		6.9	NW		0.08	75	
24	68	68	62		4.5	NW	28.57	0.06	79	
25	68	68	62		11.3	NW		0.02	59	
26	69	69	66		9.2	NW	28.51	0.09	50	
27	67	67	62		1.8	NW		0.09	84	
28	68	68	62		5.1	SE	28.52	0.06	71	
29	73	71	82		1.1	SE	28.41	0.02	89	
30	68	68	65		4.3	N		0.05	69	
1	69	70	79		3.8	N	28.28	0.07	48	
2	69	69	62		1.8	N		0.06	80	
3	72	72	75		1.2	N	28.46	0.06	85	
4	69	68	62		2.3	N		0.05	89	
5	72	72	72		2.3	N	28.61	0.05	89	
6	68	68	66		0.7	N		0.02	58	
7	70	70	69		5.4	NW	28.61	0.04	89	
8					2.9	NW		0.03	65	
9					2.4	N		0.05	80	
10					2.7	SE			43	
11	68	68	65					0.12		
12	68	68	60		9.6	N	28.55	0.07	85	
13	66	66	55					0.25	89	
14	66	61	50					0.15	83	
15	68	68	56		5.7	E	28.63	0.04	84	
16	64	61	52		4.4	NE		0.15	74	
17	64	61	52		6.5	NE	28.76	0.04	77	
18	64	61	52		9.5	NE		0.12	75	
19	65	65	54		5.2	NE	28.84	0.04	88	
20	64	64	59		4.0	NE		0.08	76	
21	61	64	51		0.2	NE	28.72	0.03	89	
22	64	64	62		1.2	E		0.03	88	
23	61	64	59		3.0	E	28.77	0.06	79	
24	64	64	61		0.8	W		0.09	89	
25	64	64	58		6.5	NW	28.54		79	
26	66	66	65		3.5	W		0.47	89	
27	64	64	59		1.5	W	28.28	0.04	90	
28	66	66	64					0.07	90	
29	64	64	62		5.1	N	28.43	0.03	89	
30	66	66	64					0.09	90	
31	64	64	62		5.1	N		0.04	89	
1	66	66	72		5.5	W	28.60	0.30	82	
Total								0.04		
Average	68.9	68.8						0.67	0.067	

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods. (Continued)

SEPTEMBER 1914

Day.	TEMPERATURE IN DEGREES FAHRENHEIT				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Evapo- ration.	Rain.	Humid- ity.
	Lake.	Foot.	Air.	Mer- cury						
				De- grees						
1	64	64	56	4.8	W	28.32	0.06		88	
2	62	62	52	4.9	W	28.34	0.03		88	
3	63	63	54	9.0	W	28.34	0.05	0.10	88	
4	60	60	48	11.1	NW	28.49	1.05		87	
5	63	63	64	12.6	NW	28.49	0.17		70	
6	63	63	52	4.4	W	28.52	0.06		88	
7	64	64	64	3.5	SE	28.34	0.05	0.14	77	
8	6	62	56	2.8	E	28.34	0.05	0.17	82	
9	6	60	55	9.4	E	28.50	0.14		74	
10	60	59	50	3.6	NE	28.05	0.16		82	
11	60	60	57	1.2	E	28.90	0.06		83	
12	59	58	55	2.6	E	28.75	0.06	0.06	94	
13	59	59	57	7.6	SE	28.87	0.17	0.54	84	
14	62	62	65	5.0	NW	28.54	0.08		76	
15	65	66	67	2.1	SE	28.71	0.02		81	
16	62	62	63	2.5	SE	28.60				
17				6.6	SE	28.57		0.87		
18				16.7	S	28.57				
19				10.2	W	28.82		0.92		
20				13.8	W	28.82			82	
21	60	60	56	1.9	SE	28.82			68	
22	62	62	59	8.5	SE	28.82			65	
23	60	60	59	11.5	W	28.83	0.01	0.05	88	
24	60	60	60	11.2	W	28.83	0.01	0.05	88	
25	59	59	52	1.5	SE	28.63	0.05	0.05	89	
26	63	63	66	8.0	SE	28.63	0.05	0.05	90	
27	59	59	59	9.7	SE	28.75		1.11		
28	61	61	64	7.4	SE	28.62		0.12		
29				9.2	W	28.41	0.05		87	
30				3.9	W	28.41	0.04		79	
31				1.8	W	28.44	0.07		84	
32	60	60	51	9.7	NW	28.48	0.06		69	
33	58	58	41	13.9	NW	28.54	0.01		82	
34	59	59	46	13.1	NW	28.54	0.01		70	
35	59	59	51	3.4	SE	28.3	0.06		58	
36	60	60	56	1.7	E	28.61	0.12		70	
37	56	56	41	8.4	SE	28.67	0.09		87	
38	57	57	59	8.1	SE	28.52	0.10		94	
39	56	56	53	2.4	SE	28.67	0.08		82	
40	59	59	61	5.5	SE	28.64			79	
41	58	58	55	3.7	SE	28.67			64	
42	60	60	63	3.0	NE	28.67				
43	62	62	62	10.5	SE	28.67	0.09			
44				14.2	SE	28.52	0.10			
45	58	58	54	4.5	SE	28.67	0.08			
46	58	58	55	5.0	NW	28.67				
47	58	58	55	3.1	NW	28.64				
48	57	57	56	4.4	SE					
49	60	60	65	1.8	SE					
Total.							3.01	4.07		
Average	60.3	60.2					0.097	0.136		

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.

OCTOBER 1914

Day	TEMPERATURE IN DEGREES FAHRENHEIT				Velocity Wind.	Direc- tion Wind	Baro- meter	Evapo- ration.	Rain.	Humi- dity
	Lake.	Tank	Air.	Mean Day						
1	57	57	58		5.0	SE		0.08		83
	58	58	70		8.0	SE.	28.47	0.06		77
2	60	60	64		6.3	S.		0.06		77
	61	61	68	65			28.42	0.08		74
3	59	59	64		7.4	SE.		0.08		75
	58	58	65	66	10.7	S.	28.25	0.06		75
4	60	60	61		10.1	SE.		0.06		79
	62	62	69	65			28.21	0.02		72
5	60	62	64		4.6	SE.		0.00		85
	59	58	58	58	6.4	S.	28.50	0.08	0.32	83
6	58	58	51		0.4	E.		0.04	0.03	94
				55	2.1	S.	28.07			
7	58	58	44		2.0	NE.		0.06		71
				54			28.55			
8	57	57	48		4.3	E.		0.08		
				52			28.47			
9	58	58	57		4.0	W.			0.07	94
				53			28.37			
10	56	56	50		5.1	SW.		0.01	0.55	87
	58	58	48		8.4	SW.	28.30	0.28	1.64	87
11	56	56	42		4.8	NW.		0.05	0.11	85
	56	56	42				28.48	0.02	0.16	92
12	54	54	36		9.8	NE.		0.02		91
	54	54	36	40	6.3	NE.	28.86	0.10		91
13	54	54	40		1.7	NE.		0.04		76
	56	56	48	49	1.3	NE.	29.20	0.02		87
14	51	54	41		5.5	SW.		0.10		85
	54	54	52	47	6.1	S.	28.70	0.01		88
15	54	54	46		6.1	S.		0.06		93
	56	56	56	53	5.5	E.	28.54	0.02		77
16	54	54	52		5.6	SW.		0.04		88
	56	56	62	51	7.4	SW.	28.32	0.05		89
17	54	54	44		2.0	NE.		0.04		93
	56	56	58	54	3.7	E.	28.33			89
18	56	56	56		11.5	SE.		0.04		82
				57			28.18			
19	51	51	54		10.2	SW.		0.02		88
	56	56	58	56	5.1	SW.	28.16	0.02		77
20	54	54	54		2.4	SW.		0.04		88
	56	56	62	58	9.2	SW.	28.01	0.02		84
21	56	56	46		3.8	N.		0.02		86
	56	56	58	52	2.1	E.	28.73	0.02		83
22	54	54	54		8.4	SE.		0.04		88
	56	56	60	55	9.6	SE.	28.65	0.02		89
23	54	54	42		11.6	N.		0.08	0.20	92
	54	54	48	49	14.1	NW.	28.73	0.04		83
24	52	52	42		4.8	SW.		0.04	0.01	92
	52	52	50	46	13.5	W.	28.71	0.06		87
25	50	50	38		10.6	NW.		0.04	0.02	92
				40			28.53	0.02		83
26	46	46	20		15.1	NW.		0.08		85
	46	46	30	24	11.1	NW.	28.84	0.06		89
27	48	48	34		8.1	W.		0.14		83
	48	48	41	35	12.9	W.	28.43	0.06		85
28	48	48	38		7.0	N.		0.04		83
	48	48	42	40	6.7	NW.	28.34	0.04		85
29	48	48	38		8.6	W.		0.06		91
	48	48	48	43	11.2	NW.	28.49	0.04		87
30	48	48	42		1.8	S.		0.04		92
	48	48	54	45	5.2	S.		0.04		82
31	48	48	46		3.5	S.		0.04		93
	50	50	52	53	4.8	S.				
Total										
Average	51.7	54.1		49.8						

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Continued.


NOVEMBER, 1914.

Day.	TEMPERATURE IN DEGREES FAHRENHEIT.				Velocity Wind.	Dire- ction Wind.	Baro- meter.	Eva-pora- tion.	Ram.	Hami- dity.
	Lake.	Tank.	Air.	Mean Day.						
1.	48	48	40		8.0	N.		0.01	0.01	84
	48	48	40	43			28.36	0.01		76
2.	47	48	40		9.2	SE.		0.08		88
	46	46	40	41	14.5	SE.	28.37	0.01		89
3.	47	47	41		7.3	W.		0.04		85
	48	48	45	44	10.3	NW.	28.05	0.05	0.02	79
4.	46	46	35		12.4	NW.		0.03	0.49	91
	47	46	36	36	16.7	NW.	28.51	0.03	0.03	91
5.	46	46	32	31	8.5	N.				
	46	44	33	35	2.9	NW.	28.58	0.14		74
6.	46	44	33	35	4.5	E.				
7.	45	44	32	31	12.8	NW.		0.01		52
	44	44	38	38	3.6	W.	28.53	0.10		79
8.	41	44	35	35	11.6	W.		0.06	0.01	71
	43	42	33			SE.	28.55	0.03	0.02	95
9.	43	42	33		5.0	SE.		0.02		95
10.	43	42	34	37	10.4	W.	28.25	0.06		90
	44	44	41	38	10.5	W.		0.02		62
11.	42	44	22		11.2	NW.	28.31	0.05		62
	41	40	28	27	7.3	NW.	28.62			93
12.	46	32	15		6.9	E.				41
	38	37	25	22	5.8	E.	28.60	0.48		50
13.	38	36	27		3.9	W.				82
	36	34	26	26	4.3	W.	28.48	0.02		82
14.	34	33	22		10.4	E.				79
15.				24			28.25			
16.			12	25	8.6	NW.	28.36		0.01	
	32		9	16	15.3	NW.				
17.	32				14.4	NW.	28.59			
			4	2	9.9	W.				
18.	34		8		9.9	NW.	28.68			
	33		1	5	8.9	N.				
19.	33		10		16.2	NW.	28.71		0.01	
	34		12	8	9.3	W.				
20.	34		20		2.9	S.	28.15			
	34		21	22	3.9	W.	28.26			94
21.	34		23		9.4	NW.				
	34		8	19	16.2	NW.	28.51			85
22.	33		13	12	8.4					
			22		2.1		28.75			
23.			31	26	5.7	N.				
			23		6.2	NW.	28.49			100
24.	34			32	6.6	NW.				59
	34		30		9.1	NW.	28.49			95
25.	31		39.5	35	2.2	NW.				92
	31		36.0		9.4	NW.	28.17			
26.	33		19.0	30	15.9	N.	28.32			100
	33		9.5		4.6	N.				
27.	33		23.0	17	5.1	S.	28.69			100
	33		27.0		6.9	S.				
28.	33		39.5	35	8.9	S.	28.35			88
	31		11.0							80
29.	31		36.5	38			28.32			81
	31		36.0		5.0	N.				91
30.	34		33.0	37	6.1	N.	28.48			76
Total									0.31	
Average	39.3			27.7					0.010	

Table 51.—Meteorological Data secured in connection with the evaporation station established by the Dominion Water Power Branch at Keewatin on the Lake of the Woods—Concluded.

DECEMBER, 1914.

Day.	TEMPERATURE IN DEGREES FAHRENHEID.				Velocity Wind.	Direc- tion Wind.	Baro- meter.	Evapo- ration.	Ram.	Humidi- ty.
	Lake.	Fank.	Air.	Mean Day.						
1			33		7.2	E.				95
2	34		23	29.0	5.9	W.	28.13	0.10		73
3			18		7.4	NW.				92
4			19	20.0			28.50	0.10		77
5	31		22	26.0	6.2	S.				
6					6.5	SE.	28.78			
7	32		28	27.0	4.7	SE.	28.76			100
8			22	28.0	13.9	SE.				100
9			28		4.4	SE.	28.84			
10			22	28.0			28.89			94
11	33		29	27.0			29.03			87
12			20							
13			16	17.0	11.1	SE.	29.12			
14			4		4.9	SE.				
15			8	6.0	6.1	SE.	29.15			
16	32		1		1.1	SE.				
17			15	9.5	1.9	SE.	28.88			
18	32		13		1.8	SE.				
19			15	10.0	3.0	SE.	28.58			
20	33		4			W.				
21			10	7.0	1.0	W.	28.12			
22			-12							
23			-11	-3.0	1.1	W.	28.59			
24			-20		2.1					
25			-12	-12.0	21.9	W.	28.61			
26			-19							
27			-8	-12.0			28.86			
28			-2							
29			0	-1.0			28.71			
30			2							
31			13	6.0			28.33			
32			12							
33			13	13.0			28.21			
34			13							
35			9	10.0			28.48			
36			10							
37			14	7.0			28.41	0.20		
38			22	11.0			28.29			
39			1							
40			-22	-18.0			28.48			
41			-19							
42			15	15.0			28.55			
43			-28	-28.0			28.70			
44			-21							
45			-7	-11.0			28.75			
46			-8							
47			3	-4.0			28.12			
48			0							
49			7	3.0			28.68			
50			9	3.0			28.28			
51			-9							
52			-7	-6.0			28.67			
53			-20							
54			-14	-14.0			28.32			
55			7							
56			13	8.0			28.30			
Total								0.40		
Average				4.33				0.013		



REPORT  
ON  
THE WINNIPEG RIVER POWER AND  
STORAGE INVESTIGATIONS

---

APPENDIX VII.  
RUN-OFF TABLES



## APPENDIX VII.

### RUN-OFF OF THE WINNIPEG RIVER WATERSHED.

#### TABLES 52 TO 69.

Data in tables 52 to 69 have been obtained by the field officers of the Dominion Water Power Branch, with the exception of the Fort Frances records, which have been supplied through the courtesy of the Dominion Department of Public Works, and of the Water Resources Branch of the United States Geological Survey.

#### WINNIPEG RIVER AT POINT DU BOIS.

*Location of Gauge.*—At the bay in tail-race of the city of Winnipeg's power plant on the Winnipeg river at Point du Bois.

*Records available.*—January 23, 1907, to December 31, 1914.

*Drainage areas.*—To Slave falls, 49,700 square miles. To Otter falls, 50,550 square miles.

*Gauge.*—Vertical staff, rock bolted to granite ledge, datum unchanged since established.

*Discharge Measurements.*—From 1907 to 1910, discharge measurements were made at Otter falls by Pratt & Ross for the Winnipeg Electric Street Railway Company; and by the engineers of the city of Winnipeg at the Barrier. In both cases the measurements have been referred to the gauge at Point du Bois, Otter falls and the Barrier being respectively 20 and 12 miles below same. Daily discharges based on Point du Bois gauge have been computed for Otter falls from the above measurements.

In October, 1911, a gauging station was established by the Manitoba Hydrographic Survey above Slave falls, which is some 6 miles below Point du Bois. At this station, a staff gauge and cable equipment were installed, and continuous discharge measurements have been made.

During the season of 1912, when a detailed survey of Slave falls was made by the Manitoba Hydrographic Survey, continuous gauge readings were recorded at Point du Bois and Slave falls. These were checked by a gauge installed midway between Slave and Eight Foot falls, the latter falls being the only break in the river between Slave falls and Point du Bois. By these records, comparison was made with the discharges obtained by using the gauge heights at Point du Bois, and it was found that for a period of a month the results were the same.

*Regulation.*—From October, 1911, the operation of the power plant at Point du Bois has caused a daily fluctuation in gauge height, but, as noted above, these fluctuations have in the past compensated in a month or less. Continuous gauge readings in 1913 have shown that a single discharge from daily gauge readings may vary one or two per cent from the mean of the days continuous readings. An automatic gauge is now being installed at the meter section at Slave falls in order to eliminate errors from this variation.

In the winter of 1910-11, a cut was made through Eight Foot falls, to reduce tail-race level at Point du Bois during high discharge. On account of this, the discharge curve for Otter falls is not applicable later than June, 1911.

*Winter Flow.*—The bay on which the gauge is located is open throughout the winter, and is controlled by Eight Foot falls, 1 mile below; the metering station also has an open discharge. Because of this the open-water rating curve has been used in computing the winter flow, though it may give discharges 5 to 10 per cent high during January and February of previous years.

Table 52.—Discharge Measurements of Winnipeg River at Otter and Slave Falls, Manitoba.

Date.	Hydrographer.	Meter No.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
			Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec. ft.
1906							
Mar. 7	Col. Ruttan.....					160.5	19,876 <sup>1</sup>
Sept. 15	J. B. Challies.....						25,433 <sup>2</sup>
1907							
Aug. 1	Pratt and Ross for Winnipeg Street Railway.....					162.2	31,047 <sup>3</sup>
Aug. 2	" ".....					162.2	30,600 <sup>4</sup>
Oct. 31	" ".....					164.2	41,300 <sup>5</sup>
1908							
July 14	Pratt and Ross for Street Railway Co.....					164.2	43,000 <sup>6</sup>
Nov. 7	" ".....					162.0	28,700 <sup>6</sup>
1909							
May 24	Pratt and Ross for Winnipeg Street Railway.....					161.0	26,360 <sup>6</sup>
July 17	" ".....					161.25	26,000 <sup>6</sup>
Oct. 8	" ".....					160.70	22,500 <sup>6</sup>
Nov. 8	" ".....					160.55	21,770 <sup>6</sup>
1910							
July 28	Pratt and Ross for Street Railway Co.....					162.25	29,375 <sup>6</sup>
1911							
Feb. 4, 6, 7,	Stamford for City of Winnipeg.....		280.5	5,475	2.26	159.26	12,375 <sup>6</sup>
Feb. 13, 14, 15,	" ".....			5,691	2.28	159.26	13,256 <sup>6</sup>
May 7	Pratt and Ross for Street Railway.....					159.42	13,450 <sup>7</sup>
May 19	" ".....					159.87	15,800 <sup>7</sup>
Oct. 13,	A. M. Beale for Water Power Survey.....	3	269	7,272	3.59	161.80	26,115 <sup>8</sup>
Oct. 29	" ".....	1	269	7,218	3.68	161.70	26,391 <sup>8</sup>
Dec. 6, 7, 8, 9,	A. M. Beale and Alex Pirie.....	1	610	21,910	1.10	160.68	24,145 <sup>9</sup>
Dec. 6, 7, 8, 9,	" ".....	1	610	21,910	1.11	160.68	24,320 <sup>10</sup>

<sup>1</sup>Just above falls at Point du Bois. One foot ice cover. Gauge height approximated.

<sup>2</sup>Float measurement.

<sup>3</sup>Below diversion dam and Pinawa channel. Two channels measured.

<sup>4</sup>Barrier chute.

<sup>5</sup>Otter Falls.

<sup>6</sup>At city meter station 10 miles below Pointe du Bois, Man., section, ice cover; check measurements.

<sup>7</sup>Otter Falls, ice measurement.

<sup>8</sup>Slave Falls.

<sup>9</sup>One and a half miles above Grand du Bonnet Falls. 0.2 and 0.8 method under ice.

<sup>10</sup>One and a half miles above Grand du Bonnet Falls. Vert. vel. curve method under ice.

NOTE.—All measurements for years 1912-13-14 are at Slave Falls.

Table 52.—Discharge Measurements of Winnipeg River at Otter and Slave Falls, Manitoba—Continued.

Date.	Hydrographer.	Meter No.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
			Feet.	Sq. ft.	Fr. per sec.	feet.	Sq. ft.
1912.							
May 8	A. M. Beale	4,197	260	6,761	2.41	160.52	19,675
May 14	G. H. Burnham	1,197	261	7,034	3.26	161.20	22,865
May 28	A. M. Beale	1,197	273	7,366	4.65	161.88	26,887
June 4	E. B. Patterson	4,196	261	7,542	3.85	162.15	28,046
June 6	G. H. Burnham	4,487	277	7,565	3.95	162.50	29,882
June 10	E. B. Patterson	1,497	277	7,546	3.92	162.25	29,543
June 17	W. H. Richardson	1,197	273	7,139	3.80	162.09	28,207
June 24	"	1,197	272	7,396	3.67	161.90	27,111
July 6	"	1,197	272	7,338	3.56	161.75	25,780
July 8	"	1,197	271	7,237	3.55	161.78	25,692
July 14	"	1,497	274	7,446	3.54	161.76	26,358
July 15	"	4,197	271	7,446	3.58	161.77	26,656
July 16	"	1,197	272	7,473	3.60	161.79	26,901
July 17	"	1,197	271	7,473	3.54	161.80	26,453
July 18	"	1,497	271	7,416	3.52	161.78	26,209
July 19	"	4,197	274	7,473	3.55	161.75	26,528
July 20	"	1,197	274	7,473	3.55	161.76	26,528
Aug. 20	Alex. Pirie	1,197	272	7,369	3.74	161.98	27,560
Oct. 23	"	1,197	293	7,934	4.46	163.28	31,628
Nov. 21	"	4,462	291	7,785	3.95	162.85	30,761
Dec. 31	"	1,162	274	7,430	3.64	162.40	27,095
1913.							
Mar. 5	A. Pirie	4,469	268	6,717	2.85	160.65	19,110
May 1	"	1,186	266	6,943	3.40	160.89	22,912
June 24	S. C. O'Grady	285	281	7,850	4.16	162.96	31,998
July 18	A. Hamington	285	277	7,522	4.03	162.11	30,290
Oct. 1	C. O. Allen	1,435	264	7,268	2.96	161.03	21,513
Nov. 5	"	1,435	256	6,535	2.54	159.92	16,600
1914.							
Jan. 13	E. B. Patterson	1,497	255	6,119	2.47	159.3	13,268
Feb. 11	C. O. Allen	1,497	254	5,954	2.00	159.53	11,922 <sup>1)</sup>
April 8	"	1,197	255	6,169	2.46	159.60	14,584
May 6	G. J. Lamb	1,475	257	6,517	2.59	159.88	16,876
May 18	"	1,475	260	6,681	2.81	160.15	18,774
May 24	"	1,475	262	6,781	2.95	160.60	20,004
June 4	A. Pirie	1,939	274	7,481	3.85	162.12	28,829
June 5	"	1,939	274	7,480	3.85	162.12	28,829
June 9	"	1,939	280	7,775	4.18	162.62	32,501
June 10	"	1,939	280	7,775	4.24	162.72	32,948
June 11	"	1,939	280	7,788	4.27	162.77	33,106
June 13	"	1,939	281	7,820	4.29	162.82	33,615
June 15	"	1,939	281	7,820	4.40	162.95	33,648
June 22	"	1,939	290	7,917	4.48	163.10	34,713
June 23	"	1,939	282	7,877	4.42	163.12	34,340
June 24	"	1,939	284	7,896	4.46	163.17	34,478
June 26	"	1,939	293	7,951	4.45	163.12	35,391
June 29	"	1,939	293	7,963	4.45	163.27	35,459
June 30	"	1,939	294	7,994	4.46	163.32	35,683
July 3	"	1,939	294	8,023	4.52	163.35	36,466
July 7	"	1,939	294	7,965	4.49	163.37	35,672
July 13	"	1,939	295	8,063	4.53	163.38	36,561
July 14	"	1,939	295	8,063	4.55	163.40	36,759
July 15	"	1,939	295	8,063	4.55	163.40	36,690
July 18	"	1,939	295	8,063	4.50	163.35	36,410
July 22	"	1,939	293	8,038	4.50	163.35	36,173
July 23	"	1,939	293	8,038	4.55	163.40	36,605
July 24	"	1,939	291	8,048	4.57	163.42	36,381
July 24	"	1,939	294	8,034	4.55	163.40	36,591
July 25	"	1,939	293	8,034	4.23	163.36	33,455
July 28	"	1,939	293	8,001	4.44	163.28	35,529
July 29	"	1,939	293	7,980	4.52	163.30	36,116
July 30	"	1,939	292	7,960	4.45	163.28	35,129
July 31	"	1,939	292	7,942	4.41	163.15	34,957
Aug. 1	"	1,939	292	7,942	4.48	163.11	34,744
Aug. 3	"	1,939	292	7,942	4.44	163.08	34,468
Aug. 4	"	1,939	294	7,896	4.42	163.14	34,115
Aug. 5	"	1,939	284	7,834	4.40	163.06	33,699
Aug. 6	"	1,939	281	7,834	4.27	163.01	33,416
Sept. 13	"	1,939	272	7,322	3.88	161.57	26,282
Sept. 14	"	1,939	271	7,292	3.55	161.67	25,942
Sept. 44	"	1,939	271	7,292	3.57	161.70	26,049
Sept. 15	"	1,939	271	7,292	3.54	161.62	25,834

<sup>1)</sup>Partial ice cover.

Table 52.—Discharge Measurements of Winnipeg River at Otter and Slave Falls, Manitoba—Concluded.

Date.	Hydrographer.	Meter No.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
			Fect.	Sq.-ft.	Ft. per sec.	Fect.	Sec. ft.
1911.							
Sept. 16	"	1,939	269	7,260	3.38	161-62	24,608
Sept. 17	"	1,939	269	7,234	3.51	161-65	25,416
Sept. 18	"	1,939	269	7,234	3.47	161-57	25,108
Sept. 19	"	1,939	269	7,208	3.45	161-52	24,938
Sept. 22	"	1,939	269	7,234	3.49	161-67	25,223
Sept. 23	"	1,939	269	7,260	3.53	161-67	25,597
Sept. 24	"	1,939	269	7,234	3.51	161-65	25,376
Sept. 25	"	1,939	269	7,234	3.50	161-62	25,301
Sept. 28	"	1,939	269	7,260	3.50	161-62	25,388
Sept. 29	"	1,939	269	7,234	3.44	161-66	24,911
Sept. 30	"	1,939	269	7,234	3.46	161-57	25,048
Oct. 1	"	1,939	269	7,207	3.44	161-60	24,801
Oct. 2	"	1,939	269	7,207	3.43	161-50	24,705
Oct. 7	"	1,939	269	7,207	3.43	161-57	24,639
Oct. 8	"	1,939	269	7,207	3.41	161-55	24,574
Oct. 26	"	1,760	265	7,088	3.32	161-32	23,533
Oct. 28	"	1,760	264	7,061	3.24	161-12	22,877
Oct. 29	"	1,760	263	7,031	3.21	161-07	22,570
Oct. 30	"	1,760	263	7,031	3.21	161-12	22,570
Oct. 31	"	1,760	262	7,001	3.19	161-07	22,333
Nov. 2	"	1,760	262	7,001	3.21	161-12	22,472
Nov. 3	"	1,760	261	6,974	3.15	160-95	21,967
Nov. 5	"	1,760	261	6,948	3.14	160-92	21,817
Nov. 6	"	1,760	261	6,948	3.14	160-87	21,817
Nov. 7	"	1,760	261	6,921	3.05	160-85	21,109
Nov. 9	"	1,760	261	6,974	3.20	161-05	22,317
Nov. 10	"	1,760	260	6,893	3.03	160-80	20,886
Nov. 11	"	1,760	260	6,893	3.02	160-77	20,817
Nov. 13	"	1,760	259	6,892	3.01	160-95	20,745
Nov. 19	"	1,760	259	6,865	2.98	160-77	20,358
Nov. 20	"	1,760	259	6,865	2.98	160-77	20,358
Nov. 21	"	1,760	258	6,813	2.98	160-72	20,303
Nov. 23	"	1,760	259	6,865	3.01	160-77	20,664
Nov. 24	"	1,760	259	6,849	2.96	160-80	20,243
Nov. 25	"	1,760	259	6,849	2.98	160-77	20,380
Nov. 27	"	1,760	258	6,813	2.97	160-72	20,235
Nov. 28	"	1,760	258	6,813	2.96	160-70	20,166
Nov. 30	"	1,760	259	6,849	2.98	160-75	20,380
Dec. 2	"	1,760	259	6,849	2.98	160-77	20,380
Dec. 4	"	1,760	259	6,813	2.97	160-80	20,235
Dec. 5	"	1,760	259	6,813	2.96	160-75	20,166
Dec. 9	"	1,760	258	6,787	2.89	160-65	19,614
Dec. 10	"	1,760	259	6,787	2.89	160-67	19,614

Table 53.—Daily Discharge of the Winnipeg River at Otter Falls in Manitoba.

[Drainage area, 50,550 square mile.]

1907.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge.										
	Feet.	Sec.-ft.										
1			61.80	27,860	60.4	19,180	60.0	16,700	59.6	14,400	60.8	21,660
2			61.75	27,550	60.4	19,180	59.9	16,100	59.7	14,950	60.8	21,660
3			61.75	27,550	60.3	18,560	59.8	15,500	59.6	14,400	60.8	21,660
4			61.80	27,860	60.2	17,940	59.7	14,950	59.6	14,400	60.8	21,660
5			62.0	29,100	60.3	18,560	59.6	14,400	59.6	14,400	60.9	22,280
6			62.0	29,100	60.4	19,180	59.6	14,400	59.6	14,400	61.0	22,900
7			61.8	27,860	60.3	18,560	59.6	14,400	59.7	14,950	61.2	23,140
8			61.6	26,620	60.1	19,180	59.6	14,400	59.8	15,500	61.2	23,140
9			61.2	24,140	60.2	17,940	59.6	14,400	59.7	14,950	61.2	23,140
10			61.2	24,140	60.1	17,320	59.6	14,400	59.7	14,950	61.2	23,140
11			61.2	24,140	60.0	16,700	59.6	14,400	59.7	14,950	61.4	25,380
12			61.2	24,140	60.2	17,940	59.6	14,400	59.7	14,950	61.6	26,620
13			60.6	20,420	60.2	17,940	59.6	14,400	59.7	14,950	61.8	27,860
14			60.8	21,660	60.2	17,940	59.6	14,400	59.7	14,950	61.8	27,860
15			60.4	19,180	60.3	18,560	59.6	14,400	59.7	14,950	62.0	29,100
16			60.4	19,180	60.1	17,320	59.6	14,400	59.7	14,950	62.0	29,100
17			60.4	19,180	60.1	17,320	59.6	14,400	59.7	14,950	62.0	29,100
18			60.3	18,560	60.1	17,320	59.6	14,400	59.8	15,500	62.2	30,340
19			60.6	20,420	60.1	17,320	59.6	14,400	60.0	16,700	62.2	30,340
20			60.5	19,800	60.1	17,320	59.6	14,400	60.1	17,320	62.2	30,340
21			60.6	20,420	60.0	16,700	59.6	14,400	60.1	17,320	62.3	30,960
22			60.4	19,180	59.9	16,100	59.6	14,400	60.2	17,940	62.3	31,580
23	61.5	26,000	60.4	19,180	59.9	16,100	59.6	14,400	60.2	17,940	62.5	32,200
24	61.5	26,000	60.5	19,800	59.8	15,500	59.6	14,400	60.1	17,320	62.6	32,820
25	61.5	26,000	60.6	20,420	59.8	15,500	59.6	14,400	60.1	17,320	62.6	32,820
26	61.5	26,000	60.8	21,660	59.8	15,500	59.6	14,400	60.2	17,940	62.6	32,820
27		26,700	60.7	21,040	59.8	15,500	59.6	14,400	60.3	18,560	62.6	32,820
28		27,400	60.6	20,420	59.8	15,500	59.6	14,400	60.4	19,180	62.7	33,440
29	61.85	28,170			59.9	16,100	59.6	14,400	60.5	19,800	62.7	33,440
30	61.85	28,170			60.0	16,700	59.6	14,400	60.5	19,800	62.7	33,440
31	61.85	28,170			60.0	16,700			60.6	20,420		

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge.										
1	62.7	33,440	62.2	30,340	62.9	34,680	63.6	39,020	64.2	42,740	64.2	42,740
2	62.8	34,060	62.3	30,960	63.0	35,300	63.6	39,020	64.2	42,740	64.2	42,740
3	62.8	34,060	62.2	30,340	63.0	35,300	63.8	40,260	64.2	42,740	64.2	42,740
4	62.7	33,440	62.2	30,340	63.0	35,300	63.8	40,260	64.2	42,740	64.2	42,740
5	62.8	34,060	62.2	30,340	63.0	35,300	64.0	41,500	64.2	42,740	64.1	42,120
6	62.7	33,440	62.2	30,340	63.1	35,920	64.2	42,740	64.2	42,740	64.1	42,120
7	62.8	34,060	62.2	30,340	63.2	36,540	64.2	42,740	64.2	42,740	64.0	41,500
8	62.7	33,440	62.2	30,340	63.2	36,540	64.2	42,740	64.2	42,740	64.0	41,500
9	62.6	32,820	62.2	30,340	63.2	36,540	64.2	42,740	64.2	42,740	64.0	41,500
10	62.5	32,200	62.2	30,340	63.2	36,540	64.2	42,740	64.2	42,740	64.0	41,500
11	62.5	32,200	62.2	30,340	63.2	36,540	64.2	42,740	64.2	42,740	63.8	40,260
12	62.5	32,200	62.2	30,340	63.2	36,540	64.2	42,740	64.2	42,740	63.8	40,260
13	62.4	31,580	62.2	30,340	63.2	36,540	64.3	43,360	64.2	42,740	63.8	40,260
14	62.4	31,580	62.2	30,340	63.3	37,160	64.2	42,740	64.2	42,740	63.7	39,640
15	62.4	31,580	62.2	30,340	63.4	37,780	64.2	42,740	64.2	42,740	63.6	39,020
16	62.4	31,580	62.2	30,340	63.4	37,780	64.2	42,740	64.2	42,740	63.6	39,020
17	62.4	31,580	62.2	30,340	63.4	37,780	64.2	42,740	64.2	42,740	63.6	39,020
18	62.4	31,580	62.2	30,340	63.4	37,780	64.2	42,740	64.2	42,740	63.6	39,020
19	62.4	31,580	62.2	30,340	63.4	37,780	64.2	42,740	64.2	42,740	63.6	39,020
20	62.4	31,580	62.4	31,580	63.4	37,780	64.2	42,740	64.2	42,740	63.5	38,400
21	62.4	31,580	62.6	32,820	63.4	37,780	64.3	43,360	64.2	42,740	63.4	37,780
22	62.4	31,580	62.6	32,820	63.4	37,780	64.4	43,980	64.2	42,740	63.4	37,780
23	62.4	31,580	62.6	32,820	63.4	37,780	64.3	43,360	64.2	42,740	63.4	37,780
24	62.4	31,580	62.6	32,820	63.4	37,780	64.3	43,360	64.2	42,740	63.4	37,780
25	62.4	31,580	62.6	32,820	63.4	37,780	64.3	43,360	64.2	42,740	63.4	37,780
26	62.3	30,960	62.6	32,820	63.4	37,780	64.3	43,360	64.2	42,740	63.4	37,780
27	62.2	30,340	62.6	32,820	63.6	39,020	64.3	43,360	64.2	42,740	63.3	37,160
28	62.2	30,340	62.6	32,820	63.6	39,020	64.3	43,360	64.1	42,120	63.2	36,540
29	62.2	30,340	62.6	32,820	63.6	39,020	64.3	43,360	64.1	42,120	63.2	36,540
30	62.2	30,340	62.7	33,440	63.6	39,020	64.2	42,740	64.1	42,120	63.2	36,540
31	62.2	30,340	62.8	34,060			64.2	42,740			63.2	36,540

Table 53. Daily Discharge of the Winnipeg River at Otter Falls in Manitoba—Continued.

1908.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge										
	Feet.	Sec. Ft.										
1	63.2	36,540	63.8	40,260	62.7	33,440	61.8	27,860	62.0	29,100	63.5	38,400
2	63.2	36,540	63.9	40,880	62.6	32,820	62.0	29,400	62.1	29,720	63.5	38,400
3	63.3	37,160	63.8	40,260	62.6	32,820	61.9	28,480	62.1	29,720	63.5	38,400
4	63.3	37,160	63.6	39,020	62.5	32,200	61.8	27,860	62.1	29,720	63.5	38,400
5	63.2	36,540	63.8	40,260	62.5	32,200	62.0	29,100	62.4	29,720	63.5	38,400
6	63.2	36,540	63.8	40,260	62.5	32,200	62.0	29,100	62.2	30,340	63.5	38,400
7	63.3	37,160	63.8	40,260	62.5	32,200	62.0	29,400	62.1	29,720	63.5	38,400
8	63.2	36,540	63.8	40,260	62.6	32,820	61.9	28,480	62.2	30,340	63.5	38,400
9	63.2	36,540	63.6	39,020	62.7	33,340	61.9	28,480	62.2	30,340	63.6	39,020
10	63.3	37,160	63.4	37,780	62.7	33,340	61.9	28,480	62.2	30,340	63.8	40,260
11	63.2	36,540	63.2	36,540	62.6	32,820	63.9	28,480	62.2	30,340	63.9	41,500
12	63.2	36,540	63.0	35,300	62.3	31,580	61.9	28,480	62.3	30,960	63.2	42,740
13	63.2	36,540	62.8	34,060	62.3	31,580	61.9	28,480	62.3	31,580	63.2	42,740
14	63.2	36,540	62.8	34,060	62.3	31,580	63.9	28,480	62.3	31,580	63.2	42,740
15	63.2	36,540	62.8	34,060	62.3	30,960	61.9	28,480	62.3	31,580	63.2	42,740
16	63.2	36,540	62.8	34,060	62.6	32,820	61.9	28,480	62.4	31,580	63.2	42,740
17	63.2	36,540	62.8	34,060	62.4	31,580	63.9	28,480	62.3	31,580	63.2	42,740
18	63.2	36,540	62.8	34,060	62.4	31,580	63.7	27,240	62.5	32,200	63.2	42,740
19	63.2	36,540	62.8	34,060	62.4	31,580	63.7	27,240	62.5	32,200	63.2	42,740
20	63.2	36,540	62.8	34,060	62.7	30,440	61.8	27,860	62.5	32,200	63.4	43,460
21	63.2	36,540	62.8	34,060	62.3	31,580	63.8	27,860	62.8	34,060	63.4	43,460
22	63.2	36,540	62.6	32,820	62.4	31,580	61.8	27,860	62.9	34,680	63.4	43,460
23	63.2	36,540	62.8	34,060	62.2	30,340	61.8	27,860	63.0	35,300	63.4	43,460
24	63.2	36,540	63.1	35,920	62.3	29,720	62.0	29,100	63.0	35,300	63.4	43,460
25	63.1	35,920	63.3	37,160	62.1	29,720	62.0	29,100	63.0	35,300	63.4	43,460
26	63.0	35,300	63.3	37,160	62.1	29,720	62.0	29,100	63.2	36,540	63.4	43,460
27	63.0	35,300	63.3	37,160	62.1	29,720	62.0	29,100	63.2	36,540	63.4	43,980
28	63.4	37,780	63.2	36,540	62.1	29,720	62.0	29,100	63.2	36,540	63.4	43,980
29	63.6	39,020	63.0	35,300	62.0	29,100	62.0	29,400	63.2	36,540	63.4	43,980
30	63.8	40,260	62.0	29,100	62.0	29,100	62.0	29,100	63.3	37,160	63.4	43,980
31	63.8	40,260	61.9	28,480	61.9	28,480	61.9	28,480	63.4	37,780	63.4	43,980
1	64.3	43,360	64.0	41,500	63.4	37,780	62.8	34,060	62.1	29,720	63.4	24,760
2	64.3	43,980	63.9	41,500	63.6	39,020	62.8	34,060	62.0	29,100	63.3	24,760
3	64.3	43,980	63.0	41,500	63.6	39,020	62.9	34,680	62.1	29,720	63.2	24,140
4	64.3	43,980	63.9	40,880	63.5	38,400	62.8	34,060	62.3	29,720	63.2	24,140
5	64.4	43,980	63.8	40,260	63.5	38,400	62.7	33,440	62.1	29,720	63.2	24,140
6	64.1	43,980	63.8	40,260	63.5	38,400	62.6	32,820	62.2	30,340	63.2	24,140
7	64.4	43,980	63.8	40,260	63.5	38,400	62.7	33,440	62.1	29,720	63.2	24,140
8	64.4	43,980	63.8	40,260	63.5	38,400	62.7	33,440	62.0	29,100	63.2	24,140
9	64.4	43,980	63.8	40,260	63.4	37,780	62.7	33,440	62.0	29,100	63.3	24,760
10	64.4	43,980	63.8	40,260	63.4	37,780	62.7	33,440	62.0	29,100	63.2	24,340
11	64.3	43,360	63.8	40,260	63.3	37,160	62.7	33,440	62.0	29,100	63.2	24,140
12	64.3	43,360	63.8	40,260	63.2	36,540	62.7	33,440	62.0	29,100	63.2	24,340
13	64.3	43,360	63.8	40,260	63.1	35,920	62.7	33,440	62.1	29,720	63.2	24,340
14	64.3	43,360	63.8	40,260	63.0	35,300	62.7	33,440	62.1	29,720	63.2	24,340
15	64.3	43,360	63.7	39,640	62.9	34,680	62.6	32,820	62.0	29,100	63.0	22,900
16	64.3	43,360	63.7	39,640	62.9	34,680	62.6	32,820	62.0	29,100	63.0	22,900
17	64.3	43,360	63.6	39,020	62.9	34,680	62.8	34,680	62.0	29,100	63.1	23,520
18	64.3	43,360	63.6	39,020	62.9	34,680	62.7	33,440	62.0	29,100	63.1	23,520
19	64.3	43,360	63.6	39,020	62.9	34,680	62.7	33,440	62.0	29,100	63.1	23,520
20	64.2	42,740	63.6	39,020	62.9	34,680	62.7	33,440	61.8	27,860	63.1	23,520
21	64.1	42,120	63.6	39,020	62.9	34,680	62.7	33,440	61.8	27,860	63.0	22,900
22	64.1	42,120	63.6	39,020	62.8	34,060	62.6	32,820	61.8	27,860	63.0	22,900
23	64.1	42,120	63.6	39,020	62.8	34,060	62.6	32,820	61.7	27,240	63.0	22,900
24	64.1	42,120	63.6	39,020	62.8	34,060	62.5	32,200	61.7	27,240	60.9	22,280
25	64.1	42,120	63.6	39,020	62.8	34,060	62.5	32,200	61.6	26,620	60.9	22,280
26	64.1	42,120	63.5	38,400	62.8	34,060	62.5	32,200	61.6	26,620	60.9	22,280
27	64.0	41,500	63.5	38,400	62.8	34,060	62.5	32,200	61.5	26,000	60.8	21,660
28	64.0	41,500	63.4	37,780	62.8	34,060	62.5	32,200	61.4	25,380	60.8	21,660
29	64.0	41,500	63.4	37,780	62.8	34,060	62.4	31,580	61.4	25,380	60.8	21,660
30	64.0	41,500	63.4	37,780	62.7	33,440	62.4	31,580	61.4	25,380	60.8	21,660
31	64.0	41,500	63.4	37,780	62.7	33,440	62.2	30,340	61.4	25,380	60.8	21,660

Table 53. - Daily Discharge of the Winnipeg River at Otter Falls in Manitoba Continued

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Dis. Charge										
	Feet.	Sec. Ft.										
1	60 89	22 280	60 99	22 000	60 89	22 080	60 10	17 370	60 00	16 700	61 30	24 110
2	60 89	22 280	60 99	22 000	60 79	21 660	60 10	17 370	59 90	16 700	61 30	24 110
3	60 89	22 280	60 99	22 000	60 69	21 010	60 10	17 370	59 90	16 700	61 25	24 130
4	60 89	22 280	60 99	22 000	60 59	20 190	60 00	16 700	59 90	16 700	61 30	24 110
5	60 89	22 280	60 99	22 000	60 59	20 190	60 00	16 700	59 90	16 700	61 30	24 110
6	60 89	22 280	60 99	22 000	60 49	19 800	60 10	17 370	59 90	16 700	61 30	24 110
7	60 99	22 900	61 19	21 410	60 49	19 800	60 10	17 370	60 00	16 700	61 30	24 110
8	61 29	21 760	61 29	21 460	60 49	19 800	60 00	16 700	60 10	17 370	61 35	24 130
9	61 69	27 210	61 39	25 480	60 49	19 800	60 00	16 700	60 20	17 910	61 30	24 110
10	61 39	27 210	61 39	25 480	60 49	19 800	60 00	16 700	60 20	17 910	61 30	24 110
11	61 69	27 210	61 39	25 480	60 49	19 800	60 00	16 700	60 30	18 560	61 25	24 150
12	61 69	27 210	61 39	26 000	60 49	19 800	60 00	16 700	60 10	19 180	61 30	24 760
13	61 69	28 180	61 59	26 670	60 39	19 180	60 00	16 700	60 50	19 800	61 30	24 760
14	61 80	28 180	61 59	26 670	60 39	19 180	60 00	16 700	60 60	20 120	61 30	24 760
15	61 79	27 860	61 59	26 670	60 39	19 180	60 00	16 700	60 30	21 010	61 25	24 450
16	61 79	27 860	61 59	26 670	60 39	19 180	60 00	16 700	60 70	21 010	61 30	24 760
17	61 79	27 860	61 59	26 670	60 29	18 560	59 90	16 700	60 70	21 010	61 25	24 450
18	61 69	27 210	61 39	25 480	60 99	17 320	59 90	16 700	60 80	21 660	61 30	24 760
19	61 59	26 620	61 39	24 110	60 19	1 910	59 90	16 700	60 80	21 660	61 20	24 110
20	61 59	26 620	60 99	22 900	60 19	1 910	59 90	16 700	60 80	21 660	61 20	24 110
21	61 49	26 000	60 89	22 280	60 19	1 910	60 00	16 700	60 90	22 280	61 30	24 760
22	61 09	24 520	60 89	22 280	60 09	17 320	60 00	16 700	60 90	22 280	61 25	24 450
23	61 05	23 210	60 99	22 900	60 09	17 320	60 00	16 700	61 09	22 900	61 25	24 150
24	60 99	22 900	60 99	22 900	60 09	17 320	60 00	16 700	61 09	22 900	61 30	24 760
25	60 99	22 900	61 09	23 520	60 09	17 320	60 00	16 700	61 10	23 520	61 30	24 760
26	60 99	22 900	61 09	23 520	60 09	17 320	60 00	16 700	61 10	23 520	61 30	24 760
27	60 99	22 900	60 99	22 900	60 09	17 320	60 00	16 700	61 10	23 520	61 25	24 450
28	60 99	22 900	60 99	22 900	60 09	17 320	60 00	16 700	61 10	23 520	61 25	24 150
29	60 99	22 900	60 99	22 900	60 09	17 320	60 00	16 700	61 10	23 520	61 30	24 760
30	60 99	22 900	60 99	22 900	60 09	17 320	60 00	16 700	61 20	24 110	61 30	24 760
31	60 99	22 900	60 99	22 900	59 99	16 700	60 00	16 700	61 20	24 110	61 30	24 760

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height	Dis. Charge										
1	61 25	24 450	61 25	21 150	61 10	23 520	60 80	21 660	60 50	19 800	60 70	21 010
2	61 25	24 450	61 25	21 150	61 00	22 900	60 75	21 450	60 45	19 490	60 75	21 500
3	61 10	21 760	61 20	21 110	61 04	22 900	60 75	21 450	60 50	19 800	60 75	21 450
4	61 30	24 760	61 20	21 110	61 04	22 900	60 75	21 450	60 55	20 110	60 75	21 450
5	61 30	24 760	61 20	21 110	61 05	23 210	60 75	21 450	60 55	20 110	60 75	21 450
6	61 30	21 760	61 30	21 760	61 00	22 900	60 75	21 450	60 55	20 110	60 75	21 450
7	61 35	25 070	61 30	21 760	60 90	22 280	60 75	21 450	60 55	20 110	60 75	21 450
8	61 35	25 070	61 30	21 760	60 95	22 590	60 70	21 040	60 55	20 110	60 80	21 660
9	61 35	25 070	61 30	21 760	60 85	21 970	60 65	20 730	60 55	20 110	60 85	21 970
10	61 35	25 070	61 30	21 760	60 90	22 280	60 60	20 420	60 55	20 110	60 95	22 590
11	61 30	21 760	61 25	21 450	60 90	22 280	60 55	20 110	60 55	20 110	60 95	22 590
12	61 30	21 760	61 25	21 450	60 90	22 280	60 55	20 110	60 55	20 110	60 95	22 590
13	61 30	21 760	61 30	21 760	60 95	22 590	60 50	19 800	60 60	20 420	60 95	22 590
14	61 30	21 760	61 35	25 070	60 95	22 590	60 50	19 800	60 60	20 420	60 95	22 590
15	61 30	21 760	61 35	25 070	60 90	22 280	60 50	19 800	60 60	20 420	60 95	22 590
16	61 30	21 760	61 35	25 070	60 90	22 280	60 50	19 800	60 60	20 420	60 95	22 590
17	61 30	21 760	61 30	21 760	60 90	22 280	60 45	19 490	60 60	20 420	60 95	22 590
18	61 30	21 760	61 30	21 760	60 95	22 590	60 50	19 800	60 65	20 740	60 95	22 590
19	61 30	21 760	61 30	21 760	60 90	22 280	60 55	20 110	60 65	20 730	60 95	22 590
20	61 30	24 760	61 20	21 110	60 90	22 280	60 55	20 110	60 65	20 740	60 95	22 590
21	61 30	24 760	61 25	21 450	60 85	21 970	60 50	19 800	60 65	20 740	60 95	22 590
22	61 30	21 760	61 25	21 450	60 85	21 970	60 55	20 110	60 65	20 740	60 95	22 590
23	61 30	21 760	61 25	21 450	60 85	21 970	60 55	20 110	60 70	21 010	60 95	22 590
24	61 30	21 760	61 25	21 450	60 80	21 660	60 55	20 110	60 70	21 010	61 00	22 900
25	61 25	24 450	61 25	21 450	60 80	21 660	60 55	20 110	60 70	21 010	61 00	22 900
26	61 20	21 440	61 25	21 450	60 80	21 660	60 50	19 800	60 70	21 010	61 00	22 900
27	61 25	21 450	61 30	21 760	60 80	21 660	60 45	19 490	60 70	21 010	61 05	23 210
28	61 20	21 440	61 30	21 760	60 80	21 660	60 55	20 110	60 70	21 010	61 20	24 110
29	61 20	21 440	61 25	21 450	60 80	21 660	60 55	20 110	60 70	21 010	61 35	25 070
30	61 15	24 830	61 15	24 830	60 80	21 660	60 50	19 800	60 70	21 010	61 20	24 110
31	61 20	24 140	61 10	23 520	60 80	21 660	60 50	19 800	60 70	21 010	61 20	24 110

Table 53. Daily Discharge of the Winnipeg River at Otter Falls in Manitoba  
Continued.

1910

Day.	January		February		March		April		May		June	
	Gauge Height	Dis. Charge										
	Feet	Sec. Ft.										
1	61.90	31.140	61.30	24.60	61.90	31.110	61.40	3.350	65.50	50.880	65.40	53.160
2	61.90	31.140	61.40	24.60	61.20	31.110	61.50	3.000	65.55	51.200	65.65	51.840
3	61.90	31.140	61.40	24.60	61.90	31.110	61.60	6.620	65.40	53.160	65.60	51.520
4	61.50	26.000	61.40	24.60	61.90	31.110	61.70	7.240	65.5	53.180	65.85	51.200
5	61.35	25.020	61.40	24.60	61.90	31.110	61.90	8.180	65.80	53.500	65.60	51.520
6	61.10	25.380	61.30	24.100	61.90	31.110	62.10	30.140	65.7	53.140	65.65	51.840
7	61.10	25.380	61.95	31.150	61.90	31.110	62.40	31.580	65.90	54.140	65.65	51.840
8	61.50	26.000	61.90	31.110	61.90	31.110	62.60	32.840	65.8	54.140	65.65	51.840
9	61.70	27.240	61.90	31.110	61.90	31.110	62.80	44.060	65.8	52.800	65.65	51.840
10	61.50	26.000	61.20	24.140	61.90	31.110	63.10	48.920	65.80	52.800	65.65	51.8
11	61.40	26.000	61.90	31.110	61.90	31.110	63.4	57.160	65.80	53.000	65.60	51.520
12	61.50	26.000	61.90	31.110	61.90	31.110	63.7	58.100	65.80	53.000	65.60	50.880
13	61.50	26.000	61.90	31.110	61.15	23.840	63.60	59.020	65.80	53.000	66.45	53.500
14	61.50	26.000	61.90	31.110	61.15	23.840	63.75	61.50	66.50	53.000	66.45	53.500
15	61.50	26.000	61.20	24.140	61.15	23.840	63.90	46.000	65.85	53.120	65.75	53.280
16	61.15	25.690	61.20	24.140	61.1	23.8	63.00	41.000	65.70	53.000	66.1	53.650
17	61.10	25.480	61.20	24.140	61.15	23.880	63.15	42.100	65.85	53.100	66.15	53.700
18	61.10	25.480	61.20	24.140	61.15	23.880	63.10	43.950	65.85	53.100	66.1	53.600
19	61.45	25.020	61.20	24.140	61.15	23.880	63.1	41.950	65.85	53.100	66.1	53.600
20	61.45	25.020	61.20	24.140	61.15	23.880	63.15	46.150	65.85	53.100	66.1	53.600
21	61.45	25.020	61.20	24.140	61.15	23.880	63.1	60.150	65.85	53.100	66.1	53.600
22	61.40	24.760	61.20	24.140	61.15	23.880	63.15	46.150	65.85	53.100	66.1	53.600
23	61.45	25.020	61.20	24.140	61.15	23.880	63.15	49.150	65.85	53.100	66.1	53.600
24	61.45	25.020	61.20	24.140	61.15	23.880	63.00	47.040	65.85	53.100	66.1	53.600
25	61.45	25.020	61.20	24.140	61.10	23.820	63.0	48.060	65.80	52.800	66.1	53.600
26	61.40	24.760	61.20	24.140	61.05	23.740	63.15	49.700	65.80	52.800	66.05	53.500
27	61.40	24.760	61.20	24.140	61.00	23.680	63.30	49.600	65.80	52.800	66.5	54.000
28	61.40	24.760	61.20	24.140	61.00	23.680	63.30	49.600	65.85	53.100	66.40	53.900
29	61.40	24.760	61.20	24.140	61.00	23.680	63.30	49.600	65.85	53.100	66.40	53.900
30	61.40	24.760	61.20	24.140	61.00	23.680	63.30	49.600	65.85	53.100	66.40	53.900
31	61.20	24.140	61.20	24.140	61.00	23.680	63.30	49.600	65.85	53.100	66.40	53.900
July.												
1	61.25	13.050	61.80	27.860	60.80	27.660	60.35	18.50	59.48	15.500	59.48	13.450
2	61.30	12.740	61.90	28.480	60.80	27.660	60.20	19.000	59.71	15.180	59.35	13.500
3	61.30	12.740	61.65	26.940	60.40	27.040	60.0	19.000	59.74	15.180	59.35	13.500
4	61.45	12.140	61.60	26.620	60.20	27.040	60.15	18.500	59.70	14.950	59.35	13.450
5	61.10	12.120	61.55	26.410	60.10	27.040	60.15	17.600	59.70	14.900	59.30	13.050
6	61.00	11.500	61.60	26.620	60.20	27.040	60.30	17.910	59.70	14.950	59.30	13.050
7	61.00	11.500	61.55	26.310	60.65	26.400	60.30	17.910	59.70	14.950	59.30	13.050
8	61.20	10.880	61.50	26.080	60.50	26.000	60.20	17.910	59.70	14.950	59.30	13.050
9	61.20	10.880	61.15	25.690	60.15	26.000	60.30	17.910	59.65	14.640	59.30	13.050
10	61.20	10.880	61.50	26.000	60.45	26.000	60.30	17.910	59.60	14.400	59.30	13.050
11	61.85	10.540	61.15	25.690	60.50	26.000	60.15	17.600	59.60	14.100	59.30	13.050
12	61.75	9.950	61.10	25.380	60.10	26.180	60.15	17.600	59.65	14.640	59.30	13.050
13	61.70	9.640	61.35	25.070	60.45	26.100	60.05	17.040	59.67	14.650	59.30	13.050
14	61.70	9.640	61.45	25.070	60.40	26.180	60.00	16.700	59.60	14.400	59.30	13.050
15	61.60	9.000	61.35	25.070	60.10	26.180	60.00	16.700	59.80	13.900	59.30	13.700
16	61.55	18.740	61.35	25.070	60.10	26.180	60.05	17.040	59.11	13.680	59.20	12.700
17	61.40	17.780	61.10	25.380	60.35	18.870	60.00	16.700	59.50	13.900	59.20	12.700
18	61.25	16.850	61.15	24.840	60.10	19.180	60.00	16.000	59.40	13.150	59.20	12.700
19	61.40	15.900	61.30	24.780	60.15	19.100	60.05	17.040	59.50	13.900	59.20	12.700
20	61.40	15.900	61.00	22.900	60.10	19.180	60.05	17.040	59.55	14.150	59.15	12.880
21	62.85	14.370	61.15	24.840	60.30	18.560	60.10	17.320	59.50	13.900	59.15	12.880
22	62.65	13.130	61.00	22.900	60.35	18.870	60.00	16.700	59.15	13.680	59.18	12.700
23	62.55	12.510	61.15	24.840	60.35	18.870	59.95	16.400	59.40	13.450	59.14	12.550
24	62.50	12.260	61.10	23.520	60.10	19.180	59.90	16.100	59.50	13.900	59.12	12.400
25	62.50	12.200	61.00	22.900	60.40	19.180	59.90	16.100	59.50	13.900	59.10	12.400
26	62.45	11.890	60.95	22.590	60.40	19.180	59.90	16.100	59.50	13.900	59.10	12.400
27	62.35	11.270	60.90	22.280	60.40	19.180	59.87	15.800	59.50	13.900	59.10	12.700
28	62.25	10.650	60.90	22.280	60.30	18.560	59.85	15.800	59.50	13.900	59.15	12.550
29	62.05	29.440	60.90	22.280	60.35	18.870	59.85	15.800	59.45	13.680	59.10	13.050
30	61.85	28.170	60.90	22.280	60.35	18.870	59.82	15.500	59.42	13.450	59.35	13.250
31	61.75	27.550	60.85	21.970	60.35	18.870	59.80	15.500	59.42	13.450	59.40	13.150

July. August. September. October. November. December.

Table 53 Daily Discharge of the Winnipeg River at Slave Falls in Manitoba  
Continued.

(Drainage in 1,420 square miles.)

Note: The rainfall data for this station may be readily revised before publication. (Water Resources Paper Number 1.)

111

Day.	January		February		March		April		May		June	
	Gauge Height	Discharge										
	Feet	Sec. Ft.										
1	59.50	14,300	59.50	14,800	59.43	14,450	59.00	14,000	59.35	14,780	60.10	16,860
2	59.58	14,300	59.54	14,350	59.40	14,950	59.40	14,950	59.40	14,950	60.15	17,140
3	59.66	14,350	59.58	14,400	59.33	14,950	59.40	14,950	59.40	14,950	60.20	17,400
4	59.78	15,000	59.46	14,580	59.30	14,950	59.40	14,950	59.40	14,950	60.20	17,400
5	59.77	14,800	59.55	14,950	59.35	14,450	59.08	14,000	59.48	14,400	60.20	17,400
6	59.70	14,800	59.65	14,550	59.48	14,450	59.17	14,000	59.44	14,350	60.20	17,400
7	59.70	14,800	59.51	14,950	59.47	14,450	59.16	14,000	59.47	14,350	60.20	17,400
8	59.70	14,800	59.43	14,300	59.40	14,000	59.17	14,000	59.40	14,450	60.20	17,400
9	59.71	14,800	59.48	14,900	59.45	14,450	59.16	14,000	59.45	14,380	60.20	17,400
10	59.73	14,950	59.50	14,800	59.48	14,600	59.00	14,000	59.47	14,380	60.20	17,400
11	59.80	15,400	59.48	14,500	59.09	14,000	59.20	14,000	59.48	14,800	60.20	17,400
12	59.95	16,050	59.40	14,300	59.40	14,450	59.05	14,100	59.50	14,800	60.20	17,400
13	60.00	16,300	59.33	14,950	59.47	14,300	59.05	14,100	59.50	14,800	60.20	17,400
14	60.08	16,350	59.24	14,800	59.48	14,000	59.05	14,150	59.50	14,800	60.20	17,400
15	60.10	16,860	59.23	14,800	59.44	14,450	59.10	14,000	59.50	14,800	60.20	17,400
16	60.15	17,140	59.34	14,580	59.44	14,450	59.15	14,150	59.50	14,800	60.20	17,400
17	60.00	16,400	59.34	14,580	59.44	14,450	59.15	14,150	59.50	14,800	60.20	17,400
18	59.78	15,000	59.23	14,800	59.47	14,300	59.17	14,150	59.50	14,800	60.20	17,400
19	59.77	14,950	59.25	14,950	59.40	14,000	59.17	14,150	59.50	14,800	60.20	17,400
20	59.77	14,800	59.20	14,950	59.05	14,150	59.15	14,150	59.50	14,800	60.20	17,400
21	59.68	14,800	59.40	14,950	59.08	14,150	59.15	14,150	59.50	14,800	60.20	17,400
22	59.64	14,550	59.37	14,800	59.10	14,000	59.15	14,150	59.50	14,800	60.20	17,400
23	59.64	14,300	59.25	14,800	59.17	14,000	59.15	14,150	59.50	14,800	60.20	17,400
24	59.60	14,000	59.20	14,600	59.15	14,150	59.15	14,150	59.50	14,800	60.20	17,400
25	59.60	13,800	59.10	14,600	59.15	14,450	59.15	14,150	59.50	14,800	60.20	17,400
26	59.40	13,350	59.03	14,380	59.00	14,000	59.10	14,150	59.25	14,050	60.60	19,660
27	59.40	13,350	59.00	14,950	58.90	14,300	59.10	14,150	59.20	14,300	60.60	19,660
28	59.40	13,350	59.35	14,450	59.10	14,000	59.10	14,150	59.20	14,300	60.60	19,660
29	59.45	13,350			59.16	14,150	59.10	14,000	60.10	16,540	60.62	19,660
30	59.45	13,350			59.15	14,100	59.15	14,150	60.10	16,860	60.62	19,660
31	59.50	13,800			59.05	14,150			60.10	16,860	60.62	19,660
July												
1	60.60	19,060				28,890	61.47	24,490	61.60	28,900	60.75	20,500
2	60.60	19,660				28,540	61.50	24,490	61.70	29,080	60.70	20,300
3	60.64	19,940				28,260	61.50	24,400	61.85	29,980	60.68	20,300
4	60.66	19,940				27,840	61.56	24,980	61.80	29,400	60.65	20,940
5	60.66	19,940				27,540	61.61	25,540	61.45	24,490	60.65	20,940
6	60.66	19,940	61			27,540	61.75	26,100	61.47	24,410	60.67	19,660
7	60.66	19,940	61			27,560	61.59	26,380	61.51	24,860	60.60	20,660
8	60.78	20,340	61			27,550	61.85	26,660	61.36	23,860	60.60	19,660
9	60.90	21,040	61.84			27,480	61.85	26,660	61.34	23,860	60.56	19,480
10	60.90	21,340	61.90			27,470	61.85	26,660	61.33	23,860	60.56	19,480
11	60.95	21,670	61.87	26,660	61.16	24,470	61.90	26,940	61.33	23,860	60.60	19,660
12	61.05	22,180	61.85	26,660	61.10	24,410	61.93	27,220	61.04	23,580	60.60	19,660
13	61.10	22,460	61.85	26,660	61.38	24,410	61.80	26,380	61.15	24,400	60.60	19,660
14	61.16	22,740	61.85	26,660	61.10	24,410	61.80	26,380	61.10	24,400	60.55	19,480
15	61.18	23,020	61.85	26,660	61.13	24,410	61.80	26,380	61.15	24,710	60.55	19,480
16	61.25	23,400	61.84	26,660	61.13	24,410	61.80	26,380	61.15	24,710	60.56	19,480
17	61.34	23,860	61.81	26,380	61.15	24,410	61.65	25,540	61.10	24,400	60.66	19,940
18	61.47	24,410	61.81	26,380	61.17	24,410	61.50	25,890	61.10	24,400	60.55	19,380
19	61.48	24,410	61.80	26,380	61.50	24,700	61.75	26,100	61.10	24,400	60.54	19,380
20	61.48	24,700	61.78	26,380	61.53	24,980	61.75	26,100	61.05	23,180	60.53	19,380
21	61.52	24,700	61.77	26,100	61.56	24,980	61.78	26,380	61.05	23,180	60.52	19,100
22	61.52	24,700	61.75	26,100	61.57	24,980	61.80	26,380	61.05	23,180	60.50	19,100
23	61.52	24,700	61.76	26,100	61.57	24,980	61.75	26,100	61.00	21,900	60.50	19,100
24	61.52	24,700	61.75	26,100	61.54	24,980	61.75	26,100	61.00	21,900	60.52	19,380
25	61.52	24,700	61.75	26,100	61.51	24,410	61.50	25,820	60.95	24,400	60.50	19,100
26	61.55	24,980	61	26,100	61.48	24,700	61.70	25,820	60.90	24,400	60.46	18,820
27	61.60	25,260	61	26,100	61.45	24,420	61.70	25,820	60.90	24,400	60.42	18,540
28	61.62	25,260	61	25,890	61.48	24,700	61.70	25,820	60.88	24,400	60.40	18,540
29	61.62	25,260	61.70	25,890	61.45	24,420	61.68	25,820	60.85	24,060	60.45	18,260
30	61.62	25,260	61.68	25,840	61.48	24,700	61.68	25,840	60.80	24,280	60.40	17,980
31	61.62	25,260	61.68	25,840			61.66	25,260			60.40	17,980

Table 53. Daily Discharge of the Winnipeg River at Slave Falls in Manitoba—Continued.

1912.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge										
	Feet.	Sec. ft.										
1	60-30	17,980	60-40	18,540	59-85	15,550	59-20	12,700		46,560	62-05	27,780
2	60-30	17,980	60-10	18,540	59-84	15,550	59-20	12,700	60-07	46,580	62-45	28,440
3	60-30	17,980	60-35	18,260	59-83	15,550	59-20	12,700	60-10	46,860	62-15	28,440
4	60-35	18,260	60-40	17,980	59-82	15,100	59-23	12,775	60-15	48,820	.....	29,000
5	60-40	18,540	60-28	17,980	59-80	15,300	59-23	12,775	60-50	49,100	.....	29,700
6	60-65	19,940	60-18	17,980	59-77	15,050	.....	12,800	60-40	48,510	62-50	30,400
7	61-00	21,900	60-28	17,980	59-75	15,050	.....	12,800	60-48	49,100	62-50	30,400
8	61-05	22,460	60-25	17,700	59-72	14,800	.....	12,900	60-52	49,100	62-55	30,580
9	61-10	22,460	60-23	17,700	59-68	14,860	.....	12,900	60-65	49,940	62-30	29,180
10	61-10	22,460	60-20	17,420	59-66	14,550	.....	12,900	.....	20,500	62-25	28,900
11	61-10	22,460	60-15	17,140	59-64	14,550	.....	12,900	60-85	21,060	.....	28,700
12	61-10	22,460	60-12	16,860	59-62	14,400	59-29	12,950	.....	21,500	.....	28,400
13	61-05	22,180	60-10	16,860	59-62	14,400	.....	13,000	61-00	21,900	.....	28,200
14	61-05	22,180	60-05	16,580	.....	14,000	.....	13,000	61-20	23,020	.....	28,000
15	61-30	21,900	60-02	16,300	.....	14,000	.....	13,000	61-35	23,860	62-05	27,780
16	60-95	24,620	60-00	16,300	.....	13,700	.....	13,100	.....	21,000	62-05	27,780
17	60-70	20,220	60-00	16,300	.....	13,700	.....	13,100	61-40	24,140	62-03	27,780
18	60-70	20,220	60-00	16,300	.....	13,400	.....	13,100	61-13	24,420	62-15	28,440
19	60-70	20,220	59-98	16,300	.....	13,400	59-35	13,150	.....	24,600	62-04	27,500
20	60-65	19,940	59-97	16,050	.....	13,100	.....	13,200	61-50	24,700	62-03	27,780
21	60-60	19,660	59-96	16,050	.....	13,100	.....	13,500	61-51	24,700	62-03	27,780
22	60-55	19,380	59-95	16,050	59-30	12,950	.....	13,800	61-55	24,980	62-00	27,500
23	60-55	19,380	59-94	16,050	.....	12,700	.....	14,100	61-62	25,260	61-95	27,220
24	60-55	19,380	59-93	16,050	.....	12,500	.....	14,100	61-70	25,820	61-90	26,940
25	60-50	19,100	59-92	15,800	59-12	12,400	.....	14,700	61-74	26,100	61-80	26,380
26	60-45	18,820	59-91	15,800	.....	12,400	.....	15,000	.....	26,400	61-89	26,940
27	60-45	18,820	59-89	15,800	.....	12,400	.....	15,300	61-85	26,660	61-88	26,940
28	60-45	18,820	59-89	15,800	.....	12,500	.....	15,600	61-88	26,940	61-88	26,940
29	60-43	18,820	59-88	15,800	.....	12,500	.....	15,900	61-91	26,940	61-89	26,940
30	60-41	18,540	.....	.....	.....	12,600	.....	16,200	61-95	27,220	61-87	26,660
31	60-40	18,540	.....	.....	.....	12,600	.....	.....	61-98	27,500	.....	.....
	July.		August.		September.		October.		November.		December.	
1	61-96	27,220	62-05	27,780	61-99	27,500	.....	30,300	63-25	34,500	62-60	30,860
2	61-89	26,940	62-05	27,780	61-99	27,500	.....	30,500	63-25	34,500	62-60	30,860
3	61-87	26,660	62-04	27,500	62-00	27,500	.....	30,700	63-25	34,500	62-60	30,860
4	61-84	26,660	62-05	27,780	62-17	30,920	.....	30,900	63-25	34,500	62-60	30,860
5	61-79	26,380	62-09	28,060	62-35	29,160	.....	31,100	63-20	31,220	62-60	30,860
6	61-75	26,100	62-07	27,780	62-16	28,340	.....	31,300	63-15	33,940	62-60	30,860
7	61-76	26,100	62-10	28,060	62-25	28,900	62-70	31,420	63-15	33,940	62-50	30,300
8	61-78	26,380	62-05	27,780	62-25	28,900	62-70	31,420	63-15	33,940	62-50	30,300
9	61-76	26,100	62-05	27,780	62-25	28,900	62-74	31,700	63-15	33,940	62-50	30,300
10	61-76	26,100	62-06	27,780	62-25	28,900	62-80	31,980	63-15	33,940	62-50	30,300
11	61-75	26,100	62-07	27,780	62-23	28,900	62-91	32,540	63-15	33,940	62-40	29,740
12	61-76	26,100	62-08	28,060	62-25	28,900	62-96	32,820	63-10	33,660	62-40	29,740
13	61-76	26,100	62-09	28,060	62-25	28,900	62-98	33,100	63-10	33,660	62-40	29,740
14	61-75	26,100	62-03	27,780	.....	29,000	63-03	33,880	63-00	33,100	62-30	29,180
15	61-77	26,100	62-03	27,780	.....	29,200	63-05	33,880	62-90	32,540	62-30	29,180
16	61-79	26,380	62-03	27,780	.....	29,400	63-06	33,880	62-85	32,260	62-30	29,180
17	61-80	26,380	62-02	27,500	.....	29,500	63-10	33,660	62-85	32,260	62-20	28,620
18	61-78	26,380	62-03	27,780	.....	29,600	63-10	33,660	62-85	32,260	62-20	28,620
19	61-75	26,100	62-05	27,780	.....	29,800	63-15	33,940	62-85	32,260	62-20	28,620
20	61-76	26,100	61-98	27,500	.....	29,900	63-20	34,220	62-85	32,260	62-20	28,620
21	61-74	26,100	62-00	27,500	62-45	30,020	63-28	34,780	62-80	31,950	62-20	28,620
22	61-70	25,820	62-05	27,780	62-16	30,020	61-28	34,780	62-80	31,980	62-20	28,620
23	61-75	26,100	62-03	27,780	62-48	30,300	63-28	34,780	62-80	31,980	62-20	28,620
24	61-77	26,100	61-98	27,500	62-51	30,300	63-25	34,500	61-80	31,980	62-20	28,620
25	61-79	26,380	62-00	27,500	62-58	30,860	63-25	34,500	62-75	31,700	62-20	28,620
26	61-80	26,380	62-00	27,500	62-57	30,580	63-20	34,220	62-75	31,700	62-20	28,620
27	61-84	26,660	62-00	27,500	62-56	30,580	61-20	34,220	62-75	31,700	62-20	28,620
28	61-85	26,660	62-00	27,500	62-56	30,580	61-20	34,220	62-75	31,700	62-20	28,620
29	61-89	26,940	61-99	27,500	62-46	30,020	63-35	34,500	62-75	31,700	62-20	28,620
30	61-90	26,940	62-00	27,500	.....	30,100	63-25	34,500	62-75	31,700	62-10	28,060
31	61-94	27,220	62-00	27,500	.....	.....	63-40	34,780	.....	.....	62-10	28,060

Table 53. Daily Discharge of the Winnipeg River at Slave Falls in Manitoba—Continued.

		1913.											
		January.		February.		March.		April.		May.		June.	
Day.	Gage Height.	Discharge.											
		Feet.	Sec. ft.										
1	62.1	28,170	62.1	28,170	60.9	21,690	59.90	16,290	60.89	21,690	62.81	31,950	
2	62.0	27,640	62.1	28,170	60.9	21,690	59.95	16,560	61.11	22,770	62.93	32,760	
3	62.0	27,640	62.1	28,170	60.9	21,690	59.95	16,560	61.18	23,310	62.89	32,490	
4	62.0	27,640	62.1	28,170	60.8	21,150	60.00	16,830	61.27	23,580	62.96	32,760	
5	62.0	27,640	62.1	28,170	60.8	21,150	60.00	16,830	61.51	24,930	63.00	33,030	
6	62.0	27,640	62.1	28,170	60.8	21,150	60.00	16,830	61.61	25,140	62.93	32,760	
7	62.0	27,640	62.1	28,170	60.8	21,150	60.00	16,830	61.72	26,010	62.96	32,760	
8	62.0	27,640	62.0	27,640	60.7	20,610	60.00	16,830	61.70	26,010	62.92	32,490	
9	62.0	27,640	62.0	27,640	60.7	20,610	60.00	16,830	61.82	26,550	63.03	33,300	
10	62.0	27,640	62.0	27,640	60.6	20,070	60.00	16,830	61.89	27,090	63.03	33,030	
11	62.0	27,640	62.0	27,640	60.6	20,070	60.05	17,100	61.98	27,630	63.05	33,300	
12	62.1	28,170	62.0	27,640	60.5	19,530	60.05	17,100	62.03	27,900	63.05	33,300	
13	62.1	28,170	62.0	27,640	60.5	19,530	60.05	17,100	62.03	27,900	63.11	33,570	
14	62.1	28,170	62.0	27,640	60.5	19,530	60.05	17,100	62.10	28,170	63.05	33,300	
15	62.1	28,170	61.9	27,090	60.1	18,990	60.05	17,100	62.11	28,170	62.94	32,760	
16	62.1	28,170	61.9	27,090	60.1	18,990	60.10	17,370	62.13	28,440	63.01	33,030	
17	62.1	28,170	61.8	26,550	60.4	18,990	60.10	17,370	62.12	28,140	63.02	33,030	
18	62.1	28,170	61.8	26,550	60.3	18,450	60.15	17,640	62.15	28,410	62.99	33,030	
19	62.1	28,170	61.6	25,470	60.3	18,450	60.15	17,640	62.37	29,520	62.94	32,760	
20	62.1	28,170	61.6	25,470	60.3	18,450	60.20	17,910	62.43	30,060	62.90	32,490	
21	62.1	28,170	61.3	23,850	60.2	17,910	60.20	17,910	62.43	30,060	62.88	32,490	
22	62.1	28,170	61.3	23,850	60.2	17,910	60.30	18,450	62.43	30,060	62.87	32,220	
23	62.1	28,170	61.2	23,310	60.1	17,370	60.30	18,450	62.68	31,410	62.95	32,760	
24	62.1	28,170	61.1	22,770	60.1	17,370	60.40	18,990	62.70	31,410	62.96	32,760	
25	62.1	28,170	61.1	22,770	60.1	17,370	60.50	19,530	62.78	31,950	62.85	32,220	
26	62.1	28,170	61.0	22,230	60.1	17,370	60.50	19,530	62.80	31,950	62.86	32,220	
27	62.1	28,170	61.0	22,230	60.1	17,370	60.60	20,070	62.76	31,680	62.85	32,220	
28	62.1	28,170	61.0	22,230	60.1	17,370	60.70	20,610	62.88	32,490	62.92	32,490	
29	62.1	28,170	61.0	22,230	60.0	16,830	60.70	20,610	62.86	32,220	62.85	32,220	
30	62.1	28,170	61.0	22,230	60.0	16,830	60.70	20,610	62.84	32,220	62.91	32,490	
31	62.1	28,170	61.0	22,230	59.9	16,290	...	...	62.86	32,220	...	...	
1	62.89	32,490	61.90	27,090	61.84	26,820	61.03	22,500	59.80	15,750	59.89	16,290	
2	62.93	32,760	61.90	27,090	61.80	26,550	60.93	21,960	59.60	14,670	59.88	15,750	
3	62.91	32,490	61.87	26,820	61.81	26,550	60.85	20,880	59.40	15,210	59.82	15,750	
4	62.91	32,490	61.90	27,630	61.89	26,550	60.59	20,040	59.70	15,210	59.77	15,480	
5	62.82	31,950	61.94	27,360	61.77	26,280	60.67	20,070	59.91	16,290	59.79	15,750	
6	62.75	31,680	61.98	27,630	61.70	26,010	60.70	20,610	59.87	16,020	59.77	15,480	
7	62.81	31,950	62.02	27,630	61.60	25,470	60.49	18,990	59.81	16,020	59.51	14,440	
8	62.72	31,410	62.01	27,630	61.77	26,280	60.45	19,360	59.84	16,020	59.81	15,750	
9	62.71	31,410	62.02	27,630	61.76	26,280	60.46	19,360	59.81	16,020	59.76	15,480	
10	62.73	31,680	61.97	27,360	61.70	26,010	60.45	19,360	59.84	16,020	59.79	15,750	
11	62.80	31,950	61.97	27,090	61.62	25,470	60.37	18,450	59.81	16,020	59.71	15,480	
12	62.68	31,410	61.99	28,170	61.66	25,740	60.16	17,640	59.69	15,960	59.69	15,410	
13	62.52	30,870	61.97	28,170	61.62	25,470	60.37	18,450	59.69	15,960	59.72	15,750	
14	62.51	30,870	61.97	27,900	61.54	25,200	60.37	18,450	59.69	15,960	59.72	15,750	
15	62.51	30,870	62.16	28,440	61.81	25,470	60.19	17,910	59.69	15,960	59.59	14,670	
16	62.47	29,520	62.13	28,440	61.59	25,470	60.19	17,910	59.79	15,750	59.59	14,670	
17	62.24	28,980	62.09	28,170	61.58	25,470	60.16	17,640	59.69	15,960	59.61	14,940	
18	62.11	28,170	62.20	28,170	61.63	25,740	60.06	17,100	59.69	15,960	59.56	14,400	
19	62.07	27,900	62.19	28,710	61.48	24,930	59.65	17,100	59.69	15,960	59.56	14,400	
20	61.99	27,630	62.14	28,440	61.43	24,660	60.07	16,830	59.69	15,960	59.49	14,130	
21	61.98	27,630	62.06	27,900	61.36	24,120	60.07	17,100	59.69	15,960	59.43	13,590	
22	61.90	27,630	62.05	27,900	61.58	25,470	60.02	16,830	59.69	15,960	59.46	13,860	
23	61.94	27,360	61.98	27,630	61.53	25,200	60.07	16,830	59.69	15,960	59.49	14,130	
24	61.90	27,090	61.96	27,360	61.48	24,930	60.00	16,830	59.69	15,960	59.59	14,670	
25	61.93	27,360	61.95	27,360	61.40	24,390	59.72	15,750	59.69	15,960	59.44	13,860	
26	61.82	26,550	61.92	27,090	61.35	24,120	59.99	16,830	59.69	15,960	59.49	14,130	
27	61.72	26,010	61.92	27,090	61.25	23,580	60.60	20,070	59.81	16,020	59.32	13,050	
28	61.85	26,820	61.88	27,090	61.16	23,040	60.10	17,370	59.86	16,020	59.38	13,590	
29	61.89	27,090	61.85	27,890	61.24	23,580	60.10	17,370	59.87	16,020	59.51	14,130	
30	61.88	27,090	61.85	27,820	61.13	23,040	60.00	16,830	59.61	14,940	59.54	14,400	
31	61.89	27,090	61.78	26,550	...	...	60.00	16,830	59.61	14,940	59.51	14,130	

Table 53.—Daily Discharge of the Winnipeg River at Slave Falls in Manitoba—  
Continued.

1914.												
Day.	January		February		March		April		May		June	
	Gauge Height	Discharge										
	Feet.	Sec. ft.										
1	59.37	13,320	59.17	12,240	59.16	11,970	59.57	11,400	59.80	15,750	61.55	25,200
2	59.47	13,860	59.35	13,320	59.42	13,050	59.59	11,100	59.72	15,210	61.50	24,940
3	59.50	11,140	59.27	12,780	59.39	13,050	59.52	11,100	59.65	14,670	61.95	27,460
4	59.37	13,320	59.37	13,320	59.39	13,050	59.50	13,100	59.63	16,000	62.12	28,170
5	59.55	11,100	59.35	13,320	59.25	12,780	59.42	13,500	59.69	16,900	62.12	28,170
6	59.50	11,140	59.35	13,320	59.43	13,050	59.57	11,400	59.85	16,900	62.21	28,980
7	59.50	11,140	59.25	13,320	59.46	13,050	59.59	11,400	59.85	16,900	62.32	29,250
8	59.55	11,100	59.30	13,050	59.40	13,050	59.60	11,400	59.85	16,900	62.43	29,790
9	59.50	11,140	59.50	14,000	59.55	14,400	59.60	14,100	60.05	17,100	62.60	30,870
10	59.42	16,500	59.36	13,050	59.58	11,440	59.69	13,800	59.95	16,500	62.72	31,410
11	59.46	14,400	59.35	13,050	59.41	13,860	59.61	14,860	60.05	18,150	62.83	31,680
12	59.49	14,900	59.41	13,860	59.41	13,860	59.61	14,900	60.15	18,600	62.94	31,950
13	59.40	14,500	59.44	13,860	59.44	13,860	59.60	14,600	60.10	19,100	63.05	31,950
14	59.49	14,900	59.38	14,100	59.58	14,100	59.69	14,400	60.15	18,150	63.16	31,950
15	59.52	14,140	59.39	13,050	59.49	13,050	59.69	14,600	60.30	18,150	63.27	32,460
16	59.41	14,860	59.44	13,860	59.44	13,860	59.67	14,400	60.30	18,150	63.38	32,970
17	59.37	14,400	59.41	13,860	59.41	13,860	59.67	14,400	60.30	18,150	63.49	33,480
18	59.47	12,780	59.44	13,320	59.69	13,600	59.58	14,400	60.45	19,700	63.60	34,020
19	59.51	14,400	59.33	13,050	59.50	13,140	59.57	14,100	60.45	19,700	63.71	34,560
20	59.47	14,860	59.67	14,400	59.57	14,410	59.67	14,940	60.50	19,530	63.82	35,070
21	59.60	14,600	59.32	14,050	59.50	14,140	59.67	14,910	60.55	19,800	63.93	35,580
22	59.57	14,900	59.01	11,000	59.40	13,500	59.70	14,910	60.55	19,800	64.04	36,090
23	59.41	13,860	59.40	14,800	59.82	14,140	59.79	15,210	60.55	19,800	64.15	36,600
24	59.50	14,100	59.42	14,500	59.58	14,410	59.79	15,210	60.55	19,800	64.26	37,110
25	59.39	13,050	59.37	14,450	59.50	14,140	59.79	15,210	60.60	20,070	64.37	37,620
26	59.41	13,860	59.39	13,050	59.58	14,410	59.60	14,600	60.85	21,420	64.48	38,130
27	59.40	13,500	59.39	13,510	59.59	14,140	59.67	15,480	61.00	22,300	64.59	38,640
28	59.27	13,050	59.39	13,180	59.50	14,140	59.80	15,480	61.09	22,300	64.70	39,150
29	59.37	13,050	59.41	14,500	59.57	14,910	59.80	16,140	61.10	22,300	64.81	39,660
30	59.39	13,050	59.41	14,050	59.57	14,410	59.67	15,480	61.20	23,410	64.92	40,170
31	59.38	13,180	59.41	14,050	59.53	14,140	59.67	15,480	61.30	23,410	65.03	40,680
July												
1	63.2	31,380	63.01	33,300	63.49	29,190	61.60	35,100	60.99	31,600	60.89	31,150
2	63.3	34,920	63.05	33,300	63.25	28,980	61.50	24,940	60.19	33,300	60.79	30,880
3	63.42	31,650	63.02	33,030	63.30	28,710	61.45	24,660	60.95	31,660	60.70	30,880
4	63.90	34,650	63.05	33,300	63.19	28,140	61.37	24,140	61.09	31,660	60.80	31,150
5	60.49	31,110	63.02	33,030	63.04	27,900	61.54	25,960	60.99	31,660	60.75	30,880
6	63.42	38,190	63.93	32,190	61.89	26,550	61.57	25,200	60.87	31,190	60.87	30,880
7	63.09	34,650	63.82	31,950	61.82	26,550	61.57	25,200	60.85	31,190	60.79	30,610
8	63.35	44,940	63.82	31,950	61.82	26,550	61.55	25,200	60.78	30,880	60.70	30,610
9	63.44	44,600	63.62	31,410	61.80	26,550	61.54	24,660	61.08	31,500	60.68	30,340
10	63.80	31,650	62.80	31,950	61.09	26,280	61.89	24,940	60.80	31,190	60.66	30,340
11	63.24	31,380	62.82	31,950	61.66	28,740	61.57	28,700	60.79	30,880	60.67	30,340
12	63.24	31,880	62.77	31,680	61.73	26,010	61.66	28,140	60.78	30,880	60.65	30,340
13	63.37	44,940	63.80	31,950	61.67	28,140	61.09	30,880	60.95	31,960	60.59	29,540
14	63.40	35,190	62.77	31,680	61.70	26,010	61.89	26,880	60.87	31,490	60.66	30,340
15	63.44	38,190	63.10	31,110	61.62	28,140	61.09	26,280	60.79	30,610	60.69	30,610
16	63.18	38,160	63.69	30,870	61.69	28,140	61.38	26,280	60.99	31,660	60.60	30,340
17	63.36	34,920	63.77	31,680	61.68	28,140	61.66	28,140	60.81	31,190	60.51	29,800
18	63.39	31,650	63.76	31,680	61.85	28,990	61.68	28,140	60.80	31,190	60.50	29,500
19	63.2	31,380	63.66	31,410	61.89	24,940	61.69	28,140	60.75	30,880	60.47	29,260
20	63.40	35,190	63.69	30,870	61.4	31,660	61.69	28,140	60.75	30,880	60.38	28,790
21	63.4	38,160	63.60	30,870	61.66	28,740	61.60	28,140	60.72	30,610	60.69	30,610
22	63.3	34,920	63.59	30,600	61.66	28,140	61.87	24,940	60.70	30,610	60.50	29,540
23	63.47	38,190	63.89	30,600	61.66	28,140	61.31	24,140	60.75	30,880	60.59	29,990
24	63.2	31,920	63.66	31,110	61.68	28,140	61.37	24,660	60.80	31,150	60.47	28,990
25	63.40	35,190	63.69	30,870	61.62	28,140	61.60	28,140	60.75	30,880	60.38	28,790
26	63.9	31,880	63.69	30,870	61.51	28,200	61.33	24,850	60.72	30,610	60.49	28,450
27	63.8	31,990	63.62	30,870	61.45	24,660	61.3	24,940	60.72	30,610	60.40	28,090
28	63.40	31,650	63.60	30,870	61.62	28,140	61.12	22,770	60.60	30,610	60.47	29,260
29	63.2	34,380	62.58	30,600	61.60	28,140	61.06	22,500	60.50	30,610	60.47	29,260
30	63.79	31,110	63.40	30,390	61.57	28,200	61.12	22,770	60.78	20,880	60.38	28,790
31	63.11	38,300	63.89	30,390	61.07	27,500	61.07	27,500	60.78	20,880	60.38	28,790

Table 54 - Monthly Discharge of Winnipeg River at Otter Falls in Manitoba.

(Drainage area, 50,850 square miles.)

Month	DISCHARGE IN CUBIC FEET				Run-off Depth in Inches on Drainage Area
	Maximum	Minimum	Mean	Per square mile	
1907					
January	38,170	76,000	96,000	0.533	0.615
February	39,100	18,500	77,880	0.455	0.434
March	49,180	18,500	41,370	0.313	0.395
April	46,160	11,100	41,500	0.389	0.323
May	0.470	41,100	46,940	0.677	0.377
June	58,440	31,600	28,040	0.555	0.639
July	33,060	30,450	37,000	0.634	0.431
August	33,060	33,400	31,840	0.670	0.415
September	39,000	31,680	34,400	0.38	0.870
October	48,080	39,000	47,850	0.811	0.910
November	47,440	17,450	37,680	0.844	0.945
December	47,400	36,540	39,000	0.487	0.904
For Year	48,080	14,100	39,770	0.48	8.1
1908					
January	40,960	37,300	36,887	0.39	0.844
February	49,880	32,850	36,600	0.38	0.375
March	84,440	28,480	31,880	0.671	0.416
April	39,100	7,750	8,800	0.64	0.630
May	78,800	39,100	8,600	0.648	0.44
June	48,980	88,400	41,600	0.874	0.931
July	44,080	44,800	47,980	0.850	0.980
August	44,800	6,800	39,860	0.84	0.907
September	87,000	34,420	88,900	0.410	0.723
October	34,680	39,440	34,040	0.684	0.81
November	39,340	38,880	38,300	0.867	0.677
December	34,600	31,600	33,440	0.167	0.832
For Year	44,980	31,600	34,342	0.677	9.20
1909					
January	38,480	27,980	31,700	0.490	0.868
February	36,600	37,980	31,480	0.478	0.498
March	37,980	40,000	38,820	0.477	0.429
April	47,800	6,100	16,300	0.301	0.369
May	34,440	16,400	30,800	0.403	0.463
June	34,600	34,440	34,800	0.486	0.832
July	38,000	28,800	24,650	0.488	0.377
August	37,000	37,500	31,800	0.488	0.840
September	38,000	31,600	37,900	0.441	0.497
October	37,600	49,000	39,450	0.403	0.464
November	37,000	49,000	39,450	0.491	0.487
December	37,000	31,040	37,840	0.448	0.844
For Year	38,480	16,100	37,010	0.457	9.1
1910					
January	37,000	31,440	37,960	0.499	0.377
February	47,600	34,440	47,980	0.480	0.400
March	47,440	37,900	38,000	0.477	0.44
April	37,400	37,880	39,900	0.89	0.800
May	38,440	80,880	37,000	1.017	1.905
June	37,450	34,800	48,690	0.600	1.01
July	43,080	37,000	36,950	0.601	0.844
August	38,480	37,000	47,000	0.488	0.864
September	37,000	38,800	49,680	0.487	0.444
October	48,080	48,800	47,000	0.877	0.888
November	47,900	43,450	44,800	0.877	0.418
December	43,450	44,000	47,900	0.877	0.377
For Year	37,440	17,400	38,088	0.674	10.1

Table 54. -Monthly Discharge of Winnipeg River at Slave Falls in Manitoba.

[Drainage area, 19,700 square miles.]

NOTE:—The run-off data for this station may be slightly revised before publication in Water Resources Paper Number 4

Month.	DISCHARGE IN SECONDS-FEET.				Run-off Depth in inches on Drainage Area.
	Maximum.	Minimum.	Mean.	Per square mile.	
1911					
January	17,140	13,350	14,820	0.298	0.444
February	14,550	12,600	13,280	0.267	0.278
March	13,350	11,700	12,540	0.253	0.291
April	12,950	11,700	12,390	0.249	0.279
May	16,860	12,780	14,770	0.297	0.313
June	19,660	16,860	18,340	0.369	0.412
July	25,260	19,660	22,900	0.461	0.531
August	26,940	25,260	26,130	0.526	0.606
September	25,820	24,130	24,810	0.499	0.588
October	27,220	24,420	25,960	0.517	0.602
November	25,260	20,780	23,950	0.462	0.516
December	20,500	17,980	19,340	0.389	0.448
The Year	27,220	14,700	19,018	0.381	5.21
1912					
January	22,460	17,980	20,080	0.401	0.466
February	18,540	15,800	16,840	0.339	0.353
March	15,550	12,300	13,820	0.278	0.321
April	16,200	12,700	13,570	0.273	0.305
May	27,500	16,500	22,800	0.459	0.529
June	30,580	26,380	28,100	0.566	0.632
July	27,220	25,820	26,380	0.531	0.612
August	28,060	27,500	27,710	0.588	0.646
September	30,860	27,500	29,110	0.592	0.655
October	34,780	30,300	33,070	0.665	0.767
November	31,500	31,700	32,610	0.656	0.732
December	30,860	28,060	29,400	0.592	0.682
The Year	34,780	12,300	24,483	0.493	6.70
1913					
January	28,170	27,630	27,996	0.563	0.649
February	28,170	22,240	26,145	0.526	0.548
March	21,690	16,790	19,095	0.383	0.413
April	20,610	16,290	17,817	0.359	0.401
May	32,190	21,690	28,370	0.571	0.688
June	33,570	31,950	32,733	0.688	0.746
July	32,760	26,010	29,503	0.593	0.681
August	28,710	26,550	27,695	0.557	0.642
September	26,820	23,040	25,263	0.508	0.568
October	22,500	14,940	18,276	0.368	0.424
November	16,290	14,670	15,662	0.315	0.352
December	16,290	13,050	14,722	0.296	0.342
The Year	33,570	13,050	23,609	0.475	6.45
1914					
January	14,670	12,510	13,703	0.276	0.318
February	14,100	11,790	13,233	0.267	0.278
March	14,670	11,970	13,815	0.279	0.311
April	15,750	13,590	14,589	0.291	0.338
May	23,310	14,670	18,745	0.377	0.435
June	34,650	24,930	31,180	0.633	0.708
July	35,460	33,300	34,335	0.698	0.806
August	33,300	29,790	31,550	0.635	0.732
September	29,790	24,660	26,170	0.526	0.588
October	26,550	22,500	24,805	0.499	0.575
November	22,700	20,610	21,530	0.438	0.477
December	21,150	18,450	19,810	0.399	0.460
The Year	35,460	11,790	21,995	0.473	6.03

## PINAWA CHANNEL AT CONTROL DAM.

*Location of Gauge.*—Immediately below the control dam of the Winnipeg Electric Railway Company, near the head of the Pinawa channel.

*Records available.*—Gauge records are available over the open-water season for the years 1908, 1909, 1910, 1911, 1912, and 1914.

*Gauge.*—Vertical staff gauge, rock bolted.

*Channel.*—Permanent, artificial rock cut.

*Discharge measurements.*—During the years 1907 to 1911, inclusive, discharge measurements were made at this station by the engineers of the Winnipeg Electric Railway Company. From 1912 to date, measurements have been secured by the officers of the Manitoba Hydrographic Survey.

*Winter Flow.*—The open-water discharge curve is not applicable during the winter season.

*Control.*—The flow through the channel is dependent upon the elevation of the water level above the diversion weirs of the Winnipeg Electric Railway Company. This water level varies directly with the stage in the river, as the weirs act as free spillways. The discharge through the channel can be completely cut off by placing stoplogs in the control dam.

Table 55.—Discharge Measurements of the Pinawa Channel of the Winnipeg River at Control Dam.

NOTE.—Gauge heights refer to Upper gauge at Control Dam.

Date.	Hydrographer	Meter No.	Weir	Area of Section	Mean Velocity.	Gauge Height	Discharge
			Feet	Sq. Ft.	Ft. per sec.	Feet.	Sec. Ft.
1907.							
Aug. 2	W. E. S. R. Co.					101.41	8,574
Aug. 11	"					101.45	8,582 <sup>1</sup>
Oct. 8	"					102.10	6,000 <sup>2</sup>
1908.							
April 3	"					101.75	1,421
July 12 and 14	"					104.90	5,644 <sup>3</sup>
Nov. 7 and 8	"					101.60	5,706 <sup>3</sup>
1909.							
Mar. 24	"					104.40	4,515
May 24	"					104.75	8,650 <sup>3</sup>
July 17	"					105.00	8,016
1910.							
Mar. 9	"					104.80	8,515
May 5	"					104.80	10,845 <sup>3</sup>
July 28	"					108.40	6,832
1911.							
May 19	"					102.60	8,084
1912.							
May 11	A. M. Beale	1,196	131.5	1,687	5.84	103.00	9,179
June 1	G. H. Burnham	1,187	132.0	1,744	5.68	103.52	10,014
June 22	"	1,187	131.5	1,758	5.78	103.52	10,150
July 17	"	1,187	131.5	1,748	5.75	103.57	9,879

<sup>1</sup>Meter measurement over Spillway. <sup>2</sup>Weir measurement over Spillway. <sup>3</sup>Meter measurement over spillway.

Table 55—Discharge Measurements of the Pinawa Channel of the Winnipeg River at Control Dam—Concluded.

NOTE: Gauge heights refer to Upper gauge at Control Dam

Date.	Hydrographer	Meter No.	Width	Area of Section	Mean Velocity	Gauge Height	Discharge.
				Sq. ft.	Ft. per sec.	Feet.	Sec. ft.
1913.							
Mar. 28	G. H. Burnham	1 186	131.5	1 716	1.39	103.81	7,197
July 16	S. C. O. Gandy	1 135	131.5	1 758	5.68	103.67	9,986
July 28	"	1 135	131.5	1 705	5.71	103.46	9,738
1914.							
Jan. 15	E. B. Patterson	1 196	131.5	1 661	1.61	103.90	7,721
Feb. 17	W. I. Ireland	1 169	131.5	1 715	1.05	103.40	6,951
May 1	M. S. Madden	1 135	131.2	1 594	1.88	103.41	7,780
May 26	"	1 135	131.3	1 661	5.61	103.71	8,435
June 5	"	1 135	131.2	1 751	5.99	103.53	9,365
June 13	"	1 135	131.2	1 775	5.55	103.55	9,332
June 19	"	1 135	131.3	1 791	5.55	103.85	9,939
June 29	"	1 197	131.3	1 801	5.34	103.90	9,613
July 8	"	1 197	131.2	1 817	5.16	103.90	9,926
July 23	E. B. Patterson	1 197	131.2	1 796	5.82	103.91	10,157
July 27	L. C. Wilson	1 197	131.2	1 796	5.77	103.91	10,455
Aug. 1	"	1 197	131.2	1 781	5.88	103.87	10,483
Aug. 4	"	1 197	131.2	1 781	5.79	103.82	10,330
Aug. 5	"	1 197	131.2	1 781	5.75	103.79	10,141
Aug. 8	"	1 197	131.2	1 772	5.82	103.71	10,423
Aug. 19	P. K. Leibold	1 197	131.2	1 770	5.92	103.68	10,495

Table 56. Daily Discharge of the Pinawa Channel of the Winnipeg River at Control Dam.

1908

Day	May		June		July		August		September		October	
	Gauge Height	Discharge										
	Feet.	Sec. ft.										
1	100.75	7,025	98.80	5,520	98.90	5,500	98.80	5,520	99.00	5,660	99.00	5,660
2	100.75	7,025	98.40	5,150	98.80	5,500	98.80	5,520	99.05	5,695	99.00	5,660
3	100.0	6,980	98.70	5,450	98.85	5,555	98.80	5,520	99.05	5,695	99.00	5,660
4	100.0	6,980	98.70	5,450	98.90	5,500	98.80	5,500	99.05	5,695	99.00	5,660
5	100.10	6,980	98.40	5,450	98.90	5,500	98.80	5,520	99.10	5,740	99.00	5,660
6	100.75	7,025	98.70	5,450	98.90	5,500	98.80	5,520	99.10	5,740	99.00	5,660
7	100.75	7,025	98.70	5,450	98.90	5,500	98.80	5,520	99.10	5,740	99.00	5,660
8	100.20	6,560	98.70	5,450	98.90	5,500	98.85	5,555	99.10	5,740	99.00	5,660
9	99.40	6,165	98.65	5,411	98.90	5,500	98.85	5,555	99.10	5,740	99.00	5,660
10	99.70	6,165	98.65	5,411	98.90	5,500	98.85	5,555	99.00	5,660	99.00	5,660
11	99.70	6,165	98.75	5,485	98.85	5,557	98.80	5,500	99.00	5,660	99.00	5,660
12	99.80	6,210	98.80	5,570	98.80	5,520	98.90	5,500	99.00	5,660	99.00	5,660
13	99.20	5,800	99.00	5,660	98.85	5,555	98.90	5,500	99.00	5,660	99.00	5,660
14	99.20	5,800	99.00	5,660	98.85	5,555	98.90	5,500	99.00	5,660	99.00	5,660
15	99.20	5,800	99.00	5,660	98.85	5,555	98.90	5,500	99.00	5,660	99.00	5,660
16	99.90	5,800	99.00	5,660	98.85	5,555	98.95	5,635	99.00	5,660	99.00	5,660
17	99.20	5,800	99.00	5,660	98.85	5,555	98.95	5,635	99.00	5,660	99.00	5,660
18	99.20	5,800	99.00	5,660	98.80	5,500	98.95	5,635	99.00	5,660	99.00	5,660
19	99.20	5,800	99.00	5,660	98.80	5,500	98.95	5,635	99.00	5,660	99.00	5,660
20	99.15	5,971	99.00	5,660	98.85	5,555	98.95	5,635	99.00	5,660	99.00	5,660
21	99.50	6,015	98.90	5,500	98.85	5,555	98.90	5,500	99.00	5,660	99.00	5,660
22	99.50	6,015	98.90	5,500	98.85	5,555	98.90	5,500	99.00	5,660	99.00	5,660
23	99.50	6,015	99.00	5,660	98.85	5,555	98.90	5,500	99.00	5,660	99.00	5,660
24	99.40	6,015	98.90	5,500	98.85	5,555	98.90	5,500	99.00	5,660	99.00	5,660
25	99.50	6,015	98.95	5,635	98.80	5,520	98.90	5,500	98.90	5,500	99.30	5,820
26	99.50	6,015	98.90	5,500	98.80	5,520	98.90	5,500	99.00	5,660	99.50	6,015
27	99.50	6,015	98.90	5,500	98.80	5,520	98.90	5,500	99.10	5,740	99.50	6,015
28	99.60	6,090	98.90	5,500	98.80	5,500	99.00	5,660	99.00	5,660	99.50	6,015
29	99.60	6,090	98.90	5,500	98.80	5,520	99.00	5,660	99.00	5,660	99.50	6,015
30	99.60	6,090	98.90	5,500	98.80	5,520	99.00	5,660	99.00	5,660	99.50	6,015
31	99.30	5,820			98.80	5,520	99.00	5,660			99.10	5,910

Table 56.—Daily Discharge of the Pinarca Channel of the Winnipeg River at Control Dam Continued.

Day.	1909											
	May.		June		July.		August		September		October	
	Gauge Height	Discharge										
	Feet.	Sq. Ft.										
1	100.30	6,640	99.85	6,280	98.60	5,388	94.60	4,200	98.50	5,370	99.00	5,660
2	100.30	6,640	99.40	6,165	98.40	5,170	98.50	5,404	98.40	5,370	99.00	5,660
3	100.30	6,640	99.85	6,280	98.60	5,388	98.60	5,485	98.50	5,370	99.00	5,660
4	100.30	6,640	99.85	6,280	98.60	5,388	98.60	5,485	98.50	5,370	98.00	5,480
5	100.30	6,640	98.10	5,640	98.65	5,414	98.80	5,570	98.70	5,450	98.40	5,480
6	100.50	6,800	98.10	5,680	98.65	5,441	98.60	5,385	98.70	5,450	98.40	5,480
7	100.60	6,890	98.15	5,680	98.65	5,441	98.10	5,560	98.80	5,500	99.00	5,800
8	100.60	6,890	98.15	5,680	98.65	5,441	98.10	5,560	98.80	5,500	99.00	5,800
9	100.60	6,890	98.15	5,680	98.65	5,441	98.10	5,560	98.80	5,500	99.00	5,800
10	100.80	7,040	98.15	5,680	98.65	5,441	98.10	5,560	98.80	5,500	99.00	5,800
11	100.90	7,160	98.10	5,680	98.60	5,410	98.80	5,570	98.80	5,500	99.00	5,800
12	101.00	7,260	98.15	5,710	98.60	5,410	98.80	5,570	98.80	5,500	99.00	6,018
13	101.05	7,310	98.10	5,710	98.60	5,410	98.80	5,570	98.80	5,500	99.00	6,018
14	101.10	7,360	98.15	5,710	98.60	5,410	98.80	5,570	98.80	5,500	99.00	6,018
15	100.00	6,400	98.15	5,710	98.60	5,410	98.80	5,570	98.80	5,500	99.00	6,018
16	99.00	5,660	98.15	5,710	98.60	5,410	98.80	5,570	98.80	5,500	99.00	6,018
17	99.30	5,800	98.18	5,710	99.00	5,660	98.80	5,570	98.80	5,500	99.00	6,018
18	99.24	5,898	98.10	5,680	99.00	5,660	98.80	5,570	99.00	5,660	99.30	6,018
19	99.60	6,030	98.10	5,680	99.00	5,660	98.80	5,570	99.00	5,660	99.30	6,018
20	99.60	6,030	98.10	5,680	99.00	5,660	98.80	5,570	99.00	5,660	100.00	6,860
21	99.40	6,090	98.10	5,680	99.10	5,740	98.80	5,670	99.00	5,660	100.00	6,860
22	99.40	6,165	98.15	5,710	99.10	5,740	98.80	5,670	99.00	5,660	100.00	6,860
23	99.65	6,420	98.10	5,680	99.10	5,740	98.80	5,670	99.00	5,660	100.00	6,860
24	99.65	6,420	98.15	5,710	99.10	5,740	98.80	5,670	99.00	5,660	100.00	6,860
25	99.65	6,420	98.10	5,680	99.10	5,740	98.80	5,670	99.00	5,660	100.00	6,860
26	99.85	6,615	98.30	5,900	99.10	5,740	98.80	5,670	99.00	5,660	100.00	6,860
27	99.85	6,615	98.30	5,900	98.60	5,385	98.80	5,440	99.00	5,660	100.65	6,980
28	99.85	6,615	98.50	5,970	98.50	5,320	98.80	5,440	99.00	5,660	100.00	6,980
29	99.10	6,165	98.60	5,385	98.50	5,340	99.30	4,630	99.00	6,630	100.00	6,980
30	99.80	6,240	98.60	5,385	98.50	5,340	98.80	5,440	99.00	6,630	100.00	6,980
31	99.80	6,240	98.60	5,385	98.50	5,340	98.80	5,440	99.00	6,630	100.00	6,980

Note.—Below gauge height 100.50 the rating given in the wood block.

1910

1	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.3	8,000
2	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
3	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
4	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
5	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
6	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
7	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
8	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
9	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
10	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
11	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
12	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
13	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
14	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
15	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
16	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
17	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
18	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
19	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
20	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
21	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
22	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
23	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
24	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
25	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
26	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
27	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
28	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
29	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
30	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000
31	104.3	10,975	104.4	10,880	99.6	6,090	99.4	5,400	99.0	8,660	99.4	8,000

Note.—Gauge height 104.3 to 104.4, 10,975; 104.4 to 104.5, 10,880; 104.5 to 104.6, 10,785; 104.6 to 104.7, 10,690; 104.7 to 104.8, 10,595; 104.8 to 104.9, 10,500; 104.9 to 105.0, 10,405; 105.0 to 105.1, 10,310; 105.1 to 105.2, 10,215; 105.2 to 105.3, 10,120; 105.3 to 105.4, 10,025; 105.4 to 105.5, 9,930; 105.5 to 105.6, 9,835; 105.6 to 105.7, 9,740; 105.7 to 105.8, 9,645; 105.8 to 105.9, 9,550; 105.9 to 106.0, 9,455; 106.0 to 106.1, 9,360; 106.1 to 106.2, 9,265; 106.2 to 106.3, 9,170; 106.3 to 106.4, 9,075; 106.4 to 106.5, 8,980; 106.5 to 106.6, 8,885; 106.6 to 106.7, 8,790; 106.7 to 106.8, 8,695; 106.8 to 106.9, 8,600; 106.9 to 107.0, 8,505; 107.0 to 107.1, 8,410; 107.1 to 107.2, 8,315; 107.2 to 107.3, 8,220; 107.3 to 107.4, 8,125; 107.4 to 107.5, 8,030; 107.5 to 107.6, 7,935; 107.6 to 107.7, 7,840; 107.7 to 107.8, 7,745; 107.8 to 107.9, 7,650; 107.9 to 108.0, 7,555; 108.0 to 108.1, 7,460; 108.1 to 108.2, 7,365; 108.2 to 108.3, 7,270; 108.3 to 108.4, 7,175; 108.4 to 108.5, 7,080; 108.5 to 108.6, 6,985; 108.6 to 108.7, 6,890; 108.7 to 108.8, 6,795; 108.8 to 108.9, 6,700; 108.9 to 109.0, 6,605; 109.0 to 109.1, 6,510; 109.1 to 109.2, 6,415; 109.2 to 109.3, 6,320; 109.3 to 109.4, 6,225; 109.4 to 109.5, 6,130; 109.5 to 109.6, 6,035; 109.6 to 109.7, 5,940; 109.7 to 109.8, 5,845; 109.8 to 109.9, 5,750; 109.9 to 110.0, 5,655; 110.0 to 110.1, 5,560; 110.1 to 110.2, 5,465; 110.2 to 110.3, 5,370; 110.3 to 110.4, 5,275; 110.4 to 110.5, 5,180; 110.5 to 110.6, 5,085; 110.6 to 110.7, 4,990; 110.7 to 110.8, 4,895; 110.8 to 110.9, 4,800; 110.9 to 111.0, 4,705; 111.0 to 111.1, 4,610; 111.1 to 111.2, 4,515; 111.2 to 111.3, 4,420; 111.3 to 111.4, 4,325; 111.4 to 111.5, 4,230; 111.5 to 111.6, 4,135; 111.6 to 111.7, 4,040; 111.7 to 111.8, 3,945; 111.8 to 111.9, 3,850; 111.9 to 112.0, 3,755; 112.0 to 112.1, 3,660; 112.1 to 112.2, 3,565; 112.2 to 112.3, 3,470; 112.3 to 112.4, 3,375; 112.4 to 112.5, 3,280; 112.5 to 112.6, 3,185; 112.6 to 112.7, 3,090; 112.7 to 112.8, 2,995; 112.8 to 112.9, 2,900; 112.9 to 113.0, 2,805; 113.0 to 113.1, 2,710; 113.1 to 113.2, 2,615; 113.2 to 113.3, 2,520; 113.3 to 113.4, 2,425; 113.4 to 113.5, 2,330; 113.5 to 113.6, 2,235; 113.6 to 113.7, 2,140; 113.7 to 113.8, 2,045; 113.8 to 113.9, 1,950; 113.9 to 114.0, 1,855; 114.0 to 114.1, 1,760; 114.1 to 114.2, 1,665; 114.2 to 114.3, 1,570; 114.3 to 114.4, 1,475; 114.4 to 114.5, 1,380; 114.5 to 114.6, 1,285; 114.6 to 114.7, 1,190; 114.7 to 114.8, 1,095; 114.8 to 114.9, 1,000; 114.9 to 115.0, 910; 115.0 to 115.1, 820; 115.1 to 115.2, 730; 115.2 to 115.3, 640; 115.3 to 115.4, 550; 115.4 to 115.5, 460; 115.5 to 115.6, 370; 115.6 to 115.7, 280; 115.7 to 115.8, 190; 115.8 to 115.9, 100; 115.9 to 116.0, 100.



Table 56. Daily Discharge of the Pimawica Channel of the Winnipeg River at Control Dam—Continued.

		1913.			
Day	June		July		
	Gauge Height	Dis. charge	Gauge Height	Dis. charge	
	Feet	Sec. ft.	Feet	Sec. ft.	
1	103.60	10,200			
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16	103.50	10,400			
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

		1914.											
Day	May.		June.		July.		August.		September.		October.		
	Gauge Height	Dis. charge											
	Feet	Sec. ft.											
1	102.20	8,500			103.89	10,600	103.73	10,100	103.41	10,000	103.10	9,600	
2	102.20	8,500			103.90	10,600	103.71	10,300	103.40	10,000	103.10	9,600	
3	102.20	8,500			103.93	10,600	103.70	10,300	103.37	9,933	103.10	9,600	
4	102.20	8,500			103.93	10,600	103.71	10,300	103.35	9,900	103.10	9,600	
5	102.30	8,680			103.90	10,600	103.69	10,300	103.36	9,950	103.05	9,550	
6	102.40	8,840			103.90	10,600	103.65	10,300	103.29	9,880	103.05	9,550	
7	102.50	8,880			103.90	10,600	103.60	10,300	103.28	9,870	103.05	9,550	
8	102.40	8,750			103.90	10,600	103.65	10,300	103.26	9,800	103.05	9,550	
9	102.40	8,750			103.87	10,600	103.65	10,300	103.24	9,750	103.10	9,600	
10					103.90	10,600	103.67	10,300	103.20	9,750	103.10	9,600	
11					103.87	10,600	103.67	10,300	103.20	9,750	103.15	9,650	
12			103.65	10,300	103.87	10,600	103.67	10,300	103.20	9,750	103.15	9,650	
13			103.68	10,300	103.85	10,300	103.59	10,200	103.17	9,700	103.15	9,650	
14			103.67	10,300	103.91	10,300	103.59	10,200	103.15	9,680	103.20	9,750	
15			103.70	10,400	103.90	10,300	103.59	10,300	103.14	9,650	103.20	9,750	
16			103.70	10,400	103.93	10,600	103.59	10,200	103.16	9,690	103.20	9,750	
17			103.70	10,400	103.90	10,600	103.59	10,200	103.13	9,670	103.20	9,750	
18			103.75	10,500	103.87	10,600	103.58	10,200	103.13	9,650	103.20	9,750	
19			103.67	10,500	103.85	10,500	103.57	10,200	103.12	9,600	103.20	9,750	
20			103.80	10,500	103.87	10,600	103.57	11,200	103.10	9,650	103.20	9,750	
21			103.80	10,500	103.87	10,600	103.57	10,200	103.10	9,600	103.15	9,650	
22			103.81	10,500	103.85	10,500	103.57	10,200	103.10	9,600	103.15	9,650	
23			103.80	10,500	103.81	10,500	103.57	10,200	103.10	9,550	103.15	9,650	
24			103.82	10,500	103.81	10,500	103.57	10,200	103.13	9,650	103.10	9,600	
25			103.82	10,500	103.87	10,500	103.57	10,200	103.15	9,680	103.10	9,600	
26			103.83	10,500	103.87	10,500	103.57	10,200	103.17	9,750	103.00	9,500	
27			103.85	10,500	103.87	10,500	103.57	10,200	103.15	9,680	103.00	9,500	
28			103.83	10,500	103.80	10,300	103.56	10,200	103.15	9,600	103.00	9,500	
29			103.84	10,500	103.79	10,500	103.54	10,100	103.10	9,600	102.95	9,400	
30			103.90	10,600	103.77	10,400	103.51	10,100	103.10	9,600	102.90	9,350	
31					103.75	10,400	103.48	10,100			102.90	9,350	

Note: Gauge height marked † interpolated.

Table 57. — Monthly Discharge of the Pinawa Channel of the Winnipeg River at Control Dam.

Month		DISCHARGE IN SECOND FEET		
		Maximum	Minimum	Mean
	1908			
May	..			
June	..	7,025	5,800	6,250
July	..	5,660	5,417	5,550
August	..	5,690	5,820	5,550
September	..	5,660	5,550	5,600
October	..	5,730	5,590	5,650
		6,015	5,660	5,750
	1909			
May	..			
June	..	7,560	5,860	6,150
July	..	6,660	5,080	5,300
August	..	5,700	5,320	5,500
September	..	5,385	4,100	5,200
October	..	5,660	5,350	5,500
		6,800	5,150	6,150
	1910			
May	..			
June	..	11,375	10,735	11,000
July	..	10,850	6,340	9,500
August	..	6,090	5,700	5,900
September	..	5,730	5,500	5,600
October	..	5,730	5,590	5,600
		6,800	5,730	6,900
	1911			
May	..			
June	..	8,975	8,300	8,700
July	..	9,350	8,975	9,150
August	..	9,735	9,350	9,600
September	..	9,735	9,735	9,750
October	..	9,600	9,600	9,600
		9,725	7,000	8,200
	1912			
May	..			
June	..	10,100	8,850	9,250
July	..	10,225	9,975	10,000
August	..			
September	..		7,200	
	1913			
June	..			
July	..	10,600	10,300	10,100
August	..	10,700	10,100	10,100
September	..	10,300	10,100	10,200
October	..	10,000	9,600	9,700
		9,750	9,350	9,600

NOTE. — Discharges marked with .. are estimated.

#### WEST BRANCH WINNIPEG RIVER AT NORTH FUNNEL ISLAND.

NOTE. — Records at this station have been used in computing the discharge since 1907 for the western outlet and Keewatin mills. This rating is only applicable for the period subsequent to the damming of the eastern outlet in 1906. The discharges in Tables 58 and 59 record the above discharges of the western outlets plus that of the eastern outlet, i.e., the total outflow from the Lake of the Woods.

*Location of Gauge.* — On pile at south end of traffic bridge below Keewatin. *Records available.* — January 1, 1907, to December 31, 1914.

*Drainage area.* — 26,400 square miles. This applies to the combined flow of the West and East branches of the Winnipeg river at the Lake of the Woods outlets.

*Gauge.*—Vertical staff. Previous to June 29, 1912, gauge heights were obtained from the Ontario Department of Public Works. They were referred to a chain gauge located in the tail-race of mill A, Lake of the Woods Milling Co., Keewatin. On the above date a gauge was established by the Manitoba Hydrographic Survey on the traffic bridge below Keewatin.

*Channel.*—Permanent, rock

*Discharge measurements.* Discharge measurements for the purposes of rating the station have been made since 1912 at a section 1 mile below the station, on the north side of Tunnel island, by the Manitoba Hydrographic Survey.

*Winter Flow.* Discharge measurements indicate that the open-water discharge curve is applicable during winter months.


*Control.* The flow is controlled by the operation of the Norman dam and the Lake of the Woods Milling Company's power plants. Some 12 miles downstream from the station the river breaks into two narrow channels, one through the Dalles and one through Throat rapids, both acting as partial controls on the discharging capacity of the river.

*Accuracy.* The estimated daily discharges, as tabulated from 1907 to 1912, are based on gauge heights furnished by the Ontario Department of Public Works. These records are at times in error, and the estimated discharges are therefore subject to correction.



# MICROCOPY RESOLUTION TEST CHART

(ANSI and ISO TEST CHART No. 2)



**APPLIED IMAGE Inc**

1653 East Main Street  
Rochester, New York 14609 USA  
(716) 482 - 0300 - Phone  
(716) 288 - 5989 - Fax

Table 58.—Total Daily Discharge of the Winnipeg River at Outlets of Lake of the Woods, Ontario.

NOTE.—The run-off data for this station may be slightly revised when the investigations of the Lake of the Woods Technical Board are completed.

[Drainage area, 26,400 square miles.]

1907.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1	.....	12,080	.....	11,530	.....	10,980	.....	10,100	.....	10,430	.....	11,420
2	.....	12,080	.....	11,530	.....	10,980	.....	10,100	.....	10,430	.....	11,420
3	.....	12,080	.....	11,530	.....	10,980	.....	10,100	.....	10,430	.....	11,420
4	.....	12,080	.....	11,420	.....	10,980	.....	10,100	.....	10,430	.....	11,530
5	.....	11,860	.....	11,420	.....	10,760	.....	10,100	.....	10,540	.....	11,640
6	.....	11,860	.....	11,420	.....	10,760	.....	10,100	.....	10,510	.....	12,740
7	.....	11,860	.....	11,420	.....	10,760	.....	10,100	.....	10,760	.....	13,180
8	.....	11,860	.....	11,420	.....	10,760	.....	10,320	.....	10,760	.....	13,290
9	.....	11,860	.....	11,310	.....	10,760	.....	10,320	.....	10,870	.....	13,490
10	.....	11,860	.....	11,310	.....	10,760	.....	10,320	.....	10,870	.....	13,400
11	.....	11,860	.....	11,310	.....	10,760	.....	10,320	.....	10,980	.....	13,730
12	.....	11,860	.....	11,310	.....	10,760	.....	10,320	.....	11,090	.....	14,060
13	.....	11,860	.....	11,310	.....	10,760	.....	10,320	.....	11,310	.....	14,280
14	.....	11,860	.....	11,310	.....	10,760	.....	10,320	.....	11,420	.....	14,500
15	.....	11,860	.....	11,200	.....	10,760	.....	10,320	.....	11,420	.....	14,500
16	.....	11,860	.....	11,200	.....	10,760	.....	10,320	.....	11,530	.....	14,720
17	.....	11,860	.....	11,200	.....	10,760	.....	10,320	.....	11,420	.....	14,720
18	.....	11,860	.....	11,200	.....	10,650	.....	10,320	.....	11,420	.....	14,720
19	.....	11,860	.....	11,090	.....	10,650	.....	10,320	.....	11,530	.....	14,830
20	.....	11,860	.....	11,090	.....	10,540	.....	10,320	.....	11,530	.....	14,940
21	.....	11,860	.....	11,090	.....	10,540	.....	10,320	.....	11,640	.....	14,940
22	.....	11,640	.....	11,090	.....	10,540	.....	10,320	.....	11,640	.....	14,940
23	.....	11,640	.....	11,090	.....	10,540	.....	10,320	.....	11,640	.....	15,160
24	.....	11,640	.....	11,090	.....	10,430	.....	10,320	.....	11,640	.....	15,160
25	.....	11,530	.....	11,090	.....	10,430	.....	10,320	.....	11,640	.....	15,160
26	.....	11,530	.....	10,980	.....	10,320	.....	10,320	.....	11,420	.....	15,160
27	.....	11,530	.....	10,980	.....	10,320	.....	10,320	.....	11,420	.....	15,160
28	.....	11,530	.....	10,980	.....	10,320	.....	10,430	.....	11,420	.....	15,160
29	.....	11,530	.....	10,980	.....	10,210	.....	10,430	.....	11,420	.....	15,380
30	.....	11,530	.....	10,980	.....	10,210	.....	10,430	.....	11,420	.....	15,380
31	.....	11,530	.....	10,980	.....	10,100	.....	10,430	.....	11,420	.....	15,380

	July.		August.		September.		October.		November.		December.	
	Discharge.											
1	.....	15,160	.....	12,740	.....	15,054	.....	19,687	.....	21,466	.....	20,347
2	.....	15,160	.....	12,520	.....	15,287	.....	19,797	.....	21,477	.....	20,439
3	.....	14,940	.....	12,300	.....	15,494	.....	19,687	.....	21,447	.....	20,386
4	.....	14,940	.....	12,300	.....	15,494	.....	20,127	.....	21,227	.....	20,290
5	.....	15,160	.....	12,520	.....	15,714	.....	20,127	.....	21,243	.....	20,277
6	.....	14,940	.....	12,520	.....	15,824	.....	20,347	.....	21,451	.....	20,164
7	.....	14,940	.....	12,300	.....	15,934	.....	20,347	.....	21,469	.....	20,183
8	.....	14,720	.....	12,300	.....	16,154	.....	20,347	.....	21,459	.....	20,127
9	.....	14,720	.....	12,300	.....	16,044	.....	20,581	.....	21,258	.....	20,164
10	.....	14,720	.....	12,080	.....	16,044	.....	20,581	.....	21,241	.....	19,936
11	.....	14,500	.....	12,080	.....	16,154	.....	20,691	.....	21,247	.....	19,988
12	.....	14,060	.....	12,080	.....	16,264	.....	20,787	.....	21,028	.....	19,878
13	.....	14,060	.....	12,300	.....	16,264	.....	20,787	.....	21,480	.....	19,755
14	.....	14,060	.....	12,080	.....	16,484	.....	20,787	.....	21,480	.....	19,794
15	.....	14,060	.....	12,300	.....	16,581	.....	20,787	.....	21,461	.....	19,674
16	.....	14,060	.....	12,300	.....	16,814	.....	20,787	.....	21,477	.....	19,520
17	.....	14,060	.....	12,080	.....	16,801	.....	20,801	.....	21,227	.....	19,574
18	.....	14,060	.....	12,520	.....	17,131	.....	20,897	.....	21,241	.....	19,526
19	.....	11,060	.....	12,520	.....	17,254	.....	20,897	.....	21,020	.....	19,438
20	.....	13,620	.....	12,960	.....	17,254	.....	21,007	.....	21,040	.....	19,410
21	.....	13,620	.....	13,721	.....	17,571	.....	21,007	.....	21,034	.....	19,439
22	.....	13,490	.....	13,721	.....	17,914	.....	21,037	.....	20,827	.....	19,250
23	.....	13,180	.....	13,941	.....	18,341	.....	21,227	.....	20,810	.....	19,398
24	.....	13,180	.....	14,149	.....	18,574	.....	21,227	.....	20,677	.....	19,379
25	.....	13,180	.....	13,954	.....	18,794	.....	21,227	.....	20,590	.....	19,307
26	.....	13,180	.....	14,284	.....	19,247	.....	21,328	.....	20,374	.....	19,307
27	.....	13,290	.....	14,601	.....	19,247	.....	21,461	.....	20,374	.....	19,399
28	.....	13,490	.....	14,724	.....	19,357	.....	21,417	.....	20,371	.....	19,359
29	.....	13,400	.....	14,834	.....	19,687	.....	21,667	.....	20,372	.....	19,202
30	.....	13,180	.....	14,834	.....	19,687	.....	21,672	.....	20,385	.....	19,379
31	.....	12,740	.....	14,821	.....	19,687	.....	21,447	.....	20,385	.....	19,376

Table 58.—Total Daily Discharge of the Winnipeg River at Outlets of Lake of the Woods, Ontario.—Continued

1908.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1	19, 278	19, 002	17, 04	16, 95	16, 841	16, 855	16, 841	16, 841	16, 841	16, 855	21, 050	
2	19, 308	18, 870	17, 07	16, 951	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	21, 284	
3	19, 295	18, 870	17, 07	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	21, 284	
4	19, 300	18, 892	17, 286	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	21, 506	
5	19, 241	18, 780	17, 288	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	22, 166	
6	19, 345	18, 670	17, 385	17, 061	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	23, 266	
7	19, 348	18, 671	17, 382	17, 061	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	23, 284	
8	19, 325	18, 434	17, 597	17, 061	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	23, 064	
9	19, 327	18, 413	17, 597	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	23, 064	
10	19, 347	18, 430	17, 710	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	23, 064	
11	19, 318	18, 430	17, 714	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	23, 284	
12	19, 234	18, 320	17, 707	16, 811	16, 811	16, 811	16, 811	16, 811	16, 811	16, 811	23, 724	
13	19, 314	18, 321	17, 597	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	23, 724	
14	19, 304	18, 319	17, 607	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	23, 914	
15	19, 261	18, 321	17, 487	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	23, 504	
16	19, 267	18, 193	17, 499	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	23, 504	
17	19, 261	18, 193	17, 492	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	23, 284	
18	19, 277	18, 101	17, 187	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	16, 841	23, 284	
19	19, 247	18, 100	17, 377	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	23, 064	
20	19, 250	18, 102	17, 377	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	23, 064	
21	19, 261	18, 102	17, 377	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	23, 064	
22	19, 045	17, 882	17, 267	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	22, 844	
23	19, 050	17, 863	17, 281	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	22, 844	
24	1 044	17, 880	17, 171	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	22, 844	
25	18, 944	17, 683	17, 207	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	16, 855	22, 844	
26	18, 917	17, 687	17, 171	16, 965	16, 965	16, 965	16, 965	16, 965	16, 965	16, 965	22, 624	
27	18, 942	17, 468	17, 061	16, 965	16, 965	16, 965	16, 965	16, 965	16, 965	16, 965	22, 624	
28	18, 829	17, 468	17, 061	16, 965	16, 965	16, 965	16, 965	16, 965	16, 965	16, 965	22, 624	
29	18, 834	17, 262	17, 061	16, 965	16, 965	16, 965	16, 965	16, 965	16, 965	16, 965	22, 642	
30	18, 913	17, 061	17, 061	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	22, 642	
31	18, 830	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	16, 951	22, 642	

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1	22, 624	20, 884	19, 370	17, 661	14, 013	11, 364						
2	22, 404	20, 864	19, 347	17, 061	14, 041	11, 379						
3	22, 404	20, 754	19, 110	16, 884	13, 924	11, 168						
4	22, 195	20, 877	19, 128	16, 858	13, 926	11, 180						
5	22, 191	20, 653	18, 872	17, 066	13, 813	11, 222						
6	22, 404	20, 647	18, 863	16, 855	13, 814	11, 141						
7	22, 404	20, 428	18, 851	16, 415	13, 827	11, 011						
8	22, 624	20, 661	18, 639	16, 201	14, 067	10, 800						
9	22, 184	20, 644	18, 638	16, 455	13, 796	10, 577						
10	22, 404	20, 429	18, 634	16, 463	13, 822	10, 795						
11	22, 404	20, 323	18, 432	16, 449	13, 601	10, 575						
12	22, 184	20, 314	18, 597	16, 231	13, 600	10, 572						
13	21, 964	20, 213	18, 180	13, 381	13, 607	10, 270						
14	21, 964	20, 322	18, 199	15, 356	13, 494	10, 350						
15	21, 744	20, 350	17, 973	15, 148	13, 353	10, 349						
16	21, 744	20, 204	17, 983	14, 714	12, 931	10, 354						
17	21, 524	20, 428	17, 981	14, 951	12, 500	10, 354						
18	21, 524	20, 429	18, 200	14, 879	12, 266	10, 582						
19	21, 524	20, 645	18, 013	14, 666	11, 826	10, 137						
20	21, 634	20, 430	17, 755	14, 694	11, 826	10, 118						
21	21, 741	20, 218	17, 740	14, 675	11, 810	10, 353						
22	21, 304	20, 213	17, 941	14, 907	11, 562	10, 334						
23	21, 304	19, 981	17, 735	14, 911	11, 591	10, 328						
24	21, 304	19, 985	17, 516	14, 925	11, 596	10, 317						
25	21, 541	20, 000	17, 527	14, 687	11, 599	10, 315						
26	21, 304	19, 801	17, 320	14, 470	11, 820	10, 320						
27	21, 084	19, 783	17, 295	14, 472	11, 600	10, 303						
28	21, 084	19, 565	17, 095	14, 469	11, 602	10, 322						
29	21, 084	19, 786	17, 528	14, 253	11, 571	10, 316						
30	21, 084	19, 769	17, 520	14, 258	11, 600	10, 320						
31	21, 085	19, 575	17, 520	14, 262	11, 600	10, 343						

Table 58.—Total Daily Discharge of the Winnipeg River at Outlets of Lake of the Woods, Ontario—Continued.

1909.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge.	Gauge Height.	Discharge.	Gauge Height	Discharge.						
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1		10,360		9,542		10,549		11,095		10,446		11,730
2		10,360		9,481		10,528		11,021		10,163		11,940
3		10,360		9,909		10,745		11,007		10,315		11,951
4		10,360		9,919		10,730		10,757		10,615		11,986
5		10,140		9,957		10,780		11,082		10,718		11,743
6		10,140		9,754		10,722		11,229		10,754		11,515
7		10,209		9,701		10,591		11,101		10,684		11,935
8		10,199		9,819		10,761		11,026		10,405		11,931
9		10,239		9,793		10,348		11,011		10,357		11,974
10		10,194		9,848		10,824		10,807		10,625		11,732
11		10,139		9,848		10,803		10,812		11,050		11,516
12		10,241		9,875		10,695		11,171		11,010		11,503
13		10,247		9,915		10,716		11,323		10,920		11,294
14		10,238		9,812		10,777		11,316		10,967		11,714
15		10,233		9,938		10,998		11,304		10,950		11,725
16		10,229		9,898		11,074		11,265		10,544		11,730
17		10,169		10,131		11,047		11,025		10,884		11,735
18		10,178		10,123		11,008		10,571		11,129		11,739
19		9,955		10,307		10,987		10,610		11,286		11,892
20		9,693		10,328		10,957		10,788		11,589		11,729
21		9,714		10,137		10,980		10,805		11,577		11,701
22		9,700		10,316		11,119		10,889		11,566		11,674
23		9,698		10,308		11,127		10,873		11,210		11,931
24		9,475		10,401		11,139		10,857		11,321		11,931
25		9,490		10,397		11,142		10,058		11,717		11,924
26		9,465		10,507		11,143		10,421		11,495		11,711
27		9,476		10,509		11,128		10,706		11,507		11,509
28		9,514		10,507		10,968		10,370		11,516		11,931
29		9,527				11,066		10,323		11,735		11,921
30		9,561				11,016		10,437		11,545		11,918
31		9,546				11,101				11,723		

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge.	Gauge Height.	Discharge.	Gauge Height	Discharge.						
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1		11,730		11,726		11,756		12,439		11,735		12,158
2		11,932		11,737		12,015		12,206		12,064		12,172
3		11,929		11,914		12,123		11,852		12,190		12,174
4		11,717		11,713		12,059		12,123		12,154		11,884
5		11,939		11,713		11,737		12,411		12,139		11,613
6		11,716		11,562		11,758		12,222		12,116		11,970
7		11,711		11,725		11,718		12,227		11,639		12,120
8		11,934		11,290		11,787		11,856		11,842		12,133
9		12,050		11,689		11,690		12,036		12,036		12,045
10		12,068		11,694		11,697		11,852		11,869		12,050
11		11,731		11,742		11,864		11,352		11,920		11,900
12		11,721		11,663		11,749		11,609		12,138		11,546
13		11,930		11,359		11,586		11,839		11,989		11,836
14		11,946		11,539		11,602		11,839		11,672		11,930
15		11,953		11,509		11,928		12,043		12,112		11,982
16		11,950		11,683		145		12,079		12,110		11,973
17		11,954		11,914		12		11,429		12,162		11,965
18		11,729		11,897		913		11,524		12,141		11,812
19		11,918		11,834		11,736		12,074		12,135		11,614
20		11,930		11,506		12,108		12,100		12,035		11,853
21		11,929		11,539		11,915		12,327		11,719		11,953
22		11,739		11,499		11,931		12,332		12,004		11,928
23		11,751		11,772		12,032		12,335		12,136		11,967
24		11,935		11,773		12,202		11,853		12,125		11,957
25		11,718		11,980		12,450		12,069		12,195		11,605
26		11,912		11,975		11,827		12,309		12,239		11,530
27		11,919		11,978		11,963		12,122		12,183		11,819
28		11,909		11,775		12,214		12,086		11,710		11,977
29		11,751		11,727		12,229		12,080		12,012		11,982
30		11,751		11,536		12,227		11,904		12,112		11,974
31		11,763		11,534				11,626				11,967

Table 58.—Total Daily Discharge of the Winnipeg River at Outlets of Lake of the Woods, Ontar.o. —Continued.

1910.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.	Feet.	Sec.								
11,730	1	11,848	11,656	11,889	20,907	21,540	23,557					
11,940	2	11,636	11,766	11,930	21,090	21,815	21,058					
11,951	3	11,906	11,770	11,601	20,854	25,041	23,971					
11,986	4	12,000	11,787	11,601	21,155	26,238	23,772					
11,743	5	12,001	11,794	11,585	21,312	25,222	23,593					
11,515	6	11,977	11,565	11,707	21,487	24,091	23,724					
11,935	7	11,552	11,761	11,705	21,705	21,919	23,725					
11,931	8	11,656	11,750	11,696	21,496	24,550	22,844					
11,974	9	11,424	11,910	11,719	21,371	24,516	22,398					
11,732	10	11,630	11,921	11,896	20,987	21,845	21,740					
11,516	11	11,706	11,902	13,596	21,269	21,701	21,281					
11,503	12	11,738	11,665	13,336	21,665	25,145	20,830					
11,294	13	11,740	11,548	12,826	21,680	25,121	21,131					
11,714	14	11,719	11,787	12,973	21,669	21,913	21,094					
11,725	15	11,488	11,915	12,918	21,746	24,556	21,125					
11,730	16	11,356	11,679	13,142	21,631	24,862	21,106					
11,735	17	11,546	11,913	13,150	21,187	25,111	21,093					
11,739	18	11,703	11,921	13,332	21,749	24,592	20,995					
11,892	19	11,685	11,781	13,377	22,191	24,981	20,956					
11,729	20	11,708	11,572	13,109	22,358	24,704	21,094					
11,701	21	11,699	11,833	13,408	22,381	25,082	21,318					
11,674	23	11,607	11,935	13,415	22,825	24,213	21,226					
11,931	23	11,340	11,931	17,783	22,735	24,515	21,083					
11,931	24	11,558	11,920	17,918	22,501	23,920	21,057					
11,924	25	11,675	11,918	18,141	22,770	24,428	21,150					
11,711	26	11,676	11,704	18,208	23,233	24,584	20,958					
11,509	27	11,643	11,583	17,835	23,707	24,346	21,079					
11,931	28	11,663	11,789	17,980	24,117	24,667	21,437					
11,921	29	11,562	.....	18,259	24,813	23,904	21,205					
11,918	30	11,327	.....	19,766	24,949	23,988	21,254					
.....	31	11,575	.....	20,402	.....	24,100	.....					

Day.	July.	August.	September.	October.	November.	December.	
	12,158	1	20,921	13,986	11,584	11,135	9,360
12,172	2	20,862	11,167	11,793	10,760	9,207	8,581
12,174	3	20,745	14,190	11,795	11,160	9,045	8,335
11,884	4	20,192	13,970	11,739	11,445	8,613	7,957
11,613	5	20,375	13,970	11,796	11,488	9,121	8,305
11,970	6	20,457	11,150	11,813	11,192	8,217	8,437
12,120	7	20,449	13,722	12,046	11,233	8,634	8,362
12,133	8	17,351	13,791	12,092	11,100	8,846	8,214
12,045	9	16,525	13,982	11,936	10,563	8,869	8,210
12,050	10	16,098	13,760	11,749	10,364	8,957	8,216
11,900	11	15,996	13,548	11,735	10,416	8,957	7,809
11,546	12	15,988	13,394	12,084	10,428	8,917	8,042
11,836	13	15,764	17,508	11,711	10,441	8,478	8,187
11,930	14	15,560	17,419	11,809	9,983	8,645	8,168
11,982	15	15,513	12,957	11,960	9,832	8,890	8,170
11,973	16	15,364	13,049	11,968	9,458	8,868	8,196
11,965	17	14,952	12,893	11,960	9,766	9,010	8,070
11,812	18	15,067	12,671	11,539	10,154	8,996	7,660
12,614	19	14,858	12,785	11,919	10,188	8,712	8,085
11,853	20	14,664	12,455	11,822	10,026	8,272	8,172
11,953	21	14,800	12,189	11,864	9,721	8,654	8,169
11,928	22	14,588	12,195	11,881	9,746	8,719	8,170
11,967	23	14,574	12,253	11,656	9,345	8,800	8,073
11,957	24	14,473	12,153	11,703	9,489	8,551	8,094
11,605	25	14,310	12,397	11,231	9,545	8,790	7,721
11,530	26	14,131	12,157	11,192	9,594	8,818	7,651
11,819	27	14,349	11,943	11,362	9,542	8,276	7,818
11,977	28	14,352	11,748	11,673	9,599	8,681	7,982
11,982	29	14,017	12,268	11,640	9,512	8,730	7,916
11,974	30	13,913	11,886	11,441	9,053	8,828	8,005
11,967	31	13,713	11,564	.....	9,329	.....	7,991

Table 58.—Total Daily Discharge of the Winnipeg River at Outlets of Lake of the Woods, Ontario—Continued.

1911.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1	.....	7,788	.....	7,304	.....	7,125	.....	8,628	.....	8,717	.....	8,522
2	.....	7,987	.....	7,212	.....	7,129	.....	8,593	.....	9,161	.....	8,517
3	.....	8,088	.....	7,247	.....	7,140	.....	8,618	.....	9,159	.....	8,733
4	.....	8,084	.....	7,066	.....	7,064	.....	8,861	.....	9,152	.....	8,585
5	.....	8,088	.....	6,732	.....	6,602	.....	9,018	.....	9,154	.....	8,657
6	.....	8,081	.....	7,117	.....	6,586	.....	9,008	.....	9,100	.....	9,041
7	.....	7,994	.....	7,269	.....	6,829	.....	9,114	.....	8,645	.....	9,149
8	.....	7,502	.....	7,218	.....	6,888	.....	8,971	.....	8,791	.....	9,172
9	.....	7,802	.....	7,236	.....	6,927	.....	8,558	.....	9,116	.....	9,152
10	.....	7,985	.....	7,236	.....	6,548	.....	8,815	.....	9,007	.....	9,048
11	.....	7,976	.....	7,241	.....	6,161	.....	9,096	.....	9,011	.....	8,707
12	.....	7,988	.....	6,733	.....	6,420	.....	9,085	.....	9,156	.....	8,662
13	.....	7,838	.....	7,117	.....	6,424	.....	9,201	.....	8,950	.....	9,019
14	.....	7,987	.....	7,230	.....	6,955	.....	9,181	.....	8,473	.....	9,127
15	.....	7,586	.....	7,201	.....	6,957	.....	9,312	.....	8,558	.....	9,150
16	.....	7,801	.....	7,129	.....	6,964	.....	8,814	.....	8,927	.....	9,151
17	.....	7,970	.....	7,187	.....	6,957	.....	8,936	.....	8,851	.....	9,160
18	.....	7,975	.....	6,940	.....	6,954	.....	9,153	.....	8,799	.....	8,624
19	.....	7,784	.....	6,711	.....	6,455	.....	9,171	.....	8,851	.....	8,829
20	.....	7,763	.....	7,935	.....	6,589	.....	9,292	.....	8,904	.....	9,326
21	.....	7,675	.....	7,131	.....	7,011	.....	9,174	.....	8,453	.....	8,797
22	.....	7,283	.....	7,116	.....	7,060	.....	9,174	.....	8,315	.....	8,540
23	.....	7,381	.....	7,164	.....	7,068	.....	8,806	.....	8,688	.....	9,149
24	.....	7,551	.....	7,142	.....	6,937	.....	8,835	.....	8,375	.....	9,374
25	.....	7,534	.....	7,151	.....	7,049	.....	9,144	.....	8,599	.....	8,870
26	.....	7,554	.....	6,817	.....	6,575	.....	9,122	.....	8,273	.....	9,041
27	.....	7,160	.....	7,187	.....	6,894	.....	9,109	.....	8,536	.....	9,387
28	.....	7,254	.....	7,147	.....	7,054	.....	9,248	.....	8,208	.....	9,176
29	.....	6,886	.....	.....	.....	7,037	.....	9,172	.....	8,421	.....	8,747
30	.....	6,997	.....	.....	.....	6,591	.....	8,695	.....	8,727	.....	8,901
31	.....	7,286	.....	.....	.....	6,581	.....	.....	.....	8,718	.....	.....

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1	.....	8,779	.....	8,566	.....	6,872	.....	5,806	.....	5,911	.....	5,450
2	.....	8,719	.....	8,341	.....	6,776	.....	5,991	.....	5,919	.....	5,612
3	.....	8,821	.....	8,343	.....	6,725	.....	6,214	.....	5,745	.....	5,094
4	.....	9,123	.....	8,235	.....	6,598	.....	6,015	.....	5,779	.....	5,463
5	.....	8,796	.....	8,230	.....	6,982	.....	6,185	.....	5,112	.....	5,629
6	.....	8,789	.....	8,100	.....	6,601	.....	6,196	.....	5,564	.....	5,680
7	.....	8,930	.....	8,138	.....	6,751	.....	6,381	.....	5,907	.....	5,690
8	.....	9,097	.....	8,122	.....	6,768	.....	5,778	.....	5,785	.....	5,563
9	.....	8,815	.....	8,125	.....	6,401	.....	5,601	.....	5,736	.....	5,675
10	.....	9,003	.....	8,160	.....	6,196	.....	6,029	.....	5,716	.....	5,078
11	.....	9,139	.....	8,131	.....	6,247	.....	6,213	.....	5,817	.....	5,306
12	.....	8,748	.....	8,244	.....	6,722	.....	6,046	.....	5,272	.....	5,581
13	.....	9,091	.....	7,988	.....	6,903	.....	6,254	.....	5,490	.....	5,443
14	.....	9,361	.....	8,248	.....	7,123	.....	6,268	.....	5,749	.....	5,666
15	.....	7,16	.....	8,250	.....	7,311	.....	5,498	.....	5,751	.....	5,701
16	.....	8,730	.....	8,261	.....	7,116	.....	5,769	.....	5,775	.....	5,695
17	.....	8,806	.....	8,201	.....	6,562	.....	6,230	.....	5,306	.....	5,193
18	.....	9,125	.....	8,045	.....	6,796	.....	6,228	.....	5,496	.....	5,384
19	.....	9,118	.....	8,396	.....	6,948	.....	6,062	.....	5,210	.....	5,696
20	.....	9,155	.....	7,479	.....	7,180	.....	6,102	.....	5,625	.....	5,695
21	.....	8,748	.....	8,107	.....	6,980	.....	6,065	.....	5,653	.....	5,669
22	.....	9,214	.....	7,955	.....	7,029	.....	5,349	.....	5,675	.....	5,660
23	.....	8,754	.....	7,951	.....	6,921	.....	5,682	.....	5,617	.....	5,686
24	.....	8,792	.....	7,940	.....	6,295	.....	5,971	.....	5,626	.....	5,165
25	.....	8,540	.....	7,926	.....	5,940	.....	5,891	.....	5,546	.....	5,113
26	.....	8,310	.....	7,750	.....	6,519	.....	5,866	.....	5,143	.....	5,469
27	.....	8,314	.....	7,293	.....	6,567	.....	5,999	.....	5,371	.....	5,714
28	.....	8,314	.....	7,459	.....	6,339	.....	5,924	.....	5,688	.....	5,790
29	.....	8,570	.....	7,300	.....	6,723	.....	5,498	.....	5,733	.....	5,604
30	.....	8,525	.....	7,419	.....	6,555	.....	5,480	.....	5,800	.....	5,786
31	.....	8,563	.....	6,799	.....	.....	.....	5,777	.....	.....	.....	5,288

Table 58.—Total Daily Discharge of the Winnipeg River at Outlets of Lake of the Woods, Ontario—Concluded.

1912.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
8,522	1	5,246	5,542	6,267	6,020	6,455	6,466					
8,517	2	5,592	5,485	6,251	6,180	6,611	5,178					
8,753	3	5,726	5,698	5,767	6,296	6,571	4,978					
8,585	4	5,698	5,171	6,071	6,289	5,956	5,942					
8,657	5	5,533	5,574	6,066	6,287	6,754	6,282					
9,041	6	5,363	5,656	6,019	6,405	6,422	6,147					
9,149	7	5,275	5,722	6,097	6,106	6,670	5,568					
9,172	8	5,637	5,744	6,070	6,120	6,873	5,121					
9,152	9	5,855	5,748	6,109	6,291	6,833	4,962					
9,048	10	5,816	5,717	5,731	6,191	6,844	4,761					
8,707	11	5,812	5,219	5,920	6,324	6,878	4,841					
8,662	12	5,787	5,481	6,242	6,330	6,382	1,913					
9,019	13	5,760	5,750	6,129	6,382	6,640	5,597					
9,127	14	5,301	5,702	6,136	5,722	7,006	5,581					
9,150	15	5,431	5,793	6,152	6,090	7,045	5,607					
9,151	16	5,633	5,856	6,085	6,286	6,968	5,603					
9,160	17	5,576	5,978	5,619	6,396	6,716	5,516					
8,624	18	5,690	5,188	5,985	6,395	6,747	5,710					
8,829	19	5,647	5,830	6,189	6,348	5,980	5,842					
9,326	20	5,551	6,083	6,181	6,373	6,280	5,853					
8,797	21	5,153	6,121	6,137	5,851	6,548	5,826					
8,540	22	5,322	5,945	6,088	6,089	6,568	5,565					
9,149	23	5,612	6,248	5,885	6,138	6,635	4,975					
9,374	24	5,618	6,102	5,610	6,496	6,527	5,015					
8,870	25	5,551	5,596	6,001	6,495	6,370	5,274					
9,041	26	5,703	5,954	6,161	6,557	5,806	5,296					
9,387	27	5,681	6,275	5,809	6,619	5,783	5,306					
9,176	28	5,266	6,321	6,131	6,036	6,345	5,238					
8,747	29	5,272	6,261	6,410	6,311	6,036	5,197					
8,901	30	5,522	5,817	5,817	6,607	6,330	4,674					
	31	5,531	5,464	5,464	6,174	6,174						

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
5,450	1	4,475	5,262	4,756	5,825	11,675	11,034					
5,612	2	4,436	5,208	5,209	5,904	11,782	10,881					
5,094	3	4,959	5,387	5,891	5,901	10,657	11,397					
5,463	4	4,894	4,726	5,723	6,899	11,154	11,478					
5,629	5	4,956	5,114	5,804	6,102	11,669	11,485					
5,680	6	5,025	5,491	5,207	7,461	11,674	11,311					
5,690	7	4,591	5,454	5,283	8,647	11,550	11,416					
5,563	8	4,665	5,021	4,955	9,240	9,996	11,228					
5,675	9	4,555	5,518	5,136	9,239	9,761	11,375					
5,078	10	5,061	5,521	5,283	9,574	8,552	11,752					
5,306	11	5,002	5,018	5,470	9,746	8,648	11,848					
5,581	12	5,106	5,300	5,466	9,773	9,467	11,856					
5,443	13	5,017	5,523	5,550	8,883	10,679	11,831					
5,666	14	4,580	5,602	5,577	9,414	11,122	11,797					
5,701	15	4,562	5,664	5,340	9,881	11,208	11,429					
5,695	16	5,111	5,665	5,451	10,197	11,117	11,648					
5,193	17	4,969	5,673	5,481	10,744	10,452	11,808					
5,384	18	5,122	5,106	5,285	11,086	10,787	11,842					
5,696	19	4,904	5,138	5,205	11,308	11,233	11,816					
5,695	20	4,875	5,599	5,289	10,321	11,043	11,851					
5,669	21	4,425	5,747	5,351	10,618	11,258	11,864					
5,660	22	4,605	5,752	5,169	10,776	11,398	11,232					
5,686	23	4,907	5,815	5,361	11,747	11,618	11,543					
5,165	24	5,111	5,890	5,525	11,628	10,822	11,543					
5,113	25	5,097	5,230	5,660	11,605	11,175	11,193					
5,469	26	5,072	5,314	5,753	11,294	11,620	11,558					
5,714	27	5,197	5,276	5,695	10,412	11,810	11,687					
5,790	28	4,672	5,554	5,828	10,771	12,010	11,709					
5,604	29	4,979	5,815	5,447	11,212	11,969	11,065					
5,786	30	5,079	5,677	5,660	11,496	11,795	11,437					
5,288	31	4,980	5,431	5,431	11,660	11,660	11,594					

Table 58.—Total Daily Discharge of the Winnipeg River at Outlets of Lake of the Woods, Ontario—Continued.

1913

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1		11,553		11,708		6,981		6,686		16,325		
2		11,581		11,517		6,978		6,616		16,122		19,719
3		11,739		11,475		7,208		6,204		16,646		20,474
4		11,819		11,482		7,410		6,039		15,798		20,531
5		11,314		11,403		7,306		6,011		16,000		20,701
6		11,545		11,491		7,279		5,817		16,710		
7		11,847		11,358		7,236		6,119		16,968		20,782
8		11,716		11,241		7,147		6,410		16,911		20,709
9		11,802		10,751		6,642		6,738		17,070		19,947
10		11,584		10,712		6,388		6,450		17,180		19,863
11		11,605		10,749		7,178						20,570
12		11,166		10,621		7,269		6,200		16,277		20,704
13		11,336		10,446		7,306		6,181		16,376		20,444
14		11,586		10,298		7,347		5,898		17,559		20,319
15		11,461		10,152		7,353		5,915		18,347		20,118
16		11,565		9,361		6,625		6,075		19,238		19,647
17		11,617		9,258		6,484		6,456		19,579		19,570
18		11,637		9,045		7,182		6,866		19,697		20,273
19		11,172		8,747		7,176		7,106		19,050		20,582
20		11,473		8,340		7,343		7,205		18,978		20,582
21		11,659		8,043		7,350		6,432		19,252		20,561
22		11,707		7,664		7,404		6,651		19,720		20,451
23		11,733		6,948		6,575		9,237		20,128		19,685
24		11,693		6,848		6,486		10,938		20,806		19,674
25		11,640		7,138		7,072		12,702		19,503		19,927
26		11,225		7,250		6,955		14,132		19,223		20,136
27		11,358		7,081		7,092		14,827		19,232		20,042
28		11,588		6,895		6,905		14,186		19,469		19,469
29		11,489				6,915		14,542		19,880		19,880
30		11,508				6,090		15,705		20,223		19,768
31		11,583				6,090		16,023		20,383		18,882
						6,101				20,443		18,837

	July.	August.	September.	October.	November.	December.
	1	18,674	15,875			
2	18,786	15,734	12,555			
3	19,476	14,921	14,380	8,407	8,447	8,287
4	19,604	14,867	14,140	8,552	7,612	8,682
5	18,570	14,664	206	8,437	8,217	8,857
6				6,977		8,842
7	17,704	14,923			8,332	8,477
8	17,142	14,981		7,997	8,392	8,087
9	16,964	15,170		8,217	8,422	6,827
10	15,596	15,150		8,412	8,147	7,327
11	13,871	14,665		8,347	7,087	7,792
12				8,532	7,337	7,962
13	13,341	14,704				
14	13,338	14,955	12,988	8,342	8,317	8,057
15	12,652	14,097	13,928	7,592	8,337	8,277
16	13,224	14,952	13,959	8,027	8,302	8,122
17	13,096	15,212	13,725	8,352	8,202	7,112
18			13,699	8,322	8,142	7,187
19	13,194	15,267	13,909			
20	13,224	14,850	13,934	8,352	6,997	7,657
21	13,246	14,550	14,021	8,342	7,692	8,082
22	12,931	14,668	14,264	8,497	8,112	8,407
23	12,237	14,648	13,811	7,272	8,287	8,127
24				7,212	8,612	8,237
25	12,267	14,731	12,207			
26	12,519	15,009	13,440	8,337	8,257	7,632
27	12,715	14,951	11,430	8,147	8,482	7,692
28	14,119	14,681	10,609	8,277	7,422	8,232
29	15,061	14,593	10,576	8,347	7,777	8,482
30				8,427	8,432	7,572
31	15,201	14,655	10,551			
	14,751	15,058	10,074	7,547	8,582	7,952
	14,960	14,426	7,260	7,752	8,627	8,457
	15,487	14,582	8,421	8,417	8,627	7,652
	15,720	14,832	8,542	8,552	9,702	7,992
	15,831	14,017	8,542	8,580	8,702	8,642
				8,482		8,797



Table 59.—Monthly Discharges of Winnipeg River at the Outlet of the Lake of the Woods.

(Drainage Area, 26,400 square miles.)

NOTE.—The run-off data for this station may be slightly revised when the investigations of the Lake of the Woods Technical Board are completed.

MONTH	DISCHARGE IN SECOND FEET.				RUN OFF. Depth in inches on Drainage Area.
	Maximum.	Minimum.	Mean.	Per Square Mile.	
1907.					
January	12,080	11,530	11,790	0.417	0.515
February	11,530	10,980	11,250	0.426	0.411
March	10,980	10,100	10,610	0.403	0.465
April	19,440	10,100	19,280	0.720	0.435
May	11,610	10,130	11,170	0.423	0.488
June	15,080	11,130	14,000	0.530	0.592
July	15,160	12,741	11,055	0.432	0.614
August	11,831	12,089	12,730	0.482	0.556
September	19,687	15,051	17,080	0.647	0.722
October	21,672	19,687	20,799	0.788	0.908
November	21,480	20,332	21,075	0.798	0.891
December	20,439	19,232	19,730	0.747	0.862
The Year	21,672	10,101	14,560	0.551	7.49
1908.					
January	19,418	18,839	19,193	0.727	0.839
February	19,002	17,267	18,230	0.691	0.720
March	17,714	16,951	17,340	0.657	0.758
April	17,1061	16,831	16,900	0.640	0.714
May	21,066	16,811	18,470	0.700	0.807
June	23,941	21,050	22,830	0.865	0.966
July	22,624	21,081	21,800	0.826	0.953
August	20,881	19,565	20,300	0.769	0.887
September	19,570	17,995	18,200	0.690	0.770
October	17,066	11,253	15,420	0.581	0.674
November	14,041	11,562	12,810	0.485	0.542
December	11,379	10,118	10,580	0.401	0.462
The Year	23,941	10,118	17,670	0.670	9.09
1909.					
January	10,360	9,465	9,970	0.378	0.436
February	10,597	9,481	10,040	0.380	0.396
March	11,143	10,528	10,910	0.413	0.477
April	11,323	10,058	10,870	0.412	0.459
May	11,735	10,168	11,040	0.418	0.483
June	11,986	11,291	11,770	0.446	0.497
July	12,068	11,711	11,850	0.449	0.518
August	11,980	11,290	695	0.413	0.511
September	12,450	11,586	40	0.452	0.505
October	12,439	11,352	95	0.455	0.525
November	12,239	11,639	720	0.455	0.508
December	12,174	11,530	915	0.452	0.521
The Year	12,450	9,465	11,345	0.430	5.84
1910.					
January	12,061	11,327	11,660	0.442	0.510
February	11,943	11,548	11,790	0.447	0.465
March	20,402	11,585	14,260	0.540	0.624
April	24,949	20,854	22,120	0.838	0.935
May	25,238	23,920	24,690	0.935	1.079
June	24,658	20,830	21,870	0.828	0.924
July	20,921	13,713	16,290	0.617	0.712
August	17,508	11,564	13,270	0.503	0.580
September	12,092	11,192	11,750	0.445	0.497
October	11,488	9,053	10,180	0.386	0.445
November	9,360	8,217	8,787	0.333	0.371
December	8,584	7,654	8,110	0.307	0.355
The Year	25,238	7,654	14,576	0.551	7.50

Table 59.—Monthly Discharges of Winnipeg River at the Outlet of the Lake of the Woods—Concluded.

MONTH.	DISCHARGE OF SECOND-FERT				Depth in inches on Drainage Area
	Maximum.	Minimum	Mean	Per Square Mile	
1911					
January	8,088	6,886	7,700	0.292	0.33
February	7,313	6,711	7,119	0.269	0.281
March	7,110	6,420	6,835	0.259	0.299
April	9,312	8,558	8,995	0.311	0.380
May	9,164	8,208	8,770	0.317	0.383
June	9,087	8,517	8,945	0.319	0.378
July	9,361	7,165	8,770	0.317	0.383
August	8,566	6,799	7,985	0.303	0.319
September	7,311	5,910	6,715	0.251	0.284
October	6,181	5,149	5,915	0.214	0.260
November	5,919	5,112	5,615	0.2	0.217
December	5,801	5,078	5,530	0.2	0.212
The Year	9,487	5,078	7,110	0.284	0.31
1912					
January	5,855	5,153	5,555	0.210	0.213
February	6,331	5,171	5,795	0.220	0.229
March	6,267	5,164	6,010	0.228	0.263
April	6,619	5,722	6,270	0.238	0.265
May	7,045	5,783	6,505	0.246	0.284
June	6,466	4,661	5,135	0.2	0.240
July	5,197	4,425	4,860	0.185	0.213
August	5,890	4,736	5,340	0.206	0.237
September	5,828	4,756	5,125	0.206	0.229
October	11,717	5,838	9,720	0.368	0.175
November	12,010	8,533	10,990	0.417	0.165
December	11,861	10,889	11,520	0.436	0.504
The Year	12,010	4,435	6,965	0.261	0.29
1913					
January	11,837	11,166	11,560	0.438	0.506
February	11,708	6,848	9,570	0.363	0.378
March	7,340	6,090	6,990	0.265	0.305
April	16,023	8,847	8,550	0.321	0.361
May	20,806	15,798	18,440	0.696	0.803
June	17,782	18,847	21,100	0.762	0.850
July	19,604	17,337	15,023	0.569	0.656
August	15,875	11,017	11,880	0.561	0.650
September	14,555	7,700	13,100	0.496	0.554
October	8,580	7,217	8,180	0.310	0.358
November	8,703	7,087	8,190	0.306	0.312
December	8,807	7,117	8,050	0.305	0.352
The Year	20,806	7,84	11,872	0.450	0.42
1914					
January	10,792	8,117	9,454	0.364	0.350
February	11,172	8,117	9,644	0.377	0.330
March	10,822	8,660	9,741	0.391	0.451
April	10,537	8,117	9,327	0.370	0.433
May	17,078	9,117	13,091	0.466	0.538
June	20,352	16,117	18,234	0.703	0.780
July	20,476	19,417	19,946	0.751	0.870
August	19,625	13,117	16,371	0.590	0.796
September	13,903	12,900	13,401	0.477	0.572
October	13,612	9,480	11,546	0.471	0.501
November	10,708	9,400	10,054	0.375	0.419
December	10,210	8,668	9,439	0.373	0.330
The Year	20,476	7,077	14,477	0.475	0.45

Table 60. -Discharge Measurements in head-race of Kerora power station.

1911.

No	Date.	Forebay Gauge	Discharge	Est. Weir.		Net Discharge	Load.	Head.	Efficiency.
				Sec. II	Sec. II				
		Feet	Sec. II.	Sec. II	Sec. II	KW.	Feet.	Per cent.	
1	February 21	97-67	1,047.8	19.8	1,028.0	1,059	22.89	54.2	
2	"	97-65	1,429.7	19.1	1,410.6	1,424	22.74	52.6	
3	" 25	97-65	1,312.0	19.1	1,292.9	1,389	22.58	56.2	
4	"	97-65	1,242.1	19.1	1,223.0	1,459	22.58	58.4	
5	"	97-65	1,282.0	19.1	1,262.9	1,340	22.58	55.5	
6	"	97-65	1,409.0	19.5	1,289.5	1,359	22.65	55.0	
7	" 26	97-66	1,394.5	19.5	1,375.0	1,114	22.50	55.4	
8	March " "	97-67	711.3	19.5	691.8	810	23.15	59.4	
9	"	97-61	776.7	18.8	757.9	846	23.29	55.9	
10	" 1	97-68	1,093.5	20.2	1,073.3	1,151	22.59	55.4	
11	"	97-68	1,164.9	20.2	1,144.7	1,610	22.47	58.6	
12	"	97-68	1,506.1	20.2	1,485.9	1,668	22.43	59.1	
13	" 7	97-65	1,259.4	19.1	1,240.3	1,372	22.60	57.8	
14	"	97-65	1,412.3	19.1	1,393.2	1,357	22.60	51.8	
15	"	97-61	1,246.4	18.7	1,227.7	1,316	22.59	56.5	
16	"	97-69	1,251.7	20.6	1,231.1	1,282	22.74	51.0	
17	"	97-68	1,212.2	20.2	1,200.0	1,267	22.68	54.0	
18	"	97-68	1,200.1	20.2	1,180.2	1,265	22.68	55.8	
19	"	97-69	1,255.6	20.5	1,235.1	1,284	22.70	54.0	
20	" 8	97-71	1,219.8	21.3	1,228.5	1,277	22.78	51.0	
21	"	97-70	1,201.9	20.9	1,181.0	1,277	22.77	55.1	
22	"	97-68	1,249.3	20.2	1,219.1	1,256	22.74	52.8	
23	"	97-69	1,223.7	20.6	1,203.1	1,250	22.74	54.0	
24	"	97-67	1,219.3	19.8	1,229.5	1,266	22.76	53.5	
25	"	97-66	1,266.4	19.5	1,246.9	1,307	22.69	54.5	
26	"	97-66	1,262.6	19.5	1,243.1	1,275	22.61	51.5	
27	" 0	97-73	815.6	22.8	792.8	717	23.29	45.8	
28	"	97-75	771.5	22.8	748.7	767	21.29	51.9	
29	"	97-76	776.6	23.2	753.4	725	21.31	48.9	
30	"	97-77	765.4	23.6	741.8	719	21.42	48.2	
31	"	97-78	719.0	21.0	695.0	702	21.52	50.8	
32	"	97-77	718.8	23.6	725.2	696	21.49	48.2	
33	"	97-76	613.0	23.2	589.8	672	21.46	57.2	
34	" 10	7-70	1,151.4	20.9	1,141.5	1,567	22.59	57.2	
35	"	97-71	1,518.0	21.3	1,516.7	1,607	22.52	55.5	
36	"	97-70	1,468.8	20.9	1,447.9	1,622	22.48	58.8	
37	" 15	97-70	1,411.7	20.9	1,420.8	1,613	22.69	59.2	
38	"	97-70	1,541.2	20.9	1,520.1	1,639	22.62	56.2	
39	"	97-69	1,439.2	20.5	1,418.7	1,607	22.54	59.4	
40	" 19	97-68	1,303.8	20.2	1,283.6	1,151	22.68	54.7	
41	"	97-68	1,270.2	20.2	1,250.0	1,354	22.68	56.4	
42	"	97-68	1,279.7	20.2	1,259.5	1,354	22.68	56.1	
43	"	97-69	1,202.9	20.6	1,182.3	1,317	22.71	58.8	
44	" 20	97-71	1,265.6	22.4	1,241.2	1,321	22.76	55.1	
45	"	97-74	1,318.2	22.4	1,295.8	1,340	22.76	53.6	
46	"	97-74	1,317.7	22.4	1,295.1	1,343	22.76	53.8	
47	"	97-74	1,269.6	22.4	1,247.2	1,118	22.76	53.8	
48	April 4	97-80	694.5	24.7	668.8	520	21.54	49.9	
49	"	97-81	729.1	25.4	704.2	536	21.54	49.9	
50	"	97-82	754.6	25.5	729.1	549	23.54	49.9	
51	"	97-82	712.8	25.5	687.3	519	23.59	37.8	
52	"	97-82	643.7	25.5	618.2	428	23.63	34.7	
53	"	97-80	687.4	24.7	662.7	496	21.55	37.5	
54	"	97-81	702.9	25.1	677.8	501	21.57	37.0	
55	" 5	97-80	657.2	24.7	612.5	547	23.55	43.3	
56	"	97-82	671.7	25.5	646.2	519	21.61	40.1	
57	"	97-82	666.5	25.5	641.0	552	23.57	43.1	
58	"	97-82	710.6	25.5	685.1	529	23.56	38.7	
59	"	97-82	691.4	25.5	665.9	527	23.56	19.7	
60	"	97-83	618.5	25.9	592.6	394	23.62	33.3	
61	"	97-83	668.1	25.9	642.2	505	21.60	39.4	
62	"	97-81	562.6	25.9	536.7	527	23.58	49.1	
63	"	97-83	719.8	25.5	694.1	525	23.59	37.8	
64	"	97-83	620.4	25.9	594.5	527	21.54	44.6	
65	"	97-81	709.0	25.1	683.9	506	23.57	37.1	
66	" 24	98-26	1,376.6	41.7	1,131.9	1,176	21.10	45.1	
67	"	98-26	1,259.0	44.7	1,214.3	1,204	23.05	50.8	

## RAINY RIVER AT INTERNATIONAL FALLS, MINN.

*Location of Gauge.*—At the steamboat dock, half a mile below the dam at International Falls.

*Records available.*—March 1, 1907, to December 31, 1912.

*Drainage area.*—14,600 square miles.

*Gauge.*—Vertical staff installed by the United States Geological Survey, April 20, 1911, at the American steamboat dock below the falls. Prior to this date gauge heights, furnished through the courtesy of the Minnesota and Ontario Power Company, were read on a gauge located just below the dam, first on the Canadian side but later on the American side. The zero of the survey gauge is 460.99 feet above that of the power company's gauge, when the slope of the river between the two points is considered.

*Channel.*—Practically permanent.

*Discharge measurements.*—Discharge measurements prior to 1911 were made by means of a beam and cable at a section several hundred yards below the gauge, where an island divides the river into two channels. Since 1911, measurements have been made above the island, where the river flows in one channel and the velocities are better distributed.

*Winter Flow.*—Ice rarely forms in the long stretch of water below the dam, but it does form at the rapids below the open stretch, causing serious backwater at the gauge, amounting at times to more than 2 feet. During 1909 and 1910 the monthly flow during the winter has been estimated indirectly from records of flow through the turbines as kept by the power company. During 1911 and 1912 the winter flow has been estimated directly from records of flow through the turbines, as computed by the Canadian Department of Public Works. Winter estimates for periods previous to 1910 can be considered only approximate.

*Artificial control.*—The dam above the gauging station raises the water level in Rainy Lake to such an extent as to cause a large increase in the storage. Since the dam and power-house have been in operation, practically no water has passed over the crest, the entire flow of the river going through the turbines and sluice gates. The plant is run on a 24-hour basis, so that with the exception of the Sunday flow the discharge is fairly uniform, though it does not represent the natural flow.

Table 61.—Daily Discharge of Rainy River at Fort Frances, Ontario.

[Drainage Area, 14,400 square miles.]

1911.

Day.	August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.								
	Feet.	Sec.-ft.								
1				6,480		5,180		4,970		5,630
2				6,515		4,110		4,850		5,615
3				6,586		5,250		4,800		4,815
4				5,835		5,505		4,400		4,605
5				6,056		5,500		4,220		5,570
6				6,415		5,560		4,260		5,575
7				6,180		5,220		4,770		5,605
8				6,300		4,475		4,785		5,690
9				6,120		4,160		5,012		6,095
10				5,700		4,680		4,987		5,090
11				5,690		5,470		4,760		4,635
12				5,980		5,480		4,315		5,645
13				5,990		5,490		4,250		5,670
14		4,820		5,950		5,050		5,060		5,660
15		6,750		5,930		4,180		5,350		5,650
16		6,730		5,990		4,100		5,420		5,705
17		6,470		4,948		4,675		5,445		4,940
18		6,385		4,415		5,300		5,555		4,370
19		6,650		6,055		5,490		3,070		5,670
20		5,134		5,838		5,170		3,895		5,700
21		4,847		5,660		4,880		5,630		5,670
22		6,540		5,660		4,500		5,620		5,700
23		6,585		5,570		4,180		5,595		5,640
24		6,711		4,595		5,015		5,915		1,080
25		6,510		4,225		5,435		6,190		2,000
26		6,740		5,150		5,445		5,110		5,355
27		5,294		5,270		5,475		4,090		5,990
28		4,968		5,550		5,260		5,620		6,100
29		6,500		5,520		4,310		5,650		6,085
30		6,510		5,560		3,960		5,625		5,705
31		6,500				4,840				3,330

Table 61.—Daily Discharge of Rainy River at Fort Frances, Ontario—Continued.

1912.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec. ft.										
1	4.490		5.085		4.856		3.953		5.880		6.315	
2	5.695		5.440		4.888		5.022		5.885		5.410	
3	5.665		5.815		4.497		5.028		5.915		5.325	
4	5.695		4.620		4.402		1.997		6.190		6.437	
5	5.640		3.995		5.101		5.102		5.250		6.382	
6	5.815		5.105		5.037		4.981		4.795		6.410	
7	4.150		5.090		5.090		3.725		6.185		6.305	
8	3.995		5.050		5.102		3.616		6.570		6.159	
9	5.725		4.985		5.064		5.049		6.610		5.971	
10	5.720		4.870		4.205		5.068		6.692		5.889	
11	5.725		1.105		4.108		5.096		6.731		6.267	
12	5.940		3.990		5.105		5.119		5.135		6.239	
13	6.220		5.930		5.060		5.052		1.800		6.283	
14	3.700		5.035		5.025		1.031		6.690		6.312	
15	5.030		5.000		5.016		1.109		6.695		6.255	
16	5.855		5.009		4.960		5.100		6.690		5.570	
17	5.930		5.017		5.828		5.060		6.350		5.730	
18	5.900		1.119		5.800		5.035		6.355		6.042	
19	5.915		4.976		4.812		5.055		4.855		6.093	
20	5.915		5.045		5.045		5.048		5.200		6.180	
21	4.700		5.014		5.096		4.130		6.730		6.261	
22	4.320		5.057		5.095		3.950		6.713		6.115	
23	5.915		5.063		5.001		5.045		6.720		5.823	
24	5.920		5.014		3.560		5.055		6.770		5.693	
25	5.875		4.169		4.429		5.385		6.577		6.190	
26	5.760		1.080		5.070		5.800		4.892		5.845	
27	5.495		5.068		5.022		5.900		5.175		5.969	
28	4.255		5.066		5.057		4.597		6.680		5.853	
29	3.935		5.056		5.090		1.338		6.495		5.555	
30	5.080				4.910		5.865		6.350		5.267	
31	5.080				4.012				5.811			

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.										
1	6.078		40.091		6.418		7.279		7.087		5.801	
2	5.660		10.072		5.892		7.202		7.122		6.133	
3	5.880		10.077		6.470		7.039		6.181		6.725	
4	5.472		9.462		8.408		7.089		6.095		7.091	
5	5.402		8.953		8.490		7.078		7.199		6.868	
6	5.905		9.825		8.363		6.199		7.136		6.655	
7	5.394		9.837		7.997		6.533		7.100		6.119	
8	5.835		9.711		7.254		7.060		7.073		5.828	
9	6.932		9.333		7.266		7.060		6.791		5.860	
10	7.013		9.332		8.057		7.039		6.175		6.913	
11	8.074		8.442		7.962		7.045		5.998		6.973	
12	8.285		8.299		7.799		7.100		6.568		6.972	
13	8.218		8.208		7.831				6.923		6.952	
14	7.576		8.216		7.880		6.664		7.020		6.675	
15	7.494		7.965		7.260		7.083		6.955		5.412	
16	8.613		7.048		7.234		7.044		7.041		5.532	
17	8.835		7.528		7.812		7.047		5.261		7.267	
18	8.148		7.720		7.579		6.852		6.511		6.987	
19	6.981		7.530		6.996		6.987		6.999		6.850	
20	7.604		8.416		6.923		6.594		7.015		6.989	
21	8.633		8.194		6.588		5.821		7.089		6.762	
22	8.405		6.865		5.910		7.076		7.034		5.900	
23	8.936		6.728		6.063		7.111		7.051		4.650	
24	9.012		6.932		6.930		7.070		6.174		6.881	
25	8.940		5.885		7.315		7.056		5.978		5.011	
26	9.061		6.166		8.892		7.078		7.002		4.591	
27	8.105		6.614		8.223		6.135		7.054		5.995	
28	8.572		6.839		7.179		5.927		7.017		6.549	
29	9.946		7.055		6.980		6.968		6.687		5.762	
30	9.569		7.152		7.024		7.076		6.422		5.137	
31	10.087		7.177				7.112				6.751	

Table 61.—Daily Discharge of Rainy River at Fort Frances, Ontario—Continued.

1913.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge.	Gauge Height.	Discharge.								
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1		6,805		6,841		6,850		6,846		6,826		5,535
2		6,795		5,647		5,602		6,246		6,831		6,216
3		6,827		6,385		5,675		5,870		6,814		6,960
4		6,978		6,864		6,749		6,187		5,978		6,852
5		5,980		6,887		6,751		6,634		6,331		6,868
6		5,216		6,895		6,900		4,406		6,827		6,904
7		6,858		6,853		6,905		5,438		6,827		6,820
8		6,796		6,900		6,919		6,621		6,814		6,273
9		6,892		5,738		5,840		6,801		6,881		6,343
10		6,920		5,849		5,725		6,865		6,820		6,795
11		6,921		6,879		6,750		6,792		5,938		6,870
12		5,778		6,884		6,780		6,783		6,172		6,911
13		6,124		6,878		6,716		5,883		6,761		6,902
14		6,911		6,872		6,798		5,419		6,788		7,052
15		6,932		6,853		6,739		6,715		6,730		6,729
16		6,941		5,618		5,464		6,837		6,765		6,398
17		6,909		5,477		5,653		6,801		6,820		7,492
18		6,947		6,865		6,730		6,716		5,994		7,410
19		6,015		6,877		6,747		6,751		6,163		7,336
20		5,073		6,853		6,682		5,324		6,772		7,473
21		6,956		6,894		6,752		6,254		6,796		7,468
22		6,945		6,844		6,715		6,368		6,777		6,689
23		6,909		5,631		5,598		6,706		6,760		7,324
24		6,937		6,054		4,921		6,758		6,785		7,814
25		6,955		6,864		6,840		6,726		6,162		7,840
26		5,896		6,847		6,813		6,746		6,088		7,856
27		6,273		6,830		6,811		5,873		6,749		8,798
28		6,856		6,830		6,775		6,180		6,550		8,832
29		6,928				6,800		6,696		6,889		9,673
30		6,977				5,946		6,913		6,896		9,863
31		6,981				5,990				6,906		

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge.	Gauge Height.	Discharge.								
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1		11,023		9,490		5,251		6,126		5,965		5,823
2		11,058		8,829		6,328		6,892		5,406		6,980
3		11,004		9,223		6,935		6,980		5,445		6,987
4		11,606		9,048		7,019		6,970		6,110		6,540
5		11,438		9,134		6,703		6,456		6,055		6,077
6		11,503		9,139		6,997		6,040		5,994		6,542
7		10,343		9,176		5,885		8,565		6,080		5,430
8		10,106		10,414		7,262		6,435		6,075		5,877
9		9,643		10,022		6,821		6,633		5,493		6,901
10		10,820		9,503		7,016		6,920		5,759		6,930
11		13,475		8,758		7,014		6,940		6,105		6,864
12		13,510		9,108		6,964		6,207		6,100		6,963
13		12,246		9,076		7,010		7,389		6,135		6,944
14		13,539		9,207		6,238		7,170		5,889		6,222
15		14,493		9,264		6,455		6,932		6,222		6,391
16		13,715		8,968		6,960		6,257		5,310		6,974
17		14,576		8,758		7,094		6,360		5,242		6,778
18		14,243		8,654		7,000		6,150		6,115		6,988
19		15,290		9,019		6,985		6,048		6,005		6,988
20		14,019		8,914		6,975		5,545		6,440		6,966
21		13,187		9,136		6,535		6,080		5,675		6,205
22		13,221		9,118		6,909		6,140		6,558		5,945
23		13,254		8,888		7,060		6,105		6,237		6,095
24		13,331		6,232		7,026		6,100		6,468		6,118
25		13,225		7,229		7,015		6,120		6,780		4,908
26		13,262		7,022		6,994		5,474		7,175		4,608
27		12,802		6,965		6,915		5,550		6,931		5,201
28		12,844		7,005		6,121		6,070		6,979		6,225
29		13,292		6,967		6,600		6,105		6,606		5,525
30		13,732		6,665		7,030		6,026		5,519		6,095
31		9,794		5,660				6,075				6,299

Table 61.—Daily Discharge of Rainy River at Fort Frances, Ontario—Continued.

1914.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1	6.070		6.439		6.161		6.898		6.868		7.874	
2	6.097		6.586		6.418		6.998		6.784		8.434	
3	6.933		6.949		6.980		6.912		5.988		8.976	
4	6.251		7.000		6.896		6.892		6.396		9.013	
5	5.492		7.020		6.956		6.050		6.598		8.749	
6	6.935		6.938		6.942		6.320		6.798		8.792	
7	6.877		6.976		6.922		6.936		6.840		6.646	
8	6.870		6.468		5.775		6.916		6.788		7.753	
9	6.785		6.482		6.394		6.918		6.752		9.054	
10	6.856		6.970		7.064		6.928		5.997		9.421	
11	6.218		6.978		7.006		6.910		6.214		8.906	
12	6.536		7.078		7.030		6.077		6.802		8.415	
13	6.961		7.050		6.986		6.214		6.814		8.860	
14	6.953		6.944		7.016		6.902		6.842		6.673	
15	6.957		6.312		5.589		6.895		6.846		7.203	
16	6.980		6.436		6.384		6.894		6.818		8.686	
17	7.021		7.280		6.950		6.932		6.269		8.953	
18	6.245		6.744		7.002		6.852		6.272		9.126	
19	6.455		6.978		7.022		5.878		6.804		9.070	
20	6.920		7.042		7.006		6.280		6.818		9.050	
21	6.950		8.023		7.016		6.900		6.864		6.968	
22	6.921		5.967		6.180		6.834		6.832		7.644	
23	6.959		6.410		6.392		6.868		6.856		8.735	
24	6.957		6.974		6.958		6.878		6.102		8.916	
25	6.326		6.988		6.850		6.876		6.620		9.466	
26	7.140		7.018		6.944		6.052		7.398		9.504	
27	7.036		6.998		6.928		6.252		7.432		9.104	
28	6.958		7.020		6.928		6.862		7.940		6.606	
29	7.004				6.056		6.796		8.630		8.198	
30	6.936				6.270		6.856		8.954		8.670	
31	6.685				6.880				6.963			

Day.	July.	August.	September.	October.	November.	December.
	1	7.778	10.704	10.410	10.520	7.601
2	8.310	8.331	10.580	10.510	8.935	10.929
3	8.960	9.081	10.540	10.065	10.839	11.060
4	8.416	10.981	10.528	7.019	10.778	10.853
5	6.184	10.854	10.528	8.651	10.821	10.399
6						
7	7.216	10.937	7.630	10.353	10.781	7.458
8	10.058	10.772	4.270	10.570	10.788	8.272
9	9.829	10.895	9.216	10.454	8.271	10.661
10	10.346	8.816	10.599	10.482	9.170	11.171
	10.669	9.021	10.600	10.540	10.788	10.711
11						
12	10.730	10.907	10.590	7.641	10.810	10.740
13	7.815	10.948	10.570	8.833	10.800	10.938
14	10.756	10.902	7.713	10.508	10.506	7.225
15	11.023	10.855	8.880	9.996	9.946	8.681
	10.953	10.877	10.600	9.269	7.783	9.308
16						
17	10.933	7.730	10.522	9.660	8.959	10.218
18	11.376	8.618	10.520	9.680	10.285	9.290
19	11.819	10.654	10.513	7.456	10.762	9.925
20	9.503	10.746	10.500	8.371	11.134	9.991
	10.472	10.599	8.045	10.533	10.744	6.911
21						
22	12.061	10.578	8.848	10.462	11.145	7.834
23	12.441	10.549	10.512	10.671	8.192	9.121
24	12.775	8.549	10.542	10.991	9.190	9.312
25	12.541	8.871	10.505	10.397	11.059	9.666
	12.445	10.607	10.515	7.007	10.911	3.448
26						
27	10.773	10.609	10.414	8.977	10.891	1.224
28	11.503	10.628	8.187	10.648	10.003	3.710
29	12.262	10.658	8.673	10.848	9.416	8.318
30	12.522	10.628	10.520	10.808	8.317	9.950
31	11.247	7.735	10.385	10.801	8.371	10.440
	10.657	8.725		10.739		10.017

Table 61.—Daily Discharge of Rainy River at Fort Frances, Ontario—Concluded.

1915.

Day.	January.		February.	
	Gauge Height.	Discharge.	Gauge Height.	Discharge.
	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1.....		10,092		7,153
2.....		10,320		8,292
3.....		6,610		8,175
4.....		9,030		8,291
5.....		10,460		8,083
6.....		10,052		8,281
7.....		10,057		6,792
8.....		10,277		7,193
9.....		10,360		8,245
10.....		6,981		8,247
11.....		8,635		8,360
12.....		10,352		8,178
13.....		10,330		7,746
14.....		10,137		
15.....		8,595		
16.....		9,565		
17.....		9,183		
18.....		8,220		
19.....		9,555		
20.....		9,545		
21.....		9,508		
22.....		9,451		
23.....		8,582		
24.....		7,938		
25.....		8,714		
26.....		9,425		
27.....		8,807		
28.....		8,564		
29.....		9,090		
30.....		9,201		
31.....		7,529		

Table 62.—Monthly Discharges of Rainy River at Fort Frances.

[Drainage Area 14,400 square miles.]

MONTH.	DISCHARGE IN SECOND-FEET.				RUN-OFF,
	Maximum.	Minimum.	Mean.	Per square mile.	Depth in inches on Drainage area.
1907					
January			5.883	0.409	0.472
February			3.641	0.251	0.263
March			4.910 <sup>1</sup>	0.341	0.394
April	6.265	4.338	4.995	0.344	0.384
May	7.710	4.480	6.070	0.422	0.487
June	11.500	9.500	10.200	0.709	0.791
July	13.700	11.700	13.000	0.904	1.042
August	19.760	15.170	17.470	1.214	1.400
September	20.800	19.760	20.110	1.408	1.559
October	20.460	18.850	19.760	1.373	1.584
November	18.850	16.550	17.700	1.230	1.372
December			13.000 <sup>1</sup>	0.904	1.042
The year			11.391	0.792	10.79
1908					
January			12.000 <sup>1</sup>	0.834	0.962
February			8.410 <sup>1</sup>	0.584	0.608
March			7.010 <sup>1</sup>	0.489	0.564
April			6.020 <sup>1</sup>	0.418	0.466
May			7.940 <sup>1</sup>	0.552	0.636
June			11.430 <sup>1</sup>	0.794	0.886
July	14.260	12.220	13.060	0.908	1.047
August	13.430	11.570	12.680	0.882	1.017
September	11.850	10.090	10.740	0.747	0.832
October	10.900	8.710	9.680	0.672	0.776
November	8.630	6.720	7.510	0.522	0.582
December			5.701	0.396	0.457
The year			9.350	0.650	8.83
1909					
January			5.170 <sup>1</sup>	0.359	0.414
February			4.740 <sup>1</sup>	0.329	0.343
March			5.500 <sup>1</sup>	0.382	0.441
April	6.240	4.484	5.250	0.226	0.252
May	8.430	7.26	4.220	0.293	0.338
June	10.900	9.76	6.850	0.476	0.531
July	11.300	9.020	10.600	0.736	0.850
August	13.700	7.320	10.600	0.736	0.850
September	10.300	7.940	9.250	0.643	0.717
October	10.300	7.020	9.050	0.628	0.726
November	8.860	3.520	5.400	0.375	0.419
December			10.000 <sup>1</sup>	0.695	0.802
The year			7.052	0.490	6.68
1910					
January			9.680 <sup>1</sup>	0.672	0.776
February			9.680 <sup>1</sup>	0.672	0.700
March			10.750 <sup>1</sup>	0.748	0.862
April	13.600	6.000	10.600	0.736	0.822
May	12.500	7.970	10.600	0.736	0.850
June	11.900	8.590	10.000	0.695	0.775
July	9.780	3.610	6.630	0.461	0.532
August	6.820	3.740	5.280	0.367	0.423
September	5.370	4.950	5.080	0.353	0.391
October	6.640	2.340	5.120	0.356	0.410
November	7.600	1.755	5.280	0.367	0.409
December			4.300	0.299	0.345
The year			7.750	0.539	7.30

<sup>1</sup>Estimated.

Table 62.—Monthly Discharges of Rainy River at Fort Frances—Concluded.

MONTH.	DISCHARGE IN SECOND-FEET.				RUN-OFF,
	Maximum.	Minimum.	Mean.	Per square mile.	Depth in inches on Drainage area.
1911					
January			2,860 <sup>1</sup>	0.199	0.229
February			2,380 <sup>1</sup>	0.165	0.172
March			2,500 <sup>1</sup>	0.176	0.203
April	4,000	2,170 <sup>1</sup>	3,020	0.210	0.234
May	6,210	2,740	4,600	0.320	0.369
June	8,240	3,740	5,740	0.399	0.445
July	6,840	1,900	3,970	0.276	0.318
August	7,220	3,570	6,560	0.456	0.526
September	6,880	4,730	5,990	0.416	0.464
October	5,890	4,320	5,210	0.362	0.418
November	6,070	4,020	5,410	0.376	0.419
December			5,900 <sup>1</sup>	0.410	0.473
The year			4,514	0.314	4.27
1912					
January	6,220	3,700	5,340	0.370	0.427
February	5,840	3,980	4,830	0.336	0.349
March	5,160	3,560	4,740	0.329	0.380
April	5,900	3,620	4,850	0.337	0.376
May	6,770	4,800	6,090	0.423	0.488
June	6,420	5,240	6,020	0.418	0.467
July	10,100	5,150	7,680	0.534	0.616
August	10,100	5,880	8,120	0.564	0.651
September	8,890	5,890	7,360	0.512	0.570
October	7,280	5,820	6,880	0.478	0.552
November	7,200	5,260	6,730	0.468	0.522
December	7,267	4,591	6,280	0.436	0.504
The year	10,160	3,560	6,243	0.434	5.90
1913					
January	6,978	5,073	6,620	0.460	0.530
February	6,900	5,477	6,561	0.456	0.474
March	6,919	4,921	6,420	0.446	0.514
April	6,913	4,406	6,405	0.445	0.497
May	6,906	5,938	6,620	0.460	0.531
June	9,863	5,535	7,274	0.506	0.564
July	15,290	9,633	12,597	0.876	1.010
August	10,414	5,660	8,544	0.594	0.685
September	7,262	5,251	6,770	0.470	0.525
October	8,565	5,474	6,318	0.439	0.506
November	7,175	5,242	6,129	0.426	0.475
December	6,988	4,608	6,309	0.438	0.506
The year	15,290	4,406	7,214	0.501	6.82
1914					
January	7,140	5,492	6,718	0.467	0.536
February	8,023	5,967	6,823	0.474	0.493
March	7,064	5,589	6,707	0.466	0.538
April	6,998	5,878	6,694	0.468	0.519
May	8,957	5,988	6,860	0.477	0.550
June	9,567	6,606	8,464	0.588	0.656
July	12,775	6,184	10,464	0.727	0.839
August	10,984	7,730	10,044	0.698	0.805
September	10,600	4,270	9,749	0.677	0.756
October	10,991	7,019	9,787	0.680	0.784
November	11,145	7,783	9,927	0.690	0.770
December	11,171	1,224	8,994	0.625	0.721
The year	12,775	1,224	8,436	0.586	7.97

<sup>1</sup>Estimated.

KETTLE R AT CHAUDIÈRE FALLS (KETTLE FALLS).

*Location of Gauge.*—At a point on the Canadian mainshore, 200 feet above the falls on the Canadian channel at the outlet of Namakan lake.

*Records available.*—August 8, 1912, to May 12, 1913.

*Drainage area.*—7,060 square miles.

*Channels.*—Permanent, bed-rock.

*Discharge Measurements.*—Discharge measurements have been made by the Manitoba Hydrographic Survey since August, 1912. As the Kettle falls are divided by an Island, this necessitated measurements at sections above each falls; the combined flow of both sections giving the total discharge from Namakan lake. The sections in both cases are directly above the crest of the falls.

*Winter Flow.*—As the gauge is located just above the falls on the Canadian channel, the station is not affected by back-water, and the open water discharge table is applicable.

Table 63.—Discharge measurements at Chaudière falls (Kettle falls) Rainy river.

[Drainage Area, 7,060 square miles.]

INTERNATIONAL CHANNEL.

Date.	Hydrographer.	Meter No.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
			Feet.	Sq.-ft.	Ft. per sec.	Feet.	Sec.-ft.
1912.							
Aug. 8	S. S. Scovil.....	1,374	213	4,351	0.769	3.34	3,345
Sept. 6	Alex. Pirie.....	1,197	213	4,353	0.680	2.72	2,960
Sept. 9	W. H. Richardson.....	1,374	213	4,318	0.643	2.77	2,775
Sept. 30	A. Pirie.....	1,187	213	4,341	0.587	2.32	2,548
Nov. 4	R. H. Nelson.....	1,196-7	213	4,156	0.481	1.65	1,999
Nov. 2	R. H. Nelson.....	1,196-7	213	4,193	0.485	1.66	2,037
1913.							
Jan. 10	A. Pirie.....	1,462	208	3,981	0.33	0.80	1,312
Jan. 10	".....	1,462	208	3,981	0.328	0.80	1,298
Mar. 17	".....	1,186	210	3,888	0.284	0.27	1,105
May 31	".....	1,197	223	5,246	1.22	6.08	6,375

CANADIAN CHANNEL.

1912.							
Aug. 8	S. S. Scovil.....	1,374	119.5	1,273	1.127	8.36	1,435
Sept. 6	A. Pirie.....	1,197	115.0	1,207	0.902	2.71	1,088
Sept. 9	W. H. Richardson.....	1,374	118.0	1,181	0.797	2.73	942
Sept. 29	A. Pirie.....	1,187	114.5	1,198	0.752	2.375	901
Sept. 30	A. Pirie.....	1,187	114.5	1,191	0.700	2.31	834
Nov. 2	R. H. Nelson.....	1,196-7	108.0	1,100	0.496	1.675	546
Nov. 4	R. H. Nelson.....	1,196-7	108.0	1,184	0.517	1.66	561
1913.							
Jan. 9	A. Pirie.....	1,462	102.0	975	0.336	0.80	328
Jan. 9	".....	1,462	102.0	975	0.333	0.80	324
Mar. 15	".....	1,186	102.0	936	0.226	0.28	212
May 31	".....	1,197	182.5	1,719	2.38	6.06	4,088

Table 64.—Daily discharge at Chaudière falls (Kettle falls) Rainy river (both channels.)

[Drainage Area, 7,060 square miles.]

1912.

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1					2-63	4,790	2-29	3,255	1-73	2,534	1-20	1,989
2					2-59	3,710	2-20	3,115	1-68	2,479	1-20	1,989
3					2-53	3,632	2-18	3,115	1-65	2,446	1-20	1,989
4					2-53	3,632	2-22	3,115	1-64	2,436	1-20	1,989
5					2-72	3,870	2-23	3,185	1-60	2,393	1-20	1,989
6					2-70	3,870	2-24	3,185	1-58	2,372	1-20	1,989
7					2-70	3,870	2-25	3,185	1-55	2,339	1-19	1,979
8			3-34	4,997	2-70	3,870	2-22	3,115	1-52	2,307	1-15	1,942
9				4,997	2-80	4,035	2-20	3,115	1-52	2,307	1-10	1,896
10			3-34	4,997	2-80	4,035	2-18	3,115	1-50	2,286	1-10	1,896
11			3-33	4,997	2-80	4,035	2-17	3,047	1-49	2,276	1-10	1,896
12			3-23	4,814	2-80	4,035	2-16	3,047	1-49	2,276	1-10	1,896
13			3-33	4,997	2-78	4,035	2-15	3,047	1-48	2,265	0-90	1,718
14			3-16	4,637	2-71	3,870	2-15	3,047	1-45	2,235	0-90	1,718
15			3-14	4,637	2-70	3,870	2-10	2,980	1-43	2,215	0-90	1,718
16			3-08	4,550	2-68	3,870	2-08	2,980	1-48	2,265	0-80	1,636
17			3-07	4,462	2-62	3,713	2-07	2,917	1-45	2,235	0-80	1,636
18			3-05	4,462	2-59	3,710	2-02	2,855	1-40	2,184	0-80	1,636
19			3-01	4,375	2-52	3,555	1-95	2,792	1-42	2,204	1-80	1,803
20			2-98	4,375	2-52	3,555	1-94	2,780	1-45	2,235	1-00	1,803
21			2-96	4,289	2-48	3,555	1-92	2,755	1-40	2,184	1-00	1,803
22			2-90	4,205	2-46	3,479	1-90	2,730	1-38	2,164	1-00	1,803
23			2-85	4,119	2-40	3,405	1-87	2,695	1-36	2,141	0-90	1,718
24			2-84	4,119	2-42	3,405	1-86	2,684	1-34	2,124	0-90	1,718
25			2-81	4,035	2-42	3,405	1-83	2,649	1-32	2,104	0-90	1,718
26			2-75	3,952	2-40	3,405	1-80	2,615	1-30	2,084	0-90	1,718
27			2-73	3,952	2-35	3,329	1-78	2,592	1-36	2,144	0-90	1,718
28			2-75	3,952	2-35	3,329	1-72	2,523	1-40	2,184	0-90	1,718
29			2-73	3,952	2-38	3,405	1-70	2,500	1-40	2,084	0-90	1,718
30			2-71	3,870	2-31	3,255	1-72	2,523	1-36	2,144	0-90	1,718
31			2-69	3,870			1-77	2,581			0-90	1,718

1913.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
1	0-90	1,718	0-60	1,486	0-40	1,297	0-23	1,259	2-65	4,790	6-30	10,990
2	0-90	1,718	0-60	1,486	0-40	1,297	0-23	1,259	2-75	3,952	6-50	11,400
3	0-80	1,636	0-60	1,486	0-30	1,297	0-25	1,270	2-85	4,119	6-68	11,810
4	0-80	1,636	0-60	1,486	0-30	1,297	0-25	1,270	2-95	4,289	6-78	12,015
5	0-80	1,636	0-60	1,486	0-30	1,297	0-26	1,275	3-05	4,462	6-94	12,322
6	0-80	1,636	0-60	1,486	0-30	1,297	0-26	1,275	3-05	4,462	7-02	12,425
7	0-80	1,636	0-50	1,418	0-30	1,297	0-26	1,275	3-20	4,725	7-10	12,630
8	0-80	1,636	0-50	1,418	0-30	1,297	0-26	1,275	3-35	4,997	7-12	12,630
9	0-80	1,636	0-50	1,418	0-30	1,297	0-27	1,281	3-42	5,090	7-16	12,732
10	0-80	1,636	0-50	1,418	0-20	1,243	0-27	1,281	3-50	5,280	7-22	12,835
11	0-80	1,636	0-50	1,418	0-20	1,243	0-27	1,281	3-60	5,470	7-22	12,835
12	0-80	1,636	0-50	1,418	0-24	1,264	0-28	1,286	3-80	5,865	7-22	12,835
13	0-80	1,636	0-50	1,418		1,270	0-32	1,309	3-72	5,665	7-22	12,835
14	0-80	1,636	0-50	1,418		1,281	0-48	1,406	3-80	5,865		
15	0-80	1,636	0-50	1,418	0-28	1,286	0-58	1,472	4-00	6,275		
16	0-80	1,636	0-70	1,418	0-28	1,286	0-72	1,576	4-10	6,480		
17	0-80	1,636	0-40	1,357	0-27	1,281	0-85	1,677	4-22	6,685		
18	0-80	1,636	0-40	1,357	0-27	1,281	1-00	1,803	4-30	6,890		
19	0-80	1,636	0-40	1,357	0-27	1,281	1-10	1,896	4-40	7,095		
20	0-70	1,561	0-40	1,357	0-26	1,275	1-28	2,065	4-45	7,197		
21	0-70	1,561	0-40	1,357	0-26	1,275	1-40	2,184	4-60	7,505		
22	0-70	1,561	0-40	1,357	0-26	1,275	1-50	2,286	4-70	7,710		
23	0-70	1,561	0-40	1,357	0-27	1,281	1-65	2,446	4-82	7,915		
24	0-70	1,561	0-40	1,357	0-28	1,286	1-75	2,558	4-90	8,118		
25	0-70	1,561	0-40	1,357	0-29	1,292	1-90	2,730	5-00	8,325		
26	0-70	1,561	0-30	1,297	0-28	1,286	2-05	2,917	5-15	8,532		
27	0-70	1,561	0-30	1,297	0-28	1,286	2-15	3,048	5-25	8,737		
28	0-60	1,486	0-30	1,297	0-28	1,286	2-30	3,255	5-38	9,145		
29	0-60	1,486			0-27	1,281	2-42	3,405	5-50	9,350		
30	0-60	1,486			0-25	1,270	2-50	3,555	5-78	9,965		
31	0-60	1,486			0-23	1,259			6-05	10,477		

Table 65.—Monthly Discharge at Chaudière Falls (Kettle falls) Rainy River (both channels.)

[Drainage Area, 7,060 square miles.]

Month.	DISCHARGE IN SECOND-FEET.				RUN-OFF Depth in inches on Drainage area
	Maximum.	Minimum.	Mean.	Per square mile	
1912.					
August <sup>1</sup>	4,997	4,870	4,400	0.620	(.554)
September	4,045	4,255	4,681	0.549	0.579
October	4,255	2,500	2,898	0.408	0.171
November	2,531	2,081	2,255	0.317	0.355
December	1,989	1,646	1,812	0.255	0.294
1913.					
January	1,718	1,486	1,602	0.226	0.260
February	1,486	1,297	1,400	0.197	0.205
March	1,297	1,244	1,282	0.180	0.208
April	3,555	1,259	1,896	0.267	0.298
May	10,477	4,790	6,595	0.928	1.070
June <sup>2</sup>	12,835	10,990	12,440	1.747	(.840)

<sup>1</sup>24 days only.    <sup>2</sup>13 days only.

WHITEMOUTH RIVER, NEAR WHITEMOUTH, MANITOBA.

*Location of Gauge.*—On general traffic bridge of Whitemouth village.

*Records available.*—May 29, 1912, to December 31, 1914.

*Drainage area.*—1,400 square miles.

*Gauge.*—Vertical staff, fastened to foundation pile of traffic bridge.

*Bench-Mark.*—Permanent bench-mark, consisting of iron staple embedded in top of concrete pile on left bank of river west of road. Elevation 100.

*Channel.*—River flowing in straight channel between clay banks, but to date no indication of shifting or change in section.

*Discharge measurements.*—Discharge measurements have been made since May 29, 1912, from the traffic bridge by the field officers of the Manitoba Hydrographic Survey.

*Winter Discharge.* The discharge rating curve applies only to open-water conditions.

Table 66.—Discharge measurements of Whitemouth river at Whitemouth, Manitoba.

[Drainage Area, 1,400 square miles.]

Date.	Hydrographer.	Meter No.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
			Feet.	Sq. Ft.	Ft. per sec.	Feet.	Sec. Ft.
1912.							
May 29	G. H. Burnham	1187	162	990.5	2.20	1.86	2,179
June 20	"	1187	151	629.4	1.07	2.18	674
July 13	"	1187	158	749.9	1.41	3.08	1,057
" 15	"	1187	158.5	858.4	1.67	3.70	1,134
Aug. 9	W. G. Warden	1187	149.7	699.6	1.30	2.95	910
Sept. 3	"	1187	149.7	845.0	1.59	3.72	1,398
Oct. 15	R. H. Nelson	1187	172.0	936.8	2.02	1.48	1,892
1913.							
Jan. 24	A. Pirie	1469	110.0	188.6	0.415	1.22	271
April 18	"	1186	154.0	752.0	0.65	3.29	1,241
May 9	G. Ebner	1186	151.0	732.1	1.48	2.92	1,010
Aug. 15	W. J. Ireland	1469	144.0	878.0	0.68	1.95	392
Sept. 21	C. O. Allen	1435	146.0	512.2	0.30	1.14	153
1914.							
Jan. 20	E. J. Budge	1467	140	207	0.07	0.78	151
Mar. 16	W. J. Ireland	1462	99	97	0.20	0.88	201
May 20	A. Pirie	1939	137	676	1.13	2.46	719
July 27	M. S. Madden	1760	175	609	0.76	2.09	467
Aug. 18	J. A. Page	1920	146	443	0.09	1.17	41
Sept. 4	H. Boyd	1919	142	492	0.26	1.40	125
Oct. 7	M. S. Madden	1911	142	522	0.30	1.51	158
Nov. 3	"	1912	147	580	0.22	2.08	451
" 30	C. O. Allen	1911	140	408	0.46	1.42	1461
Dec. 28	M. S. Madden	1462	125	260	0.07	1.09	171

<sup>1</sup>Ice measurements.

Table 67.—Daily discharge records of Whitemouth river at Whitemouth, Man.

(Drainage Area, 1,100 square miles.)

1912.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge										
	Feet	Sec. ft.										
1												
2											76 30	1,760
3											76 48	1,570
4											76 38	1,500
5											76 53	1,600
6											76 88	1,680
7												1,570
8											75 25	1,440
9											76 19	1,110
10											76 07	1,340
11											75 67	1,110
12												1,100
13											75 06	1,000
14											75 17	987
15											75 15	987
16											75 11	964
17											75 25	873
18												850
19											75 21	850
20											71 99	724
21											71 97	713
22											71 91	696
23											71 93	690
24												610
25											71 79	610
26											74 63	579
27											71 61	508
28											71 59	496
29											71 50	196
30												196
31											74 58	191
											71 86	479
											74 54	468
											77 25	2,010
											77 26	2,020
											76 99	1,860

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge										
1	74-19	271	75-75	1,160	76-12	1,370	77-22	2,000	76-35	1,500		
2	71-09	226	75-49	1,010	76-16	1,390	77-13	1,910	76-49	1,520		
3	73-97	181	75-38	947	76-15	1,390	76-97	1,850	76-45	1,560		
4	73-94	172	75-06	764	76-29	1,410	76-91	1,840	76-36	1,510		
5	73-93	169	75-05	759	76-08	1,690	76-86	1,790	76-29	1,170		
6	74-33	318	75-03	747	76-56	1,620	76-83	1,770	76-20	1,410		
7	74-38	377	75-07	770	76-47	1,570	76-77	1,740	76-07	1,340		
8	74-77	599	75-18	833	76-36	1,510	77-00	1,870	75-96	1,280		
9	74-98	719	75-37	941	76-32	1,480	77-25	2,010	75-87	1,230		
10	75-03	747	75-37	941	76-37	1,510	77-25	2,010	75-81	1,190		
11	75-07	770	75-36	935	76-42	1,540	77-21	2,010	75-76	1,160		
12	75-06	764	75-36	935	76-43	1,550	77-20	1,980	75-73	1,150		
13	75-59	1,020	75-17	827	76-43	1,550	77-16	1,960	75-67	1,110		
14	75-9	1,250	75-10	787	76-41	1,530	77-05	1,900	75-64	1,100		
15	76-17	1,400	75-02	741	76-38	1,520	76-92	1,820	75-61	1,080		
16	76-22	1,430	74-97	713	76-63	1,660	76-64	1,660	75-57	1,060		
17	76-22	1,430	74-83	633	76-75	1,730	76-55	1,610	75-57	1,060		
18	76-21	1,420	74-77	599	76-70	1,700	76-37	1,510	75-54	1,020		
19	76-21	1,420	74-73	576	76-63	1,660	76-36	1,510	75-47	1,000		
20	75-91	1,250	74-51	451	76-40	1,530	76-33	1,490	75-45	987		
21	75-83	1,200	74-49	439	76-98	1,860	76-17	1,400	75-36	935		
22	75-73	1,150	74-57	485	77-43	2,120	76-09	1,350	75-31	906		
23	75-84	1,210	74-67	542	77-53	2,170	75-97	1,280	75-23	861		
24	76-03	1,320	74-80	616	77-59	2,210	75-87	1,230	75-39			
25	76-18	1,400	74-86	650	77-57	2,200	75-66	1,110	75-61			
26	76-25	1,440	74-89	667	77-53	2,170	75-51	1,020	75-77			
27	76-29	1,470	74-91	679	77-45	2,130	75-93	1,260	75-83			
28	76-37	1,510	74-95	702	77-44	2,120	76-11	1,360	75-87			
29	76-26	1,450	74-97	713	77-35	2,070	76-21	1,420	75-87			
30	76-12	1,370	75-37	941	77-30	2,040	76-27	1,150	75-87			
31	75-93	1,260	75-97	1,280			76-29	1,470				

NOTE.—Ice conditions from November 23. Not sufficient information to compute daily discharges.

Table 67. Daily discharge records of Whitemouth river at Whitemouth, Man.—Continued.

1914.

Day.	January.		February.		March.		April.		May.		June.		
	Gauge Height	Discharge											
	Feet.	Sec.-ft.	Feet.	Sec. ft.									
1									75.28	1,180	74.75	588	
2									75.34	1,150	74.77	570	
3									75.66	1,140	74.79	560	
4									75.60	1,070	74.80	560	
5									75.57	1,060	74.80	560	
6													
7									75.51	1,040	74.88	605	
8									75.45	987	75.06	754	
9								77.56	2,150	75.15	987	74.91	747
10								77.03	2,310	75.37	941	74.88	662
11								77.87	2,470	75.47	911	74.80	646
12								78.37	2,600	75.41	964		48
13								78.20	2,850	75.39	883		19
14								77.00	3,000	75.36	93		36
15								77.41	2,160	75.33	918		14
16								77.33	2,060	75.25	873		92
17								77.37	2,070	75.15	846		62
18								77.21	1,990	75.07	770		48
19								75.74	1,150	75.07	710		47
20								75.00	1,130	75.03	737		4
21								75.70	1,130	74.97	713		82
22													
23								75.67	1,110	74.94	696		31
24								75.60	1,110	74.90	673		30
25								75.91	1,850	74.90	673		30
26								76.04	1,390	74.88	662		30
27								76.11	1,360	74.86	680		30
28													
29								76.47	1,100	74.84	609		17
30								76.47	1,100	74.80	616		160
31								76.15	1,390	74.80	616		160
								76.07	1,310	74.78	605		160
								75.95	1,270	74.75	588		160
											546		160

NOTE.—Discharge curve not defined above gauge height 74.80. For complete and full information to compute discharges.

Day.	July.		August.		September.		October.		November.	
	Gauge Height	Discharge								
1	74.81	622	73.91	163	74.53	462	73.83	113	71.71	
2	74.98	749	73.87	454	74.48	451	73.79	433	71.68	
3	74.96	707	73.84	138	74.40	388	73.74	117	71.66	
4	74.94	690	73.79	133	74.38	377	73.69	113	71.44	
5	74.81	622	73.73	121	74.33	348	73.73	121	71.31	
6	74.73	576	73.73	121	74.28	320	73.78	131	71.26	
7	74.64	525	73.67	410	74.21	282	73.76	127	71.24	82
8	74.51	451	73.63	102	74.16	258	73.74	123	71.21	282
9	74.51	451	73.59	96	74.08	222	73.83	443	71.17	262
10	74.45	417	73.56	92	74.13	244	73.94	463	71.13	214
11	74.53	462	73.53	89	74.24	298	74.03	202	71.09	226
12	74.63	519	73.53	89	74.07	218	75.04	757	71.05	210
13	75.21	850	73.49	84	74.05	210	75.20	811	71.05	210
14	75.50	1,020	74.07	218	74.00	190	75.16	992	71.05	210
15	75.55	1,040	71.29	325	73.93	169	75.51	1,020	71.05	210
16	75.71	1,130	74.68	548	73.91	163	75.54	1,040	71.05	
17	75.40	958	75.07	770	73.83	443	75.48	1,090	71.05	
18	75.28	890	75.21	850	73.91	163	75.39	952	71.05	
19	75.06	764	75.16	824	74.03	202	75.42	969	71.05	
20	75.99	724	75.11	793	73.90	187	75.35	930	71.05	
21	74.81	622	75.08	776	73.96	178	75.34	918	71.05	
22	74.65	531	74.99	724	73.95	175	75.23	861	71.05	
23	74.65	531	74.93	690	73.93	169	75.22	855	71.05	
24	74.58	491	74.91	679	73.93	169	75.15	816	71.05	
25	74.53	462	74.83	633	73.91	163	75.11	793	71.05	
26	74.41	394	74.83	633	73.87	153	75.05	759	71.05	
27	74.27	314	74.74	582	73.88	155	74.96	707	71.05	
28	74.14	248	74.66	530	73.80	150	75.01	736	71.05	
29	74.14	244	74.63	519	73.83	143	74.98	719	71.05	
30	74.00	190	74.57	385	73.81	138	74.96	707	71.05	
31	74.99	187	74.59	496			75.31	622	71.05	

Table 57.—Daily discharge records of *Whitemouth river at Whitemouth, Man.*—Continued.

1911.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge.										
	Feet.	Sec. ft.										
1							74 58		74 76	594	75 11	810
2							74 58		74 81	622	75 14	810
3							74 58		74 86	650	75 24	2,010
4							74 58		75 41	907	75 67	2,250
5							74 58		75 57	1,060	75 19	1,980
6							74 58		75 81	1,190	76 28	1,460
7							74 58		75 94	1,260	76 10	1,450
8							74 58		75 97	1,280	76 45	1,500
9							74 58		75 74	1,130	76 72	1,710
10							74 58		75 43	975	76 62	1,650
11							74 58		75 36	945	76 74	4,720
12							74 58		75 27	884	76 46	4,560
13							74 58		75 27	884	76 23	4,450
14							74 58		75 12	798	75 24	1,270
15							74 58		74 98	719	75 72	1,140
16							74 98		74 89	667	75 48	1,000
17							74 69		74 76	594	75 24	867
18							75 55		74 64	508	75 20	844
19							76 02		74 57	485	75 15	816
20							76 38		74 79	610	75 13	804
21							76 16	1,490	75 39	781	75 01	736
22							76 23	1,440	75 24	850	75 01	736
23							76 01	1,340	75 32	912	74 97	713
24							75 76	1,160	75 32	912	74 82	627
25							75 76	1,160	75 34	924	74 69	553
26							75 44	975	75 36	915	74 62	514
27							75 17	827	75 28	800	74 47	428
29							71 96	707	75 24	867	74 30	382
29							71 93	690	75 18	834	74 41	447
30							74 76	593	75 37	941	74 19	271
31									75 32	912		

NOTE.—Ice conditions from January 1, to April 20, not sufficient information to compute daily discharges.

	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge.										
1	74 19	271	74 22	287	73 87	154	74 05	210	74 39	482	73 86	
2	74 42	399	74 14	218	73 85	148	73 96	178	74 41	437	73 83	
3	74 46	422	74 08	322	73 79	133	74 01	164	74 34	437	73 87	
4	74 49	439	74 06	214	73 83	143	73 98	155	74 49	439	73 87	
5	74 49	439	74 03	202	73 79	137	74 03	163	74 48	434	73 88	
6	74 48	434	73 98	184	73 75	125	73 89	158	74 46	422	73 88	
7	74 48	434	73 92	366	73 75	125	73 89	58	74 37	371	73 87	
8	74 46	422	73 84	345	73 75	125	73 92	169	74 37	371	73 87	
9	74 35	360	73 77	329	73 73	121	74 06	214	74 34	354	73 85	
10	74 27	315	73 71	117	73 75	125	74 79	610	74 31	354	73 85	
11	74 08	222	73 67	110	73 77	129	75 61	1,080	74 33	348	73 83	
12	74 80	616	73 65	106	73 79	134	75 59	1,070	74 26	309	73 85	
13	77 11	1,950	73 56	92	73 79	133	75 55	1,040	74 26	309	73 85	
14	76 62	1,650	73 54	90	73 81	138	75 55	1,040	74 21	282	73 81	
15	76 44	1,190	73 54	90	73 84	145	75 51	1,020	74 16	258	73 8	
16	75 99	1,290	73 48	84	73 88	155	75 43	975	74 32	239	73 83	
17	75 71	1,150	73 51	90	73 91	164	75 36	935	74 31	235	73 83	
18	75 44	983	73 60	97	73 87	153	75 31	907	74 08	222	73 83	
19	75 42	969	73 60	97	73 87	153	75 25	873	74 08	222	73 73	
20	75 38	917	73 53	89	73 87	153	75 22	855	74 08	222	73 62	
21	75 30	901	73 49	84	73 89	158	75 18	833	74 08	222	73 52	
22	75 26	878	73 47	82	74 00	190	75 18	833	74 00	190	73 55	
23	75 13	804	73 47	82	74 16	258	75 01	736	74 00	190	73 55	
24	75 04	753	73 69	113	74 19	271	74 99	667	74 00	190	73 52	
25	74 92	684	73 71	117	74 24	298	74 76	593	73 93	169	73 53	
26	74 77	599	73 76	127	74 24	298	74 74	582	73 93	169	73 53	
27	74 61	508	73 81	138	74 20	276	74 69	553	73 93	169	73 53	
28	74 52	456	73 83	143	74 15	253	74 61	508	73 93	169	73 49	
29	74 46	422	73 85	148	74 09	226	74 55	474	73 90	160	73 49	
30	74 38	377	73 87	153	74 05	212	74 51	451	73 85	146	73 43	
31	74 38	377	73 89	158			74 43	405			73 41	

NOTE.—Marked thus †, interpolated, ice conditions from November 18; not sufficient information to compute daily discharges for December.

Table 68.—Monthly discharge of Whitemouth River at Whitemouth, Man.

[Drainage Area, 1,400 square miles.]

MONTH	DISCHARGE IN SECOND FEET				RCS EFF. Depth in inches on Drainage area
	Maximum	Minimum	Mean	Per square mile.	
1912					
May <sup>1</sup>			2 000	1 429	4 645
June	1 560	325	914	0 674	0 752
July	1 510	169	994	0 709	0 817
August	1 280	409	770	0 550	0 644
September	2 210	1 070	1 700	1 246	1 379
October	2 010	1 020	1 600	1 164	1 312
November <sup>1</sup>			1 000	0 714	0 797
December <sup>1</sup>			100	0 071	0 082
1913					
January <sup>1</sup>			25	0 018	0 021
February <sup>1</sup>			25	0 018	0 021
March <sup>1</sup>			25	0 018	0 021
April <sup>1</sup>			1 600	1 144	1 275
May	1 180	576	846	0 597	0 688
June	764	160	420	0 300	0 345
July	1 130	187	592	0 421	0 488
August	850	81	405	0 289	0 334
September	462	138	229	0 163	0 182
October <sup>1</sup>	1 040	114	597	0 426	0 491
November <sup>1</sup>			240	0 164	0 183
December <sup>1</sup>			50	0 036	0 041
The year			120	0 080	0 090
1914					
January <sup>1</sup>			15	0 011	0 013
February <sup>1</sup>			10	0 007	0 007
March <sup>1</sup>			20	0 014	0 016
April <sup>1</sup>			450	0 321	0 358
May	1 280	485	855	0 611	0 701
June	2 250	271	1 080	0 772	0 861
July	1 950	222	708	0 506	0 583
August	287	82	146	0 097	0 112
September	298	121	174	0 121	0 148
October	1 080	155	600	0 428	0 491
November <sup>1</sup>	449	146	274	0 195	0 218
December <sup>1</sup>			50	0 036	0 042
The year			664	0 260	0 317

<sup>1</sup>Estimated.

Table 69.—Miscellaneous Discharge Measurements in Winnipeg River Watershed.

Date.	Stream.	Tributary to	Location.	Discharge in Second Feet
Aug. 3, 1912	Rainy River	Lake of the Woods	Beaudette	10 824
" 21, 1912	"	"	"	8 287
Sept. 3, 1912	"	"	"	5 411
Oct. 3, 1912	"	"	Emo	10 119
Nov. 7, 1912	"	"	"	6 482
Jan. 14, 1914	"	"	"	6 155
Mar. 31, 1914	"	"	"	6 876
Aug. 10, 1912	Creek	Rainy Lake	in Hale Bay	1 0
" 11, 1912	Pipestone River	"	"	7 1
" 13, 1912	Rat River	"	"	No flow.
" 11, 1912	Sain	"	"	1 592 1
" 15, 1912	Creek	"	in Saine Bay	"
" 15, 1912	Creek No. 2	"	"	"
" 17, 1912	Rocky Inlet Creek	"	"	No flow.
" 20, 1912	Big Canoe River	"	"	216 4
" 21, 1912	Little Canoe River	"	"	6 8
" 22, 1912	Manitou River	"	"	815 5
" 21, 1912	Ash River	"	"	1 0
" 25, 1912	Small Creek	"	in Ash Bay	0 5
" 25, 1912	"	"	in Alexandra Bay	0 5
" 26, 1912	North-West Bay River	"	"	202 8
" 27, 1912	White Fish Creek	"	"	11 0
" 27, 1912	Brownlee's Creek	"	"	0 6
" 28, 1912	Small Creek	"	nr. Brownlee's in N. W. Bay	0 1
" 28, 1912	Lost Creek	"	"	7 0
" 29, 1912	Outlet of Wegg's Lake	"	"	0 7
" 29, 1912	Creek	"	in Brown's Inlet	(Est.) 0 5
" 30, 1912	Grassy Narrows Creek	"	"	0 1
" 31, 1912	Wasaw Creek	"	"	0 2
Sept. 1, 1912	Frog Cree	"	"	5 4

## RUN-OFF DATA OF THE WINNIPEG RIVER WATERSHED.

## TABLES 70 TO 91.

Data in Tables 70 to 91 were obtained by the field officers of the Hydro-Electric Commission of the province of Ontario, and published herein through the courtesy of the commission. The data are also available to the public in the Seventh Annual Report of the Commission.

## SEINE RIVER AT SKUNK RAPIDS.

*Location.*—About 200 feet above Skunk rapids, and 1 mile upstream from the Canadian Northern Railway bridge. One-half mile north of the C. N. R. tracks, and 1 mile west of La Seine station, in the District of Rainy River.

*Records Available.*—Discharge measurements, August to December, 1914. Daily gauge heights, September 22 to December 31, 1914.

*Drainage Area.*—3,483 square miles.

*Gauge.*—Vertical steel staff gauge with enamelled face, graduated in feet and inches, and located near La Seine station, on the Canadian Northern railway. The zero on the gauge is at an elevation of 87.73 feet, which is referred to a bench mark (assumed elevation 100.00) painted on a large boulder, on the right bank of the river, 6 feet from a 6-inch poplar tree used as a final point for soundings. The initial point is on the left bank and consists of a 2-inch spruce tree, blazed and marked I.P. with white paint. "H. E. P. Comm." is painted on the rock directly below the spruce tree.

*Channel.*—Straight for about 500 feet above and 200 feet below the station to the rapids. The right bank of the river curves into a point at the rapids forming a narrow channel. The velocity of the river is slow and the banks are high, rocky and wooded. This land has been burnt over, but most of the trees are still standing. The bed of the stream is sandy and clean, with a few boulders near the right bank. One channel exists at all stages.

*Discharge Measurements.*—Made from canoe by means of a small Price current meter.

*Accuracy.*—As only a few discharge measurements were made up to the present time, there are not sufficient data to make accurate estimates of the daily discharge. Tables of daily gauge height, daily discharge, and monthly discharge will be prepared when records are available.

*Observer.*—C. Rose, La Seine, Ont.; P.O., Banning, Ont.

Table 70. —Discharge Measurements at Skunk rapids, Seine river, Ontario.

[Drainage area, 3,483 square miles.]

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq.-ft.	Ft. per sec.	Feet.	Sec.-ft.
1914.						
Aug. 14	J. R. Taylor	194.9	2,000	0.66	8.84	1,329
Sept. 22	"	199.4	2,079	0.804	9.33	1,674
Oct. 13	"	198.5	2,061	0.73	9.15	1,522
Nov. 19	"	195.4	2,000	0.642	8.88	1,284
Dec. 5 <sup>1</sup>	"	185.0	1,879	0.57	8.25	1,059

<sup>1</sup>Boat and ice measurement. River partly frozen.

Table 71.—Daily Discharge at Skunk rapids, Seine river, Ontario.

[Drainage Area, 3,183 square miles.]

1911

Day.	September.		October.		November.		December.	
	Gauge Height.	Discharge.						
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1			9-08	1,460	8-92	1,320		
2			9-08	1,460	8-90	1,362		
3			9-06	1,442	8-92	1,320		
4			9-06	1,442	8-91	1,341		
5			9-06	1,442	8-90	1,302		
6			9-06	1,442	8-90	1,302		
7			9-06	1,442	8-90	1,302		
8			9-04	1,425	8-90	1,302		
9			9-04	1,425	8-90	1,302		
10			9-06	1,442	8-88	1,285		
11			9-13	1,503	8-85	1,260		
12			9-13	1,503	8-83	1,240		
13			9-15	1,520	8-85	1,260		
14			9-15	1,520	8-85	1,260		
15			9-13	1,503	8-85	1,260		
16			9-11	1,485	8-84	1,250		
17			9-09	1,469	8-78	1,198		
18			9-07	1,450	8-77	1,190		
19			9-03	1,415	8-77	1,190		
20			9-00	1,390	8-75	1,174		
21			8-98	1,372	8-74	1,162		
22	9-34	1,675	8-97	1,362	8-73	1,154		
23	9-27	1,625	9-03	1,415	8-73	1,154		
24	9-26	1,616	9-04	1,425	8-71	1,138		
25	9-27	1,625	9-04	1,425	8-70	1,130		
26	9-20	1,562	9-02	1,407	8-69	1,121		
27	9-17	1,537	9-00	1,390	8-67	1,104		
28	9-16	1,530	8-98	1,372	8-67	1,104		
29	9-14	1,485	8-96	1,352	8-67	1,104		
30	9-08	1,460	8-95	1,345	8-67	1,104		
31			8-94	1,337				

Table 72. —Monthly Discharge at Skunk rapids, Seine river, Ontario.

[Drainage Area, 3,183 square miles.]

Month.	DISCHARGE IN SECOND FEET			DISCHARGE IN SECOND-FOOT PER SQUARE MILE.			Depth in Inches on Drainage Area
	Maximum.	Minimum.	Mean.	Maximum.	Minimum.	Mean.	
1914							
October	4,520	1,337	1,431	0-44	0-38	0-411	0-47
November	4,320	1,104	1,220	0-38	0-32	0-350	0-39

## TURTLE RIVER AT MOUNTAIN RAPIDS.

*Location.*—About 300 feet above Mountain rapids, and about 8 miles from the Olive Mine, 12 miles from Mine Centre, which is on the Canadian Northern railway, in the Rainy River district.

*Records Available.*—Monthly discharge measurements, August to December, 1914. Daily gauge heights, August 9 to December 31, 1914.

*Drainage Area.*—1,841 square miles.

*Gauge.*—Vertical steel staff gauge with enamelled face, graduated in feet and inches, and fastened on a crib pier at the Canadian Northern Railway saw-mill, 12 miles from the station. The gauge is located 1,000 feet south of the mouth of Little Turtle river, on the east shore of Little Turtle lake. Zero on gauge (elevation 83.89) is referred to a bench-mark established on a rock with white paint, on the left bank of the river, 4 feet south of a blazed pine tree, marked I.P. with white paint, which is used as the initial point for soundings. The elevation of this bench-mark is 96.00, which is referred to another bench-mark (assumed elevation 100.00) established on a rock with white paint, 35 feet northeast of the gauge, at the Canadian Northern Railway mill at Mine Centre.

*Channel.*—Straight for about 1,000 feet above and below the station, the water running slowly. The banks are high, wooded, and rocky. The bed of the stream is sandy and clean, one channel existing at all stages.

*Discharge Measurements.*—Made from a canoe with a small Price current-meter.

*Control.*—The river is used extensively for log driving, and the log jams in Otter falls affect the section somewhat.

*Accuracy.*—As only a few discharge measurements were made up to the present time, there are not sufficient data to make accurate computations of the daily discharge. Additional tables of daily gauge height, daily discharge, and monthly discharge will be prepared and published when sufficient records are available.

*Observer.*—W. R. Miller, Mine Centre, Ont.

Table 73.—Discharge Measurements of Turtle river at Mountain rapids, Ontario.

[Drainage Area, 1,841 square miles.]

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq.-ft.	Ft. per sec.	Feet.	Sec.-ft.
1914.						
Aug. 11	J. R. Taylor	168.4	2,947	0.29	92.47	850
Sept. 23	"	167.8	2,948	0.407	92.43	1,202
Oct. 12	"	169.1	3,033	0.412	92.93	1,250
Nov. 5	"	168.1	2,964	0.39	92.58	1,161
Dec. 19 <sup>1</sup>	"	161.0	2,518	0.089	90.39	224

<sup>1</sup>Ice measurement—jam at Otter Falls.

## MANITOU RIVER AT DEVIL'S CASCADES.

*Location.*—About 150 feet below the old dam, at the head of the Devil's Cascades, Rainy River district.

*Records Available.*—Monthly discharge measurements, July to December, 1914. Daily gauge heights, July 15 to November 31, 1914.

*Drainage Area.*—440 square miles.

*Gauge.*—An inclined steel staff, graduated in feet and inches, and located on the face of the old dam. The zero of the gauge is at an elevation of 139.38 feet, referred to a bench-mark (elevation 147.37) painted on a rock, 1 foot east of the initial point of soundings. Owing to the gauge not being vertical in the face plane, 0.3 foot per foot of staff reading is to be subtracted from the staff reading before adding to gauge zero for water levels.

*Channel.*—Straight for about 150 feet above and 400 feet below the station. The right bank is high, rocky, wooded, and not liable to overflow, but the left bank is low and wooded, with a gradually rising bank, which is not liable to overflow unless the dam is operated. The bed of the stream is composed of rock, and the current is slow, one channel existing at all stages.

*Discharge Measurements.*—Made from canoe or ice, by a small Price current-meter.

*Control.*—Several dams exist on the river between the section and Manitou lake, which are not in operation at present. The operation of the dam just above the station causes fluctuations at the gauge.

*Accuracy.*—As only a few discharge measurements were made, there are not sufficient data to make accurate computations of the daily discharge. Table of daily gauge height, daily discharge, and monthly discharge will be prepared when sufficient records are available.

*Observer.*—S. H. Baldwin, Box No. 250, Fort Frances, Ont.

Table 74.—Discharge Measurements of Manitou river, Devil's Cascades, Ontario.

[Drainage area, 440 square miles.]

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec.-ft.
July 15	C. C. McLennan	110.0	493	0.577	4.83	284
Aug. 13	J. R. Taylor	98.6	483	0.56	4.69	271
Sept. 19	"	99.0	455	0.47	4.40	214
Oct. 11	"	98.7	463	0.506	4.52	234
Nov. 3	"	98.5	454	0.48	4.45	219
Dec. 17	"	91.3	474	0.43	4.35	194

Table 75.—Daily discharge of Manitou river, Devil's Cascades, Ontario.

[Drainage Area, 440 square miles.]

1914.

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1			4.81	287	4.50	230	4.44	220	4.44	220		
2			4.79	283	4.50	230	4.42	220	4.44	220		
3			4.77	279	4.42	216	4.42	220	4.44	220		
4			4.75	276	4.37	207	4.40	212	4.42	216		
5			4.73	272	4.35	203	4.40	212	4.42	216		
6			4.73	272	4.35	203	4.40	212	4.42	216		
7			4.71	268	4.37	207	4.42	216	4.40	212		
8			4.71	268	4.37	207	4.44	220	4.35	203		
9			4.71	268	4.35	203	4.46	224	4.35	203		
10			4.71	268	4.35	203	4.48	227	4.33	199		
11			4.71	268	4.33	199	4.50	230	4.35	203		
12			4.69	264	4.35	203	4.50	230	4.38	208		
13			4.69	264	4.37	207	4.50	230	4.42	216		
14			4.67	261	4.37	207	4.50	230	4.46	224		
15	4.87	298	4.67	261	4.35	203	4.48	227	4.50	230		
16	4.87	298	4.65	257	4.35	203	4.48	227	4.50	230		
17	4.92	307	4.65	257	4.37	207	4.46	224	4.50	230		
18	4.94	310	4.65	257	4.37	207	4.46	224	4.50	230		
19	4.94	310	4.62	252	4.40	212	4.48	227	4.50	230		
20	5.00	321	4.62	252	4.40	212	4.48	227	4.50	230		
21	5.04	329	4.62	252	4.39	210	4.50	230	4.50	230		
22	5.04	329	4.60	248	4.42	216	4.50	230	4.50	230		
23	5.00	321	4.60	248	4.42	216	4.50	230	4.48	227		
24	4.98	318	4.60	248	4.44	220	4.50	230	4.48	227		
25	4.98	318	4.60	248	4.44	220	4.50	230	4.48	227		
26	4.98	318	4.60	248	4.44	220	4.50	230	4.48	227		
27	4.96	314	4.60	248	4.44	220	4.48	227	4.50	230		
28	4.92	307	4.58	245	4.48	226	4.46	224	4.50	230		
29	4.90	303	4.56	241	4.48	226	4.46	224	4.50	230		
30	4.87	298	4.54	238	4.46	224	4.44	224	4.50	230		
31	4.85	294	4.52	234			4.44	220				

Table 76.—Monthly discharge of Manitou river, Devil's Cascades, Ontario.

[Drainage area, 440 square miles.]

1914.

Month.	DISCHARGE IN SECOND-FEET.			DISCHARGE IN SECOND-FEET PER SQUARE MILE.			RUN-OFF. Depth in inches on Drainage area.
	Maximum.	Minimum.	Mean.	Maximum.	Minimum.	Mean.	
	August	287	234	259	0.65	0.53	0.588
September	230	199	212	0.52	0.45	0.482	0.54
October	230	212	224	0.52	0.48	0.511	0.59
November	230	199	222	0.52	0.45	0.503	0.56
The period <sup>1</sup>	287	199	231	0.65	0.45	0.52	2.37

FOOTPRINT RIVER AT RAINY LAKE FALLS.

*Location.*—One hundred feet above the crest of the lowest fall, at the mouth of the Footprint river, where it flows into the northwest bay of Rainy lake, on Indian reserve 17A, district of Rainy River.

*Records Available.*—Monthly discharge measurements, July to December, 1914. Daily gauge heights, September 18 to December 31, 1914.

*Drainage Area.*—588 square miles.

*Gauge.*—Vertical steel staff gauge, graduated in feet and inches, and attached to a poplar tree 26.2 feet from the initial point. The zero on the gauge (elevation 102.26) is referred to a bench-mark painted on the ledge of a rock on right bank 6.7 feet upstream from initial point for soundings. Rod held on dot inside of circle marked B.M. in white paint (elevation 110.51).

*Channel.*—About 40 feet above the station the channel curves to the left and then runs straight for about 140 feet, dropping into Rainy lake. The banks are high, rocky, wooded, and not liable to overflow. The right bank has been burnt over. The bed of the river contains large boulders, and one channel exists at all stages.

*Discharge Measurements.*—Made from canoe with small Price current-meter. The initial point for soundings is marked Initial Point, H.E.P.C. on a rock ledge on the right bank, and 4.75 feet downstream from the point marked Initial Point, P.W.D., and 6.7 feet from the bench-mark.

*Control.*—Occasional operations of the dam at Footprint lake cause fluctuations in the river a . . . e.

*Accuracy.*—As only a few discharge measurements were made up to the present time, there are not sufficient data to make accurate computations of the daily discharge. Tables of daily gauge height, daily discharge, and monthly discharge will be prepared when sufficient records are available.

*Observer.*—John Lyons, Fort Frances, Ont.

Table 77.—Discharge measurements of Footprint river at Rainy Lake falls, Ontario.

[Drainage area, 588 square miles.]

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. ft.	Ft per sec.	Feet.	Sec.-ft.
1914						
July 14	C. C. McLennan	65.7	165	4.11	103.49	681
Aug. 12	J. R. Taylor	61	140	2.72	102.86	356
Sept. 18	"	54.3	101	2.38	102.38	242
Oct. 10	"	54.3	101	2.34	102.36	238
Nov. 1	"	45.0	57	1.83	101.47	105
Dec. 17	"	48.2	67	1.74	101.70	118

Table 78.—Daily discharge records of Footprint river at Rainy lake falls, Ontario.

[Drainage area, 588 square miles].

1914.

DAY.	September.		October.		November.		December.	
	Gauge Height.	Discharge.						
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1			102.38	242	101.47	106		
2			102.38	242	101.45	102		
3			102.38	242	101.45	102		
4			102.36	238	101.45	102		
5			102.36	238	101.45	102		
6			102.36	238	101.45	102		
7			102.36	238	101.45	102		
8			102.36	238	101.45	102		
9			102.36	238	101.45	102		
10			102.36	238	101.45	102		
11			102.35	235	101.45	102		
12			102.36	238	101.45	102		
13			102.36	238	101.45	102		
14			102.36	238	101.45	102		
15			102.36	238	101.45	102		
16			102.36	238	101.45	102		
17			102.36	238	101.45	102		
18	102.38	242	102.36	238	101.45	102		
19	102.38	242	102.36	238	101.45	102		
20	102.34	233	102.36	238	101.45	102		
21	102.34	233	102.36	238	101.45	102		
22	102.38	242	102.36	238	101.45	102		
23	102.38	242	102.36	238	105.68	102		
24	102.38	242	102.36	238	105.68	102		
25	102.38	242	102.36	238	105.68	102		
26	102.38	242	102.36	238	105.68	102		
27	102.34	233	102.36	238	105.68	102		
28	102.38	242	102.36	238	105.68	102		
29	102.38	242	102.36	238	105.68	102		
30	102.38	242	102.36	238	105.68	102		
31			102.36	238				

Table 79.—Monthly discharge of Footprint river at Rainy lake falls, Ontario.

[Drainage area, 588 square miles.]

1914.

Month.	DISCHARGE IN SECOND-FEET.			DISCHARGE IN SECOND-FEET PER SQUARE MILE.			Run-off.
	Maximum.	Minimum.	Mean.	Maximum.	Minimum.	Mean.	Depth in inches on Drainage area.
September.....	242	238	238	0.41	0.40	0.405	0.46
October.....	106	102	102	0.18	0.17	0.173	0.19

## WABIGOOON RIVER AT WABIGOOON FALLS.

*Location.*—About 100 feet below the lowest fall on the Wabigoon river, and 3 miles from the mouth of the Wabigoon river discharging into the English river, district of Kenora.

*Records Available.*—Monthly discharge measurements, June to November, 1914.

*Drainage Area.*—1,026 square miles.

*Gauge.*—Vertical steel staff with enamelled face, graduated in feet and inches and screwed to a 5-inch hewn spruce post, firmly wedged and braced to the left bank, about 200 feet above the metering station. The zero on the gauge (elevation 11.37) is referred to a bench-mark (elevation 120.07) on a nail driven in a 4-inch tamarac stump located 2 feet upstream from the gauge. The initial point for soundings is on the right bank, painted I.P., S. 12° E. on a blazed 5-inch poplar tree.

*Channel.*—Straight for about one-half mile above and 100 feet below the station to the falls. Both banks are high, rocky, wooded, and will not overflow. The bed of the stream is composed of rock, with a few boulders and weeds at the right bank. The current is sluggish above the station, but swift just above the falls. There is a slight backwater at the left bank.

*Discharge Measurements.*—Made from canoe and ice with a small Price current meter.

Table 80.—Discharge Measurements of Wabigoon River, at Wabigoon Falls, Ontario,  
(Drainage area, 1,026 square miles.)  
1914.

Date.	Hydrographer.	Width.	Area of section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sq. ft.
1911						
June 8	C. C. McLennan	248 0	3,658	0.91	114.88	3,312
July 17	"	247.6	3,488	0.74	114.05	2,569
Aug. 4	"	246 0	3,220	0.54	113.04	1,752
Sept. 14	"	247 0	2,957	0.47	112.04	1,103
Nov. 8	"	239.5	3,081	0.44	112.52	1,374
Dec. 21	"	217 0	2,907	0.40	111.73	900

#### WABIGOON RIVER NEAR QUIBELL.

*Location.*—About 200 feet above the second fall from the G. T. P. railway bridge which spans the first fall, or one-half mile north of the railway. One-half mile from Quibell station on the Grand Trunk Pacific railway, Quibell township, district of Kenora.

*Records Available.*—Monthly discharge measurements, June to November, 1914. Daily gauge heights, August 1 to November 30, 1914.

*Drainage Area.*—1,612 square miles.

*Gauge.*—Vertical staff gauge consisting of 9 feet of enamelled steel plate, graduated in feet and inches and screwed to a 5-inch hewn spruce post, firmly wedged and secured to a rock on the right bank of the river. The elevation of the zero mark is 24.26, which is referred to a bench-mark (elevation 33.67) located just below the gauge.

*Channel.*—Straight for about 1,200 feet above the station, where the stream enters from the right bank, making an angle of 90°. For about 200 feet below the station the river is straight and then narrows into a fall. The water is sluggish, and banks are high, rocky, and wooded. There are a few boulders apparent in the bed of the stream. One channel exists at all stages.

*Discharge Measurements.*—Made from a canoe by a small Price current-meter.  
*Control.*—The Dryden Timber and Power Company operate a dam and power plant at Dryden, on the Wabigoon river.

*Accuracy.*—As only a few discharge measurements are made up to the present time, there are not sufficient data to make accurate estimates of the daily discharge.

*Observer.*—D. C. Warner, Quibell, Ont.

Table 80A.—Discharge Measurements of Wabigoon River, rear Quibell, Ont.,

1914.

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. Feet.	Feet per Sec.	Feet.	Sec-feet.
1914.		124.0	1,484	1.82	95.32	2,703
June 4	P. V. Binns	110.0	1,258	1.20	93.44	1,503
July 18	"	84.1	720	1.72	26.59	1,237
Aug. 1 <sup>1</sup>	"	85.5	736	1.83	26.81	1,347
Sept. 17	"	83.8	703	1.62	25.46	1,138
Oct. 5	"	81.2	648	1.29	25.73	841
Nov. 11	"					

<sup>1</sup>New section established.

Table 81.—Daily Discharge Records of Wabigoon River, near Quibell, Ontario.

[Drainage Area, 1,612 square miles.]

1914.

Day.	August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.	Gauge Height.	Discharge.	Gauge Height.	Discharge.	Gauge Height.	Discharge.	Gauge Height.	Discharge.
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1	26.59	1,255	25.76	860	26.67	1,295	26.05	1,000		
2	26.54	1,230	25.75	855	26.59	1,255	26.05	1,000		
3	26.55	1,235	25.75	855	26.52	1,220	26.05	1,000		
4	26.51	1,215	25.74	845	26.50	1,210	26.05	1,000		
5	26.51	1,215	25.72	840	26.42	1,170	26.05	1,000		
6	26.50	1,210	25.68	825	26.39	1,155	26.02	985		
7	26.51	1,215	25.67	815	26.34	1,130	26.01	980		
8	26.43	1,175	25.63	805	26.30	1,115	25.94	945		
9	26.43	1,175	25.59	785	26.26	1,095	25.84	895		
10	26.47	1,195	25.68	825	26.43	1,175	25.80	880		
11	26.34	1,130	25.72	840	26.59	1,255	25.76	860		
12	26.22	1,075	25.83	920	26.67	1,295	25.75	855		
13	26.18	1,055	25.84	895	26.68	1,300	25.76	860		
14	26.18	1,055	25.89	920	26.68	1,300	25.76	860		
15	26.18	1,055	25.93	940	26.68	1,300	25.76	860		
16	26.17	1,050	26.09	1,015	26.67	1,295	25.76	860		
17	26.17	1,050	26.77	1,340	26.59	1,255	25.83	890		
18	26.09	1,015	27.26	1,580	26.58	1,250	25.80	830		
19	26.05	985	27.51	1,705	26.43	1,175	25.76	860		
20	26.01	980	27.47	1,680	26.42	1,170	25.76	860		
21	25.97	955	27.26	1,580	26.26	1,095	25.75	855		
22	25.9 <sup>2</sup>	940	27.12	1,504	26.26	1,095	25.72	840		
23	25.7	955	27.09	1,495	26.25	1,090	25.68	825		
24	25.89	920	27.17	1,535	26.24	1,085	25.68	825		
25	25.34	895	27.18	1,540	26.25	1,090	25.67	815		
26	25.80	880	27.24	1,570	26.14	1,035	25.67	815		
27	25.82	885	27.17	1,535	26.10	1,020	25.67	815		
28	25.80	880	27.93	1,910	26.09	1,015	25.66	810		
29	25.76	860	26.77	1,340	26.09	1,015	25.68	825		
30	25.76	860	26.70	1,305	26.09	1,015	25.66	810		
31	25.76	860			26.08	1,010				

Table 82.—Monthly Discharge of Wabigoon River, near Quibell, Ont.

[Drainage Area, 1,612 square miles]

1914.

Month.	DISCHARGE IN SECOND FEET.			DISCHARGE IN SECOND FEET PER SQUARE MILE.			RUN-OFF.
	Maximum.	Minimum.	Mean.	Maximum.	Minimum.	Mean.	Depth in inches on drainage area.
August .....	1,255	860	1,050	0.78	0.54	0.651	0.75
September .....	1,910	785	1,181	1.19	0.49	0.742	0.81
October .....	1,300	1,010	1,160	0.81	0.64	0.719	0.84
November .....	1,000	810	885	0.62	0.50	0.549	0.61
December .....							
The period .....	1,910	785	1,069	1.19	0.49	0.66	3.00

## EAGLE RIVER AT EAGLE RIVER.

*Location.*—At the highway bridge, 1,000 feet south of the Canadian Pacific Railway crossing of the river, and above the Cascades, in the township of Aubrey, Kenora district. This river is a branch of the Wabigoon river.

*Records Available.*—Monthly discharge measurements, January to November, 1914. Daily gauge heights, February 12 to December 31, 1914.

*Drainage Area.*—933 square miles.

*Gauge.*—Vertical steel staff gauge with enamelled face, graduated in feet and inches, and located on the south face of the bridge crib, near the southeast corner, next to the left bank of the river. The zero on the gauge (elevation 1,172.99) is referred to a bench-mark (elevation 1,193.22) consisting of the head of a spike driven horizontally in the face of the water tank near the bridge, on the main line of the Canadian Pacific railway. Another bench-mark, at an elevation of 1,176.56 is painted on a rock, on the left bank, a few feet above the cross-section.

*Channel.*—Straight for about 100 feet above the station, with the water running slowly. Below the section the channel is straight for about 20 feet, with swift water running to the fall over the Cascades. The banks are clean, high, rocky, and not liable to overflow. The bed consists of solid rock, and is practically permanent. At extreme high water the flow is cut up by the bridge piers, but under normal conditions the flow is all through one channel.

*Discharge Measurements.*—Made from the highway bridge with a Price current-meter.

*Accuracy.*—This is nearly an ideal section. The sum of the differences between curve and measured discharges for same gauge heights is 3.09 per cent of the sum of those measured discharges.

*Observer.*—J. Nelson, Eagle River, Ont.

Table 83.—Discharge Measurements of Eagle river at Eagle River, Ontario.

(Drainage Area, 911 square miles.)

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec.-ft.
1914.						
Jan. 8	C. C. McLennan	36.0	114	1.85	1173.55	212
Feb. 12	"	35.5	109	1.81	1173.53	197
Mar. 20	"	35.0	108	1.72	1173.83	187
Mar. 26	"	35.0	105	1.78	1173.49	189
Mar. 26	"	35.0	108	1.79	1173.19	189
Mar. 27	"	35.0	108	1.81	1173.51	197
Mar. 28	"	35.0	115	1.79	1173.66	206
Apr. 25	"	35.0	115	1.76	1173.66	203
April 25	"	35.0	100	3.83	1175.24	730
June 9	R. M. Carmichael	86.0	190	3.78	1175.21	721
June 9	"	86.0	190	3.83	1175.24	731
June 9	"	86.0	190	3.79	1175.24	724
June 9	"	87.5	200	4.14	1175.41	824
June 10	"	87.5	200	4.11	1175.41	824
June 10	"	81.0	194	3.70	1175.16	718
July 30	"	81.0	194	3.56	1175.11	689
July 31	"	50.0	154	2.59	1174.41	399
Sept. 2	C. C. McLennan	50.0	154	2.50	1174.41	365
Sept. 2	"	19.5	145	2.55	1174.4	366
Sept. 3	"	19.5	145	2.5	1174.28	365
Sept. 3	"	52.5	158	3.08	1174.55	486
Sept. 3	"	52.5	158	2.92	1174.50	459
Sept. 18	P. V. Bunn	51.8	157	2.68	1174.47	399
Sept. 23	"	50.6	148	2.68	1174.46	397
Oct. 7	"	50.6	148	2.61	1174.40	375
Oct. 7	"	46.1	113			
Nov. 12	"					

Table 84.—Daily Discharge Records of Eagle river at Eagle River, Ontario.

(Drainage Area, 911 square miles.)

1914.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge.										
	Feet.	Sec.-ft.										
1	1,173.53	196	1,173.51	193	1,173.50	191	1,173.70	227	1,174.65	477		
2	1,173.53	196	1,173.51	193	1,173.51	193	1,173.68	224	1,174.67	485		
3	1,173.53	196	1,173.51	193	1,173.52	194	1,173.72	232	1,174.72	502		
4	1,173.53	196	1,173.51	193	1,173.81	193	1,173.81	250	1,174.78	526		
5	1,173.51	193	1,173.51	193	1,173.51	193	1,173.80	248	1,174.80	533		
6	1,173.51	193	1,173.51	193	1,173.51	193	1,173.84	256	1,174.80	533		
7	1,173.51	193	1,173.51	193	1,173.51	193	1,173.84	263	1,174.80	568		
8	1,173.53	196	1,173.51	193	1,173.93	193	1,173.93	275	1,174.90	730		
9	1,173.53	196	1,173.51	193	1,173.51	193	1,173.93	275	1,175.24	831		
10	1,173.53	196	1,173.51	193	1,173.51	193	1,173.97	284	1,175.11	831		
11			1,173.53	196	1,173.53	196	1,173.97	281	1,175.49	883		
12			1,173.55	198	1,173.51	193	1,173.97	284	1,175.49	883		
13			1,173.55	198	1,173.51	193	1,173.95	278	1,175.59	918		
14			1,173.53	196	1,173.51	193	1,173.94	278	1,175.51	960		
15			1,173.53	196	1,173.53	196	1,173.97	284	1,175.55	920		
16			1,173.53	196	1,173.53	196	1,173.49	188	1,173.99	289	1,175.56	891
17			1,173.57	203	1,171.53	196	1,173.51	193	1,174.01	295	1,175.56	993
18			1,173.57	203	1,174.55	198	1,174.53	196	1,174.03	299	1,175.53	908
19			1,173.57	203	1,174.55	198	1,174.58	201	1,174.03	299	1,175.61	960
20			1,173.57	203	1,173.53	196	1,173.62	210	1,174.13	324	1,175.53	920
21			1,173.53	196	1,173.49	188	1,173.63	216	1,174.22	345	1,175.53	908
22			1,173.53	196	1,173.47	185	1,173.65	217	1,174.19	345	1,175.53	908
23			1,173.55	193	1,173.45	181	1,173.65	217	1,174.22	345	1,175.56	993
24			1,173.51	193	1,173.45	181	1,173.65	217	1,174.31	369	1,175.53	968
25			1,173.55	198	1,173.47	185	1,173.66	219	1,174.36	388	1,175.56	908
26			1,173.51	193	1,173.47	185	1,173.66	219	1,174.38	393	1,175.53	908
27			1,173.51	193	1,173.53	193	1,173.66	219	1,174.38	393	1,175.45	855
28			1,173.49	188	1,173.51	193	1,173.68	224	1,174.48	420	1,175.45	855
29					1,173.51	193	1,173.68	224	1,174.47	417	1,175.45	855
30					1,173.51	193	1,173.70	227	1,174.53	438	1,175.45	855
31					1,173.51	193			1,174.65	477		

Table 84. —Daily Discharge Records of Eagle river—Concluded.

Day	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge										
	Feet.	Sec.-ft.										
1	1,175-44	846	1,175-16	689	1,174-34	478	1,174-49	423	1,174-45	473	1,174-26	358
2	1,175-43	881	1,175-14	678	1,174-40	467	1,174-51	430	1,174-46	488	1,174-22	348
3	1,175-47	868	1,175-16	689	1,174-26	455	1,174-19	423	1,174-44	477	1,174-22	348
4	1,175-41	831	1,175-11	663	1,174-20	440	1,174-45	410	1,174-36	485	1,174-20	340
5	1,175-45	855	1,175-09	654	1,174-07	407	1,171-11	398	1,174-34	478	1,174-20	340
6	1,175-49	884	1,175-11	663	1,171-20	410	1,174-48	494	1,174-32	473	1,174-10	348
7	1,175-47	868	1,175-09	654	1,174-20	410	1,171-38	494	1,174-28	461	1,174-18	348
8	1,175-45	855	1,175-07	646	1,174-18	445	1,174-48	494	1,174-32	473	1,174-18	348
9	1,175-38	816	1,174-99	609	1,174-16	340	1,174-36	388	1,174-32	373	1,174-16	340
10	1,175-30	765	1,174-95	594	1,174-18	345	1,174-36	388	1,174-32	373	1,174-18	345
11	1,175-38	754	1,174-98	584	1,174-20	440	1,174-48	494	1,174-32	473	1,174-48	345
12	1,175-36	805	1,174-98	584	1,174-24	451	1,174-48	494	1,174-24	451	1,174-16	340
13	1,175-41	811	1,174-95	584	1,174-28	461	1,174-11	398	1,174-32	473	1,174-16	340
14	1,175-45	855	1,174-99	609	1,174-32	474	1,171-49	423	1,174-20	340	1,174-16	340
15	1,175-47	868	1,174-91	576	1,174-36	388	1,171-54	438	1,174-22	345	1,174-16	340
16	1,175-48	816	1,174-82	542	1,174-44	404	1,174-53	448	1,174-26	340	1,174-16	340
17	1,175-30	765	1,174-82	542	1,174-54	448	1,174-54	448	1,174-26	355	1,174-16	340
18	1,175-44	846	1,174-80	533	1,174-57	450	1,174-55	444	1,174-16	340	1,174-16	340
19	1,175-34	787	1,171-78	526	1,174-59	456	1,174-53	448	1,175-24	354	1,174-16	340
20	1,175-32	775	1,174-74	509	1,174-61	462	1,174-53	440	1,174-26	355	1,174-16	340
21	1,175-40	765	1,174-72	502	1,174-61	462	1,174-49	424	1,174-24	351	1,174-16	340
22	1,175-24	730	1,174-68	488	1,174-61	462	1,174-49	423	1,171-22	445	1,174-16	340
23	1,175-28	754	1,174-66	480	1,174-63	444	1,174-49	423	1,171-24	351	1,174-16	340
24	1,175-42	777	1,171-61	462	1,174-55	441	1,174-49	424	1,174-26	355	1,174-14	326
25	1,175-36	805	1,174-57	450	1,174-53	438	1,174-47	417	1,174-28	361	1,174-14	326
26	1,175-24	740	1,174-53	448	1,174-53	438	1,174-32	373	1,171-28	361	1,174-11	318
27	1,175-16	689	1,174-49	423	1,174-53	438	1,174-36	388	1,174-28	361	1,174-14	326
28	1,175-24	740	1,174-47	417	1,174-51	430	1,174-31	378	1,174-26	355	1,174-14	326
29	1,175-16	689	1,174-45	410	1,174-49	423	1,174-32	373	1,174-28	361	1,174-14	326
30	1,175-14	678	1,174-41	398	1,174-49	424	1,174-32	373	1,174-28	361	1,174-14	326
31	1,175-16	689	1,174-39	394	1,174-41	417	1,171-41	378	1,174-28	361	1,174-11	318

Table 85. —Monthly Discharge of Eagle river at Eagle River, Ontario.

(Drainage Area 933 square miles.)

1914.

Month.	DISCHARGE IN SECOND-FEET.			DISCHARGE IN SECOND-FEET PER SQUARE MILE.			RUN-OFF. Depth in inches on Drainage Area.
	Maximum.	Minimum.	Mean.	Maximum.	Minimum.	Mean.	
January							
February							
March	198	181	193	0-21	0-19	0-21	0-24
April	227	186	202	0-24	0-20	0-21	0-24
May	477	224	345	0-51	0-24	0-34	0-39
June	994	477	798	1-06	0-51	0-85	0-95
July	883	678	791	0-95	0-74	0-85	0-98
August	689	393	548	0-74	0-42	0-59	0-68
September	474	307	396	0-51	0-30	0-42	0-47
October	444	373	408	0-48	0-40	0-44	0-50
November	388	340	360	0-42	0-35	0-35	0-44
December	355	318	322	0-38	0-34	0-34	0-39
The period.	994	181	444	1-06	0-19	0-49	5-28

ENGLISH RIVER AT EAR FALLS.

Location. —At the foot of Lac Seul, about 3 miles below Pine Ridge, Hudson's Bay Company post, and about one-quarter mile above Upper Ear falls, Kenora district.

*Records Available.*—Monthly discharge measurements, July to October, 1914. Daily gauge heights, read at the main Hudson's Bay Company post, 75 miles above the section on Lac Seul, but do not give the fluctuations at the gauging section.

*Drainage Area.*—Not measured.

*Gauge.*—Vertical steel staff with enamelled face, graduated in feet and inches, and screwed to a 6-inch hewn spruce post, which is firmly wedged in a rock on the left bank, 200 feet below a 2-inch poplar, which is painted with white paint and used as the initial point for roundings. The zero on the gauge (elevation 115.14) is referred to a bench-mark (elevation 122.78) painted on a rock 5 feet above the gauge. Another bench-mark (elevation 122.08) is located at the head of the falls, 30 feet west of the portage entrance, directly below the section.

*Channel.*—Straight for about 400 feet above and 300 feet below the station, to the Upper Ear falls. Both banks are high, rocky, and wooded, and will not overflow. The bed of the stream is composed of rock with a little gravel, apparently stable. The current is sluggish, flowing through one channel at all stages.

*Discharge Measurements.* Made from a canoe with a small Price current-meter.

*Accuracy.*—Backwater on the left bank at certain stages of the river, causes difficulties in making accurate measurements of the discharge.

Table 86.—Discharge Measurements of English River at Ear Falls, Ontario.

Date	Hydrographer.	Width.		Mean Velocity.		Gauge Height.	Discharge
		Feet.	Sq. ft.	Ft. Per sec.	Ft.	Sec.-ft.	
1914							
July 4	P. V. Binns	339.0	8,786	1.01	120.02	8,906	
Aug. 10	"	338.6	8,749	1.06	119.85	7,318	
Sept. 12	C. C. McLennan	337.0	8,643	0.85	119.52	7,408	
Oct. 30	P. V. Binns	345.1	8,562	0.79	119.28	6,801	

#### ENGLISH RIVER AT MANITOU FALLS.

*Location.*—About 800 feet above the first chute of the Manitou falls, and 5 miles below the old Mattawa Hudson's Bay Company post, Kenora district. Cedar river enters the English river one-half mile below the metering station, after which the English river flows west.

*Records Available.*—Monthly discharge measurements, July to October, 1914.

*Drainage Area.*—Not measured.

*Gauge.*—Vertical steel staff with enamelled face, graduated in feet and inches, and screwed to a 6-inch hewn pine post firmly wedged and wired to the right bank, 15 feet south of the initial point, which consists of a 2-inch blazed jack pine, about 800 feet above the first fall. The zero of the gauge (elevation 89.42) is referred to a bench-mark (elevation 100.43) painted on a rock 2.5 feet southeast of the initial point. It is also referred to a bench-mark (assumed

elevation 100.00) located on the left bank, 800 feet south of the section and at the head of the falls, 50 feet west of the head of the portage.

*Channel.*—At a point 1,200 feet above the station, the river turns to the right into a comparatively straight stretch, and opens into a weedy marsh or small lake 800 feet below the section, just above the falls. Both banks are high, rocky, and wooded, and will not overflow. The current is sluggish and flows through one channel at all stages.

*Discharge Measurements.*—Made from a canoe with a small Price current-meter.

Table 87.—Discharge Measurements of English River at Manitou Falls, Ontario.

Date	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
1914		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec.-ft.
July 4	C. C. McLennan	190.7	6,881.86	2.46	94.46	9,555
Aug 9	"	195.7	6,961.21	2.59	93.81	10,279
Sept. 30	"	185.9	5,721.1	2.01	92.68	8,580
Oct. 31	"	180.0	5,619.01	2.28	92.09	8,257

ENGLISH RIVER NEAR OAK LAKE FALLS.

*Location.*—About 1 mile above the upper fall of Oak Lake falls, and about one-half mile below Wilcox lake, district of Kenora.

*Records Available.*—Monthly discharge measurements, August to November, 1914.

*Drainage Area.*—Not measured.

*Gauge.*—A bench-mark gauge located on a rock in the river at the station near the right bank. The initial point for soundings is established on the left bank, and consists of the head of a nail driven into the blazed side of a 12-inch poplar, painted E. P. N. 70° W.

*Channel.*—Straight for about 300 feet above and one-half mile below the station. Both banks are high, rocky, wooded, and not liable to overflow. The bed of the stream is rocky and practically permanent. The current is sluggish at the station, but swift through the little rapids 800 feet below, after which it becomes sluggish to the head of the falls. One channel exists at all stages.

*Discharge Measurements.*—Made from a canoe with a small Price current-meter.

Table 88.—Discharge Measurements of English River at Oak Lake Falls, Ontario.

Date	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
1914		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec.-ft.
Aug. 7	C. C. McLennan	397.2	7,011	1.68	197.11	11,344
Sept. 27	"	390.9	6,774	1.41	196.50	9,568
Nov. 5	"	387.7	6,672	1.30	196.25	8,698
Dec. 23	"	382.0	6,429	1.11	195.64	7,131

## ENGLISH RIVER AT STURGEON FALLS.

*Location.*—Located about 300 feet above the lowest of the three falls known as Sturgeon falls, district of Kenora.

*Records Available.*—Monthly discharge measurements, from June to October, 1914.

*Drainage Area.*—Not measured.

*Gauge.*—Vertical steel staff with enamelled face, graduated in feet and inches, and screwed to a 5-inch hewn spruce post, firmly wedged and braced to the left bank, about 150 feet below the station. The zero on the gauge (elevation 91.52) is referred to a bench-mark (assumed elevation 100.00) on the left bank, 10 feet from the initial point and 2 feet below the line of the section. The initial point for soundings is blazed on the edge of a 6-inch poplar on the left bank and marked I.P.N. 10° E.

*Channel.*—There are deep bays on both sides of the river above the station, from which point the water flows in a comparatively straight channel gradually narrowing towards the head of the falls. Both banks are high, rocky, wooded, and will not overflow. The bed is composed of rock with a little sand in the centre of the river. The velocity is low at the left bank, slight backwater existing at higher stages.

*Discharge Measurements.* Made from a canoe with a small Price current-meter.

*Control.*—The Dryden Timber and Power Company operate a dam on the Wabigoon river, which is a tributary stream.

Table 89.—Discharge Measurements of English River at Sturgeon Falls, Ontario.

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec.-ft.
1914						
June 12	C. C. McLennan	362	8,829	1.36	93.85	11,996
July 14	"	388	9,397	1.53	95.36	11,403
Sept. 11	"	354	8,620	1.29	93.25	11,089
Oct. 22	"	357	8,724	1.31	93.55	11,444

## ENGLISH RIVER AT CARIBOU FALLS.

*Location.*—About 1,200 feet above Caribou Falls, the lowest falls on the river, district of Kenora.

*Records Available.*—Monthly discharge measurements, May to October, 1914.

*Drainage Area.*—Not measured.

*Gauge.*—Vertical staff located on the left bank of the river, 25.6 feet north of a blazed jack pine, which is used as the initial point for soundings. The zero on the gauge (elevation 100.00) is referred to a bench-mark (elevation 109.45) painted on the point of a rock, 16 feet south of the blazed jack pine.

*Channel.*—Above the station the channel takes a sharp 90 degree curve to the right, thence flowing comparatively straight to the head of the falls. Both

banks are high, rocky, and wooded, and not liable to overflow. The bed of the stream is rocky, with large boulders or protruding shelves of rock and practically permanent. The water near the left bank is still.

*Discharge Measurements.*—Made from a canoe and raft with a small Price current-meter.

*Control.*—The Dryden Timber and Power Company operate a plant on the Wabigoon river, a tributary stream.

Table 90.—Discharge Measurements of English River at Caribou Falls, Ontario.

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
1914		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec. ft.
May 25	C. C. McLennan	236	10,051	0.87	101.72	8,785
June 14	"	239	10,214	1.43	102.92	14,606
July 11	"	240	10,342	1.53	103.17	15,812
Sept. 5	"	239	10,165	1.18	102.36	12,061
" 6	"	239	10,169	1.19	102.36	12,162
" 6	"	239	10,165	1.19	102.36	12,188
" 7	"	239	10,180	1.17	102.36	11,945
" 7	"	239	10,166	1.09	102.35	11,182
" 8	"	239	10,164	1.16	102.33	11,774
Oct. 20	"	240	10,191	1.22	102.45	12,409
Dec. 14	"	236	10,020	0.88	101.75	8,885

Table 91.—Miscellaneous Discharge Measurements by the Hydro-Electric Power Commission of the Province of Ontario, in Winnipeg River Watershed in Ontario.

River.	Date.	Discharge in sec. ft.	Location.
White Fish	Jan. 1906	207	White Fish falls.
"	"	146	Below Penche Lake.
Winnipeg	Oct. 14, 1905	5,321	Eastern outlet.
"	April 8, 1906	4,490	"
"	Oct. 16, 1905	899	L. of W. Milling Co. head- lake.
"	Oct. 16, 1905	490	Keowatin Lumber Co.
"	Oct. 18, 1905	21,794	Western outlet.
"	Dec. 17, 1913	8,547	Minaki.
"	Oct. 17, 1913	546	Whitedog (north channel).
"	Dec. 15, 1913	354	Whitedog (north channel).
"	Oct. 18, 1913	12,221	Whitedog (south channel).
"	Jan. 20, 1913	7,661	Whitedog falls.
"	Dec. 16, 1911	8,788	Whitedog falls.
York	Oct. 7, 1913	136	Below High falls.
"	Oct. 8, 1913	181	Below Bancroft.
English	May 26, 1906	6,740	Pelican falls.
"	June 2, 1906	6,702	Manitou rapids.
Rainy	Oct. 25, 1905	14,145	Fort Frances.
"	April 1, 1906	6,805	Fort Frances.
"	Sept. 26, 1910	5,229	Fort Frances.
Seine	July 9, 1906	1,842	Island falls.
Wabigoon	Oct. 9, 1905	206	Dryden.

## RUN-OFF OF THE WINNIPEG RIVER WATERSHED.

## TABLES 92 TO 102.

Data in tables 92 to 100 were obtained by the field officers of the Water Resources Branch of the United States Geological Survey, and published herein through courtesy of George Otis Smith, Director of the Survey. The data for the years 1911 and 1912 for the Big Fork, the Little Fork and the Vermilion rivers are also available to the public in Water-Supply Papers Nos. 305 and 325, respectively, published by the Geological Survey. The records for the Kawishiwi river for the years 1905, 1906 and 1907 were compiled by the Minnesota Canal and Power Company, and are published in the report of the Water Resources Investigation of Minnesota, 1909-12, by the State Drainage Commission.

## BIG FORK RIVER AT BIG FALLS, MINN.

*Location.*—At Big falls, about 500 feet below the lower end of the rapids.

*Records Available.*—August 27, 1909 to November 12, 1910.

*Drainage Area.*—1,320 square miles.

*Gauge.*—Vertical staff. The gauge was originally located at the Minnesota and international bridge above the falls, but jams at that point caused so much trouble that on June 10, 1911, the station was moved to its present site, the new gauge being set to read approximately 1 foot lower than the old gauge. Gauge heights for 1911 have been referred to the present gauge, and gauge heights for 1912 were taken at this gauge.

*Channel.*—Although the channel is practically permanent in itself, it is, for the greater part of the year, full of logs.

*Discharge Measurements.*—Made from a car about one-fourth mile below the gauge.

*Winter Flow.*—Daily discharge, January 1 to March 31, is estimated, because of ice, from discharge measurements, gauge heights, climatologic records, and discharge of adjacent drainage areas, as follows: January 1 to 31, 30 second-feet, varying from about 40 to 25 second-feet; February 1 to 29, 30 second-feet, varying from about 25 to 40 second-feet; March 1 to 31, 35 second-feet, varying from about 40 to 30 second-feet.

*Accuracy.*—The formation of log jams throughout the river's course makes it impossible to so place a gauge that the relation between gauge heights and discharge will be constant for any extended period. Owing to the inability to secure weekly measurements, no estimates of flow can be given except during the period of ice, when the effect of log jams is relatively unimportant, and the mean monthly discharge can be estimated from the current-meter measurements. The discharge for the entire year can be approximately estimated by determining the relation between the discharge of Little Fork and Big Fork rivers at the times of discharge measurements, assuming such relation to hold at other times, and then using it in conjunction with the gauge heights at Big falls to estimate the flow of the Big Fork.

*References.*—United States Geological Survey Water Supply Papers 305 and 325.

Table 92.—Discharge Measurements of Big Fork River at Big Falls, Minnesota.

[Drainage area, 1,320 square miles.]

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec.-ft.
1909						
Aug. 27	G. A. Gray	266	1,510		4.66	960.0
Oct. 1	"	246	1,210		4.10	535.0
1910						
July 22	Robert Follansbee				2.78	65.0 <sup>1</sup>
1911						
June 10	S. B. Soulé				7.07	1,760.0 <sup>2</sup>
" 12	"				3.89	193.0 <sup>3</sup>
Dec. 13	"				2.65	65.5 <sup>4</sup>
1912						
Jan. 23	S. B. Soulé				2.33	26.9 <sup>5</sup>
Feb. 27	"				2.39	37.2 <sup>5</sup>
April 1	"				2.24	27.0 <sup>7</sup>
" 1	"				2.24	28.4 <sup>8</sup>
May 21	"				5.06	951.0
Aug. 8	"				3.13	97.0 <sup>9</sup>
Dec. 20	"				2.40	46.0 <sup>10</sup>
1913						
Jan. 16	Soulé					28.0
1914						
Aug. 13	Stewart	115	341		3.65	418.0

<sup>1</sup>Estimated from rough measurement.  
<sup>2</sup>Measurement made from Mo. 1. Ry. bridge.  
<sup>3</sup>Measurement made from cable station.  
<sup>4</sup>Complete ice cover, average thickness 0.7 foot. Measured at cable station.  
<sup>5</sup>Ice cover 1.24 foot thick, water surface to top of ice 0.29 foot.  
<sup>6</sup>Ice cover 1.27 foot thick, water surface to top of ice 0.32 foot.  
<sup>7</sup>Section 40 feet below edge of highway bridge.  
<sup>8</sup>Section 25 feet below edge of highway bridge.  
<sup>9</sup>Backwater from logs.  
<sup>10</sup>Complete ice cover at gauge; open water at measuring section at foot of rapids.

Table 93.—Daily Discharge Records of Big Fork River at Big Falls, Minnesota.

[Drainage area, 1,320 square miles.]

1909.

Day.	August.		September.		October.		November.	
	Gauge Height.	Discharge.						
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1				812		536		1,140
2				731		492		1,070
3				628		470		1,000
4				574		465		985
5				530		460		918
6				481		460		854
7				465		445		805
8				415		445		770
9				400		470		770
10				375		552		738
11				366		679		712
12				348		784		628
13				360		840		580
14				360		840		552
15				375		840		525
16				385		875		
17				395		910		
18				375		910		
19				430		948		
20				470		1,100		
21				514		1,340		
22				616		1,820		
23				738		2,140		
24				784		2,140		
25				777		2,100		
26				718		1,960		
27		978		653		1,780		
28		1,040		604		1,600		
29		1,110		580		1,430		
30		1,069		552		1,310		
31		948				1,210		

Table 93.—Daily Discharge Records of Big Fork River at Big Falls, Minnesota—  
Concluded.

1910.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge.										
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec. ft.	Feet.	Sec. ft.	Feet.	Sec. ft.
1							6.90	2,950	6.32	2,390	4.76	1,030
2							7.15	3,200	6.21	2,320	4.72	1,000
3							7.25	3,300	5.98	2,070	4.65	948
4							7.70	3,260	6.35	2,120	4.52	854
5							6.80	2,860	6.10	2,180	4.68	970
6							6.82	2,880	6.05	2,110	4.82	1,080
7							6.95	3,000	6.12	2,200	4.79	1,050
8							6.88	2,940	6.02	2,110	4.68	970
9							6.86	2,920	5.92	2,020	4.59	903
10							6.60	2,660	5.85	1,960	4.52	854
11							6.42	2,190	5.60	1,730	4.41	777
12							6.25	2,130	5.32	1,190	4.39	764
13							6.18	2,260	5.08	1,280	4.56	882
14							6.08	2,170	4.86	1,110	4.51	817
15							6.12	2,200	4.72	1,000	4.41	777
16							6.30	2,380	5.02	1,240	4.35	748
17							7.45	3,500	5.38	1,340	4.30	705
18							8.22	4,310	5.56	1,690	4.26	779
19							8.68	4,790	5.62	1,750	4.21	646
20							6.62	4,730	5.48	1,620	4.11	586
21							8.58	4,690	5.35	1,510	3.96	503
22							8.19	4,280	5.28	1,450	4.15	610
23							7.60	3,660	5.42	1,570	4.00	525
24							7.32	3,380	5.31	1,500	3.89	465
25							7.00	3,060	5.26	1,410	3.81	425
26							6.58	2,640	5.20	1,380	3.76	400
27							6.40	2,470	5.15	1,340	3.71	375
28							6.28	2,360	5.05	1,260	3.64	343
29							6.15	2,230	4.91	1,170	3.60	325
30							6.28	2,360	4.88	1,120	3.54	301
31									4.81	1,070		

Day.	July.		August.		September.		October.		November.		December.
	Gauge Height	Discharge.									
1	3.49	281	2.95	108	2.59	48	3.26	196	3.52	294	
2	3.41	249	2.90	95	2.65	40	3.29	206	3.48	277	
3	3.36	231	2.86	86	2.80	72	3.35	227	3.39	242	
4	3.34	224	2.91	98	2.82	77	3.31	211	3.32	217	
5	3.28	203	2.86	86	2.92	100	3.24	99	3.29	206	
6	3.38	238	2.80	72	2.96	110	3.20		3.22	182	
7	3.31	214	2.75	61	2.91	98	3.16	1	3.16	163	
8	3.26	196	2.70	50	2.86	86	3.19	122	3.12	151	
9	3.20	175	2.69	48	2.85	81	3.21	179	3.01	140	
10	3.16	163	2.65	40	2.94	105	3.25	192	2.92	100	
11	3.42	253	2.65	42	2.95	108	3.28	203	2.89	91	
12	3.35	228	2.80	72	2.91	98	3.35	227	2.81	74	
13	3.28	203	2.86	86	2.89	93	3.42	253			
14	3.22	182	2.82	77	2.98	115	3.50	285			
15	3.11	148	2.79	70	2.95	108	3.62	334			
16	3.00	120	2.76	63	2.92	100	3.61	329			
17	2.94	105	2.74	58	2.91	98	3.59	321			
18	2.86	86	2.70	50	2.98	115	3.55	305			
19	2.80	72	2.66	42	2.94	105	3.65	347			
20	2.75	61	2.64	38	2.91	98	3.78	410			
21	2.75	61	2.86	86	2.89	93	3.81	425			
22	2.74	59	2.81	74	2.96	110	3.79	415			
23		82	2.74	59	3.00	120	3.75	395			
24	2.94	105	2.68	46	2.98	115	3.72	380			
25	2.95	108	2.79	70	2.94	105	3.69	366			
26	2.90	95	2.71	52	2.96	110	3.69	366			
27	2.85	84	2.62	34	3.01	122	3.76	400			
28	2.96	110	2.80	72	3.11	148	3.75	395			
29	2.96	110	2.80	72	3.19	172	3.71	375			
30	2.91	98	2.76	63	3.25	192	3.69	366			
31	3.00	120	2.71	52			3.61	329			

NOTE.—Discharge for 1910 based on a rating curve not well defined.

Table 94.—Monthly Discharge of Big Fork River at Big Falls, Minn.

[Drainage area, 1,320 square miles.]

Month.	DISCHARGE IN SECOND-FEET.				RUN-OFF.	Accuracy
	Maximum.	Minimum	Mean.	Per square mile.	Depth in inches on Drainage Area.	
1909.						
August 27-31.....	1,110	948	1,030	0.780	0.15	B.
September.....	812	348	527	0.399	0.45	B.
October.....	2,140	445	1,040	0.788	0.91	B.
November.....	1,140	.....	660	0.500	0.56	C.
1910.						
April.....	4,790	2,170	3,080	2.33	2.60	D.
May.....	2,420	1,000	1,650	1.25	1.44	C.
June.....	1,080	301	714	0.541	0.60	C.
July.....	281	59	150	0.114	0.13	C.
August.....	108	34	65.3	0.049	0.06	C.
September.....	192	40	105	0.080	0.09	C.
October.....	425	163	295	0.223	0.26	B.
November 1-12.....	293	74	177	0.134	0.06	C.

## LITTLE FORK RIVER AT LITTLE FORK, MINN.

*Location.*—At the lower of the two highway bridges in Little Fork, in section 9, township 68 N., range 25 W.,  $1\frac{1}{2}$  miles above the mouth of Beaver brook.

*Records Available.*—June 23, 1909, to December 31, 1914.

*Drainage Area.*—1,720 square miles.

*Gauge.*—Vertical staff.

*Channel.*—Practically permanent, except for temporary backwater from log jams at the railroad bridge below the station.

*Discharge Measurements.*—Made from the bridge.

*Artificial Control.*—The river is used throughout the spring and summer for log driving. There are, however, no logging dams on the river, so that the flow is natural.

*Winter Flow.*—The river is completely frozen over at the station from November to April.

*Accuracy.*—Conditions at the station are favourable, and the records of flow should be reliable.

*References.*—United States Geological Survey Water Supply Papers Nos. 305, 325 and 355.

Table 95.—Discharge Measurements of Little Fork River at Little Fork, Minnesota.

[Drainage area, 1,720 square miles.]

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec. ft.
1909.						
July 4	G. A. Gray	122	201		5.52	237
" 24	Robert Follansbee	122	184		5.41	190
Aug. 26	G. A. Gray	133	452		7.66	910
Sept. 30	"	132	445		7.50	821
1910.						
June 21	C. R. Adams	136	214		5.30	180
July 22	Robert Follansbee	54	826		4.82	87
1911.						
April 4	C. R. Adams				10.80	1,400 <sup>1</sup>
" 18	Robert Follansbee				15.46	3,730 <sup>2</sup>
" 19	"				15.00	3,580 <sup>2</sup>
June 9	S. B. Soulé				11.06	2,390
July 15	"				5.20	144
Dec. 12	"				6.00	156 <sup>3</sup>
1912.						
Jan. 21	S. B. Soulé				5.52	64 <sup>4</sup>
Feb. 26	"				5.76	73 <sup>4</sup>
Mar. 30	"				5.94	67 <sup>4</sup>
May 20	"				12.41	2,290 <sup>7</sup>
" 20	"				12.23	2,230 <sup>7</sup>
June 14	"				6.83	610
" 14	"				6.83	605
Aug. 7	W. G. Hoyt				5.28	131 <sup>4</sup>
Dec. 19	S. B. Soulé				5.82	113 <sup>4</sup>
1913.						
Jan. 15	S. B. Soulé	96	104	0.76	5.58	780 <sup>5</sup>
Feb. 18	"	91	868	0.61	5.50	530
May 1	"	151	1,420	2.51	13.32	3,560 <sup>6</sup>
July 30	B. J. Peterson	142	397	1.51	6.88	598
Dec. 26	S. B. Soulé	112	194	1.20	6.82	233 <sup>10</sup>
1914.						
Jan. 26	S. B. Soulé	94	138	0.83	6.28	115 <sup>10</sup>
Feb. 25	"	76	112	0.73	6.12	82 <sup>10</sup>
May 16	"	152	1,080	2.22	11.25	2,400 <sup>12</sup>
Aug. 14	J. B. Stewart	129	204	1.35	5.79	276
Dec. 15	S. B. Soulé	85	141	0.84	6.02	118 <sup>10</sup>
1915.						
Jan. 19	S. B. Soulé	75	107	0.79	6.16	85 <sup>11</sup>

<sup>1</sup> Ice-cover.

<sup>2</sup> Backwater from log jamb.

<sup>3</sup> Under complete ice cover about 300 feet above gauge. Average thickness of ice 0.71 foot. Water about 0.15 foot above ice.

<sup>4</sup> Ice cover, thickness 1.49 foot; water to top ice, 0.28 foot.

<sup>5</sup> " " 1.60 " " 0.07 "

<sup>6</sup> " " 1.78 " " 0.00 "

<sup>7</sup> Log jamb on railway bridge about 2 miles below gauge.

<sup>8</sup> Backwater from log boom.

<sup>9</sup> Ice cover, 0.68 foot thick.

<sup>10</sup> Complete ice cover.

<sup>11</sup> Some logs running, but not lodged anywhere.

<sup>12</sup> Logs running.

Table 96.—Daily Discharge Records of Little Fork River at Little Fork, Minnesota.

(Drainage Area 1,720 square miles.)

1909.

Day.	June.		July.		August.		September.		October.		November.	
	Gauge Height	Discharge.										
	Feet	Sec.-ft.	Feet.	Sec.-ft.								
1				210		247		1,040		708		1,360
2				237		224		909		644		1,210
3				221		208		757		614		1,170
4				208		245		667		518		1,090
5				199		237		610		464		980
6				194		291		519		393		942
7				181		304		419		371		864
8				184		302		405		344		802
9				178		852		371		347		621
10				166		896		330		377		680
11				148		1,650		291		422		750
12				137		3,760		286		472		691
13				141		4,120		266		487		598
14				166		1,380		266		387		
15				160		1,210		251		518		
16				160		980		217		598		
17				156		3,650		242		630		
18				161		4,120		228		687		
19				189		2,070		237		698		
20				193		1,860		247		778		
21				194		1,260		268		1,240		
22				197		1,080		288		2,010		
23				194		932		366		2,340		
24		377		184		908		382		2,700		
25		360		282		908		640		2,700		
26		333										
27		307		291		868		920		2,560		
28		296		307		852		988		2,310		
29		281		347		868		988		2,180		
30		268		358		1,050		920		1,660		
31		261		328		1,080		802		1,600		
				286		1,140				1,490		

Table 96.—Daily Discharge Records of Little Fork river at Little Fork, Minnesota—Continued.

1910.

Day.	January.		February.		March.		April.		May.		June.		
	Gauge Height	Discharge.											
	Feet.	Sec.-ft.											
1									8 88	1,390	6 75	565	
2									8 65	1,290	6 58	512	
3									8 12	1,190	6 40	457	
4									8 16	1,090	6 40	457	
5									7 95	1,000	6 45	472	
6													
7									7 70	900	6 10	157	
8									7 19	816	6 45	472	
9									7 45	768	6 60	518	
10									7 25	732	6 55	502	
									7 01	650	6 45	412	
11								10 58	2,200	6 70	578	6 21	411
12								10 05	1,940	6 80	581	6 35	358
13								9 68	1,750	6 60	516	6 00	344
14								9 45	1,600	6 58	512	5 95	330
15								9 10	1,490	6 50	487	5 75	278
16								9 60	1,720	6 40	457	5 62	247
17								10 80	2,410	6 45	412	5 58	237
18								14 95	4,580	6 40	457	5 51	228
19								15 60	5,000	6 40	451	5 46	210
20								15 25	4,770	6 48	451	5 48	193
21													
22								15 00	4,610	6 62	524	5 28	172
23								14 32	4,200	6 78	575	5 21	158
24								12 95	3,440	7 00	647	5 16	148
25								11 92	2,870	7 10	680	5 10	137
								11 20	2,530	7 15	698	5 01	126
26													
27								10 75	2,280	7 00	647	5 00	119
28								10 25	2,040	7 00	647	4 96	112
29								9 90	1,860	7 00	647	4 96	112
30								9 55	1,690	7 10	680	5 60	242
31								9 10	1,490	7 06	667	5 70	266
										6 82	588		

Day.	July.		August.		September.		October.		November.		December.
	Gauge Height	Discharge.									
1	5-42	201	5-72	271	4-83	91	5-00	119	5-30	176	
2	5-45	180	5-48	215	4-84	92	5-30	176	5-21	158	
3	5-15	146	5-32	180	4-86	96	5-10	197	5-18	172	
4	4-92	105	5-28	172	4-75	79	5-15	208	5-30	176	
5	5-02	123	5-28	172	4-40	40	5-10	197	5-10	197	
6	4-95	110	5-20	156	4-70	72	5-40	197			
7	4-80	86	5-05	128	4-75	79	5-30	176			
8	4-78	83	5-00	119	4-84	92	5-30	176			
9	4-72	75	5-00	119	4-80	86	5-25	166			
10	4-75	79	4-95	110	4-85	94	5-18	152			
11	4-36	112	4-85	94	4-85	94	5-10	147			
12	5-00	119	4-95	110	4-86	96	5-10	147			
13	5-00	119	4-95	110	4-90	102	5-18	152			
14	4-88	90	4-90	102	4-88	99	5-15	146			
15	5-02	123	4-98	116	4-80	86	5-10	147			
16	5-02	123	4-95	110	4-74	73	5-05	128			
17	5-15	146	4-92	105	4-70	72	5-00	119			
18	5-26	156	4-95	110	4-80	86	5-00	119			
19	4-90	102	4-98	116	4-78	83	5-38	193			
20	4-90	102	4-98	116	4-76	80	5-20	156			
21	4-88	99	4-96	112	4-90	102	5-22	160			
22	5-10	137	4-95	110	4-96	112	5-20	156			
23	5-15	146	4-93	107	4-89	100	5-19	154			
24	5-02	123	4-95	110	4-80	86	5-20	156			
25	5-02	123	4-95	110	4-89	86	5-40	176			
26	5-08	133	4-95	110	4-80	86	5-30	176			
27	5-08	133	4-95	110	4-80	86	5-30	176			
28	5-85	304	4-86	96	4-89	86	5-30	176			
29	6-10	371	4-85	94	4-86	96	5-30	176			
30	6-05	358	4-83	91	5-00	119	5-30	176			
31	5-85	304	4-83	91			5-30	176			

NOTE.—Discharges computed from a rating curve well defined below 1,000 second-feet.



Table 96. Daily Discharge Records Little Fork river at Little Fork, Minnesota - Continued.

1912

Day.	January.		February.		March.		April.		May.		June.		
	Gauge Height	Discharge.											
	Feet.	Sec. ft.											
1													
2													
3										2,000		910	
4										2,010		970	
5										10 40	2,080	8 00	1,040
6										10 60	2,180	7 40	793
7										11 60	2,660	7 10	793
8										11 70	2,710	7 40	793
9										12 40	3,060	7 50	811
10										12 70	3,210	7 40	756
11										12 80	3,110	7 40	793
12										12 60	3,160	7 20	719
13										12 50	3,110	6 20	495
14										12 60	3,160	6 50	482
15								10 50	2,130	12 90	4,310	6 70	545
16								10 00	1,900	12 80	3,260	6 80	578
17								9 80	1,820		3,910	6 70	515
18													
19								9 30	1,590		3,160	6 60	514
20								8 90	1,410		2,910	6 50	482
21								9 00	1,460		2,660	6 50	482
22								8 80	1,360		2,360	6 60	514
23								8 70	1,320		2,360	6 70	515
24													
25								8 50	1,240		2,140	6 90	612
26								8 40	1,190		1,860	6 80	578
27								8 10	1,070		1,720	6 60	513
28								7 40	795		1,500	6 50	482
29								7 20	719		1,190	6 30	223
30													
31								7 70	909	8 90	1,410	6 20	395
								9 20	1,540	8 50	1,230	6 00	311
								9 90	1,860	8 40	1,190	5 80	280
									1,900	8 10	1,070	5 70	264
									1,950	7 10	793	5 70	264
											850		

Table 96.—Daily Discharge Records of Little Fork river at Little Fork, Minnesota—Continued.

1912

Day.	July		August		September		October		November		December	
	Gauge Height	Discharge										
	Feet.	Sec. ft.										
1	6 20	395		160	5 80	289	8 00	1 030	6 00	311		180
2	7 30	756		110	5 85	302	7 90	989	6 00	311		180
3	7 20	719		150	5 80	289	7 60	870	6 00	311		180
4	6 60	514		130	5 75	276	7 10	704	6 00	311		180
5	6 30	424		112	8 80	1, 060	7 20	719	6 00	311		180
6	6 00	311		130	8 20	1, 110	7 10	684	6 00	311		180
7	6 00	311		130	8 70	1, 320	7 10	684	6 00	311		180
8	6 10	368		130	8 60	1, 280	6 80	578	6 00	311		180
9	6 00	311		130	8 70	1, 320	6 60	511	6 00	311		180
10	6 00	311		130	8 60	1, 280	6 80	578	6 00	311		180
11	5 80	289		130	8 10	1, 190	6 80	578	6 00	311		180
12	5 80	289		130	7 60	870	6 70	515	5 95	328		180
13	.....	289		130	7 80	949	6 80	578	5 95	328		180
14	.....	368		112	7 50	831	6 60	514	5 90	315		180
15	.....	311		112	7 20	719	6 70	515	5 90	315		180
16	.....	261		97	7 00	647	6 70	515	5 90	315		180
17	.....	240		112	6 80	578	6 60	514		300		180
18	.....	240		121	6 60	514	6 50	482		300		105
19	.....	216		130	6 20	395	6 40	452		300		105
20	.....	193		130	5 90	315	6 40	452		300		105
21	.....	204		130	5 90	315	6 20	395		300		105
22	.....	193		130	6 08	341	6 30	424		300		105
23	.....	193		139	6 10	424	6 30	424		300		105
24	.....	193		130	6 60	514	6 20	395		300		105
25	.....	193		130	6 90	612	6 10	368		300		105
26	.....	191		130	7 20	719	6 10	368		300		105
27	.....	204		130	7 40	756	5 95	328		300		105
28	.....	193		180	7 70	909	5 80	289		300		105
29	.....	193		216	7 90	989	6 10	368		300		105
30	.....	193		260	7 00	647	6 10	368		300		105
31	.....	193		264			6 00	311				

NOTE.—Daily discharge computed from a discharge rating table that is well defined for unobstructed channel conditions. Daily discharge interpolated, April 29 to May 2 and July 23 and 24, and daily gauge heights as published reduced 0.2 foot to enter discharge rating table May 15 to 25, because of log jams. Gauge heights reduced 0.2 foot to enter discharge rating table July 14 to August 31, because of effect of floating log. Discharge interpolated, May 31 to June 2. Discharge, January 1 to April 12 and November 17 to December 31 estimated, because of ice, from climatologic records, discharge measurements, and observer's reports, as follows: January 1 to 31, 85 second-feet, varying from about 130 to 60 second-feet; February 1 to 29, 75 second feet, varying from about 80 to 70 second-feet; March 1 to 31, 70 second-feet; April 1 to 12, 650 second-feet, varying from about 70 to 2,000 second-feet; November 17 to 30, 300 second-feet, varying from about 315 to 285 second-feet; December 1 to 31, 150 second-feet, varying from about 250 to 100 second-feet.

Table 96. - Daily Discharge Records of Little Fork river at Little Fork, Minnesota - Concluded.

1911.

Day	January.		February		March		April		May.		June.	
	Gauge Height Feet.	Dis-charge. Sec. ft.										
1		90		60		85		100	11.4	1,510	11.2	1,490
2		90		60		85		100	12.4	1,660	11.3	1,540
3		90		60		85		100	12.3	1,610	12.9	1,820
4		90		60		85		100	12.7	1,720	12.4	1,660
5		90		60		85		100	13.2	1,890	11.8	1,760
6		90		60		85		100	13.2	1,890	12.4	1,660
7		90		60		85		100	13.0	1,800	13.2	1,840
8		90		60		85		100	12.2	1,660	15.6	2,100
9		90		60		85		100	12.0	1,600	15.5	1,760
10		90		60		85		150	11.1	1,560	13.1	1,700
11		90		60		85	8.9	1,500	10.6	1,480	13.2	1,890
12		90		60		85	8.8	1,500	10.4	1,460	12.8	1,720
13		90		60		85	12.6	1,500	10.2	1,400	11.8	1,660
14		90		60		85	16.1	1,500	10.0	1,300	11.0	1,460
15		75		60		85	17.2	1,500	10.2	1,400	9.8	1,320
16		75		60		85	18.2	1,500	10.6	1,480	9.4	1,340
17		75		60		85	16.0	1,560	13.4	1,600	9.7	1,320
18		75		55		85	15.8	1,920	16.1	1,950	9.1	1,260
19		75		55		85	15.4	1,700	16.1	1,500	9.3	1,340
20		75		55		85	15.0	1,480	15.7	1,860	9.0	1,340
21		75		55		85	11.0	1,900	13.6	1,710	9.0	1,340
22		75		55		85	13.7	1,760	13.8	1,850	8.9	1,410
23		75		55		85	13.9	1,880	11.5	1,400	8.6	1,280
24		75		55		85	14.0	1,900	13.1	1,450	8.2	1,110
25		75		55		85	11.3	1,400	13.7	1,760	7.8	949
26		75		55		85	15.6	1,810	12.5	1,110	7.8	919
27		75		55		85	16.1	1,780	13.5	1,610	7.6	870
28		75		55		85	16.1	1,680	10.8	1,260	8.1	1,070
29		75		55		85	15.2	1,500	11.1	1,410	8.1	1,190
30		75		55		85	14.2	1,600	11.8	1,760	8.6	1,280
31		75		55		85			11.7	1,420		

	July.		August.		September.		October.		November.		December.	
1	8.8	1,360	6.5	182	5.8	289	6.4	174	6.9	612		1,680
2	8.6	1,380	6.1	368	5.8	289	6.1	453	6.4	452		1,680
3	8.4	1,190	5.75	276	5.9	315	6.5	485	6.1	368		1,680
4	8.1	1,020	5.6	240	6.0	341	7.7	909	5.7	264		1,680
5	8.8	1,360	5.7	264	6.0	341	8.1	1,070	5.7	264		950
6	9.2	1,540	5.7	264	6.1	368	8.6	1,280	5.9	315		950
7	9.4	1,600	5.75	276	5.2	195	9.2	1,510		300		950
8	9.2	1,540	5.8	289	6.4	423	9.8	1,820		300		950
9	8.6	1,280	5.85	302	6.4	423	10.4	2,080		300		950
10	7.9	989	5.8	289	6.6	513	10.6	2,180		300		950
11	7.6	870	5.9	315	6.8	578	10.8	2,260		300		950
12	8.0	1,000	5.9	315	7.2	719	10.6	2,180		300		950
13	9.4	1,640	5.9	315	7.0	647	10.5	2,130		300		950
14	9.5	1,680	5.9	315	6.9	642	10.4	1,950		300		950
15	9.4	1,640	5.9	315	6.8	578	9.5	1,680		300		950
16	9.1	1,640	5.85	302	6.9	612	8.9	1,410		300		280
17	9.6	1,720	5.85	302	6.8	578	8.6	1,280		300		280
18	9.9	1,860	5.75	276	6.8	578	8.4	1,150		300		280
19	10.0	1,900	5.7	264	6.6	513	8.0	1,030		300		280
20	9.6	1,720	5.65	252	6.5	482	8.0	1,030		300		280
21	9.1	1,640	5.8	289	6.4	452	7.7	909		940		280
22	9.3	1,590	6.2	395	6.4	452	7.2	719		930		280
23	9.2	1,540	6.0	341	6.3	452	7.2	719		940		280
24	9.0	1,400	5.95	328	6.3	423	7.3	756		940		280
25	8.7	1,320	5.9	315	6.3	423	7.6	870		930		280
26	8.2	1,110	5.95	328	6.3	423	7.8	949		940		280
27	7.6	870	5.9	315	6.3	423	8.0	1,000		940		280
28	7.2	719	5.9	315	6.3	423	8.3	1,150		910		280
29	7.0	647	5.9	315	6.1	423	8.2	1,110		940		280
30	6.8	578	5.9	315	6.3	423	7.8	949		930		280
31	6.7	515	5.8	289			7.1	795				280

Note. - Daily discharge computed from a well-defined rating curve. Discharge estimated, because of ice, from gauge heights, observer's notes, three discharge measurements, and climatic records, as follows. - Jan. 1-14, 90 second-feet; Jan. 15-31, 75 second-feet; Feb. 1-17, 60 second-feet; Feb. 18-28, 55 second-feet; Mar. 1-31, 85 second-feet; Apr. 1-9, 100 second-feet; and Apr. 10-16, 1,500 second-feet. Discharge also estimated from November 7 to December 31.

Table 96.—Daily Discharge Records of Little Fork River at Little Fork, Minnesota—Concluded.

1914.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1		150		112		78		383	15.5	4,760	9.2	1,540
2		150		112		78		383	17.3	5,340	8.9	1,410
3		150		112		78		383	18.3	5,930	8.7	1,320
4		150		112		78		383	18.7	6,520	8.6	1,280
5		150		112		78		383	18.3	6,300	8.3	1,150
6		150		97		78		383	18.6	6,160	7.9	989
7		150		97		78		383	17.8	6,020	7.5	831
8		150		97		78		383	16.9	5,520	7.4	793
9		150		86		78		383	15.8	4,920	12.8	3,270
10		150		86		78		383	15.2	4,590	14.6	4,260
11		150		86		78		383	14.4	4,150	14.2	4,040
12		150		86		86		383	13.6	3,710	13.1	3,440
13		150		86		86		383	13.0	3,380	12.0	2,860
14		150		86		86		383	12.4	3,060	11.0	2,360
15		150		86		86		383	11.7	2,710	10.3	2,040
16		115		86		86	10.2	383	11.2	2,460	10.0	1,900
17		115		86		86	13.1	2,260	10.8	2,260	9.6	1,720
18		115		86		114	16.3	2,260	10.2	2,000	9.2	1,540
19		115		78		114	16.8	2,260	10.3	2,040	9.5	1,680
20		115		78		114	15.8	2,260	10.6	2,180	8.6	1,280
21		115		78		114	15.2	2,260	11.2	2,460	7.8	949
22		115		78		114	14.6	2,260	12.1	2,910	7.4	793
23		115		78		114	14.2	2,260	12.6	3,160	6.8	578
24		115		78		114	13.9	2,260	12.0	2,860	6.4	452
25		115		78		114	12.4	3,060	11.1	2,410	6.0	341
26		115		78		114	12.0	2,860	10.4	2,080	6.4	452
27		115		78		114	11.7	2,710	10.9	2,310	6.8	578
28		115		78		114	12.0	2,860	10.0	1,900	7.4	793
29		115				114	13.3	3,540	10.1	1,950		949
30		115				114	14.4	4,150	9.8	1,820	8.6	1,280
31		115				114			9.5	1,680		

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.										
1		1,360	6.5	482	6.8	578		395		513		230
2	8.8	1,540	6.2	395	6.7	545		368		513		230
3	9.2	1,720	6.1	368	6.7	545		341		513		230
4	9.6	1,860	6.0	341	6.8	578		341		545		230
5	9.9	1,820	5.85	302	7.0	647		315		545		230
6	9.0	1,460	5.8	289	7.2	719		328		578		230
7	8.2	1,110	5.6	240	7.3	756		395		578		230
8	7.7	909	5.5	216	7.1	683		452		578		230
9	7.6	870	5.7	264	7.0	647		452		545		230
10	7.8	949	5.7	264	6.9	612		482		545		230
11	8.0	1,030	5.8	289	6.8	578		513		482		230
12	8.4	1,190	5.9	315	6.8	578		545		452		230
13	14.4	4,150	6.0	341	6.5	482		578		452		230
14	16.4	5,250	5.9	315	6.4	452		578		452		230
15	16.1	5,080	5.75	276	6.6	513		647		452		230
16	15.4	4,700	5.7	264	7.1	683		612		423		230
17	14.4	4,150	5.8	289	7.5	831		578		423		230
18	13.6	3,710	5.9	315	7.5	831		545		423		230
19	12.7	3,220	6.0	341	7.6	870		513		423		230
20	11.8	2,760	6.1	368	7.6	870		513		452		230
21	11.0	2,360	6.3	423	7.8	949		482		452		230
22	10.0	1,900	6.6	513	8.0	1,030		482		423		230
23	9.0	1,460	6.7	545	8.2	1,110		482		423		230
24	7.9	989	6.8	578	8.2	1,110		578		423		230
25	7.1	683	7.0	647	8.0	1,030		612		452		230
26	7.4	793	7.0	647	7.6	870		647		452		230
27	7.2	719	6.9	612	7.2	719		647		452		230
28	6.7	545	6.8	578	7.0	647		612		452		230
29	6.4	452	6.8	578	6.7	545		612		452		230
30	6.2	395	6.8	578	6.4	452		578		452		230
31	6.3	423	6.9	612				545				

NOTE.—Discharge records January 1 to April 24, and from December 1 to December 31, estimated.

Table 97.—Monthly Discharge of Little Fork River at Little Fork, Minnesota.

[Drainage area, 1,720 square miles.]

Month.	DISCHARGE IN SECOND-FEET.				RUN-OFF. Depth in inches on Drainage Area.	Accuracy
	Maximum.	Minimum	Mean.	Per Square mile.		
1909.						
June 23-30.....	377	261	310	0.180	0.05	A.
July.....	358	137	212	0.123	0.14	A.
August.....	4,380	208	1,540	0.895	1.03	C.
September.....	1,030	228	516	0.300	0.33	B.
October.....	2,700	344	1,080	0.628	0.72	B.
November 1-13.....	1,360	598	680	0.395	0.19	B.
1910.						
April 11-30.....		1,490	2,720	1.58	1.17	B.
May.....	1,390	442	703	0.409	0.47	A.
June.....	565	112	309	0.180	0.20	A.
July.....	371	75	149	0.087	0.10	A.
August.....	271	41	125	0.073	0.08	A.
September.....	119	90	88	0.051	0.06	A.
October.....	208	119	163	0.095	0.11	A.
November.....			160	0.093	0.10	B.
1911.						
April.....	3,730	900	2,100	1.22	1.36	B.
May.....	1,590	719	1,080	0.628	0.72	A.
June.....	2,610	390	1,680	0.977	1.09	B.
July.....	513	142	212	0.123	0.14	A.
August.....	793	274	492	0.286	0.33	A.
September.....	917	289	529	0.308	0.34	A.
October.....	482	264	356	0.207	0.24	A.
November.....	289		209	0.122	0.14	C.
December.....			145	0.084	0.10	C.
1912.						
January.....			85	0.049	0.06	C.
February.....			75	0.044	0.05	C.
March.....			70	0.041	0.05	B.
April.....			1,130	0.657	0.73	C.
May.....	3,310	793	2,270	1.32	1.52	B.
June.....	1,030	264	588	0.342	0.38	B.
July.....	756	193	304	0.177	0.20	C.
August.....	264	97	140	0.081	0.09	C.
September.....	1,360	276	735	0.427	0.48	C.
October.....	1,030	289	539	0.313	0.36	B.
November.....			318	0.185	0.21	C.
December.....			150	0.087	0.10	C.
The Year.....	3,310		535	0.311	4.23	
1913.						
January.....			82	0.048	0.06	C.
February.....			58	0.034	0.04	C.
March.....			85	0.049	0.06	D.
April.....			2,470	1.440	1.61	C.
May.....	5,250	1,900	3,180	1.850	2.13	B.
June.....	4,810	870	2,350	1.370	1.53	B.
July.....	1,900	545	1,320	0.767	0.88	A.
August.....	482	240	309	0.180	0.21	A.
September.....	719	289	464	0.270	0.30	A.
October.....	2,260	423	1,240	0.721	0.83	B.
November.....			526	0.306	0.34	C.
December.....	1,680		698	0.406	0.47	C.
The Year.....			1,065	0.620	8.46	
1914.						
January.....			142	0.077	0.09	C.
February.....			89	0.052	0.05	C.
March.....			95	0.056	0.06	C.
April.....			1,450	0.843	0.91	C.
May.....	6,520	1,680	3,530	2.060	2.38	B.
June.....	4,260	341	1,560	0.907	1.01	B.
July.....	5,250	395	1,920	1.120	1.29	B.
August.....	647	216	406	0.236	0.27	B.
September.....	1,110	452	715	0.416	0.46	B.
October.....	647	315	509	0.296	0.341	
November.....			478	0.278	0.310	
December.....			230	0.134	0.154	
The Year.....			927	0.540	7.35	

## VERMILION RIVER BELOW LAKE VERMILION, NEAR TOWER, MINNESOTA.

*Location.*—Just below the dam at outlet of lake Vermilion in section 2, township 63 N, range 17 W, in St. Louis county, 4 miles above the mouth of Two Mile creek, which enters from the west.

*Records Available.*—May 17, 1911, to December 31, 1914.

*Drainage Area.*—507 square miles.

*Gauge.*—Vertical staff; datum unchanged.

*Channel.*—Practically permanent.

*Discharge Measurements.*—Made from car and cable just below the gauge section.

*Artificial Control.*—At the outlet of Vermilion lake, a few hundred feet above the gauge, there is a dam which is used to raise the elevation of the lake for aid in navigation. There are no gates in the dam, but on July 19, 1912, it was repaired. For a period after this date the flow was lower than normal, as there was less leakage. The lake has a greatly greater storage capacity, at the present time, so that the flow during the winter period of 1912-13 was somewhat larger than it would have had not the dam been repaired.

*Winter Flow.*—Owing to the heavy fall at the gauge section, amounting to 20 feet in 200 yards, there is little or no backwater from ice during the winter months.

*Accuracy.*—Conditions are favourable for fairly accurate results, the only uncertainty being some inaccuracy in the discharge measurements, owing to the very rocky section.

*References.*—United States Geological Survey, Water Supply Papers Nos. 305, 325 and 355.

Table 98.—Discharge Measurements of Vermilion River below Lake Vermilion, near Tower, Minnesota.

[Drainage area, 507 square miles<sup>1</sup>]

Date.	Hydrographer.	Width.		Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. ft.				
1911.							
May 31	C. J. Emerson					1.94	518.0
June 30	"					1.88	486.0
July 30	S. B. Soulé					1.32	262.0
Oct. 8	"					0.93	173.0
1912.							
Jan. 16	S. B. Soulé					0.69	140.0
Mar. 7	"					0.52	97.6
" 7	W. G. Hoyt					0.52	103.0 <sup>2</sup>
Oct. 16	S. B. Soulé					0.58	105.0
1913.							
July 2	S. B. Soulé	47	154	5.90	2.63		908.0
" 2	"	47	153	5.95	2.62		912.0
Oct. 7	B. J. Peterson	24	53	1.39	0.32		73.0
" 7	"	24	52	1.40	0.32		73.0
1914.							
May 20	S. B. Soulé	128	754	1.42	2.91		1,070.0 <sup>2</sup>
" 21	"	144	959	1.03	2.85		991.0 <sup>3</sup>

<sup>1</sup> Open water, regular section.

<sup>2</sup> Measurement from boat about 4,000 feet below gauge. Control clear.

<sup>3</sup> Measurement from boat about 6,000 feet below gauge.

Table 99.—Daily Discharge Records of Vermilion River below Lake Vermilion, near Tower, Minnesota.

[Drainage area, 507 square miles.]  
1911.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Dis-charge.										
	Feet.	Sec.-ft.										
1											1-90	490
2											1-90	490
3											1-95	515
4											1-90	490
5											1-90	490
6											1-90	490
7											1-90	490
8											1-95	515
9											1-95	515
10											2-05	568
11											2-03	556
12											2-01	546
13											2-00	540
14											2-00	540
15											2-00	540
16											1-95	515
17									1-95	515	1-92	500
18									2-00	540	1-91	495
19									2-10	595	1-90	490
20									2-00	540	2-15	622
21									1-95	515	2-10	595
22									2-00	540	2-05	568
23									2-05	568	2-05	568
24									2-00	540	2-00	540
25									1-95	515	2-00	540
26									1-90	490	1-95	515
27									1-90	490	1-95	515
28									1-90	490	1-90	490
29									1-90	490	1-90	490
30									1-90	490	1-90	490
31									1-95	515		...

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Dis-charge.										
1	1-90	490	1-35	272	0-90	167	0-85	158	0-71	132	0-70	130
2	1-85	466	1-35	272	0-90	167	0-85	158	0-68	127	0-70	130
3	1-80	442	1-33	266	0-90	167	0-84	156	0-66	124	0-70	130
4	1-75	420	1-33	266	0-90	167	0-84	156	0-64	120	0-70	130
5	1-73	411	1-32	263	0-90	167	0-85	158	0-62	117	0-70	130
6	1-72	407	1-32	263	1-00	187	0-85	158	0-60	114	0-70	130
7	1-71	402	1-33	266	1-50	321	0-85	158	0-60	114	0-70	130
8	1-60	358	1-32	263	1-50	321	0-84	156	0-60	114	0-70	130
9	1-60	358	1-32	263	1-50	321	0-84	156	0-60	111	0-70	130
10	1-50	321	1-31	260	1-30	257	0-84	156	0-60	114	0-70	130
11	1-45	304	1-31	260	1-20	231	0-84	156	0-60	114	0-70	130
12	1-40	287	1-30	257	1-10	208	0-85	158	0-60	114	0-70	130
13	1-35	272	1-30	257	1-10	208	0-84	156	0-60	114	0-70	130
14	1-33	266	1-25	244	1-10	208	0-84	156	0-60	114	0-70	130
15	1-30	257	1-25	244	1-10	208	0-84	156	0-60	114	0-70	130
16	1-35	272	1-20	231	1-10	208	0-84	156	0-60	114	0-70	130
17	1-35	272	1-20	231	1-00	187	0-85	158	0-62	117	0-70	130
18	1-30	257	1-20	231	1-00	187	0-86	159	0-63	119	0-70	130
19	1-30	257	1-25	244	0-98	183	0-86	159	0-65	122	0-70	130
20	1-20	231	1-25	244	0-96	179	0-85	158	0-68	127	0-70	130
21	1-10	208	1-25	244	0-94	175	0-84	156	0-70	130	0-70	130
22	1-30	257	1-22	236	0-90	167	0-83	154	0-70	130	0-70	130
23	1-30	257	1-20	231	0-90	167	0-82	152	0-70	130	0-70	130
24	1-30	257	1-10	208	0-90	167	0-80	148	0-70	130	0-70	130
25	1-30	257	1-10	208	0-90	167	0-78	144	0-70	130	0-70	130
26	1-35	272	1-00	187	0-90	167	0-76	141	0-70	130	0-70	130
27	1-35	272	1-00	187	0-90	167	0-74	137	0-70	130	0-70	130
28	1-35	272	1-00	187	0-88	163	0-72	131	0-70	130	0-70	130
29	1-32	263	1-00	187	0-86	159	0-71	132	0-70	130	0-70	130
30	1-32	263	0-90	167	0-85	158	0-70	130	0-70	130	0-7	130
31	1-32	263	0-90	167			0-70	130			0-70	130

NOTE (Year 1911).—Discharge computed from a well defined rating curve.

Table 99.—Daily Discharge Records of Vermilion River below Lake Vermilion, near Tower, Minnesota—Continued.

1912.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.										
1	0.70	130	0.65	122	0.54	106	0.45	93	1.10	208	2.00	540
2	0.70	130	0.65	122	0.52	103	0.45	93	1.20	231	2.00	540
3	0.70	130	0.65	122	0.52	103	0.45	93	1.30	257	2.00	540
4	0.70	130	0.65	122	0.52	103	0.45	93	1.40	287	1.95	515
5	0.70	130	0.65	122	0.52	103	0.45	93	1.50	321	1.95	515
6	0.70	130	0.65	122	0.52	103	0.45	93	1.60	358	1.95	515
7	0.70	130	0.65	122	0.52	103	0.45	93	1.70	398	1.90	490
8	0.70	130	0.65	122	0.50	100	0.48	97	1.75	420	1.90	490
9	0.70	130	0.65	122	0.50	100	0.50	100	1.80	442	1.90	490
10	0.70	130	0.65	122	0.50	100	0.50	100	1.90	490	1.90	490
11	0.70	130	0.64	120	0.50	100	0.50	100	1.90	490	1.95	515
12	0.70	130	0.63	119	0.50	100	0.52	103	2.00	540	1.95	515
13	0.70	130	0.63	119	0.50	100	0.54	106	2.00	540	1.90	490
14	0.70	130	0.62	117	0.46	94	0.55	107	2.05	568	1.85	466
15	0.70	130	0.62	117	0.44	92	0.55	107	2.05	568	1.85	466
16	0.70	130	0.61	116	0.42	89	0.55	107	2.05	568	1.80	442
17	0.70	130	0.61	116	0.42	89	0.57	110	2.05	568	1.80	442
18	0.68	127	0.60	114	0.42	89	0.60	114	2.05	568	1.80	442
19	0.68	127	0.60	114	0.42	89	0.63	119	2.10	595	1.80	442
20	0.68	127	0.60	114	0.42	89	0.65	122	2.10	595	1.75	420
21	0.68	127	0.60	114	0.42	89	0.68	127	2.10	595	1.75	420
22	0.65	122	0.60	114	0.42	89	0.70	130	2.05	568	1.75	420
23	0.65	122	0.60	114	0.42	89	0.70	130	2.05	568	1.70	398
24	0.65	122	0.60	114	0.42	89	0.75	139	2.05	568	1.70	398
25	0.65	122	0.60	114	0.42	89	0.75	139	2.05	568	1.70	398
26	0.65	122	0.60	114	0.43	90	0.80	148	2.05	568	1.65	378
27	0.65	122	0.58	111	0.44	92	0.85	158	2.05	568	1.65	378
28	0.65	122	0.56	108	0.45	93	0.85	158	2.00	540	1.60	358
29	0.65	122	0.54	106	0.45	93	0.90	167	2.00	540	1.55	340
30	0.65	122	.....	.....	0.45	93	0.95	177	.....	540	1.55	340
31	0.65	122	.....	.....	0.45	93	.....	.....	.....	540	.....	.....

	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.										
1	1.55	340	0.65	122	0.55	107	0.60	114	0.50	98	0.50	98
2	1.50	321	0.65	122	0.55	107	0.60	114	0.50	98	0.50	98
3	1.50	321	0.65	122	0.55	107	0.60	114	0.50	98	0.50	98
4	1.45	304	0.60	114	0.55	107	0.60	114	0.50	98	0.50	98
5	1.40	287	0.60	114	0.60	114	0.60	114	0.50	98	0.50	98
6	1.40	287	0.60	114	0.60	114	0.60	114	0.50	98	0.50	98
7	1.40	287	0.60	114	0.60	114	0.60	114	0.50	98	0.50	98
8	1.35	272	0.60	114	0.60	114	0.60	114	0.50	98	0.50	98
9	1.35	272	0.55	107	0.60	114	0.60	114	0.50	98	0.50	98
10	1.30	257	0.55	107	0.60	114	0.60	114	0.50	98	0.50	98
11	1.25	244	0.55	107	0.60	114	0.60	114	0.50	98	0.50	98
12	1.25	244	0.55	107	0.60	114	0.60	114	0.50	98	0.50	98
13	1.25	244	0.55	107	0.60	114	0.60	114	0.50	98	0.50	98
14	1.30	257	0.50	100	0.60	114	0.60	114	0.50	98	0.50	98
15	1.25	244	0.50	100	0.60	114	0.60	114	0.50	98	0.50	98
16	1.25	244	0.50	100	0.60	114	0.60	114	0.50	98	0.50	98
17	1.25	244	0.50	100	0.60	114	0.60	114	0.50	98	0.50	98
18	0.80	148	0.50	100	0.60	114	0.60	114	0.50	98	0.50	98
19	0.80	148	0.50	100	0.60	114	0.60	114	0.50	98	0.50	98
20	0.70	130	0.50	100	0.60	114	0.55	106	0.50	98	0.50	98
21	0.70	130	0.50	100	0.60	114	0.55	106	0.50	98	0.50	98
22	0.70	130	0.50	100	0.60	114	0.55	106	0.50	98	0.50	98
23	0.70	130	0.50	100	0.60	114	0.55	106	0.50	98	0.50	98
24	0.70	130	0.50	100	0.60	114	0.55	106	0.50	98	0.50	98
25	0.65	122	0.50	100	0.60	114	0.55	106	0.50	98	0.50	98
26	0.65	122	0.55	107	0.60	114	0.55	106	0.50	98	0.50	98
27	0.65	122	0.55	107	0.60	114	0.55	106	0.50	98	0.50	98
28	0.65	122	0.55	107	0.60	114	0.55	106	0.50	98	0.50	98
29	0.65	122	0.55	107	0.60	114	0.55	106	0.50	98	0.50	98
30	0.65	122	0.55	107	0.60	114	0.55	106	0.50	98	0.50	98
31	0.65	122	0.55	107	.....	.....	0.55	106	.....	.....	0.50	98

Table 99.—Daily Discharge Records of Vermilion River below Lake Vermilion, near Tower, Minnesota—Continued.

1913

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge										
	Feet.	Sec.-ft.										
1	0.50	98	0.50	98	0.50	98	0.52	101		212	3.70	1,290
2	0.50	98	0.50	98	0.50	98	0.52	101		218	3.30	1,290
3	0.50	98	0.50	98	0.50	98	0.52	101		222	3.40	1,360
4	0.50	98	0.50	98	0.50	98	0.52	101		226	3.40	1,360
5	0.50	98	0.50	98	0.50	98	0.52	101	1.20	231	3.40	1,360
6	0.50	98	0.50	98	0.50	98	0.52	101	1.30	257	3.50	1,420
7	0.50	98	0.50	98	0.50	98	0.52	101	1.30	257	3.50	1,420
8	0.50	98	0.50	98	0.50	98	0.52	101	1.40	287	3.50	1,420
9	0.50	98	0.50	98	0.50	98	0.52	101	1.40	287	3.50	1,420
10	0.50	98	0.50	98	0.50	98	0.52	101	1.40	287	3.50	1,420
11	0.50	98	0.50	98	0.50	98	0.52	101	1.40	287	3.50	1,420
12	0.50	98	0.50	98	0.50	98	0.52	101	1.40	287	3.40	1,360
13	0.50	98	0.50	98	0.50	98	0.55	106	1.40	287	3.40	1,360
14	0.50	98	0.50	98	0.50	98	0.55	106	1.40	287	3.40	1,360
15	0.50	98	0.50	98	0.50	98	0.55	106	1.40	321	3.40	1,360
16	0.50	98	0.50	98	0.50	98	.....	112	1.60	358	3.40	1,360
17	0.50	98	0.50	98	0.50	98	.....	119	1.70	398	3.40	1,290
18	0.50	98	0.50	98	0.50	98	.....	125	1.80	442	3.20	1,230
19	0.50	98	0.50	98	0.50	98	.....	132	1.80	442	3.20	1,230
20	0.50	98	0.50	98	0.50	98	.....	138	2.00	510	3.20	1,230
21	0.50	98	0.50	98	0.50	98	.....	145	2.00	540	3.40	1,170
22	0.50	98	0.50	98	0.50	98	.....	152	2.50	810	3.00	1,110
23	0.50	98	0.50	98	0.50	98	.....	158	3.00	1,110	3.00	1,110
24	0.50	98	0.50	98	0.50	98	.....	165	3.40	1,170	3.00	1,110
25	0.50	98	0.50	98	0.50	98	.....	172	3.20	1,230	2.90	1,050
26	0.50	98	0.50	98	0.50	98	.....	179	3.20	1,230	2.90	1,050
27	0.50	98	0.50	98	0.50	98	.....	186	3.20	1,230	2.80	990
28	0.50	98	0.50	98	0.50	98	.....	193	3.20	1,230	2.80	990
29	0.50	98	.....	.....	0.50	98	.....	200	3.40	1,290	2.80	990
30	0.50	98	.....	.....	0.50	98	.....	205	3.30	1,290	2.70	930
31	0.50	98	.....	.....	0.50	98	.....	.....	3.30	1,290	.....	.....

KM

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge										
1	2.80	990	1.85	466	0.33	74	0.22	60	0.48	95	0.62	117
2	2.70	930	1.95	515	0.33	71	0.22	60	0.48	95	0.65	122
3	2.60	870	1.85	466	0.33	73	0.24	63	0.48	95	0.65	122
4	2.60	870	1.90	490	0.33	74	0.24	63	0.50	98	0.65	122
5	2.50	810	1.80	442	0.33	74	0.27	66	0.52	101	0.68	127
6	2.50	810	1.65	378	0.33	74	0.30	70	0.52	101	0.68	127
7	2.35	728	1.25	244	0.33	74	0.32	73	0.50	98	0.68	127
8	2.40	755	1.20	231	0.33	74	0.32	73	0.50	98	0.68	127
9	2.35	728	1.10	208	0.33	74	0.32	73	0.50	98	0.68	127
10	2.30	700	0.85	158	0.33	71	0.32	73	0.50	98	0.68	127
11	2.40	755	0.65	122	0.33	74	0.32	73	0.50	98	0.65	122
12	2.35	728	0.60	114	0.33	74	0.35	76	0.50	98	0.65	122
13	2.20	645	0.55	106	0.33	74	0.40	83	0.50	98	0.65	122
14	2.25	672	0.53	103	0.33	74	0.45	90	0.50	98	0.65	122
15	2.20	645	0.50	98	0.33	74	0.45	90	0.50	98	0.65	122
16	2.25	672	0.50	98	0.33	74	0.45	90	0.55	106	0.65	122
17	2.20	645	0.50	98	0.33	74	0.48	95	.....	106	0.65	122
18	2.30	700	0.50	98	0.33	74	0.48	95	0.55	106	0.65	122
19	2.25	672	0.50	98	0.28	68	0.48	95	0.55	106	0.65	122
20	2.20	645	0.45	90	0.28	68	0.48	95	0.55	106	0.65	122
21	2.10	590	0.45	90	0.28	68	0.48	95	0.55	106	0.65	122
22	2.20	645	0.40	83	0.25	64	0.48	95	0.55	106	0.65	122
23	2.05	565	0.40	83	0.23	62	0.48	95	0.55	106	0.65	122
24	2.20	645	0.40	83	0.23	62	0.48	95	0.55	106	0.65	122
25	2.15	618	0.35	76	0.23	62	0.48	95	0.55	106	.....	122
26	2.15	618	0.35	76	0.23	62	0.48	95	0.55	106	0.65	122
27	2.00	540	0.35	76	0.23	62	0.48	95	0.55	106	0.65	122
28	2.10	590	0.35	76	0.23	62	0.48	95	0.55	106	0.65	122
29	1.95	515	0.35	76	0.23	62	0.48	95	0.58	111	0.65	122
30	1.80	442	0.35	76	0.23	62	0.48	95	0.60	114	0.65	122
31	1.90	490	0.35	76	.....	.....	0.48	95	.....	.....	0.65	122

NOTE.—Discharge from April 16 to May 4 estimated.

Table 99.—Daily Discharge Records of Vermilion River below Lake Vermilion, near Tower, Minnesota—Concluded.

1914.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge.	Gauge Height.	Discharge.	Gauge Height	Discharge.						
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1	0-65	122	0-62	117	0-70	130	0-66	124	1-65	378	2-50	810
2	0-65	122	0-62	117	0-70	130	0-66	124	1-80	442	2-50	810
3	0-65	122	0-62	117	0-70	130	0-66	124	2-00	540	2-50	810
4	0-65	122	0-65	122	0-70	130	0-65	122	2-05	565	2-50	810
5	0-65	122	0-65	122	0-70	130	0-65	122	2-10	590	2-50	810
6	0-65	122	0-65	122	0-70	130	0-65	122	2-20	645	2-50	810
7	0-65	122	0-65	122	0-70	130	0-65	122	2-40	755	2-50	810
8	0-65	122	0-65	122	0-70	130	0-64	120	2-40	755	2-50	810
9	0-65	122	0-65	122	0-70	130	0-64	120	2-40	755	2-45	782
10	0-62	117	0-65	122	0-70	130	0-64	120	2-40	755	2-45	782
11	0-62	117	0-68	127	0-70	130	0-62	117	3-00	1,110	2-40	755
12	0-62	117	0-68	127	0-68	127	0-62	117	3-00	1,110	2-40	755
13	0-62	117	0-68	127	0-68	127	0-62	117	3-00	1,110	2-40	755
14	0-62	117	0-68	127	0-68	127	0-61	116	3-00	1,110	2-40	755
15	0-62	117	0-68	127	0-68	127	0-61	116	3-00	1,110	2-40	755
16	0-62	117	0-68	127	0-68	127	0-60	114	3-00	1,110	2-35	728
17	0-62	117	0-68	127	0-68	127	0-61	116	2-90	1,050	2-30	700
18	0-62	117	0-68	127	0-68	127	0-66	124	2-90	1,050	2-25	672
19	0-62	117	0-68	127	0-68	127	0-69	128	2-90	1,050	2-00	540
20	0-62	117	0-68	127	0-68	127	0-73	135	2-90	1,050	2-00	540
21	0-62	117	0-68	127	0-68	127	0-76	141	2-90	1,050	2-00	540
22	0-62	117	0-70	130	0-68	127	0-78	144	2-80	990	2-00	540
23	0-62	117	0-70	130	0-68	127	0-78	144	2-80	990	2-00	540
24	0-62	117	0-70	130	0-68	127	0-79	146	2-80	990	2-00	540
25	0-62	117	0-70	130	0-68	127	0-85	158	2-80	990	2-00	540
26	0-62	117	.....	130	0-68	127	0-91	169	2-80	990	1-95	515
27	0-62	117	.....	130	0-68	127	0-96	179	2-70	930	1-95	515
28	0-62	117	.....	130	0-68	127	1-15	220	2-60	870	1-95	515
29	0-62	117	.....	.....	0-68	127	1-40	287	2-60	870	1-90	490
30	0-62	117	.....	.....	0-68	127	1-55	334	2-60	870	1-90	490
31	0-62	117	.....	.....	0-68	127	.....	.....	2-50	810	.....	.....

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge.	Gauge Height.	Discharge.								
1	1-90	490	1-80	442	1-20	231	.....	208	.....	171	.....	117
2	1-90	490	1-80	442	1-20	231	.....	208	.....	171	.....	117
3	1-90	490	1-80	442	1-20	231	.....	208	.....	167	.....	117
4	1-90	490	1-70	398	1-20	231	.....	208	.....	167	.....	117
5	1-90	490	1-70	398	1-20	231	.....	208	.....	167	.....	117
6	1-90	490	1-65	378	1-15	220	.....	208	.....	163	.....	117
7	1-85	466	1-60	358	1-10	208	.....	208	.....	163	.....	117
8	1-85	466	1-55	340	1-10	208	.....	208	.....	158	.....	117
9	1-90	490	1-50	321	1-20	231	.....	208	.....	158	.....	117
10	1-90	490	1-50	321	1-20	231	.....	208	.....	158	.....	117
11	1-90	490	1-45	304	1-15	220	.....	198	.....	152	.....	114
12	1-90	490	1-45	304	1-20	231	.....	198	.....	152	.....	114
13	1-95	515	1-40	287	1-20	231	.....	198	.....	148	.....	114
14	2-00	540	1-35	272	1-20	231	.....	187	.....	148	.....	114
15	2-00	540	1-30	257	1-20	231	.....	187	.....	144	.....	114
16	2-00	540	1-30	257	1-20	231	.....	187	.....	144	.....	114
17	2-00	540	1-30	257	1-20	231	.....	187	.....	139	.....	114
18	2-00	540	1-30	257	1-20	231	.....	187	.....	139	.....	114
19	2-00	540	1-30	257	1-20	231	.....	187	.....	134	.....	114
20	2-00	540	1-30	257	1-20	231	.....	187	.....	134	.....	114
21	1-95	515	1-30	257	1-20	231	.....	183	.....	130	.....	114
22	1-90	490	1-30	257	1-20	231	.....	183	.....	130	.....	114
23	1-90	490	1-30	257	1-20	231	.....	183	.....	127	.....	114
24	1-90	490	1-30	257	1-20	231	.....	183	.....	127	.....	114
25	1-90	490	1-30	257	1-20	231	.....	183	.....	127	.....	114
26	1-90	490	1-25	244	1-20	231	.....	177	.....	122	.....	114
27	1-90	490	1-25	244	1-15	220	.....	177	.....	122	.....	114
28	1-90	490	1-20	231	1-15	220	.....	177	.....	117	.....	111
29	1-85	466	1-20	231	1-10	208	.....	177	.....	117	.....	111
30	1-80	442	1-20	231	1-10	208	.....	171	.....	117	.....	111
31	1-80	442	1-20	231	.....	.....	.....	171	.....	.....	.....	.....

Table 100.—Monthly Discharge of Vermilion River below Lake Vermilion, near Tower, Minnesota.

[Drainage Area, 537 square miles.]

Month.	DISCHARGE IN SECOND-FEET.				RUN OFF.		Accuracy.
	Maximum.	Minimum.	Mean.	Per square mile.	Depth in inches on Drainage Area.		
1911.							
May 17-31.....	595	490	522	1.03	0.57	A.	
June.....	622	490	524	1.040	1.16	A.	
July.....	490	208	309	0.609	0.70	A.	
August.....	272	167	236	0.466	0.54	A.	
September.....	321	158	197	0.389	0.44	A.	
October.....	159	130	152	0.300	0.35	B.	
November.....	132	114	122	0.211	0.27	B.	
December.....	130	130	130	0.256	0.30	B.	
1912.							
January.....	130	122	127	0.250	0.29	A.	
February.....	122	106	117	0.231	0.25	A.	
March.....	106	89	95	0.188	0.22	A.	
April.....	177	94	117	0.231	0.26	A.	
May.....	595	208	490	0.966	1.11	A.	
June.....	540	340	454	0.895	1.00	A.	
July.....	340	122	209	0.412	0.48	B.	
August.....	122	100	107	0.211	0.24	B.	
September.....	114	107	113	0.223	0.25	B.	
October.....	114	106	111	0.219	0.25	B.	
November.....	98	98	98	0.193	0.22	B.	
December.....	98	98	98	0.193	0.22	B.	
The Year.....	595	89	178	0.351	4.80		
1913.							
January.....	98	98	98	0.193	0.22	B.	
February.....	98	..	98	0.193	0.20	B.	
March.....	98	98	98	0.193	0.22	B.	
April.....	(265)	(101)	130	0.256	0.29	C.	
May.....	1,290	212	598	1.180	1.36	B.	
June.....	1,420	930	1,250	2.470	2.76	A.	
July.....	990	442	685	1.350	1.56	A.	
August.....	515	76	177	0.349	0.40	A.	
September.....	74	62	69	0.138	0.15	B.	
October.....	95	60	83	0.165	0.19	B.	
November.....	114	95	102	0.201	0.22	A.	
December.....	127	117	123	0.243	0.28	A.	
The Year.....	427	199	293	0.578	7.85		
1914.							
January.....	122	117	118	0.233	0.27	A.	
February.....	130	117	125	0.247	0.26	A.	
March.....	130	127	128	0.252	0.29	A.	
April.....	334	114	145	0.286	0.32	A.	
May.....	1,110	378	884	1.740	2.01	A.	
June.....	810	490	674	1.340	1.48	A.	
July.....	540	412	497	0.980	1.13	A.	
August.....	442	231	298	0.588	0.68	A.	
September.....	231	208	226	0.446	0.50	A.	
October.....	208	171	192	0.379	0.44		
November.....	171	117	145	0.286	0.32		
December.....	..	..	115	0.227	0.26		
The Year.....	..	..	296	0.583	7.96		

## KAWISHIWI RIVER NEAR WINTON.

*Location.*—At the logging dam at the outlet of Garden lake in section 20, township 62 N., range 11 W., about 3 miles east of Winton, Minnesota.

*Records Available.*—June 21, 1905, to June 30, 1907 These records are furnished through the courtesy of the Minnesota Canal and Power Company, by whom they were compiled.

*Records from October 14, 1912, to December 31, 1914, were secured by the International Joint Commission co-operating with the United States Geological Survey.*

*Drainage Area.*—1,200 square miles.

*Gauge.*—Vertical staff, read at 8 a.m. and 5 p.m.; the mean is taken as the mean for the day.

*Method of Compiling Records.*—Obtained by recording the flow through the five sluiceways of the logging dam, which were closed by Taintor gates. The coefficient for each sluiceway was obtained by current-meter.

*Regulation.*—The flow at Garden lake outlet is almost wholly controlled by logging reservoirs, and the daily records do not represent the natural variation in run-off.

*References.*—Report of Water Resources investigations of Minnesota 1909-1912 by the State Drainage Commissions, and the Report to the International Joint Commission, by Arthur V. White and Adolph F. Meyer, Consulting Engineers, 1915.

Table 100.A.—Discharge Measurements of Kawishiwi River near Winton, Minn.

[Drainage Area, 1,200 square miles.]

Date.	Hydrographer.	Width.	Area of Section.	Mean Velocity.	Gauge Height.	Discharge.
		Feet.	Sq. ft.	Ft. per sec.	Feet.	Sec.-ft.
1912.						
Oct. 13	Soulé	77	417	1.96	2.31	818 <sup>1</sup>
" 11	"	75	260	0.42	0.72	109 <sup>2</sup>
" 14	"	120	520	3.40	3.69	1,770 <sup>3</sup>
" 15	"	150	674	4.27	4.98	2,850 <sup>4</sup>
1913.						
April 29	Soulé	102	515	3.30	3.63	1,700
" 30	"	72	229	0.35	0.62	81
Sept. 12	Peterson	76	274	0.60	0.89	163
" 13	"	77	404	2.00	2.52	810
1914.						
May 22	Soulé	150	609	3.48	4.21	2,120 <sup>5</sup>

<sup>1</sup> One 12-foot gate in Garden Lake dam open.

<sup>2</sup> Gates closed. Represents leakage.

<sup>3</sup> One 12-foot and one 16-foot gate open.

<sup>4</sup> One 12-foot, one 16 foot, and one 20-foot gate open.

<sup>5</sup> Gauge checked with level and found correct.

Table 101.—Daily Discharge Records of Kawishwi River near Winton, Minnesota.

[Drainage area, 1,200 square miles.]

1905

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge										
	Feet.	Sec. ft.										
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												1,340
23												1,912
24												1,960
25												1,994
26												2,231
27												2,174
28												1,082
29												2,903
30												2,921
31												2,990

	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge										
1		1,693		2,320		0		3,426		1,238		1,083
2		2,650		2,342		228		3,211		1,210		1,083
3		2,070		1,645		910		2,599		1,210		1,109
4		1,900		2,050		988		1,458		1,158		1,109
5		3,192		1,613		1,180		1,898		1,131		1,134
6		3,192		1,877		1,134		2,659		1,131		1,158
7		3,766		3,018		1,159		2,123		1,109		1,158
8		4,131		2,901		2,286		1,350		1,083		1,158
9		3,747		1,693		2,200		1,361		1,060		1,158
10		3,736		2,118		1,302		1,768		1,060		1,158
11		3,159		2,550		1,100		2,439		1,039		1,158
12		2,985		1,810		1,897		1,711		972		1,158
13		2,818		2,315		2,344		1,341		850		1,158
14		2,562		846		2,659		1,085		888		1,158
15		3,088		203		2,290		934		908		1,158
16		3,370		1,172		2,098		813		928		1,099
17		3,097		2,605		193		775		928		1,070
18		2,386		2,194		850		731		928		1,070
19		122		1,887		2,445		775		820		1,070
20		1,800		1,606		2,387		820		629		1,050
21		3,213		1,406		2,353		88		671		1,021
22		1,608		1,288		2,332		964		706		1,021
23		2,422		739		2,656		1,033		933		1,021
24		887		0		3,426		1,109		1,288		908
25		1,025		0		3,426		1,158		1,185		975
26		1,878		130		3,574		1,210		1,134		951
27		912		622		3,719		1,265		1,109		931
28		2,102		622		3,790		1,288		1,083		931
29		2,694		192		3,719		1,265		1,066		910
30		1,149		0		3,581		1,265		1,060		880
31		2,300		0				1,238				880

Table 101.—Daily Discharge Records of Kawishiwi River near Winton, Minnesota—Continued.

1906

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge										
	Feet.	Sec. ft.										
1		856		506		360		276		1,682		2,585
2		847		506		360		289		1,840		2,920
3		837		523		360		289		1,846		2,444
4		847		506		360		289		1,889		2,351
5		810		506		360		300		1,930		2,911
6		783		506		360		300		2,105		3,146
7		760		491		345		315		2,680		1,146
8		731		491		345		315		2,057		1,096
9		731		474		345		330		2,172		1,074
10		731		474		345		330		2,880		3,020
11		714		474		345		345		2,706		1,094
12		695		474		330		360		2,150		1,327
13		695		458		330		416		2,370		2,764
14		676		458		330		474		1,795		1,144
15		660		435		330		506		1,836		2,685
16		660		445		330		579		2,057		2,843
17		660		445		330		660		2,914		3,070
18		642		416		320		760		3,087		2,846
19		642		416		315		856		3,212		2,940
20		621		400		315		931		3,055		2,378
21		621		400		315		1,024		3,008		2,830
22		600		400		300		1,158		2,987		2,062
23		600		400		300		1,265		3,091		1,344
24		579		380		300		1,491		3,113		2,259
28		579		380		300		1,730		3,005		2,387
26		579		360		300		2,389		2,634		2,251
27		560		360		300		1,654		2,603		2,623
28		540		360		300		2,307		2,605		1,232
29		540				289		2,600		2,565		1,870
30		540				289		2,580		2,446		2,050
31		523				289				2,559		

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height	Discharge										
	Feet.	Sec. ft.										
1		2,276		455		400		276		400		660
2		1,152		1,150		360		276		400		642
3		1,095		214		400		276		416		621
4		1,505		750		400		263		416		600
5		1,860		524		400		250		400		579
6		830		0		380		263		400		579
7		880		795		380		276		400		579
8		920		0		416		276		416		540
9		930		848		435		300		435		523
10		950		1,275		435		330		435		506
11		962		1,070		435		330		435		506
12		985		830		416		330		491		474
13		1,050		780		400		310		540		474
14		1,275		708		400		315		592		474
15		985		702		360		300		680		474
16		950		525		345		300		783		474
17		1,546		550		330		289		911		474
18		830		600		315		289		975		474
19		810		560		300		276		998		435
20		830		523		289		289		998		435
21		840		523		289		300		975		458
22		840		523		276		330		931		416
23		830		523		276		330		910		400
24		800		523		263		330		837		400
25		745		523		300		330		783		400
26		740		506		289		330		783		380
27		710		491		300		330		760		360
28		1,422		474		289		345		731		360
29		585		458		276		360		695		360
30		1,181		435		276		389		676		360
31		455		400				400				360

Table 101—Daily Discharge Records of Sawishiwi River near Winton, Minnesota.—Continued.

1907

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height	Discharge.										
	Feet.	Sec.-ft.										
1		145		261		200		222		510		5,000
2		145		263		210		245		506		5,200
3		310		261		210		215		491		5,250
4		340		261		210		250		458		5,200
5		310		250		210		263		145		5,100
6		110		250		210		276		416		1,900
7		110		250		210		276		105		4,710
8		140		250		210		276		50		4,550
9		315		250		200		289		59		4,350
10		315		250		200		300		66		4,130
11		315		245		200		315		552		4,000
12		315		245		200		330		816		3,475
13		300		245		200		340		1,265		3,700
14		300		245		200		345		1,131		3,110
15		300		222		200		3		1,366		2,917
16		300		222		200		380		981		2,981
17		300		222		200		380		80		3,235
18		300		222		200		380		81		2,900
19		300		222		190		380		1,129		2,695
20		289		210		190		400		2,214		1,327
21		289		210		190		400		2,270		1,601
22		289		210		190		415		2,400		2,600
23		289		210		190		0		1,100		3,810
24		289		210		200		0		2,390		3,700
25		289		200		200		951		1,677		3,475
26		276		200		210		0		3,716		3,120
27		276		200		210		880		3,810		1,669
28		276		200		222		837		3,120		986
29		276		200		210		711		4,315		971
30		263				222		621		4,710		539
31		263				210				4,760		



Table 101. Daily Discharge Records of the Kawishiwi River—Continued.  
(Records of the International Joint Commission co-operating with the United States Geological Survey)

1911

Day.	January		February.		March		April.		May		June.	
	Gauge Height	Discharge.										
	Feet.	Sec.-ft.	Feet.	Sec.-ft.	Feet.	Sec. ft.	Feet	Sec. ft.	Feet	Sec. ft.	Feet	Sec.-ft.
1	186	150	143	143	143	143	143	143	143	143	143	143
2	185	148	142	142	142	142	142	142	142	142	142	142
3	184	146	141	141	141	141	141	141	141	141	141	141
4	182	145	140	140	140	140	140	140	140	140	140	140
5	180	144	139	139	139	139	139	139	139	139	139	139
6	177	143	138	138	138	138	138	138	138	138	138	138
7	174	142	137	137	137	137	137	137	137	137	137	137
8	172	140	136	136	136	136	136	136	136	136	136	136
9	170	139	135	135	135	135	135	135	135	135	135	135
10	168	139	134	134	134	134	134	134	134	134	134	134
11	165	138	133	133	133	133	133	133	133	133	133	133
12	163	137	132	132	132	132	132	132	132	132	132	132
13	161	136	131	131	131	131	131	131	131	131	131	131
14	161	135	130	130	130	130	130	130	130	130	130	130
15	161	134	129	129	129	129	129	129	129	129	129	129
16	161	133	128	128	128	128	128	128	128	128	128	128
17	163	133	127	127	127	127	127	127	127	127	127	127
18	161	133	127	127	127	127	127	127	127	127	127	127
19	163	133	127	127	127	127	127	127	127	127	127	127
20	162	133	127	127	127	127	127	127	127	127	127	127
21	162	133	127	127	127	127	127	127	127	127	127	127
22	161	131	127	127	127	127	127	127	127	127	127	127
23	160	131	127	127	127	127	127	127	127	127	127	127
24	159	131	127	127	127	127	127	127	127	127	127	127
25	158	131	127	127	127	127	127	127	127	127	127	127
26	157	131	127	127	127	127	127	127	127	127	127	127
27	156	131	127	127	127	127	127	127	127	127	127	127
28	154	131	127	127	127	127	127	127	127	127	127	127
29	153	131	127	127	127	127	127	127	127	127	127	127
30	152	131	127	127	127	127	127	127	127	127	127	127
31	151	131	127	127	127	127	127	127	127	127	127	127

Note.—Estimated

	July.	August.	September.	October.	November.	December.
1	905	390	301	182		747
2	1,030	590	441	387		742
3	1,040	600	794	487	940	736
4	1,060	125	22	365	1,050	710
5	1,060	127	256	625	908	720
6	1,060	289	445	448		
7	1,050	347	163	367	817	714
8	1,05	616	272	729	817	703
9	1,340	130	816	262	817	698
10	736	130	239	436	1,363	682
11	940	494	331	655	1,309	676
12	1,040	541	464	618	1,270	671
13	989	530	394	823	1,220	661
14	1,380	110	326	633	1,190	650
15	1,050	541	670	93	1,140	645
16	1,300	130	157	1,100	1,130	610
17	1,020	133	157	1,119	1,110	630
18	536	555	187	1,016	1,080	625
19	736	381	652	1,490	868	620
20	738	146	317	1,490	575	610
21	716	474	154	1,470		
22	820	571	157	1,340	585	580
23	906	182	301		590	561
24	742	381	807		500	541
25	1,110	554	262		347	522
26	1,490	351	266			503
27	1,440	652	322			
28	1,730	329	363			
29	1,790	364	631			
30	1,640	378	382			
31	1,020	113				

Table 101.--Daily Discharge Records of the Kawishiwi River--Concluded.  
(Records of the International Joint Commission co-operating with the United States Geological Survey.)

1914.

Day.	January.		February.		March.		April.		May.		June.	
	Gauge Height.	Discharge.										
	Feet.	Sec.-ft.	Feet.	Sec. ft.	Feet.	Sec.-ft.	Feet.	Sec. ft.	Feet.	Sec.-ft.	Feet.	Sec.-ft.
1		423		314		70		190		906		2,612
2		418		311		235		190		1,120		2,520
3		409		308		15		190		1,178		3,800
4		400		306		15		190		1,131		4,475
5		396		303		15		187		1,252		3,870
6		391		300		15		187		1,727		3,870
7		382		297		60		187		2,432		3,870
8		374		294		163		187		2,831		2,914
9		369		292		60		183		2,895		2,520
10		365		289		15		183		3,690		2,520
11		356		286		70		183		3,973		2,241
12		356		283		247		180		3,684		1,146
13		356		280		243		180		3,740		1,545
14		356		277		239		141		3,490		11,131
15		356		274		235		48		3,192		1,518
16		356		272		231		49		2,920		1,200
17		356		269		231		51		2,568		2,144
18		356		266		231		290		2,630		12,180
19		356		263		227		345		2,457		1,999
20		356		260		227		239		2,286		1,200
21		356		257		227		247		2,643		1,131
22		356		254		227		258		2,401		1,863
23		356		252		227		274		2,080		1,863
24		356		250		224		178		2,090		1,131
25		356		247		216		73		1,464		1,131
26		350		245		216		71		2,120		2,520
27		344		242		212		75		1,949		2,520
28		338		239		201		623		2,018		2,020
29		332		176		197		960		2,246		2,020
30		326		197		197		879		2,695		2,020
31		320		194		194				2,928		

<sup>1</sup>Note.—Estimated.

Day.	July.		August.		September.		October.		November.		December.	
	Gauge Height.	Discharge.										
1		1,996		1,638		667		880		242		197
2		1,503		1,719		924		1,480		794		197
3		1,389		1,104		918		1,618		615		197
4		1,996		841		965		495		610		197
5		2,020		271		931		725		608		197
6		2,004		502		1,015		730		595		197
7		1,324		868		976		736		590		197
8		1,355		337		977		714		600		197
9		1,709		176		792		1,488		680		235
10		2,930		515		981		665		595		235
11		2,950		696		743		453		585		235
12				805		770		792		580		235
13				823		776		714		575		235
14				829		898		829		824		235
15				836		1,032		485		2,020		235
16				805		1,105		1,093		1,590		235
17				784		737		381		1,320		235
18				811		964		692		1,117		235
19				799		782		687		956		235
20		1,124		272		675		687		817		235
21		860		170		805		682		709		235
22		810		414		805		676		615		235
23		930		330		1,113		564		440		235
24		342		817		1,327		531		274		235
25		1,493		1,052		785		662		235		235
26		857		981		1,342		635		197		235
27		703		566		698		630		163		235
28		720		1,127		1,267		524		163		235
29		759		854		656		142		163		235
30		1,322		972		793		406		163		235
31		1,443		1,444				906				235

Table 102.—Monthly Discharge of the Kawishiwi River near Winton, Minnesota.

Month.	DISCHARGE IN SECOND-FEET.				RUN-OFF.
	Maximum.	Minimum	Mean.	Per square mile.	Depth in inches on Drainage Area.
1905.					
June 21-30 .....	2,921	1,082	2,052	1-71	
July .....	4,131	422	2,470	2-06	2-38
August .....	3,018	0	1,422	1-18	1-36
September .....	3,790	0	2,086	1-74	1-94
October .....	3,426	734	1,493	1-24	1-43
November .....	1,288	629	1,016	0-847	0-945
December .....	1,185	880	1,065	0-888	1-02
The period .....	4,131	0	1,658	1-38	9-08
1906.					
January .....	856	523	672	0-560	0-646
February .....	506	360	444	0-370	0-385
March .....	360	289	326	0-272	0-314
April .....	2,600	276	904	0-753	0-840
May .....	3,212	1,682	2,446	2-04	2-35
June .....	3,327	1,344	2,690	2-24	2-50
July .....	2,276	455	1,012	0-843	0-972
August .....	1,275	0	588	0-490	0-565
September .....	445	263	348	0-290	0-324
October .....	400	250	310	0-258	0-297
November .....	998	400	654	0-515	0-608
December .....	660	360	477	0-398	0-459
The Year .....	3,327	0	906	0-755	10-26
1907.					
January .....	345	263	303	0-252	0-290
February .....	263	200	230	0-192	0-200
March .....	222	190	204	0-170	0-196
April .....	951	0	368	0-307	0-342
May .....	4,760	50	1,572	1-31	1-51
June .....	5,250	549	3,389	2-82	3-15
The period .....	5,250	0	1,011	0-822	5-69

Table 102.—Monthly Discharge Records of the Kawishiwi River—Continued.  
(Records of the International Joint Commission co-operating with the United States Geological Survey.)

Month.	DISCHARGE IN SECOND-FEET.				RUN-OFF.
	Maximum.	Minimum.	Mean.	Per square mile.	Depth in inches on Drainage Area.
1912.					
October 14-27.....	609	105			
November 19-30.....	512	40			
December.....	314	188	227		0.22
1913.					
January.....	186	151	165		0.16
February.....	150	133	137		0.12
March.....	141	127	131		0.13
April.....	1,750	143	520		0.49
May.....	3,190	133	1,930		1.88
June.....	3,380	88	2,290		2.16
July.....	1,790	305	1,060		1.03
August.....	652	120	357		0.35
September.....	816	154	367		0.35
October.....	1,680	262	968		0.94
November.....	1,363	145	806 <sup>1</sup>		0.73
December.....	747	428	614		0.60
The Year.....	3,380	88	779		8.94
1914.					
January.....	423	320	364		0.35
February.....	314	239	276		0.24
March.....	247	15	167		0.16
April.....	960	48	241		0.23
May.....	3,973	996	2,414		2.35
June.....	4,475	1,131	2,318 <sup>2</sup>		1.82
July.....	2,950	342	1,415 <sup>3</sup>		1.02
August.....	1,719	170	789		0.77
September.....	1,342	656	907		0.85
October.....	1,618	142	733		0.71
November.....	2,020	163	645		0.61
December.....	235	197	224		0.22
The Year.....	4,475	15	874		9.33

<sup>1</sup> Mean of 29 days.<sup>2</sup> Mean of 25 days.<sup>3</sup> Mean of 23 days.

INDEX.

Vertical text on the left edge, likely bleed-through from the reverse side of the page. The text is faint and difficult to read, but appears to contain a list or index of items.

## INDEX.

	PAGE.
Acknowledgments .....	18, 41
Administration .....	11
Agreements .....	12, 352
Anchor ice .....	52
" Effect on plant operation .....	53
Annual Charges, Du Bonnet site .....	210
" Lower Seven Sisters site .....	233
" McArthur site .....	221
" Oil power in Winnipeg .....	274, 275, 276
" Pine Falls site .....	198
" Pine Falls power in Winnipeg .....	266
" Producer gas power in Winnipeg .....	274, 276
" Slave Falls site .....	257
" Steam plant in Winnipeg .....	271, 274, 275
" Summary of .....	259
" Upper Pinawa site .....	248
" Upper Seven Sisters site .....	243
Applications for power rights .....	12, 350
Areas—Drainage .....	84
Areas—Lake .....	84
Auxiliary plant .....	269
Barnes, Prof. H. T., on Ice Formation .....	49, 55
Basin, Winnipeg river .....	26
Basins, Storage .....	84
Bear Creek dam .....	174
Bench-marks, List of .....	Appendix V.
Big Clearwater or White Otter lake .....	93
Big Fork river, Run-off .....	75
Birch lake .....	305
Birch Lake Diversion .....	120, 305
Bonnet falls, Grand du .....	29, 201
Bonnet falls, Little du .....	29, 201
Bonnet, Lac du .....	29, 212
Camsell, Chas .....	341, Appendix III.
Capital Costs, Du Bonnet site .....	210
" Hydro-electric distribution in Winnipeg .....	265, 277
" Lower Seven Sisters site .....	235
" McArthur site .....	221
" Oil power in Winnipeg .....	275, 276
" Pine Falls site .....	198
" Pine Falls power in Winnipeg .....	266, 278
" Producer gas power in Winnipeg .....	276, 277
" Slave Falls site .....	256
" Steam plant in Winnipeg .....	271, 274, 275
" Summary of .....	259
" Upper Pinawa site .....	248
" Upper Seven Sisters site .....	243
Chace, W. G. ....	1-3, 150
Chaudiere falls (Kettle falls), Dam .....	173
" Run-off .....	74
Coal, Cost of power from .....	274, 275
" Power from .....	269
Conclusions from Investigations .....	9
Construction of Power undertakings .....	13
Consulting Engineers .....	18
Control dam, Winnipeg Electric Railway Company .....	142
Control of Run-off .....	132, 133
Costs (see "Annual Charges" and "Capital Costs").	14
Crown control of water-power, necessity for .....	28
Dalles rapids .....	174
Dam, Bear creek .....	173
" Chaudiere (or Kettle falls) .....	142
" Control on Pinawa .....	142, 234
" Diversion .....	172
" Fort Frances .....	174
" Gold Portage .....	66, 99, 168
" Norman .....	150
" Proposed power (see Layouts) .....	146
" City of Winnipeg .....	182
" Winnipeg Electric Railway Company .....	274, 275, 276
Design, General basis of .....	274, 275, 276
" Diesel Oil Plant in Winnipeg .....	237
Discharge, river (see Run-off)	17
Diversion weirs, Winnipeg Electric Railway Company .....	142, 234
Diversion weirs, Removal of .....	17
Dominion Lands, Reservation of .....	84
Drainage areas .....	15
Drainage of lands adjacent to river .....	199
Du Bonnet concentration .....	207
" Discharge capacity .....	321
" Effect of the Lake of the Woods Regulation .....	209
" Estimates of Cost .....	203
" Flooding .....	203
" Foundation conditions .....	204

	PAGE.
Du Bonnet concentration Head- and tailwater elevations.....	202
"  "  "  Ice conditions.....	203
"  "  "  Layout.....	205
"  "  "  Navigation.....	209
"  "  "  Pondage.....	203
"  "  "  Reach developed.....	200
"  "  "  Special considerations.....	199
"  "  "  Unwatering.....	207
"  "  "  Whitemud falls.....	200
"  "  "  Whitemud Falls disposal.....	201
Eagle river, Run-off.....	75
East Clearwater lake.....	93
Eastern Outlet of the Lake of the Woods.....	66
Eight Foot falls, Disposal of.....	249
English river.....	28
English River regulation.....	122, 127
"  "  "  Above Lac Seul.....	125
"  "  "  Effect of.....	128
"  "  "  Summary.....	130
English river run-off.....	121, 125
"  "  "  watershed.....	120
Estimates of cost of developing power sites.....	8, 184, 259, 264
"  "  "  Du Bonnet site.....	209
"  "  "  Hydro-electric distribution in Manitoba.....	296
"  "  "  Lower Seven Sisters site.....	233
"  "  "  McArthur site.....	220
"  "  "  Oil power in Winnipeg.....	275, 276
"  "  "  Pine Falls power in Winnipeg.....	265, 278
"  "  "  Pine Falls site.....	196
"  "  "  Producer Gas power in Winnipeg.....	276, 277
"  "  "  Slave Falls site.....	257
"  "  "  Steam power in Winnipeg.....	274, 275
"  "  "  Upper Pinawa site.....	248
"  "  "  Upper Seven Sisters site.....	243
Evaporation in Winnipeg River basin.....	57
"  "  "  records.....	58
"  "  "  station.....	58
Existing power plants.....	137
First development on Winnipeg river in Manitoba.....	34
First falls below English river.....	75
Footprint river, Run-off.....	180
Flooding.....	191
"  "  "  Du Bonnet site.....	228
"  "  "  Lower Seven Sisters site.....	214
"  "  "  McArthur site.....	191
"  "  "  Pine Falls site.....	251
"  "  "  Slave Falls site.....	246
"  "  "  Upper Pinawa site.....	237
"  "  "  Upper Seven Sisters site.....	237
Flow, river (see run-off).....	26
Forest cover.....	26
"  "  "  Beneficial effect of.....	26
Forest conservation.....	170, 307
Fort Frances, Power station.....	72
"  "  "  Run-off at.....	182
Foundation conditions.....	204
"  "  "  Du Bonnet site.....	229
"  "  "  Lower Seven Sisters site.....	215
"  "  "  McArthur site.....	192
"  "  "  Pine Falls site.....	251
"  "  "  Slave Falls site.....	246
"  "  "  Upper Pinawa site.....	238
"  "  "  Upper Seven Sisters site.....	52
Frazil ice.....	53
"  "  "  effect on plant operation.....	18, 31, 36, 214, 298
Freeman, J. R., Consulting Engineer.....	272, 273, 275, 278
Fuel power in Winnipeg, Cost of.....	272
"  "  "  Sources of.....	276, 277
Gas, Cost of power from.....	269
"  "  "  Power from.....	99
Gauge records, Lake of the Woods Surface Level.....	114
"  "  "  Rainy lake Surface level.....	74
Gauging station, Chaudiere falls (Kettle falls).....	72
"  "  "  Fort Frances.....	68
"  "  "  Kenora power station.....	65
"  "  "  Pinawa channel.....	61
"  "  "  Slave falls.....	70
"  "  "  Tunnel island.....	74
"  "  "  Whitemouth river.....	74
"  "  "  (For other rivers see Appendix VII).....	26 Appendix III.
Geological formation.....	174
Gold Portage dam.....	14
Government control of water power, necessity for.....	29, 201
Grand du Bonnet falls.....	36
"  "  "  Survey of.....	308
"  "  "  Power concentration (see Du Bonnet).....	338
Greater Winnipeg Water District.....	183
Hartwell, H.....	202
Head- and tailwater elevations.....	227
"  "  "  "  Du Bonnet site.....	213
"  "  "  "  Lower Seven Sisters site.....	190
"  "  "  "  McArthur site.....	190
"  "  "  "  Pine Falls site.....	190


	PAGE.
Head and tailwater elevations Slave Falls site	250
"                    "          Upper Pinawa site	245
"                    "          Upper Seven Sisters site	244
Hirt, L. J.	148, 338
Historical	23
Hogan's Mill, effect of storage at	92
Hydro-electric development in Canada	282, 284
"                    "          in the United States	282
"                    "          Distribution in Manitoba	294
"                    "          Power Commission of Ontario (see Ontario)	198, 273, 277
"                    "          Power in Winnipeg, Cost of	16, 297
"                    "          Power in Winnipeg, Present status	52
Ice, Anchor	203
Ice conditions, Du Bonnet site	228
"                    "          Lower Seven Sisters site	215
"                    "          McArthur site	191
"                    "          Pine Falls site	251
"                    "          Slave Falls site	246
"                    "          Upper Pinawa site	238
"                    "          Upper Seven Sisters site	147
"                    "          Winnipeg Electric Railway Company plant	159
"                    "          Winnipeg Municipal plant	48, 181
"                    "          Winnipeg river	52
Ice, Frazil	49
" Sheet	13
Inspection of construction	305
International falls (see Fort Frances)	305
International Joint Commission	305
International Waterways Commission	120, 305
"                    "          Birch Lake Diversion	308
"                    "          Winnipeg Water Supply	98, 311
"                    "          Lake of the Woods Levels	9
Investigations, Conclusions from	14
"                    "          Necessity for	31
"                    "          Organization of	10, 113
"                    "          Recommendations based on	17
"                    "          Scope of	16
"                    "          Situation leading to	5
"                    "          Summary of	68
Ka-ka-be-kitchewan falls	76
Kawishiwi river, Run-off	67
Keewatin	70
Keewatin Lumber and Milling Company	4, 168
Kennedy, Jas. C.	69, 168
Kennedy, Wm.	66, 163
Kenora power station	68, 71
" Run-off at	Appendix VI.
" Temperature records at	27, 112
Kettle falls (see Chaudiere falls)	92
Koochiching falls	212
Lac des Milles Lacs	120
Lac du Bonnet	120
Lac Seul	125
" Storage in	125
" Run-off from	125
" watershed	84
" watershed, Regulation of	97, 98
Lake areas	106
Lake of the Woods	66
" Commanding position	109
" Cycle regulation	110
" Eastern outlet	98
" Five-foot storage	97, 103
" Regulation in interests of power reach	130
" Relation to basin	99, 313
" Storage possibilities	101
" Summary of storage possibilities	66, 99
" Surface levels	104
" Theoretical inflow	67, 69, 166
" Western outlet	67, 69, 168
" Yearly regulation	311
" Milling Company Mill "C"	313
" Milling Company Mill "A"	317
" Reference	313
"    " Influence on run-off	319
"    " Influence on power	317
"    " Lake levels	321
"    " Relation to Du Bonnet site	322
"    " Relation to Lower Seven Sisters site	319
"    " Relation to Outlets of Lake of the Woods	317
"    " Relation to McArthur site	321
"    " Relation to Pine Falls site	319
"    " Relation to Slave Falls site	321
"    " Relation to Upper Pinawa site	319
"    " Relation to Upper Seven Sisters site	318
"    " Relation to White Dog site	318
"    " Relation to Winnipeg City plant	320
"    " Relation to Winnipeg Electric Railway Company Plant	322
"    " Summary	28
Lamprey falls	205
Layout, Du Bonnet site	229
" Lower Seven Sisters site	216
" McArthur site	

	PAGE.
Layout, Pine Falls site .....	192
" Slave Falls site .....	252
" Upper Pinawa site .....	246
" Upper Seven Sisters site .....	238
Lease for lands .....	12, 352
Levels, River .....	31
" Lake of the Woods .....	99, 311
" Rainy lake .....	114
License for use of water .....	12, 352
Little du Bonnet falls .....	29, 201
Little Fork river, Run-off .....	76
Load curves,—Power consumed in Winnipeg .....	292
Lower Seven Sisters concentration .....	222
" " " Discharge capacity .....	231
" " " Effect of Lake of the Woods Regulation .....	319
" " " Estimates of cost .....	233
" " " Flooding .....	228
" " " Foundation conditions .....	229
" " " Head- and tailwater elevations .....	227
" " " Ice conditions .....	228
" " " Layout .....	229
" " " Navigation .....	232
" " " Pondage .....	228
" " " Reach developed .....	224
" " " Special considerations .....	224
" " " Unwatering .....	232
Manitoba Hydrographic Survey .....	60
Manitoba lake .....	91, 111
" river .....	75
Market for power .....	281
" Electro-chemical industries .....	298
" Manitoba .....	294
" Pulp and paper .....	298
" Winnipeg .....	287
Masqua rapids .....	189
McArthur Falls concentration .....	211
" " " Discharge capacity .....	219
" " " Effect of Lake of the Woods Regulation .....	321
" " " Estimates of Cost .....	220
" " " Flooding .....	214
" " " Foundation conditions .....	215
" " " Head- and tailwater elevations .....	213
" " " Ice conditions .....	215
" " " Layout .....	216
" " " Navigation .....	220
" " " Pondage .....	215
" " " Reach developed .....	212
" " " Special considerations .....	211
" " " Unwatering .....	220
McArthur falls, First fall .....	212
" Second fall .....	212
MacRae, J. B., Consulting Engineer .....	18, 31, 40, 182, 250 Appendix 1
Minaki .....	76
Minnesota Canal and Power Company .....	305
" " " re Birch Lake Diversion .....	75
Minnesota drainage .....	13, 16
Monopolistic control of water power .....	112
Namakan lake .....	74
" Outlet .....	112
" Storage .....	113, 173
" Regulation .....	15, 183
Navigation .....	209
" Du Bonnet site .....	232
" Lower Seven Sisters site .....	220
" McArthur site .....	196
" Pine Falls site .....	256
" Slave Falls site .....	248
" Upper Pinawa site .....	242
" Upper Seven Sisters site .....	4
Necessity for investigation .....	66, 99, 168
Norman dam .....	99
" Construction .....	99
" Necessity for impartial control .....	90
" Regulation of .....	275, 276
Oil, Cost of power from .....	269
" Power from .....	72, 112, 170, 307
Ontario and Minnesota Power Company .....	91
Ontario Hydro Electric Commission, Report .....	75, Appendix VII.
" Power Commission, Run-off records .....	75, Appendix VII.
Operating Costs (Annual Charges) .....	259
" Power Sites, Summary of .....	37
Organization of investigation .....	61, 64
Otter falls, Run-off at .....	91
Otukamanawan lake .....	66, 68, 71
Outlets of the Lake of the Woods, Run-off .....	163, 166, 317
" " " Power at .....	125
Outlet of Lac Seul, Run off from .....	138
Paper (see Pulp) .....	29
Pearson, F. S. .....	65
Pinawa channel .....	38
" Run-off .....	243
" Survey of .....	243
" Upper power site .....	243

	PAGE.
Pine-falls concentration	186
"    "    Discharge capacity	195
"    "    Effect of the Lake of the Woods Regulation	322
"    "    Estimates of Cost	197
"    "    Flooding	191
"    "    Foundation conditions	192
"    "    Head- and tailwater elevations	190
"    "    Ice conditions	191
"    "    Layout	192
"    "    Navigation	196
"    "    Pondage	191
"    "    Power delivered to Winnipeg	265
"    "    Reach developed	189
"    "    Special considerations	196
"    "    Unwatering	180
Pondage	203
"    Du Bonnet	228
"    Lower Seven Sisters site	215
"    McArthur site	191
"    Pine Falls site	251
"    Slave Falls site	246
"    Upper Pinawa site	237
"    Upper Seven Sisters site	11
Policy of Department	Appendix VI.
Port Arthur, Temperature records at	40
Power concentration studies	28
Power reach in Manitoba	130, 322
"    Effect of storage on	152
Power station, City of Winnipeg	206
"    Du Bonnet site	170
"    Fort Frances	163
"    Kenora	231
"    Lower Seven Sisters site	217
"    McArthur site	194
"    Pine Falls site	253
"    Slave Falls site	247
"    Upper Pinawa site	239
"    Upper Seven Sisters site	142
"    Winnipeg Electric Railway Company	8, 258
Power, Summary of dependable	55, Appendix VI.
Precipitation in Winnipeg basin	55
"    Records available	55
"    at Kenora	55
"    at Port Arthur	55
"    at Savanne	55
"    at Winnipeg	165
Pringle, T. and Sons	14
Private enterprise, Unrestricted	276, 277
Producer gas plant in Winnipeg	31
Profile of Winnipeg river	298
Pulp and paper market	111
Rainy lake	116
"    Basin, Cycle regulation	114
"    "    Regulation of	120
"    "    Summary of regulation	112
"    Regulation	114
"    Storage	114
"    Surface levels	114
"    Theoretical inflow	111
"    Watershed	72
Rainy river, Run-off	13, Appendix IV.
Rates	281
Ratio of power to population	282, 284
"    "    in Canada	282
"    "    in United States	10, 133
Recommendations	31, 40
Reconnaissance, Preliminary	133
Regulating authority	132, 134
Regulation, Control of	131
"    General principles of	125
"    of, Lac Seul	110
"    of, Lake of the Woods (See storage)	110
"    of, Rainy lake	11, Appendix IV.
Regulations, Water power	36, 214, 298
Report, by J. R. Freeman on Winnipeg river	269
Reserve fuel plant	270
"    Estimates of cost	144
"    Winnipeg Electric Railway Company	133
Reservoirs, Government construction of	60, 180, Appendix VII.
Run-off	74
"    Miscellaneous records	75, Appendix VII.
"    Ontario Hydro-Electric Power Commission records	61
"    Regularity of	75
"    United States Geological Survey records	74
Run-off at Chaudiere falls (Kettle falls)	72
"    Fort Frances	66, 68, 71
"    Kenora	62, 64
"    Otter falls	60, 68, 71, 313
"    Outlet of Lake of the Woods	61, 64
"    Outlet of Lac Seul	61, 64
"    Slave falls	61, 64

	PAGE.
Run-off, General	76
Run off of, Big Fork river	75
" Eagle river	75
" English river at mouth	121
" English river at Lac Seul Outlet	125
" English river, Miscellaneous	75
" Footprint river	75
" Kawishiwi river	76
" Little Fork river	76
" Manitou river	75
" Pinawa channel	65
" Rainy river	72
" Seine river	75
" Turtle river	76
" Vermilion river	75
" Wabigoon river	61, 64
" Winnipeg river	74
" Whitemouth river	150, 163
Ruttan, Col. H. N.	92
Savanna, Effect of storage	Appendix VI.
" Temperature records	Appendix VI.
Seul Lac (see Lac Seul)	
Seven Sisters falls, Fifth, Sixth and Seventh falls	224
" Fourth fall	224
" First fall	234
" Second fall	234
" Third fall	227
Seven Sisters reach	28, 222
Seine river, Run-off	75
Sheet ice	53
" Effect on plant operation	308
Shoal lake, Water supply for Winnipeg	29, 190
Silver falls	28, 249, 248
Slave falls	248
" Concentration	255
" Discharge capacity	319
" Effect of the Lake of the Woods regulation	256
" Estimates of Cost	251
" Flooding	251
" Foundation conditions	250
" Head- and tailwater elevations	251
" Ice conditions	252
" Layout	256
" Navigation	251
" Pondage	249
" Reach developed	249
" Special considerations	256
" Unwatering	61, 64
" Run-off of	150
Smith, C. B.	271
Steam power in Winnipeg	272, 274, 276
" Cost of	144
Steam reserve plant, Winnipeg Electric Railway Company	83
Storage	93
" battery plant, Winnipeg Electric Railway Company	144
Storage in Big Clearwater or White Otter Lake	93
" East Clearwater lake	92
" Lac des Milles lakes	97, 311
" Lake of the Woods	84
" Lesser lakes	91, 112
" Manitou lake	112
" Namakan lake	91
" Otakamawan lake	111
" Rainy lake	120
" Seul Lac	93
" White Otter or Big Clearwater lakes	120
Storage of, English River discharge	127
" Lac Seul discharge	97
" Lake of the Woods discharge	93
" Otter-Slave Falls discharge	114
" Rainy Lake discharge	130
Storage, Summary of results	259
Summary of Capital and Operating costs	258
" Dependable power	312
" Influence of Lake of the Woods on power	317
" Influence of Lake of the Woods on Run-off	1
" Investigations	323
" Relation of Lake of the Woods to the Winnipeg watershed	17
Survey, Commencement of	36
" Field	17
" Scope of	16
" Situation leading to	16
Tailwater elevations (see Headwater)	45
Temperature, In Winnipeg basin	46
" Influence on run-off	4
Thibaudeau, W.	38
Topographic sheets	14
Transmission, Duplication of	157
" City of Winnipeg	147
" Winnipeg Electric Railway Co.	70
Tunnel Island metering station	75
Turtle river, Run-off	95, 110
Twenty-thousand second-foot minimum flow	95, 110

	PAGE.
Twenty-two thousand second feet minimum flow .....	110
United States Geological Survey discharge records .....	75, Appendix V 11
Upper Plnawa Concentration .....	247
"    "    Discharge capacity .....	247
"    "    Effect of Lake of the Woods Regulation .....	248
"    "    Estimates of Cost .....	246
"    "    Flooding .....	216
"    "    Foundation conditions .....	245
"    "    Head- and tailwater elevations .....	246
"    "    Ice conditions .....	246
"    "    Layout .....	248
"    "    Navigation .....	246
"    "    Pondage .....	245
"    "    Reach developed .....	243
"    "    Special considerations .....	248
"    "    Unwatering .....	241
Upper Seven Sisters Concentration .....	241
"    "    Discharge capacity .....	241
"    "    Effect of Lake of the Woods Regulation .....	248
"    "    Estimates of cost .....	237
"    "    Flooding .....	248
"    "    Foundation conditions .....	244
"    "    Head- and tailwater elevations .....	248
"    "    Ice conditions .....	248
"    "    Layout .....	242
"    "    Navigation .....	237
"    "    Pondage .....	244
"    "    Reach developed .....	247
"    "    Removal of weirs .....	244
"    "    Special considerations .....	242
"    "    Unwatering .....	76
Vermilion river .....	75
Wabigoon river, Run-off .....	26
Watershed, Winnipeg river .....	308
Water Supply Commission, City of Winnipeg .....	308
"    "    Diversion for Winnipeg .....	66
Weirs, Winnipeg Electric Railway Company (see Diversion weirs) .....	28, 31, 318
Western Outlet of Lake of the Woods .....	74
White Dog rapids .....	201
Whitemouth river, Run-off .....	200, 94
Whitemud falls .....	265
White Otter or Big Clearwater lakes .....	287
Winnipeg, Cost of delivery of power to .....	290
"    "    History and growth of .....	287
"    "    Industrial development of .....	16, 138, 120
"    "    Market .....	138
Winnipeg Electric Railway Company Plant .....	142, 234, 148
"    "    "    Construction .....	320
"    "    "    Diversion weirs .....	148
"    "    "    Effect of Lake of the Woods Regulation .....	146
"    "    "    Flow required .....	142
"    "    "    Head available .....	138
"    "    "    Headrace .....	144
"    "    "    Historical .....	142
"    "    "    Installation .....	147
"    "    "    Power station .....	16, 148, 318
"    "    "    Transmission .....	318
Winnipeg municipal plant .....	152
"    "    "    Effect of regulation .....	157
"    "    "    Flow required .....	148
"    "    "    Forebay .....	155
"    "    "    Head available .....	159
"    "    "    Historical .....	159
"    "    "    Installation .....	152
"    "    "    Operation .....	318
"    "    "    Power .....	150
"    "    "    Power Station .....	250
"    "    "    Relation of Lake of the Woods Reference to .....	157
"    "    "    Scheme of development .....	151
"    "    "    Tailwater .....	151
"    "    "    Transmission .....	207, Appendix 11, 61, 64
Winnipeg river basin, Control of run-off .....	55
"    "    "    Power Company .....	308
"    "    "    Run-off .....	308
Winnipeg, Temperature records at .....	310
Winnipeg water supply .....	310
"    "    "    Board of Engineers .....	310
"    "    "    Rights secured .....	310
Woods, Lake of the (see Lake of the Woods).	



87

## CLASSIFIED LISTS OF REPORTS

The Reports published by the Dominion Water Power Branch with the exception of the Annual Reports, have been called Water Resources Papers, and have been numbered 1, 2, etc.

- Annual Reports previous to 1913 are included with the Annual Report of the Department of the Interior, and can be secured from the Secretary of the Department.
- Annual Report for 1912-13, published 1914. Out of print.
- Annual Report for 1913-14, published 1915.
- Annual Report for 1914-15. In Press.
- WATER RESOURCES PAPER No. 1.**—Report of the Railway Belt Hydrographic Survey for 1911-12, by P. A. Carson, B.A., D.L.S., Chief Engineer. Published 1914.
- WATER RESOURCES PAPER No. 2.**—Report of Bow River Power and Storage Investigations (Bow river west of Calgary,) by M. C. Hendry, B.A.Sc., Chief Engineer in charge of surveys. Published 1914.
- WATER RESOURCES PAPER No. 3.**—Report on Power and Storage Investigations, Winnipeg river, by J. T. Johnston, B.A.Sc., Chief Hydraulic Engineer, Dominion Water Power Branch. Published 1915.
- WATER RESOURCES PAPER No. 4.**—Report of the Manitoba Hydrographic Survey to end of year 1914, by M. C. Hendry, B.A.Sc., Chief Engineer. In Press.
- WATER RESOURCES PAPER No. 5.**—Preliminary Report on the Pasquia Reclamation Project, by T. H. Dunn, C.E., O.L.S., Chief Engineer in charge of Reclamation Survey. Published 1914. Out of print.
- WATER RESOURCES PAPER No. 6.**—Report on cost of various sources of power for pumping in connection with the South Saskatchewan Water Supply Diversion Project, by H. E. M. Kensit, M.I.E.E. and Mem. Am. Inst. E. E. Mem. Can. Soc. C. E. Published 1914. Out of print.
- WATER RESOURCES PAPER No. 7.**—Report on the Manitoba Water Powers, by D. L. McLean, S. S. Scovill, and J. T. Johnston, compiled for the Manitoba Public Utilities Commission. Published 1914.
- WATER RESOURCES PAPER No. 8.**—Report of the British Columbia Hydrographic Survey for 1913, by R. G. Swan, B.A.Sc., Chief Engineer. Published 1915.
- WATER RESOURCES PAPER No. 9.**—Report of Red River Navigation Surveys, by S. S. Scovill, B.Sc., Assistant Chief Engineer of Manitoba Hydrographic Survey. In course of preparation.
- WATER RESOURCES PAPER No. 10.**—General Guide for Compilation of Water Power Reports of Dominion Water Power Branch, prepared by J. T. Johnston, B.A.Sc., Chief Hydraulic Engineer. Published 1915. Limited edition.
- WATER RESOURCES PAPER No. 11.**—Final Report on the Pasquia Reclamation Project, by T. H. Dunn, C.E., O.L.S., Chief Engineer in charge of Reclamation Survey. Published 1915.
- WATER RESOURCES PAPER No. 12.**—Report on Small Water Powers in Western Canada, and discussion of sources of power for the Farm, by A. M. Beale, B.Sc. Published 1915.
- WATER RESOURCES PAPER No. 13.**—Report on the Coquitlam-Buntzen Hydro-Electric Development, by G. R. G. Conway, M. Inst. C.E., M. Can. Soc. C.E., Chief Engineer of the British Columbia Electric Railway Company, Limited. In press.
- WATER RESOURCES PAPER No. 14.**—Report of the British Columbia Hydrographic Survey for 1914 by R. G. Swan, B.A.Sc., Chief Engineer. Published 1915.
- WATER RESOURCES PAPER No. 15.**—Report on the Water Powers of Alberta and Saskatchewan by C. H. Attwood, O.L.S., Chief Engineer Alberta and Saskatchewan Power Surveys. In course of preparation.
- WATER RESOURCES PAPER No. 16.**—Water Powers of Canada. A series of five pamphlets in one volume covering the water power situation in Canada prepared for distribution at the Panama-Pacific Exposition, San Francisco, 1915, by G. R. G. Conway, Consulting Engineer, Toronto, Percival H. Mitchell, E.E., Consulting Engineer, Toronto, H. G. Acres, Hydraulic Engineer Hydro-Electric Power Commission Ontario, F. T. Kaellin, Asst. Chief Engineer Shawenegan Power Co., Montreal, Quebec, K. H. Smith, Engineer, Nova Scotia Water Power Commission, Halifax, N.S. Published 1915.
- WATER RESOURCES PAPER No. 17.**—Canadian Hydraulic Power Development and Electric Power in Canadian Industry, by Charles H. Mitchell, C.E., Consulting Engineer to Dominion Water Power Branch.

